

From: Lawrence Burkhart ^{NRR}
To: Rick Croteau; Stacey Rosenberg ^{OCM} — EDO
Date: 10/18/01 4:47PM
Subject: BULLETIN 2001-01 TABLES

Please find attached the tables that summarize the reviews of responses to Bulletin 2001-01. Please keep in mind that we may receive information from the licensees that may result in changes to this status.

CC: Allen Hiser; Jacob Zimmerman

Information in this record was deleted
 in accordance with the Freedom of Information
 Act, exemptions 4
 FOIA- 2002-229

E-23

4

PLANTS WITH CRACKING/LEAKAGE HISTORY (BIN 1) AND HIGH SUSCEPTIBILITY PLANTS (BIN 2)

Plants	Last Inspection		Next Inspection				CCDP* (IPE)	Response Acceptable ?
	Date	Method	Date	OK	Method	OK		
Oconee 1	11/2000	Qual. Visual - 100%	03/2002	OK	Qual. Visual - 100%	OK	1E-2 3.5E-3 (Response)	YES
Oconee 2	04/2001	Qual. Visual - 100%	[REDACTED]	OK	Qual. Visual - 100%	OK	1E-2 3.5E-3 (Response)	YES
Oconee 3	2/2001	Qual. Visual - 100%	11/2001	OK	Qual. Visual - 100%	OK	1E-2 3.5E-3 (Response)	YES
ANO-1	03/2001	Qual. Visual - 100%	[REDACTED]	OK	Qual. Visual - 100%	OK	3E-3	YES
TMI-1	09/1999	Eff. Visual - 100%	10/2001	OK	Qual. Visual - 100%	OK	7.5E-3	YES
Robinson	04/2001	Qual. Visual - 100%**	[REDACTED]	OK	Qual. Visual - 100%**	OK	2E-2	YES
Surry 1	Spr 2000	GL 88-05 & GL 97-01	10/2001	OK	Qual. Visual - 100%**	OK	5.8E-3	YES
North Anna 1	02/1996	ID NDE - 31%	09/01 (completed)	OK	Qual. Visual (100%) & ECT/UT**	OK	6.6E-3	YES
North Anna 2	Spr 2001	GL 88-05 & GL 97-01	Prior to 12/31/01****	OK	Qual. Visual - 100%**	OK	6.6E-3	YES
Davis-Besse	03/2000	Qual. Visual (< 100% and > 18 months from next planned insp.)	04/2002	NO	Qual. Visual - 100%	OK	6.9E-3	NO
D.C. Cook 2	09/1994	ID NDE - 91%	1/19/2002	NO	Remote Visual & ECT/UT	OK	4.7E-3	NO
Surry 2	Fall 2000	GL 88-05 & GL 97-01	03/2002	NO	Qual. Visual - 100%**	OK	5.3E-3	NO

* Conditional core damage probability.
 ** Licensee stated its intention to submit information to "qualify" the inspection.
 *** Licensee stated its intention to shutdown and perform "qualified" inspection if it could not "qualify" previous inspection.
 **** Licensee stated its intention to perform "qualified" inspection of 100% of VHP nozzles prior to 12/31/01.
 ☐ Pending acceptability of licensee's supplemental response. As of 10/18/01

PLANTS HAVING MODERATE SUSCEPTIBILITY TO PWSCC AS OF 10/18/2001

Plant	Ranking (EFPY)	Next Inspection			Response Acceptable?
		Date	Method		
Beaver Valley 1	11.5	Sept. 2001	Eff. Visual in Sept. 2001	OK	YES
Beaver Valley 2	16.5	Feb. 2002	Eff. Visual in Feb. 2002	OK	YES
Calvert Cliffs 1	9.8	Feb. 2002	Eff. Visual or Qual. Vol., Feb. 2002	OK	YES
Calvert Cliffs 2	10.2		Eff. Visual or Qual. Vol.	OK	YES
Crystal River 3	5.9	Oct. 2001	Eff. Visual in Fall 2001	OK	YES
Diablo Canyon 1	20.8	May 2002	Eff. Visual in May 2002	OK	YES
Diablo Canyon 2	16.1		Eff. Visual in	OK	YES
Farley 1	6.9	Oct. 2001	Eff. Visual in Oct. 2001	OK	YES
Farley 2	8.3		Eff. Visual or Qual Vol.	OK	YES
Fort Calhoun	17.9	Spring 2002	Eff. Visual in Spring 2002	OKD	YES
Kewaunee	21.9	Oct. 2001	Eff. Visual in Fall 2001	OK	YES
Point Beach 1	11.5		Eff. Visual in	OK	YES
Point Beach 2	9.6	April 2002	Eff. Visual in Spring 2002	OK	YES
Prairie Island 1	26.7		Eff. Visual in	OK	YES
Prairie Island 2	26.8	Feb. 2002	Eff. Visual in Feb. 2002	OK	YES
Salem 1	13.8		Eff. Visual in	OK	YES
Salem 2	17.4	Apr. 2002	Eff. Visual in Apr. 2002	OK	YES
San Onofre 2	10.7	May 2002	Eff. Visual or Qual Vol., May 2002	OK	YES
San Onofre 3	10.8		Eff. Visual or Qual Vol.	OK	YES
St. Lucie 1	10.3		Eff. Visual in	OK	YES
Turkey Point 3	6.3	Oct. 2001	Eff. Visual in October 2001	OK	YES
Turkey Point 4	6.4	Mar. 2002	Eff. Visual in Spring 2002	OK	YES
Waterford 3	7.8	Mar. 2002	Eff. Visual in Spring 2002	OK	YES
Ginna	15.0	Mar. 2002	Not Specified (notify 1/02)**	?	?
St. Lucie 2	11.3	Nov. 2001	<100% Eff. Visual at next outage*	?	?
Millstone 2	14.3	Feb. 2002	Not Specified (notify 1/02)**	?	?
ANO-2	17.1	April 2002	Surface of Vol. of 25% in Spring 2002***	NO	NO
Indian Point 2	26.6		GLs 88-05 & 97-01***	NO	NO
Indian Point 3	14.5		GLs 88-05 & 97-01***	NO	NO
Palo Verde 1	17.0		None (Vol. in)***	NO	NO
Palo Verde 2	17.7	May 2002	None (Vol. in)***	NO	NO
Palo Verde 3	17.3	Sept. 2001	None (Vol. in)***	NO	NO

- * Licensee stated intentions to perform 100% Eff. Visual Inspection at next outage. (For St. Lucie 2 only: In a telecon on 10/11/01 the licensee stated its intention to perform a 100% eff. visual insp. However, 100% may not be feasible due to insulation interference - licensee is reviewing info now and will provide feedback to the staff).
 - ** Licensee stated its intention to provide more information to the staff regarding the scope and schedule of inspection.
 - *** Licensee stated that it would reconsider its position re: scope of inspection and would provide feedback to the staff.
- Pending acceptability of licensee's supplemental response.

As of 10/18/01