

James E. McGreevey

Governor

Department of Environmental Protection

Bradley M. Campbell Commissioner

Division of Environmental Safety, Health,
Analytical Programs
Radiation Protection Programs
Bureau of Nuclear Engineering
PO Box 415
Trenton, NJ 08625-0415

August 22, 2002

U.S. Nuclear Regulatory Commission Attention: Document Control Desk Washington, DC 20555

To Whom It May Concern:

Subject:

Salem Generating Station Units -1 and 2

Docket No. 50-272/50-311

Amendment to Facility Operating License

License Change Request S02-03

The subject request was submitted to the NRC by PSE&G letter dated June 28, 2002. The request proposes to revise the requirements for Fuel Decay Time prior to commencing movement of radiated fuel. Technical Specification 3/4.9.3 is to be revised to allow 100 hours of decay time between October 15 and May 15, but is remain at 168 hours between May 16 and October 14, until the end of the year 2010.

The New Jersey Department of Environmental Protection's Bureau of Nuclear Engineering has reviewed the request in accordance with the requirements of 10 CFR 50.91 (b) and has no comments.

If you have any questions, please contact Rich Pinney at (609) 984-7558.

Sincerely,

Kent W. Tosch, Manager

Bureau of Nuclear Engineering

Jenning. Zanroni / FOR

1000

c: <u>Distribution</u>

Jill Lipoti N.J. DEP

D. Zannoni N.J. DEP

R. Bores NRC Region I State Liaison Officer

R. Lorsen NRC Sr. Resident Inspector

R. Fretz NRC Sr.Project Manager

G. Salaman PSE&G



State of New Jersey

James E. McGreevey

Governor

Department of Environmental Protection

Bradley M. Campbell Commissioner

Division of Environmental Safety, Health, and Analytical Programs Bureau of Nuclear Engineering P.O.Box - 415 Trenton, NJ 08625-0415

August 22, 2002

U.S. Nuclear Regulatory Commission Attention: Document Control Desk Washington, DC 20555

Gentlemen:

Subject:

Hope Creek Generating Station

Docket No. 50-354

Amendment to Facility Operating License

License Change Request H02-07

The subject request was submitted to the NRC by PSE&G letter dated July 03, 2002. The request proposes to relocate the contents of Technical Specification Surveillance Requirement 4.7.5.e, Functional Tests, Snubbers. The utility is requesting expanding the testing interval of select snubbers from 18 months to 54 months. This type of snubber has been in service at Hope Creek since 1997. The testing interval reduction request is based on their functional failure history.

The New Jersey Department of Environmental Protection's Bureau of Nuclear Engineering has reviewed the request in accordance with the requirements of 10CFR50.91 (b). The State of New Jersey has no comment.

If you have any questions, please contact Rich Pinney at (609) 984-7558.

Sincerely,

Kent W. Tosch, Manager

Bureau of Nuclear Engineering

c: <u>Distribution</u>

J. Lipoti N.J. DEP

D. Zannoni N.J. DEP

R. Bores NRC Region I State Liaison Officer

J. Shoppy NRC Sr. Resident Inspector

G. Wunder NRC Project Manager

G. Salamon PSE&G