

(v) Secondary Water Chemistry Monitoring Program

The licensee shall implement a secondary water chemistry monitoring program to inhibit steam generator tube degradation. This program shall be described in the station chemistry manual and shall include:

1. Identification of a sampling schedule for the critical parameters and control points for these parameters;
2. Identification of the procedures used to measure the values of the critical parameters;
3. Identification of process sampling points;
4. Procedure for the recording and management of data;
5. Procedures defining corrective actions for off control point chemistry conditions; and
6. A procedure identifying (a) the authority responsible for the interpretation of the data, and (b) the sequence and timing of administrative events required to initiate corrective actions.

(w) The steam generator tube inspection surveillance maximum inspection interval of Technical Specification 4.4.5.3 is extended until the start of cycle 13, but no later than June 30, 2002.

Amdt.
#232,
1-30-01

(x) The emergency diesel generator engine Technical Specification surveillance requirements of 4.8.1.1.2.e.1 and 4.8.1.1.2.e.7 have been extended to allow their performance during refueling outage 13, but no later than December 31, 2001.

The station battery service testing Technical Specification surveillance requirements 4.8.2.3.2.d and 4.8.2.5.2.d have been extended to allow them to be performed during the refueling outage 13, but no later than December 31, 2001.

(y) During the essential service water pump replacement, a one-time extension of the Technical Specification 3.7.4.1 Action a and b requirement that an inoperable essential service water loop be restored to an operable status within 72 hours may be extended to 140 hours. This extension is applicable only during the preplanned replacement of an essential service water pump with a modified pump and may not be used when the essential service water pump is found to be inoperable. The extension is subject to the following conditions:

- This allowance may be invoked once for each essential service water pump to allow replacement of the pump with a modified pump.
- This allowance may be invoked once for each Unit 2 essential service water loop when the associated Unit 1 essential service water pump is being replaced. This will be done in accordance with Unit 1 Technical Specification 3.7.4.1 Action b.1.
- This allowance is applicable until January 31, 2003.
- When the essential service water loops are declared inoperable during the pump replacement, the systems supported by the essential service water system need not enter their limiting conditions for operation action statements.

D. Physical Protection

The licensee shall fully implement and maintain in effect all provisions of the Commission-approved physical security, guard training and qualification, and safeguards contingency plans including amendments made pursuant to provisions of the Miscellaneous Amendments and Search Requirements revisions to 10 CFR 73.55 (51 FR 27817 and 27822) and to the authority of 10 CFR 50.90 and 10 CFR 50.54(p). The plans, which contain Safeguards Information protected under 10 CFR 73.21, are entitled: "Donald C. Cook Nuclear Plant Security Plan," with revisions submitted through July 21, 1988; "Donald C. Cook Nuclear Plant Training and Qualification Plan," with revisions submitted through December 19, 1986; and "Donald C. Cook Nuclear Plant Safeguards Contingency Plan," with revisions submitted through June 10, 1988. Changes made in accordance with 10 CFR 73.55 shall be implemented in accordance with the schedule set forth therein.

Amdt.
#109
3-15-89