



Duke Power
526 South Church St. EC07H
Charlotte, NC 28202
P. O. Box 1006 EC07H
Charlotte, NC 28201-1006
(704) 382-2200 OFFICE
(704) 382-4360 FAX

M. S. Tuckman
Executive Vice President
Nuclear Generation

September 5, 2002

U. S. Nuclear Regulatory Commission
Washington, DC 20555-0001
ATTENTION: Document Control Desk

Subject: Duke Energy Corporation
Oconee Nuclear Station, Units 1, 2, and 3
Docket Nos. 50-269, 50-270, 50-287
McGuire Nuclear Station, Units 1 and 2
Docket Nos. 50-369, 50-370
Catawba Nuclear Station, Units 1 and 2
Docket Nos. 50-413, 50-414

Request for Authorization to Utilize Wire-Type Image Penetrators in
Accordance with 10CFR50.55(a)(3)(i). – Supplement 1
Duke Energy Corporation Serial Number 02-GO-001

Reference: Letter from M. S. Tuckman to NRC on the above subject, dated
February 14, 2002.

In the reference letter, Duke Energy Corporation (Duke) requested relief from specified inspection requirements to authorize the use of wire-type Image Quality Indicators (IQI's). Duke has recently discussed this issue with your staff. As a result of this discussion, the Justification of Using the Proposed Alternative has been clarified to include the following paragraph:

“The intent of this request for relief is to apply the sensitivity level specified in Tables NB-5111-1 and NC-5111-1 to the selection of the appropriate wire diameter or plaque-type IQI size as provided for in ASME Section III, 1992 Edition, with 1993 Addenda. DEC will comply with all related requirements of ASME Section III, 1992 Edition, with 1993 Addenda for the selection and use of IQI's.”

Questions regarding this request may be directed to G. S. Kent at 704 373-6032.

M. S. Tuckman

Attachment

A047

DUKE ENERGY CORPORATION

Oconee Nuclear Stations, Unit 1, 2 & 3
McGuire Nuclear Station, Units 1 & 2
Catawba Nuclear Station, Units 1 & 2

Request For Relief No. 02-GO-001

Request for Alternative use of wire-type Image Quality Indicators (IQI's) in performing radiographic examinations

Applicable Code Edition and Addenda

- ASME Boiler and Pressure Vessel Code, Section III, 1989 and 1992 Editions, No Addenda
- ASME Boiler and Pressure Vessel Code, Section XI, 1989 Edition, No Addenda and 1995 Edition with 1996 Addenda.

Description of Code Requirement (s) for Which an Alternative is Requested

ASME Section III NB and NC (1989 and 1992 Editions) stipulates the use of the IQI's listed in Table NB -5-1111-1 and NC-5111-1, respectively. ASME Section III NB and NC do not state that the use of wire-type IQI's is unacceptable, it just does not include a listing of the wire diameters that will provide equivalent sensitivity for the specified plaque-type IQI and essential hole.

The Oconee steam generator replacement outages for Units 1, 2, and 3 will invoke Code Case N-416-1, "Alternate Pressure Test Requirements for Welded Repairs or Installation of Replacement Items by Welding, Class 1, 2, and 3, Section XI, Division 1." ASME Code Case N-416-1 invokes the 1992 Edition, no Addenda, of the ASME Section III Code in the performance of nondestructive examination of piping weldments. The 1993 Addenda to the 1992 Edition incorporated equivalent wire type IQI's into Tables NB-5111-1 and NC 5-111-1.

Description of Proposed Alternative

DEC is requesting NRC approval to use wire-type penetrameters in addition to plaque-type IQI's for performing radiographic examinations. The current code of record does not list wire-type IQI's for use. DEC has determined that the proposed alternative would provide an acceptable level of quality and safety.

Justification for Using the Proposed Alternative

DEC considers that plaque-type IQI's are in some cases impractical for use due to physical placement and radiographic characteristics. Placement of flat plaque-type IQI's on curved surfaces of pipe components normally require shimming. When using Plaque-type IQI's, the recorded radiographic characteristics of the essential T-hole is often obscured or distorted due to specimen anomalies or part geometry. These difficulties create re-shoot conditions. Re-shoots have a negative ALARA impact due to the additional personnel radiation exposure.

Wire-type IQIs have been shown to provide quality and sensitivity equivalent to plaque-type IQI's as documented in Table 4 of ASTM E747-87. Equivalent sensitivity has also been demonstrated in ASME Section v, Article 22, SE-747 and in ASME Section III, 1992 Edition, 1993 Addenda, tables NB and NC 5111-1. Because of the equivalent sensitivity, the proposed alternative provides equivalent or superior results to current exam method utilizing only plaque-type IQI's. Therefore, the quality of the examination and resulting safety of the plant, based on the exam results are not impacted by this proposed alternative.

The intent of this request for relief is to apply the sensitivity level specified in Tables NB-5111-1 and NC 5111-1 to the selection of the appropriate wire diameter or plaque-type IQI size as provided for in ASME Section III, 1992 Edition, with 1993 Addenda. DEC will comply with all related requirements of ASME Section III, 1992 Edition, with 1993 Addenda for the selection and use of IQI's.

The Quality and Safety Provided by the Proposed Alternative

Information provided above supports the proposed use of wire-type IQIs and provides an acceptable level of quality and safety. The use of only plaque-type IQI's may result in unusual difficulty and additional personnel radiation exposure with no benefit of quality and safety.

Originated By: TL Tucker 09/05/2002
Date

Reviewed By: J.P. Barlow 09/05/2002
Date

U. S. Nuclear Regulatory Commission
September 5, 2002
Page 2

xc:

L. A. Reyes, Regional Administrator
U. S. Nuclear Regulatory Commission, Region II
Atlanta Federal Center
61 Forsyth St., SW, Suite 23T85
Atlanta, GA 30303-8931

L. N. Olshan (addressee only)
NRC Senior Project Manager (ONS)
U. S. Nuclear Regulatory Commission
Mail Stop 0-8 H12
Washington, DC 20555-0001

R. E. Martin (addressee only)
NRC Senior Project Manager (MNS)
U. S. Nuclear Regulatory Commission
Mail Stop 0-8 H12
Washington, DC 20555-0001

C. P. Patel (addressee only)
NRC Senior Project Manager (CNS)
U. S. Nuclear Regulatory Commission
Mail Stop 0-8 H12
Washington, DC 20555-0001

M. C. Shannon
NRC Senior Resident Inspector
Oconee Nuclear Station

S. M. Shaeffer
NRC Senior Resident Inspector
McGuire Nuclear Station

D. J. Roberts
NRC Senior Resident Inspector
Catawba Nuclear Station

U. S. Nuclear Regulatory Commission
September 5, 2002
Page 3

bxc:

L. E. Nicholson – ON03RC
C. J. Thomas – MG01RC
G. D. Gilbert – CN01RC
R. K. Rhyne – EC07J
T. Wills – WC28H
R. O. Sharpe – WC28H
R. L. Gill – EC12R
J. O. Barbour – EC07J
T. L. Tucker – EC07J
J. E. Smith – ON03RC
K. L. Crane – MG01RC
K. E. Nicholson – CN01RC
NCMPA-1
SREC
PMPA
NCEMC
ONS Master File – ON03DM (File OS 801.01)
MNS Master File – MG01DM
CNS Master File – CN01DM
ELL