

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.6.2.4.1 Verify upper containment pool water level is \geq 23 ft 3 inches above the pool bottom.	24 hours
SR 3.6.2.4.2 Verify upper containment pool water temperature is \leq 125°F.	24 hours
SR 3.6.2.4.3 Verify each SPMU subsystem manual, power operated, and automatic valve that is not locked, sealed, or otherwise secured in position is in the correct position.	31 days
<p style="text-align: center;">-----NOTE----- The requirements of this SR are not required to be met when all upper containment pool levels are maintained per SR 3.6.2.4.1 and suppression pool water level is maintained \geq 18 ft 5 1/12 inches (one inch above LCO 3.6.2.2 Low Water Level). -----</p> SR 3.6.2.4.4 Verify all upper containment pool gates are in the stored position or are otherwise removed from the upper containment pool.	31 days
SR 3.6.2.4.5 -----NOTE----- Actual makeup to the suppression pool may be excluded. ----- Verify each SPMU subsystem automatic valve actuates to the correct position on an actual or simulated automatic initiation signal.	18 months

3.10 SPECIAL OPERATIONS

3.10.9 Suppression Pool Makeup-MODE 3

LCO 3.10.9 The requirements of LCO 3.6.2.2, "Suppression Pool Water Level" and LCO 3.6.2.4, "Suppression Pool Makeup (SPMU) System," may be suspended in MODE 3 to allow drain-down of the Upper Containment Pool, provided the following requirements are met:

- a. Suppression Pool Average Temperature is $\leq 95^{\circ}\text{F}$;
- b. Suppression Pool and Upper Containment Pool water levels are maintained within limits of Figure 3.10.9-1;
- c. The fuel storage and transfer canal areas of the Upper Containment Pool are maintained at a minimum of 23 ft 3 inches.
- d. Reactor Steam Dome pressure is < 230 PSIG;
- e. Reactor has been subcritical > 3 hours; and
- f. Each SPMU subsystem valve is OPERABLE per SR 3.6.2.4.3 and SR 3.6.2.4.5 and Upper Containment Pool temperature is in compliance with SR 3.6.2.4.2.

APPLICABILITY: MODE 3 with LCO 3.6.2.2 and 3.6.2.4 not met.

ACTIONS

-----NOTE-----
Separate Condition entry is allowed for each requirement of the LCO.

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more of the above requirements not met.	A.1 Suspend draining the Upper Containment Pools.	Immediately
	<u>AND</u> A.2 Restore compliance with LCO requirements.	4 hours
B. Required Actions and Completion Time of condition A not met.	B.1 Restore compliance with suspended MODE 3 requirements.	12 hours
C. Required Action and associated Completion Time not met.	C.1 Be in MODE 4.	24 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.10.9.1 Verify Suppression Pool temperature \leq 95°F.	12 hours
SR 3.10.9.2 Verify Reactor Steam Dome pressure is < 230 PSIG.	12 hours
SR 3.10.9.3 Verify level in the Upper Containment Pool and the Suppression Pool to be within limits of Figure 3.10.9-1.	12 hours
SR 3.10.9.4 Verify level in the fuel storage and transfer canal areas of the Upper Containment Pool are \geq of 23 ft 3 inches.	12 hours

Figure 3.10.9-1
Upper Containment and Suppression Pool Levels

