September 13, 2002

Mr. Dale E. Young, Vice President Crystal River Nuclear Plant (NA1B) ATTN: Supervisor, Licensing and Regulatory Programs 15760 W. Power Line Street Crystal River, Florida 34428-6708

SUBJECT: CRYSTAL RIVER UNIT 3 - NOTICE OF CONSIDERATION OF ISSUANCE OF

AMENDMENT (TAC NO. MB6189)

Dear Mr. Young:

The Commission has forwarded the enclosed "Notice of Consideration of Issuance of Amendments to Facility Operating License, Proposed No Significant Hazards Consideration Determination, and Opportunity for Hearing" to the Office of the Federal Register for publication.

This notice relates to your application dated August 14, 2002, to revise the note to the Crystal River Unit 3 (CR-3) Improved Technical Specification (ITS) 3.7.18 completion time to allow a 24-hour extension of completion time for entry into ITS 3.0.3. This change is requested as a contingency for two inoperable control complex chillers while the control complex cooling system chiller refurbishment is performed.

Sincerely,

/RA/

Brenda L. Mozafari, Senior Project Manager, Section 2 Project Directorate II Division of Licensing Project Management Office of Nuclear Reactor Regulation

Docket No. 50-302

Enclosure: As stated

cc: See next page

September 13, 2002

Mr. Dale E. Young, Vice President Crystal River Nuclear Plant (NA1B)

ATTN: Supervisor, Licensing and Regulatory Programs

15760 W. Power Line Street Crystal River, Florida 34428-6708

SUBJECT: CRYSTAL RIVER UNIT 3 - NOTICE OF CONSIDERATION OF ISSUANCE OF

AMENDMENT (TAC NO. MB6189)

Dear Mr. Young:

The Commission has forwarded the enclosed "Notice of Consideration of Issuance of Amendments to Facility Operating License, Proposed No Significant Hazards Consideration Determination, and Opportunity for Hearing" to the Office of the Federal Register for publication.

This notice relates to your application dated August 14, 2002, to revise the note to the Crystal River Unit 3 (CR-3) Improved Technical Specification (ITS) 3.7.18 completion time to allow a 24-hour extension of completion time for entry into ITS 3.0.3. This change is requested as a contingency for two inoperable control complex chillers while the control complex cooling system chiller refurbishment is performed.

Sincerely, /RA/

Brenda L. Mozafari, Senior Project Manager, Section 2 Project Directorate II Division of Licensing Project Management Office of Nuclear Reactor Regulation

Docket No. 50-302

Enclosure: As stated

cc: See next page

DISTRIBUTION:

PUBLIC PDII-2 Reading
EDunnington(Hard Copy) LWert, RII
RidsNrrPmBMozafari RidsOGCRp

RidsAcrsAcnwMailCenter

ADAMS ACCESSION NUMBER: ML022560425

OFFICE	PDII-2/PM	PDII-2/LA	OGC /	PDII-2/SC (A)
NAME	BMozafari	EDunnington		KJabbour
DATE	9/12/02	9/12/02		9/12/02

OFFICIAL RECORD COPY

Mr. Dale E. Young Florida Power Corporation

CRYSTAL RIVER UNIT NO. 3

cc:

Mr. R. Alexander Glenn Associate General Counsel (MAC-BT15A) Florida Power Corporation P.O. Box 14042 St. Petersburg, Florida 33733-4042

Mr. Daniel L. Roderick Plant General Manager Crystal River Nuclear Plant (NA2C) 15760 W. Power Line Street Crystal River, Florida 34428-6708

Mr. Michael A. Schoppman Framatome Technologies Inc. 1700 Rockville Pike, Suite 525 Rockville, Maryland 20852

Mr. William A. Passetti, Chief Department of Health Bureau of Radiation Control 2020 Capital Circle, SE, Bin #C21 Tallahassee, Florida 32399-1741

Attorney General Department of Legal Affairs The Capitol Tallahassee, Florida 32304

Mr. Joe Myers, Director Division of Emergency Preparedness Department of Community Affairs 2740 Centerview Drive Tallahassee, Florida 32399-2100 Chairman
Board of County Commissioners
Citrus County
110 North Apopka Avenue
Inverness, Florida 34450-4245

Ms. Sherry L. Bernhoft Manager Regulatory Affairs Crystal River Nuclear Plant (NA2H) 15760 W. Power Line Street Crystal River, Florida 34428-6708

Senior Resident Inspector Crystal River Unit 3 U.S. Nuclear Regulatory Commission 6745 N. Tallahassee Road Crystal River, Florida 34428

Mr. Richard L. Warden Manager Nuclear Assessment Crystal River Nuclear Plant (NA2C) 15760 W. Power Line Street Crystal River, Florida 34428-6708