



**TXU Energy**  
Comanche Peak Steam  
Electric Station  
PO Box 1002 (E01)  
Glen Rose, TX 76043  
Tel 254 897 8920  
Fax: 254 897 6652  
lance.terry@txu.com

**C. Lance Terry**  
Senior Vice President &  
Principal Nuclear Officer

Ref: 10CFR50.90

CPSES-200203220  
Log # TXX-02165  
File # 236

September 6, 2002

U. S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, DC 20555

**SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION (CPSES)  
DOCKET NOS. 50-445 AND 50-446  
ADDITIONAL INFORMATION REGARDING LICENSE  
AMENDMENT REQUEST (LAR) 01-012 STEAM  
GENERATOR TUBE REPAIR USING LEAK TIGHT SLEEVES**

- REF:**
- 1) TXU Energy Letter, logged TXX-01086, from Mr. C. Lance Terry to the NRC dated October 23, 2001
  - 2) TXU Energy Letter, logged TXX-02107, from Mr. C. Lance Terry to the NRC dated July 23, 2002
  - 3) TXU Energy Letter, logged TXX-02159, from Mr. C. Lance Terry to the NRC dated August 29, 2002
  - 4) NRC letter from Mr. D. H. Jaffe to Mr. C. Lance Terry dated December 14, 2001

Gentlemen:

In Reference 1, TXU Generating Company LP (TXU Energy) submitted proposed changes to the Technical Specifications associated with steam generator (SG) repair using leak tight sleeves at CPSES Unit 1 (License Amendment Request LAR 01-012).

References 2 and 3 provided additional information regarding the subject License Amendment Request as requested by the NRC staff.

After review of the proposed submittals, the NRC staff requested additional information. Based on the responses provided and telephone conversations with the NRC staff, TXU Energy provides the following information regarding the hydraulic equivalency of leak-tight sleeves.

D029

TXX-02165  
Page 2 of 3

TXU Energy will use the hydraulic equivalency for the leak-tight sleeves, as approved in Reference 4 and identified in WCAP-15090 Rev. 1, Table 3-8 for 36-inch hot leg, 30-inch hot leg, and 30-inch hot leg and cold leg (combined). These values will also be used for sleeves shorter than 30 inches.

This communication contains the following new or revised commitments:

<u>Commitment Number</u>	<u>Commitment</u>
27271	TXU Energy will use the hydraulic equivalency for the leak-tight sleeves, as approved in Reference 4 and identified in WCAP-15090 Rev. 1, Table 3-8 for 36-inch hot leg, 30-inch hot leg, and 30-inch hot leg and cold leg (combined). These values will also be used for sleeves shorter than 30 inches.

TXX-02165  
Page 3 of 3

If you have any questions please contact J. D. Seawright at (254) 897-0140.

I state under penalty of perjury that the foregoing is true and correct.


Executed on September 6, 2002.

Sincerely,

TXU Generation Company LP

By: TXU Generation Management Company LLC,  
Its General Partner

C. L. Terry  
Senior Vice President and Principal Nuclear Officer

By:   
Roger D. Walker  
Regulatory Affairs Manager

JDS/js

c - E. W. Merschoff, Region IV  
W. D. Johnson, Region IV  
D. H. Jaffe, NRR  
Resident Inspectors, CPSES

Mr. Authur C. Tate  
Bureau of Radiation Control  
Texas Department of Public Health  
1100 West 49th Street  
Austin, Texas 78704