



TXU Energy
Comanche Peak Steam
Electric Station
PO Box 1002 (E01)
Glen Rose, TX 76043
Tel 254 897 8920
Fax: 254 897 6652
lance.terry@txu.com

C. Lance Terry
Senior Vice President &
Principal Nuclear Officer

Ref: 10CFR50.90

CPSES-200203220
Log # TXX-02165
File # 236

September 6, 2002

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555

**SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION (CPSES)
DOCKET NOS. 50-445 AND 50-446
ADDITIONAL INFORMATION REGARDING LICENSE
AMENDMENT REQUEST (LAR) 01-012 STEAM
GENERATOR TUBE REPAIR USING LEAK TIGHT SLEEVES**

- REF:**
- 1) TXU Energy Letter, logged TXX-01086, from Mr. C. Lance Terry to the NRC dated October 23, 2001
 - 2) TXU Energy Letter, logged TXX-02107, from Mr. C. Lance Terry to the NRC dated July 23, 2002
 - 3) TXU Energy Letter, logged TXX-02159, from Mr. C. Lance Terry to the NRC dated August 29, 2002
 - 4) NRC letter from Mr. D. H. Jaffe to Mr. C. Lance Terry dated December 14, 2001

Gentlemen:

In Reference 1, TXU Generating Company LP (TXU Energy) submitted proposed changes to the Technical Specifications associated with steam generator (SG) repair using leak tight sleeves at CPSES Unit 1 (License Amendment Request LAR 01-012).

References 2 and 3 provided additional information regarding the subject License Amendment Request as requested by the NRC staff.

After review of the proposed submittals, the NRC staff requested additional information. Based on the responses provided and telephone conversations with the NRC staff, TXU Energy provides the following information regarding the hydraulic equivalency of leak-tight sleeves.

D029

TXX-02165
Page 2 of 3

TXU Energy will use the hydraulic equivalency for the leak-tight sleeves, as approved in Reference 4 and identified in WCAP-15090 Rev. 1, Table 3-8 for 36-inch hot leg, 30-inch hot leg, and 30-inch hot leg and cold leg (combined). These values will also be used for sleeves shorter than 30 inches.

This communication contains the following new or revised commitments:

<u>Commitment Number</u>	<u>Commitment</u>
27271	TXU Energy will use the hydraulic equivalency for the leak-tight sleeves, as approved in Reference 4 and identified in WCAP-15090 Rev. 1, Table 3-8 for 36-inch hot leg, 30-inch hot leg, and 30-inch hot leg and cold leg (combined). These values will also be used for sleeves shorter than 30 inches.

TXX-02165
Page 3 of 3

If you have any questions please contact J. D. Seawright at (254) 897-0140.

I state under penalty of perjury that the foregoing is true and correct.


Executed on September 6, 2002.

Sincerely,

TXU Generation Company LP

By: TXU Generation Management Company LLC,
Its General Partner

C. L. Terry
Senior Vice President and Principal Nuclear Officer

By: 
Roger D. Walker
Regulatory Affairs Manager

JDS/js

c - E. W. Merschoff, Region IV
W. D. Johnson, Region IV
D. H. Jaffe, NRR
Resident Inspectors, CPSES

Mr. Authur C. Tate
Bureau of Radiation Control
Texas Department of Public Health
1100 West 49th Street
Austin, Texas 78704