

September 18, 2002

Mr. Anthony Pietrangelo
Nuclear Energy Institute
1776 I Street, N. W.
Suite 400
Washington, DC 20006-3708

Dear Mr. Pietrangelo:

The Nuclear Regulatory Commission (NRC) has completed its review of the Nuclear Energy Institute Technical Specification Proposed Change Traveler, TSTF-415, "Six Hour Test Allowance." The proposed changes add Notes to the SR Tables for LCO 3.3.3.1, LCO 3.3.3.2 and LCO 3.3.8.2, and for NUREG-1433 only - LCO 3.4.6, and for NUREG-1434 only - LCO 3.4.7, to allow a delay in entering the associated Conditions and Required Actions for up to 6 hours when a channel is inoperable solely for the performance of required Surveillance.

The staff reviewed the justification provided for the proposed changes. A Completion Time is the appropriate method for managing risk when equipment is made inoperable. Ideally, such a completion time would be risk-informed. We would be glad to review proposals that meet this guidance. This completes our review of TSTF-415.

Please contact Robert Dennig at (301) 415-1156 or e-mail rld@nrc.gov if you have any questions or need further information on these proposed changes.

Sincerely,

/RA/

William D. Beckner, Program Director
Operating Reactor Improvements Program
Division of Regulatory Improvement Programs
Office of Nuclear Reactor Regulation

cc: P. Infanger, BWROG
D. Bice, CEOG
T. Silko, BWOG
S. Wideman, WOG
D. Hoffman, EXCEL

September 18, 2002

Mr. Anthony Pietrangelo
Nuclear Energy Institute
1776 I Street, N. W.
Suite 400
Washington, DC 20006-3708

Dear Mr. Pietrangelo:

The Nuclear Regulatory Commission (NRC) has completed its review of the Nuclear Energy Institute Technical Specification Proposed Change Traveler, TSTF-415, "Six Hour Test Allowance." The proposed changes add Notes to the SR Tables for LCO 3.3.3.1, LCO 3.3.3.2 and LCO 3.3.8.2, and for NUREG-1433 only - LCO 3.4.6, and for NUREG-1434 only - LCO 3.4.7, to allow a delay in entering the associated Conditions and Required Actions for up to 6 hours when a channel is inoperable solely for the performance of required Surveillance.

The staff reviewed the justification provided for the proposed changes. A Completion Time is the appropriate method for managing risk when equipment is made inoperable. Ideally, such a completion time would be risk-informed. We would be glad to review proposals that meet this guidance. This completes our review of TSTF-415.

Please contact Robert Dennig at (301) 415-1156 or e-mail rld@nrc.gov if you have any questions or need further information on these proposed changes.

Sincerely,

/RA/

William D. Beckner, Program Director
Operating Reactor Improvements Program
Division of Regulatory Improvement Programs
Office of Nuclear Reactor Regulation

cc: P. Infanger, BWROG
D. Bice, CEOG
T. Silko, BWOOG
S. Wideman, WOG
D. Hoffman, EXCEL

DISTRIBUTION

ADAMS PUBLIC
NBLe DMatthews/FGillespie
WBeckner RDennig
TSS R/F TSTF-415 (LHill)

ADAMS ACCESSION NUMBER: ML022590484

DOCUMENT NAME: C:\ORPCheckout\FileNET\ML022590484.wpd

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	TSS:IMA	TSS:RE	TSS:SC	RORP:PD
NAME	LHill	TLee	RDennig	WBeckner
DATE	09/18/2002	09/18/2002	09/18/2002	09/18/2002

OFFICIAL RECORD COPY