

September 13, 2002

Mr. Mano Nazar
Site Vice President
Prairie Island Nuclear Generating Plant
Nuclear Management Company, LLC
1717 Wakonade Drive East
Welch, MN 55089

SUBJECT: PRAIRIE ISLAND NUCLEAR GENERATING PLANT, UNITS 1 AND 2 -
CORRECTION TO AMENDMENT NOS. 158 AND 149 REGARDING
CONVERSION TO IMPROVED TECHNICAL SPECIFICATIONS

Dear Mr. Nazar:

On July 26, 2002, the Commission issued Amendment No. 158 to Facility Operating License No. DPR-42 and Amendment No. 149 to Facility Operating License No. DPR-60 for the Prairie Island Nuclear Generating Plant, Units 1 and 2. These amendments converted the Technical Specifications (TSs) for Prairie Island, Units 1 and 2, to improved TSs.

The purpose of this letter is to make two corrections to Pages B-2 (of Appendices B, "Additional Conditions," to both licenses) which were issued with Amendment Nos. 158 and 149. First, Pages B-2 were incorrectly numbered. These pages should have been numbered as B-3 instead of B-2. Secondly, the date of July 26, 2002, should have been included in the license conditions for Amendments Nos. 158 and 149 related to the relocation of TS requirements to a licensee-controlled program. This date reflects the date of the Nuclear Regulatory Commission staff's safety evaluation.

Please replace Pages B-2 that were issued with Amendment Nos. 158 and 149 with the enclosed corrected Pages B-3.

Sincerely,

/RA/

Tae Kim, Senior Project Manager
Project Directorate III-1
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-282 and 50-306

Enclosure: Replacement Pages B-3 for Amendment Nos. 158 and 149

cc w/encl: See next page

September 13, 2002

Mr. Mano Nazar
Site Vice President
Prairie Island Nuclear Generating Plant
Nuclear Management Company, LLC
1717 Wakonade Drive East
Welch, MN 55089

SUBJECT: PRAIRIE ISLAND NUCLEAR GENERATING PLANT, UNITS 1 AND 2 -
CORRECTION TO AMENDMENT NOS. 158 AND 149 REGARDING
CONVERSION TO IMPROVED TECHNICAL SPECIFICATIONS

Dear Mr. Nazar:

On July 26, 2002, the Commission issued Amendment No. 158 to Facility Operating License No. DPR-42 and Amendment No. 149 to Facility Operating License No. DPR-60 for the Prairie Island Nuclear Generating Plant, Units 1 and 2. These amendments converted the Technical Specifications (TSs) for Prairie Island, Units 1 and 2, to improved TSs.

The purpose of this letter is to make two corrections to Pages B-2 (of Appendices B, "Additional Conditions," to both licenses) which were issued with Amendment Nos. 158 and 149. First, Pages B-2 were incorrectly numbered. These pages should have been numbered as B-3 instead of B-2. Secondly, the date of July 26, 2002, should have been included in the license conditions for Amendments Nos. 158 and 149 related to the relocation of TS requirements to a licensee-controlled program. This date reflects the date of the Nuclear Regulatory Commission staff's safety evaluation.

Please replace Pages B-2 that were issued with Amendment Nos. 158 and 149 with the enclosed corrected Pages B-3.

Sincerely,
/RA/
Tae Kim, Senior Project Manager
Project Directorate III-1
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-282 and 50-306

Enclosure: Replacement Pages B-3 for Amendment Nos. 158 and 149

cc w/encl: See next page

DISTRIBUTION

PUBLIC	OGC	RDennig
PDIII-1 Reading	ACRS	CSchulten
LRaghavan	WBeckner	
TKim	GHill(4)	
RBouling	RLanksbury, RGN-III	

ACCESSION NO.: ML022590537

*No legal objection

OFFICE	PDIII-1/PM	PDIII-1/LA	OGC/NLO*	PDIII-1/SC
NAME	TKim	RBouling	RWeisman	LRaghavan
DATE	08/28/02	08/28/02	09/09/02	09/11/02

OFFICIAL RECORD COPY

Prairie Island Nuclear Generating Plant,
Units 1 and 2

cc:

J. E. Silberg, Esquire
Shaw, Pittman, Potts and Trowbridge
2300 N Street, N. W.
Washington, DC 20037

Site Licensing Manager
Prairie Island Nuclear Generating Plant
Nuclear Management Company, LLC
1717 Wakonade Drive East
Welch, MN 55089

Adonis A. Neblett
Assistant Attorney General
Office of the Attorney General
455 Minnesota Street
Suite 900
St. Paul, MN 55101-2127

U.S. Nuclear Regulatory Commission
Resident Inspector's Office
1719 Wakonade Drive East
Welch, MN 55089-9642

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
801 Warrenville Road
Lisle, IL 60532-4351

Administrator
Goodhue County Courthouse
Box 408
Red Wing, MN 55066-0408

Commissioner
Minnesota Department of Commerce
121 Seventh Place East
Suite 200
St. Paul, MN 55101-2145

Tribal Council
Prairie Island Indian Community
ATTN: Environmental Department
5636 Sturgeon Lake Road
Welch, MN 55089

Mr. Roy A. Anderson
Executive Vice President and
Chief Nuclear Officer
Nuclear Management Company, LLC
700 First Street
Hudson, WI 54016

Nuclear Asset Manager
Xcel Energy, Inc.
414 Nicollet Mall
Minneapolis, MN 55401

APPENDIX B

ADDITIONAL CONDITIONS

FACILITY OPERATING LICENSE NO. DPR-42

<u>Amendment Number</u>	<u>Additional Conditions</u>	<u>Implementation Date</u>
158	<p>The schedule for performing Surveillance Requirements (SRs) that are new or revised in Amendment No. 158 shall be as follows:</p> <p>For SRs that are new in this amendment, the first performance is due at the end of the first surveillance interval, which begins on the date of implementation of this amendment.</p> <p>For SRs that existed prior to this amendment, whose intervals of performance are being reduced, the first reduced surveillance interval begins upon completion of the first surveillance performed after implementation of this amendment.</p> <p>For SRs that existed prior to this amendment that have modified acceptance criteria, the first performance is due at the end of the surveillance interval that began on the date the surveillance was last performed prior to the implementation of this amendment.</p> <p>For SRs that existed prior to this amendment, whose intervals of performance are being extended, the first extended surveillance interval begins upon completion of the last surveillance performed prior to the implementation of this amendment.</p>	October 31, 2002
158	<p>The licensee is authorized to relocate certain Technical Specification requirements previously included in Appendix A to licensee-controlled documents, as described in Table LR, "Less Restrictive Changes - Relocated Details," and Table R, "Relocated Specifications," attached to the NRC staff's safety evaluation dated July 26, 2002. Those requirements shall be relocated to the appropriate documents no later than October 31, 2002.</p>	October 31, 2002
158	<p>The licensee will complete evaluation of the maximum test face velocity for the ventilation systems included in Technical Specifications (TS) Section 5.5.9 by February 28, 2003. The licensee will also submit a license amendment request for TS amendment by February 28, 2003, to specify the maximum test face velocity if the maximum actual face velocity is greater than 110 percent of 40 fpm based on the licensee's evaluation.</p>	February 28, 2003

APPENDIX B

ADDITIONAL CONDITIONS

FACILITY OPERATING LICENSE NO. DPR-60

<u>Amendment Number</u>	<u>Additional Conditions</u>	<u>Implementation Date</u>
149	<p>The schedule for performing Surveillance Requirements (SRs) that are new or revised in Amendment No. 149 shall be as follows:</p> <p>For SRs that are new in this amendment, the first performance is due at the end of the first surveillance interval, which begins on the date of implementation of this amendment.</p> <p>For SRs that existed prior to this amendment, whose intervals of performance are being reduced, the first reduced surveillance interval begins upon completion of the first surveillance performed after implementation of this amendment.</p> <p>For SRs that existed prior to this amendment that have modified acceptance criteria, the first performance is due at the end of the surveillance interval that began on the date the surveillance was last performed prior to the implementation of this amendment.</p> <p>For SRs that existed prior to this amendment, whose intervals of performance are being extended, the first extended surveillance interval begins upon completion of the last surveillance performed prior to the implementation of this amendment.</p>	October 31, 2002
149	<p>The licensee is authorized to relocate certain Technical Specification requirements previously included in Appendix A to licensee-controlled documents, as described in Table LR, "Less Restrictive Changes - Relocated Details," and Table R, "Relocated Specifications," attached to the NRC staff's safety evaluation dated July 26, 2002. Those requirements shall be relocated to the appropriate documents no later than October 31, 2002.</p>	October 31, 2002
149	<p>The licensee will complete evaluation of the maximum test face velocity for the ventilation systems included in Technical Specifications (TS) Section 5.5.9 by February 28, 2003. The licensee will also submit a license amendment request for TS amendment by February 28, 2003, to specify the maximum test face velocity if the maximum actual face velocity is greater than 110 percent of 40 fpm based on the licensee's evaluation.</p>	February 28, 2003