

CONDITION REPORT						CR Number 02-05705	
<b>TITLE:</b> CLADDING CRACK FOUND IN ORIGINAL RVH CAVITY							
O R I G I N A L I O N	DISCOVERY DATE	TIME	EVENT DATE	TIME	SYSTEM / ASSET#		
	9/6/2002	N/A	na	N/A	N/A N/A		
	EQUIPMENT DESCRIPTION Original Davis-Besse Reactor Head Cavity						
	DESCRIPTION OF CONDITION and PROBABLE CAUSE (if known) Summarize any attachments. Identify what, when, where, why, how.						
	<p>The 17" diameter specimen that was removed from the original Davis-Besse Reactor Pressure vessel is currently undergoing examination in a laboratory. The laboratory informed Davis-Besse today that a crack approximately 3/8" long was found in the center of the exposed cladding area of the cavity. This new information will need to be evaluated for possible effects on the safety significance analysis.</p> <p>The laboratory also performed cladding thickness measurements. The results were as follows:</p> <p>Average - 0.256" Minimum - 0.202" Maximum - 0.314"</p> <p>These results will also need to be evaluated to determine their effect on the safety significance analysis.</p>						
SUPV COMMENTS / IMMEDIATE ACTIONS TAKEN (Discuss CORRECTIVE ACTIONS completed, basis for closure.)							
NA							
QUALITY ORGANIZATION USE ONLY		IDENTIFIED BY (Check one)			ATTACHMENTS		
Quality Org. Initiated <input type="checkbox"/> Yes <input type="checkbox"/> No		<input checked="" type="checkbox"/> Individual/Work Group <input type="checkbox"/> Supervision/Management			<input type="checkbox"/> Self-Revealed <input type="checkbox"/> Internal Oversight <input type="checkbox"/> External Oversight		
Quality Org Follow-up <input type="checkbox"/> Yes <input type="checkbox"/> No					<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
ORIGINATOR	ORGANIZATION	DATE	SUPERVISOR	DATE	PHONE EXT.		
MCLAUGHLIN, M	CH	9/9/2002	MCLAUGHLIN, M	9/9/2002	8295		
P L A N T  O P E R A T I O N S	SRO REVIEW	EQUIPMENT OPERABLE	EVALUATION REQUIRED	IMMEDIATE INVESTIGATION REQUIRED	ORGANIZATION NOTIFIED	MODE CHANGE RESTRAINT	
	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	N/A	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
	MODE	ASSOCIATED TECH SPEC NUMBER(S)	ASSOCIATED LCO ACTION STATEMENT(S)				
	N/A	N/A	#1 N/A				
			#2				
DECLARED INOPERABLE (Date / Time)		REPORTABLE?	One Hour N/A		APPLICABLE UNIT(S)		
N/A		<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Eval Required	Four Hour N/A		<input checked="" type="checkbox"/> U1 <input type="checkbox"/> U2 <input type="checkbox"/> Both		
COMMENTS							
N/A							
Current Mode - Unit 1	Power Level - Unit 1	Current Mode - Unit 2	Power Level - Unit 2				
N/A	N/A	N/A	N/A				
SRO - UNIT 1		SRO - UNIT 2		DATE			
Approved By Supv		N/A		9/9/2002			

IEP2