

September 24, 2002

MEMORANDUM TO: File

FROM: Jack N. Donohew, Senior Project Manager, Section 2
Project Directorate IV /RA/
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

SUBJECT: PROPRIETARY REVIEW OF SAFETY EVALUATION DATED
SEPTEMBER 13, 2002, FOR LICENSE AMENDMENT NO. 153 FOR
THE CALLAWAY PLANT REGARDING STEAM GENERATOR
ELECTROSLEEVE TUBE SURVEILLANCE (TAC NO. MB1214)

Union Electric Company (the licensee) submitted an application dated February 15, 2001, for a license amendment to amend Technical Specification (TS) 5.5.9, "Steam Generator (SG) Tube Surveillance Program," to remove the requirement that all SG tubes containing an Electrosleeve, a Framatome proprietary process, had to be removed from service within two operating cycles following installation of the first Electrosleeve. This requirement was incorporated in TS 5.5.9 in Amendment No. 132 issued May 21, 1999. The first Electrosleeve tube was installed in the Fall of 1999, and the two-cycle allowance will expire in the Fall of 2002.

The staff issued Amendment No. 153 to remove the restriction that all SG Electrosleeve tubes had to be removed from service within two operating cycles following installation of the first Electrosleeve tube. The amendment was issued September 13, 2002, and requested, pursuant to Section 2.790 of Title 10 of the *Code of Federal Regulations* (10 CFR), that the licensee review the safety evaluation (SE) dated September 13, 2002, enclosed with the license amendment to determine if there is proprietary information in the SE. The licensee was requested to identify by e-mail to the staff as soon as reasonably possible if there is proprietary information, and follow the e-mail by a letter that identifies such information line by line and defines the basis pursuant to 10 CFR 2.790.

The licensee contacted the staff by the attached e-mail and included the letter dated September 16, 2002, from Framatome ANP to the licensee that stated the SE contained no proprietary information.

Docket No. 50-483

Attachment: E-mail dated September 17, 2002

September 24, 2002

MEMORANDUM TO: File

FROM: Jack N. Donohew, Senior Project Manager, Section 2
Project Directorate IV /RA/
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

SUBJECT: PROPRIETARY REVIEW OF SAFETY EVALUATION DATED
SEPTEMBER 13, 2002, FOR LICENSE AMENDMENT NO. 153 FOR
THE CALLAWAY PLANT REGARDING STEAM GENERATOR
ELECTROSLEEVE TUBE SURVEILLANCE (TAC NO. MB1214)

Union Electric Company (the licensee) submitted an application dated February 15, 2001, for a license amendment to amend Technical Specification (TS) 5.5.9, "Steam Generator (SG) Tube Surveillance Program," to remove the requirement that all SG tubes containing an Electrosleeve, a Framatome proprietary process, had to be removed from service within two operating cycles following installation of the first Electrosleeve. This requirement was incorporated in TS 5.5.9 in Amendment No. 132 issued May 21, 1999. The first Electrosleeve tube was installed in the Fall of 1999, and the two-cycle allowance will expire in the Fall of 2002.

The staff issued Amendment No. 153 to remove the restriction that all SG Electrosleeve tubes had to be removed from service within two operating cycles following installation of the first Electrosleeve tube. The amendment was issued September 13, 2002, and requested, pursuant to Section 2.790 of Title 10 of the *Code of Federal Regulations* (10 CFR), that the licensee review the safety evaluation (SE) dated September 13, 2002, enclosed with the license amendment to determine if there is proprietary information in the SE. The licensee was requested to identify by e-mail to the staff as soon as reasonably possible if there is proprietary information, and follow the e-mail by a letter that identifies such information line by line and defines the basis pursuant to 10 CFR 2.790.

The licensee contacted the staff by the attached e-mail and included the letter dated September 16, 2002, from Framatome ANP to the licensee that stated the SE contained no proprietary information.

Docket No. 50-483

Attachment: E-mail dated September 17, 2002

DISTRIBUTION:

PUBLIC
RidsNrrPMJDonohew
RidsNrrLAEPeyton
LLund

ADAMS ACCESSION NUMBER: ML022620721

OFFICE	LDPIV-2/PM	LPDIV-2/LA	LPDIV-2/SC
NAME	JDonohew	EPeyton	SDembeck
DATE	9/23/2002	9/20/2002	9/23/2002

OFFICIAL RECORD COPY

E-MAIL DATED SEPTEMBER 17, 2002

From: "Shafer, David E" <DShafer@ameren.com>
To: "Jack Donohew (E-mail)" <jnd@nrc.gov>
Date: 9/17/02 8:14AM
Subject: FW: FANP-02-2256 (Electrosleeve Proprietary Item)

This should closeout the open proprietary item on the Electrosleeve amendment. Give me a call when you have a chance.

Dave Shafer

Phone 314-554-3104
Fax 314-554-3558
Email dshafer@ameren.com

-----Original Message-----

From: HUMPHRIES Bubba [mailto:Bubba.Humphries@framatome-anp.com]
Sent: Monday, September 16, 2002 4:26 PM
To: MIKE CHAPMAN (E-mail)
Cc: DAVE SHAFER (E-mail); TIM HERRMANN (E-mail)
Subject: FW: FANP-02-2256

Mike, attached is the "formal" letter. I have it coming to you in the US Mail, let me know if you need a fax copy. Bubba

> -----Original Message-----

> From: JOUVIN Shaleen A
> Sent: Monday, September 16, 2002 4:46 PM
> To: HUMPHRIES Bubba
> Subject: FANP-02-2256

>

> <<FANP-02-2256.doc>>

>

> Shaleen Jouvin
> Phone 434-832-3140
> Fax 434-832-2620

>

CC: "Chapman, J Mike" <JChapman@ameren.com>, "Herrmann, Timothy E." <teherrmann@cal.ameren.com>, "Blosser, John D." <jdblosser@cal.ameren.com>, "Bubba Humphries (E-mail)" <Bubba.Humphries@framatome-anp.com>

September 16, 2002
FANP-02-2256

Mr. Mike Chapman
Licensing Department
AmerenUE
1901 Chouteau Avenue
PO Box 66149
St. Louis, MO 63166

Subject: Safety Evaluation by the Office of Nuclear Reactor Regulation Related to
Amendment No. 153 to Facility Operating License No. NPF-30

Reference: 1) BS Humphries to Alan Passwater Letter FANP-01-1052 dated April 9, 2001
2) D. Shafer to B. Humphries e-mail of 9/13/2002, same subject

Dear Mr. Chapman:

Reference 2 requested Framatome ANP review the subject document for any "proprietary information" contained in the subject document. Using reference 1 (for proprietary information to be held from disclosure) Framatome ANP has completed the review and determined that there is no proprietary information in the subject document. If you have any further questions, please contact the writer.

Sincerely,

B. S. Humphries
Senior Project Manager

c: D. Shafer
T. Herrmann
J. Mallay

Bc : J. Galford
J.C. Brown
S.B. Brown
D. Firth