V.C. SUMMER NUCLEAR STATION

NRC JOB PERFORMANCE MEASURE JPS-090

CALCULATE SUBCOOLING MARGIN (NRC)

Revision No. 0

A15

PAGE 0

CALCULATE SUBCOOLING MARGIN (NRC)

5

TRAINEE	EVA	LUATOR		
EVALUATOR SIGNATURE		,,,	DATE	
EVALUATION METHOD:	PERFORM			
EVALUATION LOCATION:	SIMULATOR			
ESTIMATED TIME:	10.0 MINUTES	TIME	STARTED:	
10CFR55.41(b)14 PR: ANI	INCIPLES OF HEAT TRA D FLUID MECHANICS	NSFER THERMOI	DYNAMICS	
TIME CRITICAL: No	FAULTED JPM	: No		
TRAINEE PERFORMANCE:	SATISFACTORY	UNSATISE	FACTORY	

READ TO OPERATOR: WHEN I TELL YOU TO BEGIN, YOU ARE TO PERFORM THE ACTIONS AS DIRECTED IN THE INITIATING CUES. I WILL DESCRIBE GENERAL CONDITIONS UNDER WHICH THIS TASK IS TO BE PERFORMED AND PROVIDE THE NECESSARY TOOLS WITH WHICH TO PERFORM THIS TASK. BEFORE STARTING, I WILL EXPLAIN THE INITIAL CONDITIONS, WHICH STEPS TO SIMULATE OR DISCUSS, AND PROVIDE INITIATING CUES. WHEN YOU COMPLETE THE TASK SUCCESSFULLY, THE OBJECTIVE FOR THIS JOB PERFORMANCE MEASURE WILL BE SATISFIED.

INITIAL CONDITIONS:

- The plant was at 100% power when a loss of service power 1. occurred.
- The crew has taken appropriate actions of EOP-1.0 and 1.1. 2.
- 3. Management has directed a Natural Circulation Cooldown per EOP-1.3.
- The crew is verifying subcooling per step 10 of EOP-1.3. 4:
- 5. PT-402 has failed low and PT-403 indication is unreliable.

TOOLS AND EQUIPMENT NEEDED:

NONE

REFERENCED DOCUMENTS:

REV DATE

NATURAL CIRCULATION COOLDOWN EOP*1.3 1.

11/17/94

PAGE 1

ור

I

J١

CALCULATE SUBCOOLING MARGIN (NRC)

TASK STANDARDS:

 Student calculates subcooling marging of 105°F (±2°F).

INITIATING CUES:

1. The CRS directs you to calculate subcooling margin due to the problems with PT-402 and PT-403.

TERMINATING CUES:

1. Subcooling margin is calculated.

SAFETY CONSIDERATIONS:

NONE

î

:

-11

JOB PERFORMANCE MEASURE CHECKLIST

PAGE 2

SAT. UNSAT.

- (S) DENOTES SEQUENCED ELEMENT
- (*) DENOTES CRITICAL ELEMENT
- PERFORMANCE CHECKLIST:

STANDARD

*1. Determines pressure to calculate subcooling margin

STEP

Uses pressurizer pressure of 2200 psia (±10 psia).

COMMENTS:

۲.

<u>STEP</u>

STANDARD

*2. Determines RCS temperature.

Determines RCS temperature from RCS That indication or Core Exit T/C indications of $544°F (\pm 1°F)$.

COMMENTS:

<u>STEP</u>

STANDARD

S*3. Determines subcooling margin.

Using steam tables, determines subcooling margin of 105°F (±2°F).

COMMENTS:

Examiner Stops JPM At This Point

TIME STOPPED.

-

ē

GENERAL COMMENTS:

NRC KA REFERENCES:

KA NUMBER

000074.EA2.01

•

Ability to determine subcooling margin.

.

PAGE 3

11

 $\begin{array}{c} \text{IMPORTANCE} & \text{FACTOR} \\ \underline{\text{RO}} & \underline{\text{SRO}} \\ \hline 4.6 & 4.9 \end{array}$