

TABLE OF CONTENTS (cont'd)

		Page
Section 5	Design Features	
5.1	Size	5.1-1
5.2	Containment	5.2-1
5.3	Auxiliary Equipment	5.3-1
Section 6	Administrative Controls	
6.1	Responsibility	6-1
6.2	Organization	6-1
6.3	Facility Staff Qualifications	6-2a
6.4	DELETED	6-3
6.5	Review and Audit	6-3
6-6	Reportable Event Action	6-9
6-7	Safety Limit Violation	6-9
6-8	Procedures and Programs	6-10
6-9	Reporting Requirements	6-13
6-10	Record Retention	6-17
6-11	Radiation Protection Program	6-18
6-12	(Deleted)	6-18
6-13	High Radiation Area	6-18
6-14	Environmental Qualification	6-19*
6-15	Integrity of Systems Outside Containment	6-19
6-16	Iodine Monitoring	6-19
6-17	Post Accident Sampling	6-20
6-18	Process Control Plan	6-20
6-19	Offsite Dose Calculation Manual	6-20
6-20	DELETED	6-20

*Issued by NRC Order dated 10-24-80

- c. A break of at least eight hours should be allowed between work period, including shift turnover time.
- d. In a, b, and c above, the time required to complete shift turnover is to be counted as break time and is not to be counted as work time.
- e. Except during extended shutdown periods, the use of overtime should be considered on an individual basis and not for the entire staff on a shift.

Any deviation from the above guidelines shall be authorized by the Department Managers, or higher levels of management, in accordance with established procedures and with documentation of the basis for granting the deviation.

- j. The Senior Manager - Operations or an Operations Manager, and the Shift Manager require Senior Reactor Operators licenses. The licensed Nuclear Plant Operators require a Reactor Operators license.

6.2.2.3 Individuals who train the operating staff and those who carry out the health physics and quality assurance function shall have sufficient organizational freedom to be independent of operational pressures, however, they may report to the appropriate manager on site.

6.3 Facility Staff Qualifications

- 6.3.1 Each member of the unit staff shall meet or exceed the minimum qualifications of ANSI/ANS 3.1 of 1978 for comparable positions unless otherwise noted in the Technical Specifications, with the following exceptions: 1) the education and experience eligibility requirements for operator license applicants (described in Exelon letter RS-02-100, dated June 19, 2002), and changes thereto, shall be approved by the NRC and described in an applicable station training procedure, and 2) technicians and maintenance personnel who do not meet ANSI/ANS 3.1 of 1978, Section 4.5, are permitted to perform work for which qualification has been demonstrated.
- 6.3.2 The management position responsible for radiological controls shall meet or exceed the qualifications of Regulatory Guide 1.8 (Rev. 1-R, 9/75). Each other member of the radiation protection organization for which there is a comparable position described in ANSI N18.1-1971 shall meet or exceed the minimum qualifications specified therein, or in the case of radiation protection technicians, they shall have at least one year's continuous experience in applied radiation protection work in a nuclear facility dealing with radiological problems similar to those encountered in nuclear power stations and shall have been certified by the management position responsible for radiological controls as qualified to perform assigned functions. This certification must be based on an NRC approved, documented program consisting of classroom training with appropriate examinations and documented positive findings by responsible supervision that the individual has demonstrated his ability to perform each specified procedure and assigned function with an understanding of its basis and purpose.
- 6.3.3 The Shift Technical Advisors shall have a bachelor's degree or equivalent in a scientific or engineering discipline with specific training in plant design, response and analysis of the plant for transients and accidents.

6.4 DELETED

6.5 REVIEW AND AUDIT

6.5.1 TECHNICAL REVIEW AND CONTROL

The director of each department shall be responsible for ensuring the preparation, review, and approval of documents required by the activities described in 6.5.1.1 through 6.5.1.5 within his functional area of responsibility as assigned in the Review and Approval Matrix. Implementing approvals shall be performed at the cognizant manager level or above.

ACTIVITIES

6.5.1.1 Each procedure required by Technical Specification 6.8 and other procedures which affect nuclear safety, and substantive changes thereto, shall be prepared by a designated individual(s)/group knowledgeable in the area affected by the procedure. Each such procedure, and substantive change thereto, shall be reviewed for adequacy by an individual(s)/group other than the preparer, but who may be from the same division as the individual who prepared the procedure or change.