

1 MEMBER POWERS: I guess what I'm really  
2 worried about is, we've done, I don't know 17 tests  
3 something like that.

4 MR. NOWLEN: This set was 18, yes.

5 MEMBER POWERS: And you've got quite a few  
6 phases here. But a fairly limited set of experimental  
7 conditions, a fairly limited number, that I have a  
8 problem with the tests. It's very difficult for me to  
9 extrapolate them to the specific conditions of fire  
10 I'm likely to have in a nuclear power plant. And so  
11 I'm sitting here saying, gee, can I take that, use  
12 that 80 percent, should I correct it, should I fiddle  
13 with it, should I spread it out a little to account  
14 for all the problems I have in using the test data  
15 correctly?

16 What I'm asking for is, what are the  
17 caveats I put on this 80 percent before it becomes a  
18 number carved in stone?

19 MR. NOWLEN: Again, the caveats are that  
20 this is a mechanistic view of the way the cables  
21 themselves fail. It does not tie you to the circuits.  
22 It doesn't tell you whether you've got a spurious  
23 actuation yet or not. Now beyond that, you know, the  
24 issues of the test limitations of the data that we  
25 have, I place high confidence in this number as a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 indicator of the mechanistic mode of cable failure.

2 MEMBER WALLIS: I think it would very  
3 different if you had an external fire like yours or if  
4 you have a branch type fire where the fire was in the  
5 cables themselves.

6 MR. NOWLEN: I'm not so sure. I think it's  
7 -- I think you're still going to see this same  
8 behavior. We saw it -- you know, again, we did a  
9 review of that existing literature that was a number  
10 of tests that had explored this behavior in not quite  
11 as clear a manner but we saw very consistent numbers  
12 coming out of it on the order of 80 percent or more of  
13 these faults were always occurring conductor-to-  
14 conductor and some of those were, in fact, multi-tray  
15 tests. The one set that we had that was most complete  
16 was four tray tests where the fire was ignited in one  
17 tray and spread to 2, 3, 4 and those saw the same type  
18 of behavior, again 80 percent of --

19 MEMBER WALLIS: I guess failure to the tray  
20 is most likely for some reason the tray gets very hot  
21 not the -- it's not so hot -- I think it's from the  
22 tray rather than -- that would rather different to  
23 me than a fire from above that heats the cables first  
24 and not the tray.

25 MR. NOWLEN: Well, these were fires from

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 below and the tray and cables heat together really.  
2 I mean, they're an intimate system. The only way I  
3 could think of that is some how inducing inductive  
4 heating in the tray or something like that.

5 MEMBER WALLIS: A radiation fire to the  
6 tray rather than an inductive fire or some --

7 MR. NOWLEN: Yeah, that --

8 MEMBER WALLIS: That might make a  
9 difference, I don't know. It's speculative.

10 MR. NOWLEN: It might, yes. I suspect that  
11 you will still see in this mechanistic view of the  
12 cables failing, I think you're still going to see this  
13 number, take it to the bank and put it in your  
14 account. I think this is the right number.

15 MEMBER WALLIS: Was the tray perforated or  
16 was it solid?

17 MR. NOWLEN: This was a ladder. Yeah, it's  
18 a ladder. Yeah, it's like an aluminum ladder.

19 MEMBER WALLIS: An open tray?

20 MR. NOWLEN: Yes, that's the predominant  
21 configuration.

22 MEMBER WALLIS: That must make a  
23 difference.

24 MR. NOWLEN: It might, it might.

25 MEMBER SIEBER: It's like just being out in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 the air.

2 MR. NOWLEN: It's like -- well, except that  
3 you have the rungs supporting -- you know, the cables  
4 are resting on the rungs and that's a pressure point.

5 MEMBER SIEBER: That's the grounding.

6 MR. NOWLEN: That's where the ground path  
7 is, yeah.

8 MEMBER KRESS: Yeah, but that may a  
9 cooler spot, too.

10 MR. NOWLEN: It's possible, yes.

11 MEMBER KRESS: I think what's happening is  
12 you're heating up in between.

13 MR. NOWLEN: Okay, let's see.

14 MEMBER POWERS: Well, I mean, here's the --  
15 we're talking about the research program here and  
16 you've gone and you've got a gee-whiz test and you've  
17 got some fuel for the modes of containing -- of  
18 conductive failures but I don't have a physical model  
19 for the cable here. So, I can't take an arbitrary  
20 fire and apply those results, whether it's blow torch  
21 over the top of the cable, whatever, some other fire  
22 and so I ask the question, why isn't the research  
23 program developing this mechanistic cable model, the  
24 whole shebang.

25 MR. NOWLEN: Can I defer an answer --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER POWERS: Is that the question that's  
2 on your mind, Graham?

3 MEMBER WALLIS: It's been on my mind for a  
4 long time, yes. This seems to very much the gee-  
5 whiz try it and see what happens type research.

6 MR. NOWLEN: Okay, let me defer that to my  
7 last slide.

8 MEMBER WALLIS: Generalizing it to some  
9 other situation and it becomes different.

10 MR. NOWLEN: Yes, I agree. Let me defer my  
11 answer to the last slide. Okay, let's see, the  
12 incidents factor as we saw, some of these that we  
13 thought to important proved to important. I think  
14 we've covered those. There was one new one that  
15 popped up. We had identified the circuit details and  
16 a general influence factor. But specifically in the  
17 NEI tests, the MOV circuits, these control power  
18 transformers turned out to a very important effect  
19 here. We hadn't picked up on that specifically. We  
20 had identified general configuration as a factor and  
21 I believe Fred will cover that, so I'm not going to  
22 get into detail there.

23 We did see a broad consistency between the  
24 IR and the MOV results that Fred's going to tell you  
25 about. The idea that the embedded conductors fail

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 later. The conductors shorting to nearest neighbors,  
2 short complex behaviors, durations of the hot shorts  
3 and spurious actuations that were observed and the  
4 fact that all of the cables eventually shorted to  
5 ground, all those were consistent between the two  
6 sets.

7 MEMBER WALLIS: I'm curious about what  
8 happens if you turn on the sprinkler before the cables  
9 fail. Is it more likely to lead to failure, early  
10 failure?

11 MR. NOWLEN: That's a question we didn't  
12 answer. The sprinklers were turned on in a number of  
13 the tests but usually it was after the cables had all  
14 failed and fuses had blown. There was one case --  
15 there was one -- no, okay, I'm going to let Fred  
16 answer that one then, because Fred knows the details  
17 of that.

18 MEMBER KRESS: On your second sub-bullet on  
19 that slide there, I would hard-pressed to see how  
20 conductor could short to something which wasn't as  
21 near as many.

22 MR. NOWLEN: We agree. Well, again, you  
23 know, these were things that we thought we knew and,  
24 you know, we've confirmed it. We've said that. These  
25 tests clearly give us definitive, yes, that's what

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 happens.

2 CHAIRMAN ROSEN: This question about what  
3 would happen if the sprinkler turned on is that same  
4 question I asked this morning about damage to operable  
5 safety system equipment in the event of actuation of  
6 fire suppression equipment, either automatic or  
7 manual. We were talking about it in the context of a  
8 fire brigade but I was really thinking about this  
9 situation, too.

10 MR. NOWLEN: Yeah, yeah.

11 CHAIRMAN ROSEN: You said you didn't handle  
12 that in the modeling. You were talking about  
13 modeling.

14 MEMBER SIEBER: The other thing, as long as  
15 we're talking about things that bother us, one of the  
16 things that bothers me is not all cables in nuclear  
17 power plants are installed horizontal. Somehow they  
18 go up too, and down. So we don't have any tests of  
19 what happens when the cables are --

20 A VOICE: Some of these tests --

21 MR. NOWLEN: Yeah, some of them were  
22 vertical trays as well.

23 CHAIRMAN ROSEN: Oh, were they?

24 MR. NOWLEN: Yes.

25 CHAIRMAN ROSEN: And did you see any

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 difference in failure modes, anything different about  
2 that?

3 MR. NOWLEN: It wasn't a very strong  
4 influence factor. There were some differences. It  
5 wasn't very strong.

6 CHAIRMAN ROSEN: Because you showed us a  
7 plan view and it all looked like it was all at one  
8 level.

9 MR. NOWLEN: Yeah, I didn't show you the  
10 one with the vertical tray.

11 MEMBER SIEBER: I would think that the  
12 vertical tray would deteriorate faster because, you  
13 know, there's more space for combustion. On the other  
14 hand, gravity is not pulling cables into ground.  
15 They're tied in there with tie wraps.

16 MR. NOWLEN: That's right, that's the point  
17 is they are tied in with tie wraps, so it's not like  
18 they're sort of hanging out in air. That we didn't  
19 do. We didn't do the air drop configuration and --

20 MEMBER KRESS: But, you're not actually  
21 burning this insulation.

22 MR. NOWLEN: Not explicitly. In some sense  
23 there was some burning of the cables, but not --

24 MEMBER KRESS: It wasn't part of the test.

25 MR. NOWLEN: No, that wasn't part of the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 test.

2 MEMBER KRESS: You're just heating it up  
3 and then --

4 MR. NOWLEN: Yeah, these were intended to  
5 exposures.

6 MEMBER WALLIS: Suppose I do a one-  
7 dimensional analysis? You have a round conductor and  
8 you have this stuff, and I instantaneously impose a  
9 temperature of x degrees on the circumference and it  
10 would seem not too difficult to develop some idea of  
11 what happens as a transient, chemically, thermally,  
12 diffusing and so on, one dimensional radial transport  
13 phenomenon. This must have been done by somebody?

14 MR. NOWLEN: Yes, it's --

15 MEMBER KRESS: I don't even think you need  
16 that. I think what you've got is radiant heating and  
17 conductive heating of the gases go through --

18 MEMBER WALLIS: Whatever you want to put on  
19 for your outside --

20 MEMBER KRESS: -- going through a --

21 MEMBER WALLIS: I'm trying to make the  
22 problem simple.

23 MEMBER KRESS: Well, this is --

24 MEMBER WALLIS: No, it's not because I've  
25 got a uniform temperature. I think it's an easier

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 problem radiant than a convective flow.

2 MEMBER KRESS: Well, all I'm trying to do  
3 is find out when the given cable reaches a given  
4 temperature at a given spot. That's pretty simple.

5 MEMBER WALLIS: Well, I'm trying to figure  
6 out what's the given mechanism and it appears it has  
7 to some sort of diffusion of charred products  
8 through the char or something like that.

9 MEMBER KRESS: I think it's just the  
10 mapping of the cable.

11 MR. NOWLEN: Yeah, it's primarily a  
12 diffusion of heat into the cable.

13 MEMBER WALLIS: But that seems to me is  
14 much too quick. It seems to me --

15 MEMBER KRESS: I think when you get it up  
16 to the melting temperature or some other magic  
17 temperature, it fails. And I think you can correlate  
18 the temperature --

19 MEMBER WALLIS: That's too quick, that's  
20 too quick.

21 MR. NOWLEN: Well, keep in mind though --

22 MEMBER WALLIS: I think an order of  
23 magnitude, for heaven sake. Well, this is somewhat  
24 transient. What is the thermo relaxation time of this  
25 installation? It must very short.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. NOWLEN: Well, it's a very large mass  
2 of cables. It's not very --

3 MEMBER WALLIS: It's a very large mass?

4 MR. NOWLEN: It's a mass of cables, yes.  
5 It's big with lots of copper and lots of thermo mass.

6 MEMBER WALLIS: This is a lots of argument  
7 rather than a quantitative one? You're going to go  
8 back to freshman class here.

9 MR. NOWLEN: It's a semi-quantity. It was  
10 a --

11 MEMBER WALLIS: But I would encourage  
12 somebody to do some of these simple -- relatively  
13 simple calculations that we think it's thermo-mass,  
14 gee, whiz when we work out the numbers we get 10  
15 seconds that are at 3,000 so we'd better change our  
16 minds or whatever.

17 MR. NOWLEN: I agree, and as I mentioned up  
18 front, we have barely scratched the surface of this  
19 data set. We've looked at it in this context, but  
20 there are many other contexts in which this data is  
21 interesting and important.

22 MEMBER WALLIS: I just can't see how you  
23 could resist doing at least one homework problem on  
24 this.

25 MR. NOWLEN: You haven't seen my work

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 schedule. Okay. Quickly, two more slides; we did  
2 see some unique things from the MOV tests, certainly.  
3 I think it's worthy of noting that in most of the  
4 tests here cables did fail, at least one device in the  
5 MOV circuits did actuate.

6 MEMBER WALLIS: Can I ask -- I'm sorry to  
7 keep on asking questions. Would you give me, please,  
8 the dimensions and properties of the stuff so that I  
9 could do a homework problem? Would that an  
10 unreasonable request?

11 MR. NOWLEN: No, sure.

12 MEMBER WALLIS: Maybe after a break or  
13 during a break.

14 A VOICE: I think it's in the report.

15 MEMBER WALLIS: Well, I don't think I have  
16 the report. I'm not sure I'm in the right pipeline  
17 here.

18 MR. NOWLEN: Yeah, we can get it to you.  
19 I don't have that information with me, but I certainly  
20 have it at home.

21 MEMBER WALLIS: Maybe someone has the  
22 report here I can look at. Okay, thanks.

23 MR. NOWLEN: The one you need is the test  
24 report, the published NUREG CR, not the draft.

25 Okay, the MOV tests, we did see in several

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 tests there was more than one device actuation. In  
2 one test the -- there was one test where again, there  
3 was four MOVs typically in each test and there was one  
4 test where all four of the MOVs saw at least one  
5 spurious actuation hit. So, I think that was very  
6 interesting and it's important information for us.  
7 The device actuations due to intra-cable hot shorts  
8 were the most common but there were a number -- a  
9 small number of interactions due to inter-cable.

10 MEMBER POWERS: Then spurious actuation did  
11 occur.

12 MR. NOWLEN: It tells me that these are not  
13 incredibly low probability events.

14 MEMBER POWERS: Yeah, I mean, that's all it  
15 tells you, right?

16 MR. NOWLEN: Well, I think that's an  
17 important insight. I think there's been a lot of  
18 argument about what the likelihood of these is. I  
19 think we have a much better feel for what these  
20 likelihoods are today than we did two years ago.

21 CHAIRMAN ROSEN: These were originally  
22 thought to once in a lifetime, once in a million  
23 kind of events and in fact, they're not. These  
24 probable events in a serious fire. That's the  
25 conclusion I take away. You have a serious fire with

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 a lot of electrical cables involved, you're going to  
2 have -- you'll probably have a hot short.

3 MR. NOWLEN: I tend to agree, yes.

4 MEMBER POWERS: I mean, I'm not sure how to  
5 interpret that exactly. It would probably operate  
6 from the frame of mind that say, I always thought  
7 actuations would occur.

8 CHAIRMAN ROSEN: Well, you know, I've  
9 always thought they wouldn't and, you know, now I  
10 think these tests say to me that they probably will.  
11 They're not all going to -- not every cable that's  
12 involved is going to show a hot short, but if you have  
13 a lot of cables involved and a persistent hot fire,  
14 you're probably going to have one.

15 MEMBER POWERS: What I struggle with a  
16 little bit is right now I have deterministic kind of  
17 analyses that say though shall hypothesize by shorts,  
18 possibility of spurious actuation and you do it for  
19 every conceivable configuration that you've got.  
20 Okay, so now I say, well, I'd really like to put this  
21 on a more probabilistic frame and do this in a less  
22 demanding fashion. And I'm not sure I can use this to  
23 these results, do that.

24 And so I'm asking is there -- am I wrong  
25 about that? Has my life changed? I mean, I want to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 do a sophisticated job. Can I use these results to  
2 change my life and I'm not sure I can but see my next  
3 question is, can I do a test in which I do change my  
4 life. And then my third question is, should we do a  
5 test to change my life. I eventually get back to you,  
6 David.

7 MEMBER WALLIS: The thing is can we devise  
8 a test which will change your life?

9 CHAIRMAN ROSEN: Have you ever changed  
10 your mind about anything is the question? Let me take  
11 control here for a minute and tell you what's going to  
12 happen. We've got 20 minutes more till we break and  
13 four more minutes of that time is up for you and the  
14 rest is reserved for Fred.

15 MR. NOWLEN: Well, we still have Fred as  
16 well.

17 CHAIRMAN ROSEN: That's right. He's got --  
18 after you get done messing with the four minutes  
19 you've got, he gets the next 15.

20 MEMBER POWERS: Well, I thought he got the  
21 break?

22 CHAIRMAN ROSEN: What?

23 MEMBER POWERS: I thought he got the break.

24 CHAIRMAN ROSEN: No.

25 MR. NOWLEN: Okay, the last slide. There

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 are challenges that -- and areas of uncertainty,  
2 clearly that we have not yet resolved. The first one  
3 gets to the point that was raised earlier, the  
4 combinatorial models, this mechanistic connection  
5 between the behavior of these cables and the behavior  
6 of some circuit that I'm specifically worried about in  
7 my plant. There have been some proposals made in this  
8 area, in particular Dan Funk, one of the industry  
9 folks, has proposed a model. We haven't really had a  
10 chance to explore that fully to see how well it works.  
11 I think we're -- you know, we're working that  
12 direction. We're not quite there yet.

13 The DC versus AC we talked about, still  
14 some uncertainty there. We're not quite sure why.  
15 There's a little uncertainty on the conduits, not  
16 quite so bad. The influence factors, we didn't look  
17 at all the influence factors and some of them have  
18 been bandied about here, the things that we didn't  
19 look at. So we need to understand those better or at  
20 least understand which ones are going to make a  
21 difference to us. Quantification for a specific case  
22 still requires some expert judgment.

23 And this is just the last point, can you  
24 use this? Yes, absolutely. I argue this is the best  
25 stuff you've got. Now, can you just take the number

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 and apply it in your analysis? No. It still takes  
2 some expert judgment to make the connection between  
3 the behaviors we observed in these tests and your  
4 circuit and your cable. That still has to happen and  
5 we're still partly expert judgment here.

6 MEMBER POWERS: This is the problem I have  
7 when you tell me use expert judgment to transfer the  
8 results from these tests to the real accident, without  
9 experimental data, how do I have expert judgment in  
10 this thing?

11 MR. NOWLEN: I understand. It's a  
12 challenging problem.

13 MEMBER WALLIS: By expert judgment, he  
14 means guesswork and --

15 MEMBER POWERS: Hope and prayer it looks to  
16 me like all you've got going for you right now. I  
17 mean, it's -- the only way I can make this transition  
18 is to have a mechanistic mental model of the fire both  
19 the accident fire and the test fire, and a mechanistic  
20 mental model of the way the cable behaves. Now the  
21 trouble with that is that it's my mental model and I  
22 don't give the opportunity for Graham to criticize my  
23 momentum equation in there because I don't write the  
24 damn thing down.

25 MEMBER WALLIS: I don't think the momentum

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 equation is all that important in this --

2 MEMBER POWERS: Well, it's never very  
3 important.

4 MEMBER WALLIS: It isn't going to go very  
5 far very fast.

6 MEMBER POWERS: But I also don't let you  
7 criticize my chemical kinetic model because you don't  
8 ever get to see it here.

9 MEMBER WALLIS: I don't think you have one.

10 MEMBER POWERS: Oh, I always have a  
11 chemical kinetic model, you can go to the bank on that  
12 one.

13 CHAIRMAN ROSEN: You're using up his four  
14 minutes.

15 MR. NOWLEN: Yes.

16 MEMBER POWERS: I'm using my four minutes  
17 here. So the question we come back to is the one you  
18 deferred, is why aren't we producing these mechanistic  
19 models?

20 MEMBER SIEBER: The better question, a  
21 forerunner to that is, do you think you have enough  
22 data to validate --

23 CHAIRMAN ROSEN: Not from these tests.

24 MEMBER SIEBER: This gives good insight but  
25 it's not a validated model.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           A VOICE: This is the way you develop a  
2 model.

3           MR. SIU: I think we are well beyond where  
4 we were, as Steve indicated, two years ago. I think  
5 we actually do have some valid test data which  
6 certainly doesn't cover all possible conditions. I'll  
7 certainly grant that. I guess one of the reasons that  
8 we haven't thought about the mechanistic model, maybe  
9 that's something we'll need to address as we update  
10 our research plan.

11           When we think about the application of  
12 that mechanistic model in the real world PRA, start  
13 thinking about the data demands of such a model, I get  
14 a little worried. It's my similar fears about  
15 computational fluid dynamics. Yes, I know I can do  
16 very nice jobs -- a very nice job using those models  
17 but I have to develop the model actually to employ  
18 that. I have to put the cables in there, I have to  
19 put in the supports, I have to do a lot of things that  
20 take a lot of time and effort and maybe I don't need  
21 to do that.

22           You asked that question, what's good  
23 enough? I'm not sure -- let me back up a little bit.  
24 Some of the factors Steve has mentioned before in, I  
25 think, a previous talk, we talked about where the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 cable is in the cable tray. Is it on top, is it on  
2 the bottom, because the effect of the weight on top of  
3 that cable could make a difference. How are the wires  
4 hooked up, which one is the power wire, which one is  
5 not? These are things that if you get into a very  
6 sophisticated model, which is quite possible, I think  
7 it's quite feasible to develop this, you're going to  
8 have to do a lot, so this is -- I'm not saying that  
9 we're not going to do this. I'm simply saying that  
10 this -- in the past, this is some of the thinking  
11 that's gone behind where we are now.

12 We've put a lot of our resources in this  
13 whole program, into this effort and has continued and  
14 continued, kind of like Topsy.

15 CHAIRMAN ROSEN: I'm going to let you  
16 finish and then I'm going to let Graham Wallis have a  
17 word.

18 MR. SIU: So I'm just -- and maybe it's a  
19 rationalization of why we're not -- we haven't done it  
20 to date and again, we're listening and we welcome your  
21 input on that.

22 MEMBER WALLIS: I'm usually very  
23 impassioned but now you're giving the standard student  
24 excuse that I don't want to do any analysis because  
25 I'd have to analyze everything and it would too

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 difficult. I think you can go quite a long way with  
2 some relatively simple analysis to figure out what  
3 matters and what doesn't matter, what might  
4 different about your test and the nuclear plant test  
5 and so on. You've got to do that. I don't think it's  
6 that difficult.

7           You cannot say, it's difficult because the  
8 model is going to have to be too complicated. You  
9 haven't even tried it seems to me the simple one.

10           MR. SIU: Well, I'm sorry, maybe I gave the  
11 wrong impression. I'm sure we can come up with a  
12 reasonable explanation of what's going on, what's the  
13 mechanism driving this. I'm going the next step and  
14 saying, how do I apply this in the PRA and that's  
15 where I'm -- I have certain expectations of what I  
16 think is going to be important and therefore, what I'm  
17 going to have to model. And if I have to start  
18 modeling in this mechanistic, completely mechanistic  
19 view where exactly the cable is, sometimes it's on  
20 top, sometimes it's on the bottom, sometimes the fire  
21 is off to one side, sometimes it's directly  
22 underneath, I'm wondering if I'm at a point of  
23 diminishing returns.

24           MEMBER WALLIS: But it's simply time to  
25 melt, and you simply --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. SIU: Well, no, the time to melt again,  
2 that's the problem. I don't -- we know how to model  
3 it and we are modeling that. It's this competition  
4 between the specific locations of the melt point if  
5 you will that's telling me do I connect these two  
6 conductors first or these two and if these two  
7 conductors are connected first, I might just go  
8 directly to ground and I don't have a problem or my  
9 trips match actuation device. I'm sorry.

10 CHAIRMAN ROSEN: All right, thank you very  
11 much.

12 MR. NOWLEN: I will leave my last bullet  
13 unstated because that's another hot -- you know,  
14 there's another aspect of this that we're not dealing  
15 with very well yet and that's the transient behavior  
16 and this gets you to some of the regulatory issues of  
17 simultaneous, concurrent, sequential, how do I deal  
18 with it. And again, that's another challenge that we  
19 have. So with that --

20 CHAIRMAN ROSEN: NEI, it's your 15 minutes.

21 A VOICE: Surely you can more generous  
22 than that.

23 CHAIRMAN ROSEN: Generosity is not the  
24 issue. Wait for Christmas and you'll see generosity.

25 MR. EMERSON: Thank you. Given the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 discussion that has taken place over the last hour and  
2 15 minutes, I've concluded that there is absolutely no  
3 way I can do justice to these slides in 15 minutes.  
4 Take me time?

5 CHAIRMAN ROSEN: No, take your 11 minutes.

6 MR. EMERSON: So I will take my 11 minutes.

7 CHAIRMAN ROSEN: I'll give you the full 15,  
8 but go ahead.

9 MR. EMERSON: Okay. First I'd like to  
10 start by -- you're going to probably have to review  
11 the slides to get a lot of the data that I'm going to  
12 present but let me just try to summarize briefly what  
13 the differences are between what Steve presented and  
14 what we presented. Steve was looking for IR results,  
15 insulation resistance breakdown. We were looking more  
16 for circuit effects in circuits that reasonably  
17 approximate what you would see in an actual nuclear  
18 plant. Take fire phenomena and determine what would  
19 happen to reasonably, accurately portrayed circuits  
20 for control cables, for -- which is where you expect  
21 the bulk of consequences to with spurious actuations  
22 and that was really our goal.

23 So with that, I'm going to skip the first  
24 couple of slides. Now, what I have in my presentation  
25 is a quick summary of an EPRI test report that Steve

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 indicated is still -- the report is 400 some odd pages  
2 long, covers a great deal of ground and as I say, I'm  
3 not going to try to do justice to it. And the last  
4 two slides in the presentation are a couple of the  
5 more important results of the EPRI expert panel that  
6 was convened to determine what the probabilities of  
7 spurious actuations are from the results of these and  
8 other tests.

9 Steve gave a pretty good summary of what  
10 the tests included. What we will include in the test  
11 report, we'll reporting on the test arrangement  
12 parameters, electrical results and temperature results  
13 and melding those together. The -- you'll see them  
14 for all of the 18 tests, you'll see key observations  
15 and conclusions and you'll see implications for the  
16 NEI guidance document that's being developed to guide  
17 the industry in the resolution of circuit failure  
18 issues.

19 Steve presented some profiles or presented  
20 one example profile from the IR measurements that he  
21 did. I'd like to show one typical example of what you  
22 will see in the EPRI report for one of the tests.  
23 Now, you can see what this represents, that's one  
24 bundle of seven conductor and single conductor cables,  
25 350 kilowatt heat release rate and with the bundle

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 located in the bottom of the tray and the laboratory  
2 power supply as opposed to a CPT.

3 MEMBER WALLIS: What do you mean by the 350  
4 kilowatt heat release rate, that's in a fire of some  
5 sort somewhere?

6 MR. EMERSON: Yeah, that's the heat release  
7 rate associated with the fire for this particular  
8 test.

9 MEMBER KRESS: That's basically the rate of  
10 gas flow.

11 MR. EMERSON: Yeah, it's based on the rate  
12 of gas flow. That's correct.

13 MEMBER WALLIS: But you still don't know  
14 the heating weight of the cable itself.

15 MR. EMERSON: That's correct, this was  
16 based on the parameters of the fire itself, not of the  
17 cable.

18 MEMBER KRESS: Now, when you talk about a  
19 bundle, cables?

20 MR. EMERSON: Yeah, the bundle is the --

21 MEMBER KRESS: Are they just strapped  
22 together or is there something that --

23 MR. EMERSON: The bundle is the seven  
24 conductors surrounded by three single conductor cable  
25 configuration that Steve showed.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER KRESS: Yeah, my question is, what  
2 holds the bundle together?

3 MR. EMERSON: They are strapped together  
4 loosely so that they won't --

5 MEMBER KRESS: Okay.

6 MEMBER SIEBER: But the seven has a single  
7 jacket, right?

8 MR. EMERSON: Yes.

9 MEMBER SIEBER: And the three are on the  
10 outside.

11 MR. EMERSON: Right.

12 MEMBER KRESS: It has a jacket of what?

13 MEMBER SIEBER: Some kind of a thermo-  
14 plastic material.

15 MR. EMERSON: It's either thermo-set or  
16 thermo-plastic material.

17 MEMBER SIEBER: Usually the jacket is  
18 thermo-plastic even though the insulation may  
19 thermo-set.

20 MEMBER KRESS: Okay, so it's completely  
21 closed to the gas flow.

22 MEMBER SIEBER: That's right. And then the  
23 three extra cables are tie wrapped to the outside.

24 MR. EMERSON: Basically.

25 MEMBER SIEBER: That's what it looked like

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 in the drawing.

2 MR. EMERSON: That's correct.

3 MEMBER KRESS: Okay.

4 MEMBER BONACA: Which means the outside  
5 cables are not --

6 MEMBER SIEBER: They're not inside the  
7 jacket.

8 MR. EMERSON: Well, they could but we  
9 tried to keep them as equally spaced as we could and  
10 there were four such bundles in each test in addition  
11 to the IR bundle that Steve talked about.

12 Now, this is a typical temperature profile  
13 from the test that shows not only the average and  
14 maximum temperatures and when I say that, I mean,  
15 these are the temperatures that were -- we had thermo-  
16 couples attached to bundles that were adjacent to the  
17 test bundle. We didn't want to attach them directly  
18 to the test bundle itself because when the jacket  
19 goes, then you get some interference between the  
20 measurement and the cable itself in terms of sorting.  
21 So we put them on the adjacent ones.

22 MEMBER WALLIS: What's the temperature of  
23 the flame?

24 MR. EMERSON: The temperature of the flame?  
25 I'm sorry, was that your question?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER WALLIS: Yes, the temperature of the  
2 flame.

3 MR. EMERSON: We did not measure the flame  
4 temperature directly. We measured the temperatures on  
5 the tray and adjacent to the cable bundles and we had  
6 two thermo-couples trees that measured temperatures in  
7 the hot gas layer and the plume of the fire.

8 MEMBER KRESS: What kind of gas are you  
9 using?

10 MR. EMERSON: I think it was propane but  
11 I'm not --

12 MEMBER WALLIS: This is just a heat-up of  
13 cable. You'd expect a simple RC type transient  
14 expediential. It looks a little bit like an  
15 expediential to me. No one has tried to model that?  
16 You --

17 MR. EMERSON: No one has tried to model it.

18 MEMBER WALLIS: Okay. Like an RC, right.

19 MR. EMERSON: What we've tried to portray  
20 with this temperature measurement in addition is  
21 there's a line for the -- let's see if I've got this  
22 right, for the onset of failure which was basically  
23 the point at which you started getting leakage  
24 currents and the time when you got full failure which  
25 is either a hot short or a short to ground, depending

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 on the particular failure.

2 This one is a little harder to read and in  
3 your package you should have a full size slide. I'm  
4 not going to try to describe what all of the curves  
5 mean. This particular one indicates when you start  
6 off with a zero voltage and then it spikes up, that's  
7 where you had a hot short.

8 MEMBER KRESS: What's the voltage on the  
9 top?

10 MR. EMERSON: This is 120 volts and the  
11 nominal voltage that we ran in the conductors that we  
12 had powered.

13 MEMBER KRESS: Okay, so that's the  
14 potential difference.

15 MR. EMERSON: That's the potential  
16 difference is 120 AC. So in a case like this, it  
17 would start off with zero volts. There would an  
18 interaction with a 120 volt cable and it would spike  
19 up and you would get a hot short in that case.  
20 Whether or not you got a spurious actuation depends on  
21 the current and we found pretty much throughout the  
22 test that it required a current of about a quarter of  
23 an amp to actually get it. When you had a spurious  
24 actuation it as associated with a current of about a  
25 quarter of an amp.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER KRESS: That's for a particular MOV  
2 or something?

3 MR. EMERSON: This is for -- the type of  
4 MOV we tested, it wasn't actually an MOV, it was a  
5 motor started for one and this is a relatively small  
6 one.

7 MEMBER SIEBER: This is a relay in effect.

8 MR. EMERSON: Yeah, it was a relay, the  
9 kind you would find on the typical small valve, small  
10 MOV. But below 25 milli-amps you would get -- I'm  
11 sorry, before 250 milli-amps, you would get a hot  
12 short but not necessarily a spurious actuation.

13 MEMBER SIEBER: Right.

14 MR. EMERSON: In a case like this, this  
15 shows where you have a short to ground that's going  
16 along a 120 AC and then bingo, it falls off when you  
17 shorted it out.

18 MEMBER SIEBER: One point, when you get the  
19 short, it's a high resistance short, then there's this  
20 relay coil attached to it, it wouldn't go all the way  
21 up to 120 volts, would it?

22 MR. EMERSON: Not all cases did it, but  
23 typically you wouldn't get it. The lower threshold  
24 was probably about 80 or 90 volts.

25 MEMBER SIEBER: Okay, so that's the reason

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1       why the relay didn't pull in --

2               MR. EMERSON: Right.

3               MEMBER SIEBER: -- because you didn't get  
4       enough voltage to it.

5               MR. EMERSON: Right.

6               MEMBER SIEBER: It's not a current thing.

7               MR. EMERSON: Okay, I'd like to talk  
8       briefly about the summary of the types of failure  
9       modes. Now I'd like to emphasize that this slide and  
10      the next one are covering hot shorts and then after  
11      that we'll talk about spurious actuations and as Steve  
12      indicated the two phenomena are not identical with  
13      each other.

14              Okay, in this case what we were trying to  
15      do is to illustrate the -- by cable type what  
16      generally you got in terms of ground faults or faults  
17      to ground versus hot shorts as a percentage of total  
18      failures. And we did that, we broke that down for  
19      armored, thermo-set and thermo-plastic cable and  
20      totaled them. Now, recognize this covers a wide range  
21      of fire conditions so this is not -- this is just a  
22      very broad indication of the overall results.

23              What you can take home from this slide is  
24      that generally the percentage of ground faults is a  
25      percentage of total faults is roughly the same for

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 thermo-set or thermo-plastic cable. The phenomena are  
2 different when you go to spurious actuations but for  
3 the basic faulting modes that's what we saw. For  
4 armored it's a little bit different. There was a  
5 higher percentage of ground faults and from what Steve  
6 said, you might expect that given the grounded -- the  
7 fact that the armor is grounded.

8 MEMBER SIEBER: A question on that before  
9 you move on.

10 MR. EMERSON: Sure.

11 MEMBER SIEBER: I take it that some of the  
12 hot shorts show up in these numbers covert themselves  
13 to ground faults?

14 MR. EMERSON: Yes, all of them do  
15 eventually.

16 CHAIRMAN ROSEN: But I think this --

17 MR. EMERSON: I'll talk about duration  
18 later.

19 CHAIRMAN ROSEN: This is the slide where it  
20 says that originally we would have argued or some of  
21 us or I would have argued that that 31.6 percent is an  
22 order of magnitude too high. Now, we see a third of  
23 the faults are going to hot shorts.

24 MEMBER SIEBER: And these are hot shorts  
25 that are solid enough to be able to actuate the starter

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 coil.

2 MR. EMERSON: No, these are hot shorts, not  
3 spurious actuations.

4 MEMBER SIEBER: Okay.

5 MR. EMERSON: This is where we saw evidence  
6 of shorting between the conductors and I should  
7 indicate that although -- we were measuring two  
8 different things. One was actually what happened to  
9 a typical circuit, but we were also taking fairly  
10 detailed voltage and current measurements to correlate  
11 the electrical behavior with what happened in the  
12 circuit, so we can see what was actually going on in  
13 the circuit at the time of the spurious actuation.

14 Okay, the next slide has a somewhat  
15 different view of this data and rather than looking at  
16 it by cable type, we were looking at it as to whether  
17 a seven conductor or a single conductor cable. As you  
18 see for the seven conductor cable, the percentage --  
19 and again, this is brushing across both thermo-set and  
20 thermo-plastic, there's a lot of ways you could slice  
21 and dice the data but we chose this one. The  
22 percentage of down faults and hot shorts for seven  
23 conductor cables is about the same. In fact, it's  
24 exactly the same based on the data that we took.

25 For single conductor cable, you're more

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 likely to get ground faults. And that's really to  
2 expected also because there are more opportunities for  
3 hot shorts in a seven-conductor cable. And the next  
4 slide I'm going to talking about the spurious  
5 actuations rather than the hot shorts and what we saw  
6 there. And the first two lines show spurious  
7 actuations as a percentage of the total devices where  
8 you could have had spurious actuations and the tests  
9 that we ran. You can see that there's a much higher  
10 percentage for thermo-plastic cable and thermo-set  
11 cable. So you can see that although the percentage of  
12 hot shorts versus ground faults is the same -- is  
13 about the same for the two cable types. The  
14 percentage of spurious actuations is different.

15 And again, given the less robust nature of  
16 thermo-plastic cable, that was to expected. Armored  
17 is lower because, again, the inherently more rugged  
18 construction of the armored cable. The next two lines  
19 show spurious actuations as a percentage of the total  
20 cable failures and as you can see here, for armored  
21 cable, given the two tests that we ran there, this --  
22 you could argue that this wasn't a very complete data  
23 set but we -- I'm presenting it for illustration that  
24 the percentage of spurious actuations to total cable  
25 failures is about 30 percent. For thermo-set it's

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 about 40 percent and thermo-plastic it's about 50  
2 percent.

3 The last two lines show the average time  
4 to failure and as you can see, the lowest average was  
5 about 26 minutes for thermo-plastic, 36 minutes for  
6 armored and 46 minutes for thermo-set cable, again  
7 brushing across a wide range of temperature  
8 conditions, heat release rates and so forth.

9 MEMBER SIEBER: Fred, do you have any data  
10 that you could tell us about that shows what  
11 percentage of hot shorts converts to a spurious  
12 actuation? It looks like it's about half.

13 MR. EMERSON: I think you can probably  
14 derive that from the figures that I've presented.

15 MEMBER SIEBER: Yeah, it looks like I would  
16 guess about half.

17 MR. EMERSON: Which would show you --  
18 again, illustrates the point that not all hot shorts  
19 turn into spurious actuations. And the last line has  
20 to do with duration. The durations ranged from very  
21 short, just a few seconds, to as much as 10 minutes.  
22 The average was in the range of one to two minutes.

23 MEMBER POWERS: Let me ask you a question  
24 that there is, of course, no answer to.

25 CHAIRMAN ROSEN: If there was an answer

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 you'd know it and you wouldn't have to ask.

2 MEMBER POWERS: If I sat down and did this  
3 whole data set all over again, how would those numbers  
4 change?

5 MR. EMERSON: I'm sorry, if you did it all  
6 over again?

7 MEMBER POWERS: Yeah, did the whole data --  
8 did the whole test sequence over again.

9 MR. EMERSON: Oh, okay, you're rerunning  
10 the tests.

11 MEMBER POWERS: As closely to identical as  
12 you did them in the original, how much would the  
13 numbers change? I mean, you've got 20.6 percent  
14 there.

15 MR. EMERSON: What you're asking is how  
16 repeatable are the tests.

17 MEMBER POWERS: Yes, that's right.

18 MR. EMERSON: Well, if you ran them in the  
19 same test chamber and you ran them with the same  
20 release rates as identical, same types of cables, same  
21 everything, I'm sure there would some variability.

22 R. KRESS: Did you run a couple of tests  
23 like that?

24 MR. EMERSON: We didn't run two tests  
25 exactly the same. Because a sequence of 18 tests,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 you're trying to get as much bang for the buck as  
2 possible and vary the parameters in an intelligent way  
3 to get useful information. So we did not repeat  
4 tests, no.

5 MEMBER KRESS: But that's useful  
6 information.

7 MR. EMERSON: Yes. It would useful  
8 information.

9 MEMBER SIEBER: It tells you something  
10 about the uncertainties.

11 MR. EMERSON: We didn't have --

12 MEMBER POWERS: There is at least one  
13 person at the table that believes that in a short  
14 sequence of expensive tests that it's absolutely  
15 essentially to run --

16 CHAIRMAN ROSEN: You mean there are two?

17 MEMBER POWERS: Two of us.

18 MR. EMERSON: As I recall, you gave us some  
19 input on the test plan before we actually ran the  
20 tests and we did take your advice as much as we could.

21 MEMBER POWERS: But you didn't run her up.

22 MR. EMERSON: We did not run her up. Okay,  
23 moving along, I want to go through the general  
24 observations, in fact, the rest of the presentation as  
25 quickly as I can. Steve mentioned this as an

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 observation. We would certainly concur. Proximity is  
2 a strongly determining factor. One could argue on the  
3 second bullet that we didn't have enough data to  
4 support sweeping conclusions and I would agree with  
5 that but we think that given what we saw and while we  
6 didn't repeat any tests, we saw a lot of common  
7 phenomena in what happened when we tested the same  
8 types of cable under different conditions that we can  
9 achieve some statistical characterization and predict  
10 on a broad sampling of cables a certain fraction of  
11 failures as we did in the earlier data.

12 We have a better understanding of what  
13 were the main influence factors. Obviously, we could  
14 do more to beef that information up. What we can't do  
15 is to look at an individual circuit and predict how  
16 it's going to fail. We can't say this particular  
17 thermo-set cable in this particular room and under  
18 these particular conditions, we can't say you will  
19 have a short to ground here or you will have a hot  
20 short. We can't do that because, as Steve indicated,  
21 the short phenomena are pretty complex and very hard  
22 to predict on a microscopic level.

23 MEMBER SIEBER: But it's good enough to  
24 give you some sense of the probability.

25 MR. EMERSON: We think so, yeah, and the --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER SIEBER: And the distribution?

2 MR. EMERSON: And the expert panel felt  
3 that way, too.

4 MEMBER WALLIS: Now, you said the phenomena  
5 are hard to predict so you didn't do it.

6 MR. EMERSON: Well, on a microscopic level.

7 MEMBER WALLIS: Well, are they hard to  
8 predict on any level?

9 MR. EMERSON: We think if you look at a  
10 broad sampling -- if you look at say, I'm a plant guy  
11 and I have all thermo-set cables in my plant, and I  
12 have some knowledge of what fires I can expect in a  
13 certain area, yeah, I think I can say with some  
14 confidence that I can expect something to happen or  
15 something not to happen and from a spurious actuation  
16 standpoint. That doesn't mean I can't ignore --

17 MEMBER WALLIS: But if I knew that really  
18 was happening, it was simply heating up the cable till  
19 it reaches a temperature and then it fails, and this  
20 is a transient heat-up problem, all you need to know  
21 is get the integrated heat transferred to the cable  
22 from the fire, then we're learning that the  
23 uncertainty and prediction is in characterizing the  
24 fire.

25 MEMBER KRESS: That's right.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER WALLIS: And it's in relationship to  
2 the cable.

3 MR. EMERSON: Yeah, you need to --

4 MEMBER WALLIS: If we knew that, that would  
5 help us because we would stop worrying about some  
6 other uncertainties.

7 MEMBER KRESS: Maybe we could find that  
8 out.

9 MEMBER WALLIS: You might able to find  
10 that out by rather simple calculations.

11 MEMBER KRESS: Run a test --

12 MEMBER WALLIS: Right.

13 MEMBER KRESS: Yeah, I think you're right.  
14 I think the thermo-set probably tells --

15 MEMBER WALLIS: Just by heating it up.

16 MEMBER KRESS: -- the product time and  
17 temperature and the thermo-plastic fails when it  
18 reaches melting.

19 MEMBER WALLIS: Whatever.

20 MR. EMERSON: These are the influence  
21 factors that we thought were -- based on the test  
22 results that we thought were important. Cable type,  
23 obviously, we think thermo-set is more robust than  
24 thermo-plastic in terms of its resistance. Tray fill,  
25 the more tray fill you have the less exposure you have

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 of individual cables in the middle of the fill. You  
2 have a greater thermo-mass and we saw some pronounced  
3 effects when we ran a similar test with one row  
4 instead of four rows. The conductor connection  
5 pattern had some influence. We varied the connection  
6 of the conductors to the circuits so that some  
7 conductors where you had a power cable against --  
8 right against an unpower cable or you had other cases  
9 where the power cable was in the middle and some of  
10 the target cables were on the outside, there was some  
11 influence of the connection pattern and as Steve  
12 indicated, the power source characteristics seemed to  
13 play a major difference, too, in terms of whether you  
14 had current limiting devices on your circuit or you  
15 were just using a regular power supply.

16 MEMBER WALLIS: You always had the same  
17 fire and the tray was in the same place? I forget  
18 now. I would think the biggest influence would where  
19 the fire is relative to the tray.

20 MR. EMERSON: As Steve indicated, we varied  
21 the location of the -- when we were looking for plum  
22 effects, we had the flame right under the corner of  
23 the tray and --

24 MEMBER WALLIS: So wasn't that the biggest  
25 effect, how close the fire is to the cable?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. EMERSON: Well, plume effects are  
2 certainly more pronounced than hot gas.

3 MEMBER WALLIS: I think that's the first  
4 thing my wife would tell me. Isn't that the biggest  
5 effect? I mean, you're saying influence factors, but  
6 really the biggest effect in all of this is where's  
7 the fire relative to the cable? How big is the fire?  
8 Isn't that the biggest thing?

9 MR. EMERSON: I think what we're talking  
10 about is --

11 MEMBER WALLIS: I think if you knew that  
12 you'd throw out all the other uncertainties as being  
13 relatively unimportant compared with that uncertainty.

14 MR. EMERSON: Yes, the location of the fire  
15 is certainly an important factor. If you're looking  
16 at influence factors for hot shorts versus spurious  
17 actuations, the location of the fire is less important  
18 than the temperature it gets to.

19 Some secondary influence factors and I'm  
20 not going to try and get into these in any detail, the  
21 orientation exposure type, we did run two vertical  
22 tests. We did run plume versus hot gas layer. To  
23 address the water spray issue that we touched no  
24 during Steve's presentation, the -- what we tried to  
25 do is to spray just before the end of the test when

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 there was still some unfailed circuits to see whether  
2 those additional failures would take place just based  
3 solely on the water spray. And of the 18 tests we  
4 ran, only once did that happen. So there was some  
5 effect but it wasn't a major one.

6 MEMBER POWERS: Let me ask you a question,  
7 on the brute force you say five percent of the time  
8 the water spray caused failure, just strictly from --

9 MR. EMERSON: Yes, uh-huh.

10 MEMBER POWERS: Okay, but maybe I should do  
11 that. Maybe I should just say the result of the test  
12 is that indeed sprays can cause actuations.

13 MR. EMERSON: They can, that is true.

14 MEMBER POWERS: Okay, I mean, which  
15 conclusion am I sounder to take?

16 MR. EMERSON: Well, the reason we -- I'm  
17 sorry. The reason we ran the test was to see if it  
18 was a pronounced effect, whether you could get circuit  
19 failures like this from any time you sprayed it and if  
20 so, that would tell us we need to think about how we  
21 fight fires in areas that have this potential problem.

22 MEMBER SIEBER: But that alternative is to  
23 not fight the fire. And it would seem to me that it  
24 would better trying to put the fire out than  
25 worrying about whether something is going to --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. EMERSON: I don't know if it's a  
2 question of whether you put the fire out or not. It's  
3 what additional precautions you might want to take to  
4 deactivate the circuits before you fight the fire.

5 MEMBER SIEBER: That's true, you would want  
6 to do that regardless of whether you sprayed or not.

7 MR. EMERSON: You would think so but it  
8 would give you an idea of how much time you had.

9 MEMBER SIEBER: That's true.

10 MEMBER POWERS: The trouble is it's just  
11 not clear to me that the answer I come out of this is  
12 don't worry about it, it's only a five percent effect.  
13 It seems to me I come to the second conclusion, yeah,  
14 worry about it, because it does occur.

15 MEMBER WALLIS: I would worry about how I  
16 sprayed it. I mean, if I sprayed it with a jet which  
17 had momentum, I might create forces which would push  
18 the conductors together.

19 MEMBER SIEBER: Cable tray fires are  
20 usually fought with fog.

21 MEMBER WALLIS: Yeah, well, that's quite  
22 different.

23 MEMBER SIEBER: Yeah, it sort of diffuses  
24 out there and gets everything soaking wet.

25 MEMBER KRESS: What causes it to create a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 short then?

2 MEMBER SIEBER: Pardon?

3 MEMBER KRESS: What causes the -- what is  
4 the cause of --

5 MEMBER SIEBER: Water sprayed up.

6 MEMBER KRESS: It's a conductor, is that  
7 the problem you're stating?

8 MEMBER POWERS: I think that's right.

9 MEMBER WALLIS: I would think it cause  
10 brittle failure by thermo-shock.

11 MEMBER KRESS: That's what I would think.

12 MR. EMERSON: Well, by the time we sprayed  
13 the cables, the insulation was pretty well gone  
14 anyway, so it wasn't -- we weren't losing insulation.  
15 Okay, in looking at some of the observations we can  
16 make about internal versus external hot shorts and  
17 what you're seeing here is conclusions without seeing  
18 a lot of the data that went into it. Mr. Chairman,  
19 feel free to bang the gavel whenever you feel like it.

20 CHAIRMAN ROSEN: Well, I feel completely  
21 free, but you're making what appear to be  
22 unsupported assertions which is our stock and trade.  
23 Go ahead.

24 MR. EMERSON: It's the result of turning a  
25 50-slide presentation into one with far fewer slides.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 You have to cut the slides somewhere. When you read  
2 our 417-page test result, I think you'll have much  
3 better support for the conclusions. The external hot  
4 shorts do occur but we've -- the data tell us that  
5 they're less likely than internal hot shorts and you  
6 might empirically guess that anyway from the proximity  
7 of the internal shorts and the existence of jacket  
8 material between the conductors as opposed to the  
9 extra layer that you would get between two cables  
10 shorting externally.

11 One thing that was interesting was the  
12 second bullet it indicates that we did get external  
13 hot shorts but they've now resulted in spurious  
14 actuations. Does that mean we're going to say you  
15 cannot possibly get -- no, we're not going to say that  
16 but it was an interesting result of the data. And as  
17 we saw from the data table, thermo-plastic cable has  
18 a higher propensity for spurious actuations from  
19 external shorts than thermo-set cable does.

20 Now, if I were -- this first bullet was  
21 one as a true blue industry person, that I would least  
22 likely have wanted to see as a result of this test but  
23 it says that if you get a hot short in a multi-  
24 conductor cable it's pretty likely that you're going  
25 to see multiple hot shorts. And so we're going to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 factor that into the methods we have for addressing --  
2 for doing -- for analyzing cable failures. These are  
3 what we would call and what the expert panel would  
4 call dependent hot shorts within the same multi-  
5 conductor cable.

6 You can have multiple independent hot  
7 shorts but it happens with less frequency than for a  
8 single multi-conductor cable. The next slide shows  
9 for all 47 spurious actuations that we observed it's  
10 just a bar chart of the time it took to get them and  
11 you can see some very, very long time frames and you  
12 can see some very short time frames.

13 MEMBER WALLIS: There's something odd about  
14 the two minute --

15 MR. EMERSON: That was the thermo-plastic  
16 cable in a plume which --

17 MEMBER WALLIS: Right above the fire.

18 MR. EMERSON: Right above the fire. It  
19 shows that spread over all of the tests a large  
20 majority of them were over 20 minutes, about two-  
21 thirds of them were over 30 minutes and about one-  
22 third of them were over 40 minutes. So what that  
23 tells us is that in many cases you'll have time to  
24 interdict the fire before you get a spurious  
25 actuation.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER WALLIS: Do you have a room like the  
2 one that Sandia has?

3 MR. EMERSON: A room?

4 MEMBER WALLIS: Yes, a steel room where the  
5 fire --

6 A VOICE: It's the same room.

7 MR. EMERSON: It's the same room.

8 MEMBER WALLIS: It's the same room.

9 A VOICE: It's the same test.

10 MEMBER KRESS: The same test.

11 MEMBER SIEBER: The same test.

12 MEMBER WALLIS: If the room is an oven, how  
13 long does it take to heat up to temperature? Does it  
14 take something like 60 minutes or something?

15 MR. EMERSON: Well, you could see from the  
16 earlier slide what the temperature profile is at the  
17 cable.

18 MEMBER WALLIS: I did. I noticed that. I  
19 thought that was very interesting.

20 MR. EMERSON: It was not a really quick  
21 rise. Obviously the --

22 MEMBER WALLIS: I was discussing with my  
23 neighbor here whether or not it's characteristic of  
24 the cable or of the room.

25 MR. EMERSON: It was some of both, I think.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 MEMBER WALLIS: Ah, some of both.

2 MEMBER KRESS: I bet you could depending on  
3 how fast you heat up the room.

4 MR. EMERSON: Actually, I don't think  
5 that's true, especially in the case of the vertical  
6 test. Radiation heat transfer was -- might have been  
7 the predominant mechanism that was saw but I'm not an  
8 expert in that area.

9 MEMBER WALLIS: Especially if it's coming  
10 from the walls of the room rather than directly from  
11 the flame.

12 MR. EMERSON: This slide, I've pretty much  
13 covered before. It just gives a little more  
14 information about the durations, the shortest, longest  
15 average and standard deviations for each of the three  
16 cables.

17 MEMBER WALLIS: How hot does the room get,  
18 the wall of the room get?

19 MR. EMERSON: How hot?

20 MEMBER WALLIS: Yeah.

21 MR. EMERSON: We did not have the  
22 instrumented, but I guarantee you it was too hot to  
23 touch. It was not insulated.

24 MEMBER SIEBER: Fred, now these times here  
25 don't really make any difference if the fault causes

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 the contact to close for an instant.

2 MR. EMERSON: The implication of this slide  
3 is that for most MOVs once you get an instantaneous  
4 fault you're locked in.

5 MEMBER SIEBER: You are locked in.

6 MR. EMERSON: For some AOV's it could make  
7 a difference.

8 CHAIRMAN ROSEN: Get to your key  
9 conclusions.

10 MEMBER SIEBER: You're talking about AOV's  
11 that are operative.

12 MR. EMERSON: I don't claim enough  
13 expertise to answer your question.

14 MEMBER SIEBER: For them to close, it takes  
15 an instantaneous signal. For them to open you've got  
16 to hold it.

17 MR. EMERSON: Okay, moving on to the key  
18 conclusions, given cable damage, you can certainly get  
19 spurious actuation singly or multiply. You can get  
20 external cable hot shorts but we didn't see any of  
21 those for thermo-set cables result in various  
22 actuations and overall, as Steve said, the likelihood  
23 of spurious actuations is higher than we thought using  
24 fairly elderly NUREG 258.

25 We think there exists thresholds below

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 which you do not get cable failures and this was a  
2 conclusion that the expert panel reached also in  
3 coming up with probabilities. The time --

4 MEMBER WALLIS: And of course that must  
5 true.

6 MR. EMERSON: Yes.

7 MEMBER SIEBER: Or they'd failing now.

8 MR. EMERSON: The fact, the time for  
9 failure was fairly significant, in many cases meant  
10 that in many cases people will have an opportunity to  
11 interdict the fires before you have the effect of a  
12 spurious actuation. And we've talked about the effect  
13 of current limiting devices like CPTs and such.

14 There are implications both for the  
15 deterministic analysis and the risk informed methods  
16 and I'm not going to go into detail on those. It will  
17 impact the way we think about both of those and those  
18 impacts will addressed as we finish this document in  
19 the next few weeks. Now, just quickly two slides on  
20 the expert panel results, these results are taken  
21 directly from the EPRI report which is currently  
22 available.

23 There are a number of cases from therm-set  
24 tray, conduit, thermo-plastic tray and armor tray that  
25 the expert panel and I'm not even going to begin to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 describe the process.

2 MEMBER WALLIS: The probability of this  
3 happening in a fire?

4 MR. EMERSON: This is the probability of  
5 spurious actuations based primarily but not  
6 exclusively on the test results that I just presented  
7 or that will be available in more detail.

8 MEMBER WALLIS: But there must have been  
9 the real situation. The only thing that matters is  
10 the probability, I think, not enough, close enough to  
11 damage the cable.

12 MR. EMERSON: And therein is a key point  
13 because this presents a probability given cable damage  
14 but there's also a probability associated with getting  
15 to the point where you have cable damage and that is  
16 reflected in the NEI document as a total risk  
17 treatment of likelihood of --

18 MEMBER WALLIS: I don't understand that  
19 because if you have cable damage and it lasts long  
20 enough or the fire continues after that point, you're  
21 eventually going to get short, aren't you?

22 MR. EMERSON: Yes, but --

23 MEMBER WALLIS: What is the probability  
24 really saying then? Eventually, if you wait long  
25 enough you always get a short.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. EMERSON: But if you have a hot short  
2 that results in a spurious -- an initial hot short for  
3 most MOVs, it doesn't make any difference how long it  
4 lasts if you get the initial voltage and current.  
5 It's locked in, you have the spurious actuation and --

6 MEMBER WALLIS: So these are probabilities  
7 of spurious actuation.

8 MR. EMERSON: That's correct, that's  
9 correct.

10 MEMBER WALLIS: Ah, okay.

11 MR. EMERSON: Given cable damage.

12 MEMBER KRESS: It seems to me like you need  
13 a model for what causes spurious actuation. That  
14 model involves getting up to a particular voltage to  
15 actuate the -- the question is how do you get that  
16 voltage? It seems to me there's a missing element  
17 here.

18 MEMBER WALLIS: It must depend on the  
19 relay, the voltage. The relay needs to --

20 MR. EMERSON: It depends on the  
21 characteristics of the relay or whatever the  
22 electrical --

23 MEMBER WALLIS: How can they make any  
24 estimate at all if they haven't done an electrical  
25 analysis of the relay? It's just a blind guess.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. EMERSON: Well, this is taking --

2 MEMBER WALLIS: For this particular relay  
3 that was used in this particular test.

4 MR. EMERSON: That's correct.

5 MEMBER WALLIS: Okay.

6 MR. EMERSON: Not intended to generalize to  
7 all types of relays.

8 MEMBER WALLIS: Okay.

9 MEMBER SIEBER: That's really not a bad  
10 value, 80 volts or so.

11 MR. EMERSON: And last but not least --

12 MEMBER WALLIS: But someone would take it  
13 out of context and apply it to any relay in any test.

14 MR. EMERSON: The other primary product of  
15 the expert panel was fragility curves which plotted  
16 the probability of any cable damage versus the  
17 temperature at the cable. This curve is for thermo-  
18 set, thermo-plastic cable. This one is for armored,  
19 this one is for thermo-set. And there were zero  
20 values if you will, below which probability was  
21 essentially zero. But now, I urge you to read the  
22 EPRI report which provides --

23 MEMBER WALLIS: Why does everything kink at  
24 .5?

25 MR. EMERSON: Well, that's an artifact of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 the way these were plotted. There were actually three  
2 values given. Basically, it was .05, .5 and .95.

3 MEMBER WALLIS: Oh, two straight lines,  
4 yeah.

5 MR. EMERSON: And it was just two straight  
6 lines.

7 CHAIRMAN ROSEN: Well, with that, I'll ask  
8 if there are any other brief questions. If not, we'll  
9 take a 15-minute break. Try to back at 3:25 and  
10 we'll try to make up some time. We've already lost  
11 control of the meeting. We will resume at 3:25.

12 (A brief recess was taken.)

13 CHAIRMAN ROSEN: It is definition 3:25.  
14 Please, Mark and See-Meng, you have the floor.

15 MR. REINHART: Thank you. I'm Mark  
16 Reinhart, the Chief of the Licensing Section of the  
17 Probabilistic Safety Assessment Branch in NRR. Our  
18 purpose today is to discuss the fire protection  
19 significance determination process, a product we've  
20 been working on for about two and a half to three  
21 years. We've -- at our desire and the desire of the  
22 industry, we've been working at refining the tool we  
23 have.

24 Around April of this year we took some  
25 efforts in the staff to focus on the product, on what

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 needed to worked upon. Then in July we brought the  
2 industry and other stakeholders into the discussion  
3 and today See-Meng is going to give us a presentation  
4 that will show where we are with the fire protection  
5 SDP and where we hope to go.

6 MEMBER WALLIS: And who are the other  
7 stakeholders?

8 MR. REINHART: It was a public meeting.  
9 Whoever showed up at the public meeting we had. It  
10 was NEI and licensees.

11 MEMBER WALLIS: That was all?

12 MR. REINHART: That was all that showed up.

13 MR. WONG: Some of the public meetings --  
14 the public attendees as well. Thank you, Mark. Good  
15 afternoon. I'm See-Meng Wong in the PRA branch and as  
16 Mark has stated, we have been -- our branch has been  
17 involved in developing the fire protection SDP that is  
18 currently that exists in the inspection manual Chapter  
19 06098 and is described as Appendix F. The original  
20 developer of this SDP is J.S. Hyslop who has moved  
21 onto the office of research and has been presenting a  
22 lot of the research work this morning to you.

23 As I look at it, it is more difficult to  
24 developing a tool and for me to involved in trying  
25 to improve it, I think it should an easier task.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 Anyway the fire protection SDP is one of the many SDP  
2 tools that used in the direct oversight process. It  
3 is designed to assess the significance of  
4 degradations in fire protection defense and death  
5 elements, mainly fire prevention, fire detection and  
6 suppression and protection of the SSE's important to  
7 safety against fire damage to accomplish land safe  
8 shutdown.

9 And this fire protection SDPs those are  
10 designed to support the risk informed focus of the  
11 tri-level fire protection inspections that are going  
12 on. Just very briefly, as a background, go onto to  
13 summarize this actually what is in the two-phased  
14 methodology. The first phase methodology is  
15 essentially a qualitative screening process that  
16 screens the fire protection findings that are related  
17 to operational or functional fire protection future  
18 conditions, that means it will ask questions, is the  
19 fire protection system, whether there is a fixed  
20 suppression system or is a fire barrier, is it  
21 degraded and if it is, then it screens into the Phase  
22 2 process.

23 The Phase 2 methodologies also by design  
24 is a screening methodology and it is more of a  
25 quantitative approach to try to assess the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 significance of the collective impact of the findings  
2 on the fire protection defense in-depth elements.  
3 This Phase 2 methodology is a nine-step process, okay,  
4 and within this nine-step process it uses a simplified  
5 fire risk equation which attempts to provide an  
6 integrated assessment of the fire ignition frequency  
7 with the degraded fire protection defense in-depth  
8 elements.

9 Fire protection defense in-depth elements  
10 are fire barrier effectiveness, automatic suppression  
11 effectiveness, and manual suppression effectiveness  
12 and also the term that try to come for common cause  
13 contributions.

14 MEMBER SIEBER: Before you leave this  
15 slide, when you screen using Phase 1, if it's of no  
16 safety significance, it goes away, right? If it has  
17 some significance in Phase 1, you come out with a  
18 color (phonetic) and then you go to Phase 2 and my  
19 question is, how often does the color decrease in  
20 significance between the Phase 1 screen and Phase 2?

21 MR. WONG: Okay.

22 MEMBER SIEBER: Do you see what I mean? Do  
23 you understand my question?

24 MR. WONG: Okay, right. The short answer  
25 is very briefly, okay, the Phase 1 screening process

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 is that we want to screen findings that is of  
2 significance, so it is by design, conservative in  
3 nature. So most of the findings that we have --

4 MEMBER SIEBER: I understand that.

5 MR. WONG: -- may not string to green  
6 and most of the time, our top -- this is actually one  
7 of the issues that we're trying to find guidance  
8 (phonetic) and most of the time the findings has gone  
9 right through to the Phase 2 methodology. Then the  
10 Phase 2 methodology, because of some of the problems  
11 that we have experienced, that is why we are trying to  
12 come up with better guidance on each of the issues  
13 that I will discuss a little later.

14 MR. REINHART: Maybe I could add a thought.  
15 The Phase 1 screening needed work, so one of the  
16 efforts that we think we've made progress on to date  
17 is to get a better Phase 1 screening. Like See-Meng  
18 said, almost all of them right now have just ended up  
19 as Phase 2.

20 MEMBER SIEBER: And that's because Phase 1  
21 determined significance, risk significance.

22 MR. REINHART: What Phase 1 would do, it  
23 would say it's either green or greater than green. If  
24 it's green, one of licensee's corrective action  
25 program. If it was greater than green, it would go

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 beyond.

2 CHAIRMAN ROSEN: So you said almost all  
3 Phase 1 findings would greater than green, did I  
4 understand what you're saying?

5 MR. REINHART: What I've said so far is  
6 that the Phase 1 screening questions that were there,  
7 we saw a need to improve to make them more effective.  
8 Consequently, almost all of the performance  
9 deficiencies in the fire protection area were Phase 2  
10 or Phase 3 efforts.

11 MEMBER SIEBER: That means that they were  
12 greater than green in Phase 1.

13 MR. REINHART: In essence it means that --

14 MR. WONG: Yes.

15 MEMBER SIEBER: Okay, now, let me ask the  
16 second part again. When you get to Phase 2, how many  
17 of the greater than green from Phase 1 turned into  
18 green in Phase 2, percentage-wise, roughly?

19 MR. JOHNSON: While they're -- this is Mike  
20 Johnson. While they're thinking about the answer to  
21 that, let me talk about Phase 1 one more time.

22 MEMBER SIEBER: Okay.

23 MR. JOHNSON: In Phase 1 what you're trying  
24 to do is to set aside those issues that are clearly  
25 green but certainly no more than green. So if you go

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 -- you pass the threshold where we've talked about  
2 you've got a performance deficiency that is  
3 significant enough to documenting. You go to Phase  
4 1. If something doesn't screen beyond Phase 1, it's  
5 a green. If it goes beyond Phase 1, that doesn't  
6 necessarily mean that it will more than a green, but  
7 because it could potentially go to Phase 2 and then  
8 you decide that it's a green. It's just that simple  
9 screen that we have in Phase 1 can't make the  
10 determination.

11 MEMBER SIEBER: Well, I think it's fair to  
12 conservative in your screen. On the other hand, you  
13 may making yourself extra work because now you've  
14 got to do an additional phase of evaluation because  
15 it's too conservative. So my question is, how  
16 conservative is it really?

17 MR. JOHNSON: I understand.

18 MR. REINHART: If you go to slide 4, what  
19 it shows is there is 73 findings --

20 MEMBER SIEBER: Yeah, I read that, that's  
21 what prompted my question.

22 MR. REINHART: -- and 19 or 52 of those 73  
23 ended up as green. Now, I follow up on both what you  
24 and Michael said, the -- my belief is that once we get  
25 our improved Phase 1 screening effective and as of our

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 last meeting, I think the staff had some thoughts, the  
2 industry had some thoughts, and the industry is going  
3 to combine those and propose to us a method. If  
4 that's successful, that should do exactly what you  
5 said and screen out more of these so we don't have to  
6 go to Phase 2 analysis.

7 MEMBER SIEBER: Thank you.

8 MR. WONG: Well, I think we jumped ahead a  
9 little bit.

10 MEMBER SIEBER: Yeah, I know. I asked the  
11 question because I was looking at your later slides.

12 MR. WONG: Okay, then I'll just go very  
13 quickly to state that --

14 MEMBER WALLIS: Well, I'm curious about the  
15 first slide of Phase 2. You have this simplified fire  
16 risk equation. And if I were going to improve the  
17 fidelity, I would think that one way to improve it  
18 would to improve the equation. Is that part of the  
19 scope?

20 MR. WONG: Yes, yes, I will get to it when  
21 I talk about Phase 2 issues. In fact, I think that's  
22 probably central to the improvement initiative. This  
23 next slide is based on the information that we had  
24 from the inspection program branch. To date, since  
25 April 2000 there has been 50 tried fire protection

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 inspection completed and out of this there as been 73  
2 fire protection inspection findings. And out of this  
3 73, 39 issues are related to safe shutdown and  
4 alternate safe shutdowns. For example, those issues  
5 are the associated circuits that are effected and  
6 which we have the moratorium on inspection until we  
7 resolve this issue.

8 And 17 of these 73 are fire protection  
9 system issues and this related to problems with  
10 suppression systems and detection systems.

11 MEMBER SIEBER: You mean inoperable.

12 MR. WONG: Inoperable, degraded, depending  
13 on the observation from the inspectors. Then there  
14 are 13 fire barrier issues. These are related to  
15 again degradations observed in three out of five  
16 barriers, problems with, you know, fire domes  
17 (phonetic). And then there are four procedural  
18 adherence issues. These are problems related to not  
19 taking appropriate corrective actions to correct some  
20 of the problems.

21 MEMBER SIEBER: Is anybody still using  
22 thermal lag?

23 MR. WONG: Yes, there is one issue.

24 MEMBER SIEBER: As a three-hour barrier or

25 -- MR. WONG: As a three-hour barrier. In

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 fact --

2 MEMBER SIEBER: When do you think that one  
3 will disappear? I mean, when will they take it out?

4 MR. WONG: That question, I think, is the  
5 fire protection branch would probably have a better  
6 answer for you.

7 MEMBER SIEBER: Okay, so I take it some of  
8 these 13 in the fire barrier issues are thermal lag  
9 issues or are they?

10 MR. WONG: Well, some of this is related to  
11 the use of the hammock (phonetic) fire wrap issues and  
12 that again, is a generic issue. It's awaiting  
13 resolution but if you look at the SDP  
14 characterization, one of the issues that we finalize  
15 as a white finding is actually related to a degraded  
16 three-hour thermal lag fire barrier issue at one of  
17 the sites.

18 MEMBER SIEBER: Okay.

19 MR. WONG: And the other finalized white  
20 findings relate to an inadequate smoke detectors in  
21 the cable spraying room that was not installed in  
22 accordance with NAPA codes.

23 MEMBER SIEBER: Okay, thank you.

24 MR. WONG: Right, but what is of challenge  
25 to us is that there are a pool of 19 findings that are

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 of significance that needs to be determined and there  
2 is, therefore, the impetus for us to try to improve  
3 the tools that we have currently in place as soon as  
4 we can and we have -- as I will elaborate a little bit  
5 further, we have an aggressive schedule to try to  
6 accomplish this by next year.

7 MEMBER SIEBER: Now, is this a backlog  
8 that's being worked off, these 19 or are they just  
9 sitting there --

10 MR. WONG: These 19 are --

11 MEMBER SIEBER: -- waiting for you to come  
12 out with your guide.

13 MR. WONG: Yes, most of those 19 are  
14 sitting there and waiting, for example, the  
15 resolution. A lot of these 19 findings are the  
16 associated circuits and the use of the hammock wrap  
17 fire barrier issues. That's the pool of them.

18 MEMBER SIEBER: And they're sitting there  
19 because we're still working on associated circuits,  
20 right?

21 MR. WONG: Yes.

22 MEMBER SIEBER: So this could take some  
23 time.

24 MR. WONG: Yeah.

25 MR. REINHART: It could. I believe it's

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 waiting on the resolution of some generic issues.  
2 They're in the region. They haven't come to us, like  
3 as a Phase 3. But they are -- there's some generic  
4 issues also involved.

5 MEMBER POWERS: As I understood the  
6 resolution of the associated circuits, the NEI came  
7 forward with their proposal, right.

8 MEMBER SIEBER: That's true. On the other  
9 hand, I take it we're still not doing inspections on  
10 associated circuits, right?

11 MR. WONG: Yeah, my understanding.

12 MR. REINHART: That's our understanding.

13 MEMBER SIEBER: Okay, thank you.

14 MR. WONG: Okay? My next slide is to  
15 summarize the major issues related to the fire  
16 protection SDP as we have today, okay. And one of the  
17 first issue is a determination of the performance  
18 deficiency that is related to the fire protection  
19 finding. This came about actually from an experience  
20 that we have in trying to resolve one of the issues  
21 related to the Halon system concentration that did not  
22 meet the NAPA code but the point here is that --

23 MEMBER SIEBER: Is Halon -- there was some  
24 question as to whether that would allowed or not,  
25 right?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. WONG: Yeah.

2 MEMBER SIEBER: I don't think they even  
3 make Halon any more, do they?

4 MR. WONG: No.

5 MEMBER SIEBER: Isn't that an environmental  
6 concern?

7 MR. REINHART: They don't make any more but  
8 there are plants that have it stockpiled.

9 MEMBER SIEBER: Okay.

10 MR. REINHART: And it becomes very  
11 expensive because of that stockpile.

12 MEMBER SIEBER: Well, if you can't reach  
13 the concentration when it discharges, that means you  
14 don't put out the fire.

15 MR. REINHART: Right.

16 MR. WONG: Yes. The point I'm trying to  
17 make here is that in the determination of performance  
18 deficiency the question was did the licensee meet the  
19 licensing basis.

20 MEMBER SIEBER: Okay.

21 MR. WONG: And so this is one of the areas  
22 which probably await much broader generic resolution.  
23 So currently there is, in the fire protection SPD that  
24 we have today there is no clear guidance that asked  
25 inspectors how to deal with it.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER SIEBER: How to deal with it.

2 MR. WONG: So that's an area that we have  
3 to look at. The second bullet in this slide is the  
4 issues related to Phase 1 screening process and we  
5 have briefly touched on that. One of the things is  
6 related definition of the SDP entry conditions. The  
7 guidance that we had, we did not provide the verbiage  
8 to direct say the inspectors to go through what we  
9 call whether the observation is -- or the finding is  
10 more than minor through the criteria that is described  
11 in the inspection manual Chapter 0612. And then from  
12 there where does it go.

13 So there's kind of a linkage or direction  
14 but it's not clear how -- when do they go to the Phase  
15 1 and then from Phase 1 how they go to the Phase 2 as  
16 the finding is being processed. So that's an area in  
17 which we think we need to provide better guidance.

18 But the main --

19 MEMBER SIEBER: But that's not why these 19  
20 are sitting there, right?

21 MR. WONG: No, that's not why the 19 is --  
22 the 19 is sitting there for other issues.

23 The four main issues that we have  
24 identified for the Phase 2 screening methodologies is,  
25 one area is the use of the fire ignition frequencies,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1       okay. You've heard discussion on you know, whether we  
2       use a room frequency versus a component ignition  
3       frequency, whether we use the pre-data base as, you  
4       know, reflective of you know, the events data base  
5       that we should       looking at to derive the fire  
6       ignition frequencies because this is always a point of  
7       contention when we try to process it, are we looking  
8       at the right fire ignition frequencies.

9               And this is an area which one of these  
10       solutions is that we might try to use the EPRI data  
11       base as, you know, one of the standards to try to  
12       derive fire ignition frequencies and then provide a  
13       table of fire ignition frequencies that as a guide for  
14       the inspectors when they use this Phase 2 screening  
15       process.

16               MEMBER SIEBER: Are you going to use the  
17       Houghton (phonetic) study?

18               MR. WONG: I've looked at the Houghton  
19       study and in fact, from my experience when I tried to  
20       process one of the findings looking at his -- his data  
21       base is limited to a certain time window, I think 1986  
22       to --

23               MEMBER SIEBER: It ends at 1999 but he's on  
24       2000 and 2001 right now.

25               MR. WONG: Right.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER SIEBER: But --

2 MR. REINHART: Well, we talked about this  
3 in one of our meetings. I believe if I remember the  
4 number right, there's maybe seven different data bases  
5 you could look at.

6 MEMBER SIEBER: Yes, there are.

7 MR. REINHART: And we --

8 MEMBER SIEBER: But this one is yours.

9 MR. REINHART: Right. Our long term goal  
10 would to get Jim Houghton's data base up to date and  
11 formatted in a way that we could go into it and come  
12 out of it simply and have everyone agree that that's  
13 the appropriate data base for the appropriate  
14 situation. If we can do that, we're miles ahead and  
15 we're working on that.

16 MEMBER SIEBER: Okay.

17 MR. WONG: So this is one of the areas.

18 MEMBER SIEBER: Okay.

19 MR. WONG: The second area is related to  
20 the degradation ratings for the --

21 MEMBER POWERS: Why is there a resistance  
22 to using for instance, the EPRI data base?

23 MR. REINHART: I don't think there's a  
24 resistance to it. I think we -- from time to time it  
25 gets used. What happens is in a given situation,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 somebody likes the EPRI, somebody likes something else  
2 and so we're in a discussion. What we want to be able  
3 to do is say what's the appropriate place to go for  
4 category A, B or C to get the right answer.

5 MEMBER POWERS: If I'm a member of the  
6 public and I want to look at the data base that you've  
7 used to assess one of these things, can I get to the  
8 EPRI data base?

9 MR. REINHART: I don't know the answer to  
10 that question.

11 MEMBER POWERS: If I can't get to the EPRI  
12 data base, then I ipso facto can't use it?

13 MR. REINHART: The big picture, we want to  
14 make sure the data base that we agree with or data  
15 bases that we agree with are in the public arena. If  
16 the information is not, at least we'll be able to show  
17 the information that we had that we used to make the  
18 decision. That would be public. But whether the EPRI  
19 data base per se, in its entirety is public right now,  
20 I don't know the answer to.

21 MR. JOHNSON: And, of course, I guess, it  
22 goes without saying, the major challenge that we face  
23 on all of these issues is to make sure that we have an  
24 acceptable agreed upon methodology, in this case, an  
25 acceptable agreed upon frequency and then we've always

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1        tried in the SDP to make sure that whatever we use  
2        then in terms of the tool is available so that people  
3        outside of the agency can see what we've done so that  
4        the process is predictable.

5                So your question is a good one. We just  
6        haven't -- we've got to seize upon what is the right  
7        source of data, what is the right data base for fire  
8        ignition frequency and then we need to make it  
9        available to people can see what it is we used.

10               MEMBER POWERS: I can think of nothing that  
11        would -- I mean the peculiarity of fire is that it's  
12        one that everybody thinks they know everything about  
13        because, I mean, it's a hazard, it's a nuclear hazard.  
14        It's not like a neutronic hazard and nobody can  
15        calculate except some guy at Brookhaven or something  
16        with a fancy computer group. And so fire is of  
17        interest to people.

18               I mean, they know that this is a hazard  
19        and when you go through a significance determination  
20        process in a fairly mechanistic thing kind of that  
21        somebody can understand fire, fire ignition frequency,  
22        times the degradation factor, that I just love because  
23        I can never figure out what it is, but you go through  
24        these steps, you know, if I remember the public, you  
25        know, the first thing I'm going to do is say, gee, how

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 would I get there. And I'm going to sit down.

2 And if I can't get to the data base, I'm  
3 going to irritated. I'm going to irked. And  
4 then, you know, you'd say, well, this is an agreed  
5 upon process. Yeah, you and somebody else agreed to  
6 it, I didn't agree to it.

7 MR. REINHART: I understand.

8 MR. WONG: Okay, let me go to the next  
9 major issue that we have through our discussions. The  
10 second major issue that we have identified has to do  
11 with degradation ratings for the defense in-depth  
12 elements, okay. The defense in-depth elements are --  
13 that is currently we are -- that is in the SDP  
14 guidance document is the fire barriers, okay, the  
15 automatic suppression and also the manual suppression.  
16 And we have degradation ratings of whether that fire  
17 barrier is highly degraded or moderately degraded or  
18 whether it is in the normal operating state.

19 And this is an area in which there has  
20 been subjectivity and this is an area in which we're  
21 trying to get the I call the fire protection world to  
22 come to grips to provide us, you know, a good set of  
23 criteria what is really highly degraded, you know,  
24 description, what is moderately degraded? Is it  
25 nearer to scale of a highly degraded or is it more to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 the nominally operating --

2 MEMBER POWERS: Just what the hell do you  
3 mean?

4 MR. WONG: Yes.

5 MEMBER POWERS: You know, since this thing  
6 has been founded, I've been railing about, I don't  
7 know what -- how to evaluate that number.

8 MR. WONG: Right, so this is one of the big  
9 problem areas and this is actually -- a lot of these  
10 issues is causing us to get, you know, two hours or  
11 three hours of magnitude away from what we think is  
12 the, you know, the reasonable significance. And so  
13 this is a problem area which is part of the  
14 improvement initiative we're having for fire  
15 protection folks, and engaging or so the NEI industry  
16 to at least come to some consensus agreements like  
17 Dana, what you said is what does it really mean. Is  
18 it moderately degraded, versus a highly degraded  
19 description and the basis that go with it.

20 MR. REINHART: In fact, what you're  
21 questioning there is the question we have to ourselves  
22 for each factor. We want each one to be scrutable, and  
23 understandable, why do we have it, what does it mean,  
24 when do we use it and where do we enter this table,  
25 chart, et cetera and how do we know we're right?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER SIEBER: What would nice is if you  
2 took five independent analysts and they all got the  
3 same factors.

4 MR. REINHART: Right.

5 MR. WONG: Well, that's one of --

6 MEMBER SIEBER: Because it's not clear to  
7 me that that's happening, right?

8 MEMBER POWERS: It's probably not clear it  
9 will ever happen but if you could have some categories  
10 and antidotes and examples and say, okay, this is what  
11 we mean by moderate, this is what we mean by severe  
12 and this is what we mean by close enough to normal  
13 operation, I mean, enough of them so that people could  
14 look at them and say, okay, since I will never have  
15 exactly that situation in any other plant at any other  
16 time, but I kind of know what pot to put it in --

17 MEMBER SIEBER: Right,

18 MEMBER POWERS: -- that's about the best  
19 you're going to ever have on that very subjective  
20 factor.

21 MEMBER SIEBER: Right.

22 MEMBER POWERS: I mean, that one is just  
23 really subjective.

24 MR. WONG: Yes.

25 MEMBER POWERS: Well, there's another one

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 and that's the degradation of the fire brigade.

2 MR. WONG: Yes, that's another area which  
3 we're --

4 MEMBER POWERS: The guy's five pounds  
5 overweight, does that mean he's moderately degraded or  
6 badly degraded or what?

7 MEMBER SIEBER: That's easy. I've gone  
8 through all of those phases.

9 MR. WONG: Okay, the third issue is the use  
10 of the fire severity factors and right now in the  
11 current guidance document, we don't use it but when we  
12 do a Phase 3 analysis, we use it and the fire severity  
13 factors that I have used in Phase 3 analysis is from  
14 the -- what is provided in the five document, the EPRI  
15 five document.

16 Again, here it is, you know, how -- how do  
17 we -- you know, and when do we use it, you know, to  
18 adjust the fire ignition frequencies or the population  
19 of the fire because this is tied to when we develop  
20 the five scenario we're looking at, you know, a big  
21 challenging fire or do we, you know, screen away the  
22 smaller fires and try to establish the significance of  
23 that. So this one you know, it's one of those things  
24 that we have to come to have some agreement.

25 MEMBER POWERS: You're doing this radically

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 differently than the analyses for Phase 2 significance  
2 determination processes for the really classic  
3 operational event analysis. I mean, they do Phase 1  
4 by walking through a worksheet based on some PRA  
5 analyses and then in Phase 2 they actually run the  
6 SPAR (phonetic) codes and things like that.

7 MR. WONG: Right.

8 MEMBER POWERS: Why don't you just beat up  
9 research and say give me a good fire analysis tool and  
10 I can do Phase 2 by a risk assessment methodology the  
11 way the guys in Ops do? Make my life easy for me.

12 MR. WONG: They are part of the team.

13 MEMBER POWERS: Tell them it will make  
14 their life easy for them.

15 MR. REINHART: Our Phase 2 actually, it's  
16 a notebook that we run through and the SPAR would get  
17 involved in the Phase 3. Whether it's us running a  
18 software, a licensee running a software, comparing  
19 results, there's --

20 MEMBER POWERS: You're just determined to  
21 make Phase 2 difficult and make Phase 2 automatic.

22 CHAIRMAN ROSEN: What you're saying is they  
23 ought to get away from the subjective scales and get  
24 to analysis technique that provides some relevant  
25 answer. And to me, you know, as much as I hate to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 admit it, I think I agree with you. You know, trying  
2 to interpret these subjective scales, you know, look  
3 at a fire barrier, is that moderately degraded, minor  
4 --- degraded in a minor way or severely degraded, you  
5 know. It shouldn't matter. The question really is,  
6 is what is an analysis say.

7 It may turn out that the fire that you  
8 postulate doesn't require a fire barrier within that  
9 area. And so I think we'll never get done, we'll  
10 here in 10 years arguing about fire barriers and as a  
11 matter of fact, now that I say that, I think it was  
12 one of the NRC staff people who said we had a decade  
13 of arguing ahead of us. If -- and so, you know, I  
14 kind of agree with Dana's comment, that maybe rather  
15 than starting this six months into that decade, rather  
16 than do that, we ought to step back and say, let's  
17 figure out a way to avoid a decade of arguing, which  
18 might fire modeling.

19 MR. REINHART: We're aware of the sentiment  
20 and I think there's a spectrum of sentiments that are  
21 out there from going to a fully automatic analysis to  
22 a semi-automatic analysis, to the notebook check sheet  
23 type of an approach. We appreciate that.

24 MR. WONG: Okay, the last sub-bullet is the  
25 development of the fire scenario and here the issue

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 is, you know, trying to develop a credible fire  
2 scenario or a fire modeling that is needed, you know,  
3 to support the SDP process. Basically, you know, the  
4 guidance that we have to identify the ignition  
5 sources, the likely ignition sources, the fire  
6 modeling, you know, from fire initiation to fire  
7 growth, the example, some of the switch gear room  
8 scenarios is what are the heat release rates that we  
9 will using to model the fire -- you know, to get the  
10 time line of when the fire will go to an extended  
11 damage cables that is overhead.

12 And we have again, argument as to, you  
13 know, which is the right heat release rates that we  
14 will using? Is it 200 kilowatt or is it 300  
15 kilowatt or 400 kilowatt and that's an area which, you  
16 know, we want to take advantage of what the work that  
17 the fire protection folks have done in trying to  
18 develop a spreadsheet, you know, fire dynamic  
19 spreadsheet, you know. We want to see how we can take  
20 advantage of that and use that. This again, is an  
21 area that we need improvement and especially, you  
22 know, develop, you know, kind of a time line that we  
23 need to look at in order to say whether there's a  
24 credible fire scenario or not.

25 These are just the major issues. That's

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 not to say that there are other issues as well in the  
2 Phase 2 that we have identified and we're going forth  
3 to try to find you know, agreement and resolution for  
4 fixes for some of these issues. The Phase 2  
5 objectives and the goals, this one is sort of a  
6 general issue and one of the things we're striving for  
7 in the objective of the Phase 2 screening methodology  
8 is you may have heard the word simplicity,  
9 transparency, repeatability and reasonableness. Okay.  
10 This is a list that we're trying to use as a measure  
11 to try to improve the SDP.

12 But really one of the desired goals is to  
13 see if we can come up with a methodology that we have  
14 like one order of magnitude so and see if we can  
15 strive to that, but recognize that the fire PRA  
16 methodology that we're using, we have been using the  
17 traditional fire PRA method and technique and so  
18 that's a achievable goal but that's something that we  
19 have to look at because from our past experience, we  
20 have, you know, been getting two orders and three  
21 orders of magnitude from the Commission's desires is  
22 that in the SDP to consistent with the overall RFP  
23 process the goals is to try to see in the Phase 2 what  
24 order of magnitude, so that if we proceed to a Phase  
25 3 analysis, then all we have to do is to look at, you

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 know, what are the findings and assumptions that we  
2 need to make to bring it back to that order of  
3 magnitude that we're looking for.

4 The second bullet is related to  
5 quantification approach and this was asked earlier.  
6 We have a simplified formula that is in the current  
7 Appendix F. And as I stated, it is this simplified  
8 formula that one, we tried to get what we call the  
9 fire mitigation frequency, okay, trying to integrate  
10 the assessment of the fire ignition frequency that  
11 we've calculated and used and what are the  
12 effectiveness of the defense in-depth elements. Okay,  
13 all those four put together.

14 What we see is that the problem is that it  
15 does not link some of the dependencies between one  
16 factor from the other and like you mentioned earlier,  
17 you may have a degraded fire barrier but if your  
18 ignition source or your combustible loading is very  
19 small, you know, it's how significant is this highly  
20 degraded fire barrier in the context of the SDP? Or  
21 you know, and there's also the -- when we model the  
22 fire scenarios, the competing factors of, you know,  
23 manual suppression when you postulate if there's a big  
24 fire growing, you know, if there's good suppression  
25 does this degraded, you know, fire barrier, does it

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1       come into play? So those dependencies are not there  
2       right now and so one approach which we're going to try  
3       out is to the same as like what we did in the safety  
4       SDP, try to develop an event tree and come up with,  
5       you know, some sequences and try to capture this  
6       dependencies and make this a better tool.

7               That's all that we can think at this point  
8       in time. The other issues is how do we credit for  
9       compensatory measures that has not -- to date has not  
10      been vigorously addressed in fire PRA methodology?

11             MEMBER SIEBER: You mean like fire watches  
12      and those --

13             MR. WONG: Yeah, fire watches, closed  
14      circuit TV, roving watches and so on and so forth. I  
15      understand that Sandia or Steve Nowlen is doing it and  
16      they have done some study looking at, you know, the  
17      net impact of, you know, compensatory measures. So  
18      this is an area in which we probably would take, you  
19      know, some of the insights and try to improve the  
20      guidance I this area.

21             Critical human actions and the treatment  
22      of safe shutdown actions, this again, we are trying to  
23      come up with a better, you know, basis and you know,  
24      common, you know, rules of how we credit the human  
25      actions and HEPs for, you know, manual shutdown and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 remote shutdown actions. So there's work that has  
2 been done and we'll take advantage of those insights  
3 from research work.

4 Treatment of Appendix R exemptions, this  
5 area is right now is not in the guidance and we need  
6 to take a look at how do we evaluate the risk changes  
7 due to a deficiency in the approved exemption and  
8 where against the baseline the approved exemption.

9 MEMBER SIEBER: What was the basis for the  
10 Appendix R exemptions in the past before risk  
11 consideration were predominant?

12 MR. WONG: That, I think --

13 MEMBER SIEBER: You know, there were some  
14 exemptions because of Appendix R came after some  
15 plants were designed and built and so you might have  
16 ended up, you know, I know of one plant where all the  
17 ox feed pumps were in one room and you're supposed to  
18 have redundancy. Even though they put in a fourth  
19 pump in a different room, it wasn't safety grade. And  
20 so there was an exemption there and but there's been  
21 a fair number of Appendix R exemptions in the past.

22 MEMBER POWERS: Didn't the agency go  
23 through and look at these for the previous chairman  
24 and come back and say that there were none of the  
25 exemptions whose risk wasn't adequately addressed by

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 compensatory measures that they imposed? I mean, very  
2 few of these exemptions were given willy nilly.

3 MEMBER SIEBER: That's true, that's true.  
4 We had to do something for every one of them.

5 MEMBER POWERS: I think it cost you more to  
6 get the exemption than what it would without but I  
7 mean, haven't we looked at that once before?

8 MR. WONG: I think --

9 MS. BLACK: Yeah, this is Suzanne Black.  
10 We looked at that. I've seen a study that showed  
11 certain plants we had to go back and do some more. We  
12 did a screening study at first and then looked at a  
13 couple of plants for these specific exemptions and  
14 determined that the total of them was not really  
15 significant.

16 MEMBER POWERS: That's right, and so maybe  
17 we're recognizing too much of the risk exemptions  
18 here.

19 MS. BLACK: I hate to say that but the  
20 criteria we used, the 5109 criteria for exemptions,  
21 you know, to show that the alternative was as safe or  
22 almost.

23 MR. REINHART: And I think the thought here  
24 is whatever was done, is it appropriate or maybe not  
25 appropriate to consider that in the SDP. We just want

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 to make sure, is this something we should give credit  
2 for, should we --

3 MEMBER SIEBER: I would think so. The  
4 exemption is out there and it's been audited and it's  
5 legitimate.

6 MR. WONG: J.S. has a comment.

7 MR. HYSLOP: There was one thing, as I  
8 recall this and I'm not sure we're getting at it, it  
9 was for a room or an area with an exemption, should  
10 the a part of the baseline from which you calculate  
11 departures for the risk significance associated with  
12 your finding. That's how I recall it coming out, or  
13 do you look at the case of compliance as your baseline  
14 and I think that was the thrust behind the statement  
15 treatment of Appendix R exemptions for purposes of  
16 impact on the SDP. I don't know if that's what  
17 everyone was getting at or not.

18 MEMBER POWERS: I doubt it.

19 MR. HYSLOP: Okay, okay.

20 MEMBER SIEBER: Well, I do understand it  
21 but it seems to me including whatever exemptions have  
22 been granted, if they were granted and it's true, then  
23 they weren't really significant. And that, I would  
24 think, becomes the licensing basis and a baseline to  
25 start for SDP. That's my opinion, personally.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER POWERS: Well, the headache in all  
2 of this stuff is that you end up with every SDP now  
3 becomes absolutely plant specific.

4 MEMBER SIEBER: That's right, absolutely.

5 MEMBER POWERS: And there's no generic  
6 guidance here whatsoever.

7 MR. REINHART: And we have to go back to  
8 that issue of the licensing basis, what is the  
9 licensing basis.

10 MEMBER SIEBER: That's right.

11 MR. REINHART: How things were written in  
12 the '80's and how people are looking at the words  
13 today, a different set of folks looking at those  
14 words. There's questions coming up, old issues coming  
15 up.

16 MEMBER SIEBER: Well;, and then you've got  
17 the added complication that different plants are under  
18 different sets of rules.

19 MR. REINHART: That's right.

20 MEMBER SIEBER: Some are Appendix R, some  
21 are not, some are branch technical positions.

22 CHAIRMAN ROSEN: And there are different  
23 people at the plants, too. It's not just on the  
24 regulatory side.

25 MR. REINHART: That's right.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN ROSEN: There's knowledge  
2 transfers.

3 MEMBER POWERS: And to cap it all off, we  
4 don't know what the licensing basis is anyway.

5 MEMBER SIEBER: Well, somebody ought to and  
6 it may take awhile to find out but just the fact that  
7 there's different sets of regulations for different  
8 plants, every SDP is going to plant specific. So we  
9 might as well just make matters worse and add a new  
10 wrinkle to it.

11 MEMBER POWERS: I'm glad I don't have your  
12 job.

13 MR. WONG: Well, I want to make a closing  
14 statement. The next one is very easy. This is a  
15 summary of the -- all the actions completed to date  
16 that we started to embark on this implement  
17 initiative. This is essentially we do need a request  
18 to research.

19 CHAIRMAN ROSEN: You don't have to read it  
20 to us.

21 MR. WONG: Okay.

22 CHAIRMAN ROSEN: Go ahead to the next one.

23 MR. WONG: Go ahead to the next one? Okay.  
24 The next one is essentially the future activities,  
25 okay, what we plan ahead for us. And one of the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 things that we plan in the imminent future is to have  
2 a public workshop some time in the early or in early  
3 November to go through each one of these Phase 2 SDP  
4 issues and engage the external stakeholders and  
5 internal NRC stakeholders, meaning, the people, the --  
6 from the regional offices, the inspectors, the SRA's  
7 to work through each one of these issues and reach,  
8 you know, a general consensus agreement. That's my  
9 goal on each one of these issues because at the end of  
10 the day and the bottom line is that I don't want to  
11 have to go to a regulatory conference and then have to  
12 in a contentious argument with the licensee on some  
13 of these issues which we can resolve it, you know,  
14 generically beforehand.

15 MEMBER SIEBER: I think you have your work  
16 cut out for you.

17 MR. WONG: Yes.

18 CHAIRMAN ROSEN: You have a busy year  
19 coming.

20 MR. REINHART: And hopefully, and to get  
21 back to your question, your comment, a goal is to have  
22 an SDP that is generic.

23 MEMBER SIEBER: But flexible enough to  
24 accommodate all these differences.

25 MR. REINHART: Right, and that's -- a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 challenge is going to getting our arms around that  
2 licensing basis, how to address it up front and then  
3 what to give credit and not give credit for as we go  
4 through it.

5 MEMBER SIEBER: Do you folks know what the  
6 licensing basis is for each plant or would you rely on  
7 the licensee who may not know either?

8 MR. REINHART: That's an issue that is out  
9 there and the goal is to have the staff and the  
10 licensee able to understand what the licensing basis  
11 is.

12 MEMBER SIEBER: See, without knowing for  
13 sure what it is, I'm not sure how you can inspect the  
14 plant.

15 MR. REINHART: I understand the dilemma.

16 CHAIRMAN ROSEN: All right, it's quarter  
17 after 4:00. Thank you very much and we will --

18 MEMBER WALLIS: Can I ask a naive question?

19 CHAIRMAN ROSEN: -- move onto the --

20 MEMBER WALLIS: Can I ask a naive question?

21 CHAIRMAN ROSEN: Oh, you're asking them a  
22 question?

23 MEMBER WALLIS: Yeah, I wondered if I  
24 could. I mean, I'm just puzzled about what all this  
25 has to do with what we heard the rest of the day. I

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 cant' make the connection.

2 CHAIRMAN ROSEN: It's just another fire  
3 protection issue. I mean, it's in the area of --

4 MEMBER WALLIS: Yeah, but I thought we were  
5 going to hear something about how the research being  
6 done served the needs of NRR.

7 MEMBER POWERS: Well, I mean, there were  
8 several points where the speaker said that they were  
9 going to look at what came from research. I think the  
10 research that we've heard about is well beyond this.  
11 I mean, I think he's looking at stuff that was done in  
12 the past.

13 MEMBER WALLIS: In the past, that's right.

14 MR. REINHART: Maybe a clarifying point,  
15 the person that did a lot of the initial work for us,  
16 as See-Meng mentioned, was J.S. Hyslop.

17 MEMBER WALLIS: Right, who presented this  
18 morning.

19 MR. REINHART: But now he went to research.

20 MEMBER WALLIS: That's right.

21 MR. REINHART: So he's supporting us along  
22 with his contractors are supporting our refinement.

23 CHAIRMAN ROSEN: Mark, one of the questions  
24 that was asked earlier today was about vision and it  
25 was about what is your vision for this fire protection

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 area and maybe more specifically about fire protection  
2 research. Can you tell us what -- you know, we asked  
3 a few vision questions. You're asking really what  
4 would you like your future to like?

5 MR. REINHART: Well, I have to address the  
6 SDP, that's the part that I own, and my vision would  
7 , as I said, that we have a way to understand, first  
8 of all, what's a finding and what's not a finding,  
9 what's a performance deficiency, what's not a  
10 performance deficiency, get our arms around the  
11 licensing basis, then take that and most of those  
12 issues as in the other SDPs, are screened out through  
13 those ineffective Phase 1 screening.

14 The next part would the Phase 2, it  
15 could scrutable, repeatable, that we can quickly  
16 move through, move that and I know we talked about can  
17 the inspector do that, do we need a fire protection  
18 excellence group, somehow have a group that can  
19 quickly give us the significance so we can put it in  
20 its proper place and move on.

21 MEMBER POWERS: I guess the issue that I  
22 hear most from the licensees in connection with fire  
23 protection boils down to asking what do you mean by  
24 quickly, what would your target from going from a --  
25 you've had a Phase 1 determination that something is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 greater than green, so it's gone to Phase 2. What  
2 kind of turnaround time would you like in Phase 2.

3 MR. REINHART: I'm trying to --

4 MEMBER POWERS: I'm not going to hold you  
5 to it. I'm just trying to understand.

6 MR. REINHART: Ideally, if an individual  
7 had everything at hand, he ought to be able to sit down  
8 that week and come up with an answer that another  
9 person could sit down with the next week and come up  
10 with the same answer and depending upon the  
11 complication, it's going to be longer than a week or  
12 shorter than a week.

13 MEMBER POWERS: Yeah, I would caution you  
14 against having as an aspiration that somebody else  
15 would come up with the same answer. I think my  
16 aspiration would be that somebody else could understand why  
17 he came up with the answer he did.

18 MR. REINHART: And they would hopefully  
19 agree that it's within the decade of green or yellow  
20 or white.

21 MEMBER POWERS: I understand. That's what  
22 I was looking for. Next year I will not say why you  
23 got eight days and you said a week.

24 CHAIRMAN ROSEN: I think you've annunciated  
25 a pretty useful vision. What I think -- what I would

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 like you to do is to write it all down in one or two  
2 paragraphs. That would helpful. What is the vision  
3 and then you've annunciated and here's how I'd like my  
4 future to look. I mean, you could create --

5 MR. REINHART: That's a good suggestion.  
6 Maybe we could do that going into our workshop so that  
7 everybody can see --

8 CHAIRMAN ROSEN: You know, it ought to  
9 exceed your grasp, your vision. Man's reach ought to  
10 exceed his grasp but write down the way you'd like to  
11 and you might find a lot of people agree with you and  
12 that will a good basis to work together.

13 MEMBER POWERS: I think based on our  
14 interactions with the licensees, if they just  
15 understood that that's what we were trying to invoke,  
16 it would a great comfort to them. They just see us  
17 going in the other direction and taking longer and  
18 longer and longer to do these things.

19 CHAIRMAN ROSEN: Thank you. Mr. Coe,  
20 welcome back.

21 MR. COE: Good afternoon, Mr. Chairman.  
22 I'm always glad to come back.

23 CHAIRMAN ROSEN: One of the two greatest  
24 lies, right?

25 MR. COE: Even though I'm the anchor man.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN ROSEN: The check is in the mail.

2 MR. COE: Not always the best position to  
3 in is the anchor man. So I've prepared a very brief  
4 presentation.

5 CHAIRMAN ROSEN: Well, I compliment you on  
6 the positioning of the staples in your package,  
7 something that's been giving people trouble with all  
8 day. You can see what the tenor of the debate has  
9 been.

10 MR. COE: I was asked to prepare a brief  
11 presentation on the type of inspection findings that  
12 we've had in our program since its inception. The ROP  
13 program that is. What you heard at the last  
14 presentation was a categorization I think and some --  
15 of the inspection findings that came out of the tri-  
16 annual inspection procedure. We also have a monthly  
17 and a quarterly inspection procedures that is  
18 conducted by the resident inspection staff on site and  
19 what I'm going to give you here today is a little bit  
20 more expansive set of numbers. These are the numbers  
21 that have come from the reactor oversight program  
22 since its inception.

23 There's 156 fire protection findings that  
24 we've classified as fire protection findings. They  
25 fall into these four categories, which are the same

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 categories that you just saw a moment ago. There is  
2 a little bit of overlap and there's maybe some  
3 findings that could fall into one or the other and  
4 we've made some choices here. But in general, you can  
5 see out of 156 findings, we've had two white issues  
6 and although I wasn't here for all of the last  
7 presentation, I understood that both of these  
8 particular issues may have been touched upon.

9 In each of these categories, all I'm going  
10 to do now is show you a set of -- or some examples of  
11 some of the findings in each of these categories.  
12 Okay, the first category is the safe  
13 shutdown/alternate safe shutdown. And here we're  
14 talking about as an example, the first bullet,  
15 inadequate protection of safe shutdown components,  
16 this might typically a safe shutdown path for a  
17 given fire area has not been protected in accordance  
18 with the Appendix R requirements.

19 CHAIRMAN ROSEN: What does that mean, the  
20 thermal lag isn't adequate?

21 MR. COE: Either the thermal lag isn't  
22 adequate or the separation isn't there or there's --  
23 or maybe there's deficiencies in being able to  
24 complete the function that's intended by that safe  
25 shutdown path, path meaning a series of actions taken

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 to provide a particular reactor safety function.

2 Okay, emergency lighting deficiencies for  
3 performing manual actions for the alternative safe  
4 shutdown path, shutdown outside the control room where  
5 the procedure itself could not performed as written  
6 under the circumstances that the procedure assumed or  
7 finally inadequate procedure for implementing  
8 alternate safe shutdown for fire in the main control  
9 room, just the procedure itself inadequate in some  
10 other aspect other than it couldn't performed or  
11 perhaps it would, you know a little bit confusing or  
12 it would lead you astray in some manner.

13 Okay, so these are findings and again, out  
14 of 157, you'll find -- we found most of these to of  
15 green significance. Fire protection issues, this  
16 really has to do with detection and suppression  
17 issues, smoke detectors inadequate, maybe they were  
18 misplaced, they weren't in the proper position.  
19 Perhaps they were inoperable, they wouldn't work for  
20 various reasons, inadequate testing with sprinkler  
21 system, inadequate Halon system, failure to maintain  
22 full area detector coverage, smoke detector or flame  
23 or fire detector, fire brigade problems. Okay, these  
24 we classified under this broad category of fire  
25 protection issues.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1           The third category is barrier issues.  
2       There are your typical barrier degradation issues,  
3       holes in barrier walls, lagging or a thermal lag that  
4       was not -- found not to       rated at its required  
5       rating, fire doors that had been left open,  
6       compensatory measures that have not been maintained  
7       and adequacy -- questions, continuing questions of  
8       adequacy of thermal barriers.

9           And finally, failure to follow procedures  
10       is outside of the other category that we looked at, at  
11       the first. That was the alternate safe shutdown  
12       category also had some procedural problems in there,  
13       but other than that, other failures to follow  
14       procedures might       involving transient combustibles,  
15       fire damper surveillance tests or surveillance tests  
16       in general, failing to follow those tests in  
17       accordance with the written requirements, equipment  
18       control, and failing to follow a procedure which  
19       actually resulted in a fire.

20           Okay, and finally, we have a category of  
21       findings that we send directly to traditional  
22       enforcement. I think we may have touched on this when  
23       I spoke on Monday. Impeding the regulatory process is  
24       one of three specific cases that we send directly to  
25       traditional enforcement regardless if there was an

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 impact that could measured in using and SDP process.  
2 This, of course, would invoke escalated enforcement  
3 and civil penalties and those sorts of sanctions.

4 In this particular case, impeding the  
5 regulatory process may involve failure to obtain NRC  
6 approval when it was required, failure to provide the  
7 NRC with complete and accurate information if we -- if  
8 the approval was being sought, failure to complete --  
9 failure to complete monthly inspections of  
10 extinguishers. That doesn't sound like it's in the  
11 right category. I don't think that's correct. I'm  
12 sorry, I guess it is an error. I apologize.

13 And the final point here is or the final  
14 example is failure to perform a safety evaluation and  
15 submit it again. It's just the general nature of  
16 these findings is that we should have been part of a  
17 decision that the licensee made and we were not  
18 provided that opportunity.

19 That completes my presentation.

20 CHAIRMAN ROSEN: Fantastic, Doug.

21 MEMBER POWERS: Doug, if I wanted to locate  
22 and follow up on the details of these, is there a  
23 summary written some place?

24 MR. COE: Yes, the way that we conducted  
25 these examples is we looked in our inspection data

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 base procedure or our findings data base and if you  
2 wanted to look at more detail, we can provide that to  
3 either basically a high level line item description or  
4 we can gather further detail from our plant issues  
5 matrix.

6 MEMBER POWERS: I guess, why don't we start  
7 w with the highest, the next --

8 MR. COE: The next level down.

9 MEMBER POWERS: If I wanted to follow it up  
10 more than that, I can get in touch with you.

11 MR. COE: Sure. In fact, do we have a copy  
12 of that here with us? We do. We'll provide that to  
13 you right away.

14 MEMBER POWERS: Thanks. Let me ask a  
15 question. How do your inspectors feel about  
16 inspecting for fire protection nowadays.

17 MR. COE: How do they feel about inspecting  
18 for fire protection nowadays.

19 MEMBER POWERS: You know, the last time we  
20 talked they felt like they were --

21 MR. COE: I'm going to ask Peter Koltay to  
22 address that question. Peter is on my staff and is  
23 actively engaged in participating in the SDP process  
24 that you just heard about and the improvement process  
25 there. He also attends fire protection meetings that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 are held out in the field, in the regions and in  
2 various industry forums. So, I'll let --

3 MEMBER POWERS: Did he go to the Seattle  
4 meeting?

5 MR. COE: Yes.

6 MR. KOLTAY: Pardon me?

7 MEMBER POWERS: I asked if you went to the  
8 Seattle meeting.

9 MR. KOLTAY: Yes, I did. I missed you. I  
10 didn't see you there.

11 MEMBER POWERS: I know, I couldn't go this  
12 time and I was crying in my beer ever since.

13 MR. KOLTAY: I don't know if I need further  
14 clarification on your question, but the inspections  
15 are done at several levels. One is designated team  
16 leaders, each region has, and there's a -- I mean,  
17 some team leaders are better trained in fire  
18 inspection than others. So we get fewer phone calls  
19 from the ones that are trained and have more  
20 experience and have quite a few phone calls -- no  
21 longer directed to us because we refer them to the  
22 technical group, Eric Weiss' (phonetic) group for  
23 technical questions.

24 As far as the SDP goes, though, I would  
25 say that there's a good percentage of inspectors out

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 there who do not dislike the existing SDP.

2 MEMBER POWERS: Do not what?

3 MR. KOLTAY: Do not -- they got used to it  
4 and after a year or so, they -- some of them actually  
5 feel that it works for them. Don't forget, not every  
6 issue comes into headquarters and not every issue is  
7 as complicated as the ones we constantly discuss.  
8 There are hundreds of issues out there handled in the  
9 region by the inspectors and the SRAs and they don't  
10 come to us because it works for them and probably  
11 because they screen them to green and they're  
12 comfortable with the outcome. So you know, it's not  
13 a total failure at that level.

14 MEMBER POWERS: You're giving me the sense  
15 that I'm looking for is that -- I mean, I think what  
16 you're telling me is that you have a growing and  
17 they're growing up comfortable with this whole thing.

18 MR. KOLTAY: I believe so, until we get  
19 down to the real PRA risk informed technical detail on  
20 what they should pick for an ignition frequency or  
21 they get confused just how to grade it or barriers or  
22 what do to with the fire brigade not performing  
23 properly and they don't even know how to enter it into  
24 the inspection report right now. So you know, those  
25 questions come up regularly but at some level, most

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 findings are handled at the regional level by the  
2 inspectors.

3 CHAIRMAN ROSEN: Why don't you let them  
4 enter fire brigade performance into an inspection  
5 report? I don't understand that or I never knew that.

6 MR. KOLTAY: It's -- I'm not sure how we  
7 got where we are with this. Right now, we give  
8 instructions to the inspectors to inspect the fire  
9 brigade or observe fire brigade drills at least once  
10 a year and spend so many hours doing this. But  
11 there's no real -- there's not an SDP to assess the  
12 brigade performance, and their observations or any  
13 comments they would like to make about the fire  
14 brigade right now, manual Chapter 0612 on  
15 documentation, basically tells you, well, if it's a  
16 minor violation or just an observation, you can't  
17 really enter it here. So it's sort of a Catch 22 for  
18 them. We didn't provide them the right vehicle at  
19 this point and I think the technical people are  
20 looking at that and we should coming up with some  
21 kind of solution to that.

22 CHAIRMAN ROSEN: That's alarming, I think.  
23 I think because we count so much on suppression, and  
24 very much of that is the fire brigade, it would seem  
25 to me a fairly --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MR. KOLTAY: It's not totally lost --

2 CHAIRMAN ROSEN: -- not trivial but  
3 certainly possible to define two things that you wish  
4 fire brigades didn't do or maybe better what they do  
5 do, you know, that they look at the pre-plan before  
6 they go and fight the fire, that way they understand  
7 that and communicate each other to it, that their  
8 bunker gear is in good shape and that they don't do it  
9 properly and timely. I mean, it's the obvious things.

10 MR. KOLTAY: There is one source for that  
11 and that's really the licensee's drill critique.  
12 They're supposed to and they do critique their own  
13 drills and that's recorded and it's available to us.

14 CHAIRMAN ROSEN: Right.

15 MR. KOLTAY: But it would be nice if they  
16 had a more independent assessment, like the NRC  
17 assessment.

18 CHAIRMAN ROSEN: So why don't you have your  
19 resident inspectors watch their drills?

20 MR. KOLTAY: They do. They do.

21 CHAIRMAN ROSEN: And write down what they  
22 see.

23 MR. KOLTAY: And they do and right now it's  
24 sort of information that they provide to the tri-  
25 annual team but it's not found necessarily in an

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 inspection report like you would expect it to , I  
2 would expect it to .

3 CHAIRMAN ROSEN: Right, I didn't know you  
4 weren't doing that and that, to me, is -- that's  
5 alarming.

6 MR. COE: There is a threshold above which  
7 an inspector will write a fire brigade finding and  
8 I've given you one example that we drew from the data  
9 base of findings that we use to prepare this  
10 presentation. The specific case that I held up was a  
11 fire brigade that receives a failing grade during  
12 drill or the failure to use a self-contained breathing  
13 apparatus during a drill when they should have.

14 I think that the problem that Peter is  
15 relating to you is in many ways the standards that  
16 should applied to fire brigade performance are very  
17 unclear and subjective. And so I think it's difficult  
18 in some cases for inspectors to generate a finding  
19 when the standards are so subjective, but there is a  
20 threshold, as I've shown here, that clearly we will  
21 document.

22 MEMBER WALLIS: Can I ask my question  
23 again? Maybe I'm just perplexed because I have the  
24 wrong concept of what the meeting is about. I thought  
25 that part of our real purpose today was to look at the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 research program and see how it met the needs of NRR  
2 and I just don't see the connect. I mean, we hear  
3 this list of findings, it tells me nothing about  
4 whether the research program is adequate or not.  
5 Maybe I've got completely the wrong idea of what's  
6 going on.

7 CHAIRMAN ROSEN: Well, I think you did. I  
8 think our meeting was to look at the research plan but  
9 there were other objectives as well.

10 MEMBER WALLIS: So these are separate items  
11 all together.

12 CHAIRMAN ROSEN: Yes.

13 MEMBER WALLIS: They don't fit some overall  
14 objective.

15 CHAIRMAN ROSEN: Right. The meeting became  
16 a hodge-podge after.

17 MEMBER WALLIS: Okay.

18 CHAIRMAN ROSEN: Yes, there were some other  
19 issues besides the research plan.

20 MEMBER WALLIS: Okay, I was under some  
21 misunderstanding then.

22 MEMBER POWERS: One of the reasons these  
23 last two topics came up explicitly is some of the  
24 feedback we got during our various plant visits and to  
25 the regions and we got an earful on these things.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN ROSEN: Doug, let me get back to  
2 your --

3 MEMBER POWERS: On the SDP, the fire SDP  
4 got hit more than any other single thing that I heard  
5 and it addressed all the issues that the speaker  
6 brought up. I mean, he got them all, so I suspect  
7 he's gotten an earful.

8 CHAIRMAN ROSEN: On this slide where you  
9 listed all the findings, you have URI there's 29  
10 unresolved issues.

11 MR. COE: Yes.

12 CHAIRMAN ROSEN: Those are things that are  
13 tied up in these barriers, like 10 of them are in  
14 barriers.

15 MR. COE: Yes, yes, and typically they're  
16 either going to an unresolved item because we  
17 haven't decided if a deficiency exists and some of  
18 that, of course, goes to the question of the clarity  
19 of the design basis or the licensing basis and  
20 otherwise an unresolved item may that an issue has  
21 entered an SDP process and the report was simply not  
22 delayed for the completion of that process and so the  
23 report was issued as an unresolved item.

24 CHAIRMAN ROSEN: Well, it's 4:35 and we are  
25 finished except for what should we do with what we've

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 heard. Thank you, Doug.

2 MR. COE: Thank you.

3 CHAIRMAN ROSEN: I have been taking notes  
4 of some questions that the committee has asked and  
5 what the committee seemed to interested in with  
6 respect to these speakers and I can go through that  
7 but I would prefer maybe before I did that or in lieu  
8 of doing that, perhaps give me some guidance to what  
9 we say, what I say on your behalf to the full  
10 committee on, I think it's Friday or maybe Friday and  
11 Saturday.

12 CHAIRMAN ROSEN: Yeah, that's why I asked  
13 the -- oh, I thought it was Mark Reinhart. Oh, well,  
14 okay. Let's -- we've got about, I don't know a really  
15 short time on the agenda, I think only a half an hour  
16 to summarize the subcommittee's deliberations today  
17 for Friday and what I was going to propose was that I  
18 just tell the full committee what we heard in terms of  
19 you know, just going through the agenda and then spend  
20 some time on everything you questioned and talked  
21 about but trying to hit some what I think are the high  
22 points of what the committee was interested in by  
23 extrapolation from the questions and comments. Dana,  
24 did you have any other ideas on that?

25 Okay, let me go through it. On initial

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 briefing, on fire risk research plan, the committee  
2 was interested in what the mission for fire protection  
3 research was and we didn't hear that and what future  
4 was desired. The committee was interested in what the  
5 likelihood of multiple fires was, what the cleanup  
6 from smoke effects of fires and the fire risks in non-  
7 reactor facilities, including facilities being  
8 decommissioned.

9 MEMBER SIEBER: That's a serious issue.

10 CHAIRMAN ROSEN: Stock side fuel  
11 fabrication.

12 A VOICE: Well, that's the only thing -- we  
13 looked at the risks. We spent some time looking at  
14 criticality but criticality effects people at the site  
15 itself. It's not going to go much beyond that. And we  
16 worry some about safeguarding the material but that's  
17 somewhat outside of the risk domain. When you get  
18 into the risk domain, the only place that we came up  
19 with anything that was really significant as far as  
20 the public was concerned was it's fire and it's fire  
21 over and over and over again. Every time you turn  
22 around in that facility, you got fire. And in the  
23 processing facility, you've got fire with kerosine. In  
24 the cindering facility you've got fire with the  
25 furnaces and in the fuel assembly area, you've got

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 fire with clad.

2 A VOICE: Yeah, but you're grinding an  
3 oxide. You got a little aerosol problem there, you  
4 know, hook the filters and take care of it. But fire  
5 is -- fire is the biggy in this facility.

6 CHAIRMAN ROSEN: Okay, I've added that to  
7 the list. In the area of fire risk requantification  
8 activities that we heard about, the committee asked  
9 questions in the area of the scope and schedule and  
10 process and participants, who is involved. We note  
11 that fire risk requantification during shutdown is  
12 important and that it's excluded from the current  
13 studies. We noted that the techniques that are being  
14 developed in the requantification studies would used  
15 ultimately by plants that adopt NFP 805 so the whole  
16 issue of whether 805 will ever used by anybody, it's  
17 critically determined, I think, by how one ends up on  
18 risk requantification, whether that technique is  
19 amenable to use.

20 MEMBER SIEBER: I need somebody to refresh  
21 my memory. Was it ever decided whether licensees  
22 would allowed to partially adopt 805?

23 CHAIRMAN ROSEN: Yes, and it was decided  
24 and the answer is, yes, they can.

25 MEMBER SIEBER: Boy that turns things into

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 another little bit of a mess as far as being able to  
2 inspect and establish what the licensing base is, I  
3 think.

4 CHAIRMAN ROSEN: Maybe.

5 MEMBER SIEBER: You know, they'll cherry  
6 pick whatever the --

7 CHAIRMAN ROSEN: Well, the issue is whether  
8 the staff should let them cherry pick and I think that  
9 the decision is based on that it was the desire not to  
10 place another barrier --

11 MEMBER SIEBER: Well, the argument to allow  
12 them to partially adopt is the fact that they would  
13 probably never adopt if they to do it totally all at  
14 once.

15 CHAIRMAN ROSEN: Right.

16 MEMBER SIEBER: On the other hand, I can  
17 picture the cherry picking.

18 CHAIRMAN ROSEN: Is there any --

19 MEMBER SIEBER: That's okay if it's okay  
20 with the staff.

21 MS. BLACK: We had a lot of discussion  
22 about that and what actually it means to cherry pick  
23 because in 805 you don't have to reanalyze all of your  
24 rooms and so I think our position is that when you  
25 decide to adopt it, you should do all the up front

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 work that you need to do which is not that much to get  
2 into the process and then area by area you can decide  
3 to analyze an area once you run into a problem, but  
4 you don't have to analyze the whole plant. So that's  
5 what we would call cherry picking.

6 MEMBER SIEBER: So it's built into the  
7 process.

8 MS. BLACK: So it's built into the process.  
9 So you would an 805 plant but with your old  
10 licensing basis, you probably wouldn't pick it up  
11 unless you have one problem area that you wanted to  
12 analyze but you would 805 in the plant with your old  
13 deterministic licensing basis in most of the fire  
14 areas.

15 MEMBER SIEBER: Okay, thank you.

16 CHAIRMAN ROSEN: One other protocol  
17 question, I think that at this stage of the meeting we  
18 typically go off the record, just to -- am I correct  
19 about that?

20 So I'll adjourn the meeting for the  
21 purposes of the record.

22 (Whereupon, at 4:41 p.m. the meeting in  
23 the above entitled matter concluded.)  
24  
25

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

CERTIFICATE


This is to certify that the attached proceedings  
before the United States Nuclear Regulatory Commission  
in the matter of:

Name of Proceeding: Advisory Committee on  
Reactor Safeguards Fire  
Protection Subcommittee

Docket Number: N/A

Location: Rockville, Maryland

were held as herein appears, and that this is the  
original transcript thereof for the file of the United  
States Nuclear Regulatory Commission taken by me and,  
thereafter reduced to typewriting by me or under the  
direction of the court reporting company, and that the  
transcript is a true and accurate record of the  
foregoing proceedings.

  
Matthew Needham  
Official Reporter  
Neal R. Gross & Co., Inc.

**NEAL R. GROSS**  
COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



ADVISORY COMMITTEE ON REACTOR SAFEGUARDS  
FIRE PROTECTION SUBCOMMITTEE MEETING  
SEPTEMBER 11, 2002, ROCKVILLE, MARYLAND

Contact: Tim Kobetz (301-874-8716, [tjk1@nrc.gov](mailto:tjk1@nrc.gov))

**-PROPOSED SCHEDULE-**

	<b>Topics</b>	<b>Presenters</b>	<b>Time</b>
I.	Opening Remarks	S. Rosen, ACRS	8:30-8:35 a.m.
II.	RES Staff Introduction	Mark Cunningham	8:35-8:45 a.m.
III.	Fire Risk Research Plan, FY 2001-2002	Nathan Siu/J.S. Hyslop	8:45-9:45 a.m.
	<b>BREAK</b>		<b>9:45-10:00 a.m.</b>
IV.	a. Fire Risk Re-quantification and Fire PRA Guide Upgrade Report	J.S. Hyslop/Steve Nowlen (SNL)	10:00-11:00 a.m.
	b. Risk Methods Insights Gained from Fire Incidents (NUREG-6738)		
V.	Fire Detection and Suppression Analysis: An Assessment and Update of PRA Methods and Data	Steve Nowlen (SNL)	11:00-12:00 noon
	<b>LUNCH</b>		<b>12:00-1:00 p.m.</b>
VI.	Circuit Analysis - Failure Mode and Likelihood Analysis	Steve Nowlen (SNL)	1:00-2:30 p.m.
	<b>BREAK</b>		<b>2:30-2:45 p.m.</b>
VII.	Improvements in the Significance Determination Process for Fire Protection	Mark Reinhart/See-Meng Wong, NRR	2:45-3:45 p.m.
VIII.	Plant Fire Protection Inspections	Doug Coe, NRR	3:45-4:45 p.m.

**NOTE:**

- Presentation time should not exceed 50 percent of the total time allocated for specific item. The remaining 50 percent of the time is reserved for discussion.
- 25 copies of the presentation materials to be provided to the Subcommittee

SUBCOMMITTEE CHAIRMAN OPENING STATEMENT  
FIRE PROTECTION SUBCOMMITTEE MEETING  
SEPTEMBER 11, 2002

Good morning. This is the meeting of the ACRS Subcommittee on Fire Protection. I am Steven Rosen, Chairman of the Subcommittee.

The ACRS Members in attendance are George Apostolakis, Mario Bonaca, Graham Leitch, Dana Powers, and Jack Sieber.

The purpose of this subcommittee meeting is to discuss the staff's Fire Protection Research Plan, status of the fire protection research activities, fire protection inspection process and findings, and other related matters including industry activities.

The Subcommittee will gather information, analyze relevant issues and facts, and formulate the proposed positions and actions, as appropriate, for deliberation by the full Committee.

Tim Kobetz is the Cognizant ACRS staff engineer and the Designated Federal Official for this meeting. The rules for participation in today's meeting were noticed in the Federal Register on August 21<sup>st</sup>, 2002. A transcript of this meeting is being kept and will be made available as stated in the Federal Register Notice.

It is requested that speakers first identify themselves, use one of the microphones, and speak with sufficient clarity and volume so that they can be readily heard.

We have received no requests for time to make oral statements or written comments from members of the public regarding today's meeting. ( if comments/statements received they should be presented/read now and then make the following statement: The staff will address these concerns as part of today's presentation.)

We will now proceed with the meeting. I call upon Mr. Mark Cunningham, Chief, Probabilistic Risk Analysis Branch, to provide some opening remarks.

# **FIRE PROTECTION FINDINGS**

**APRIL 2000 - PRESENT**

	SSD / ASSD	FIRE PROTECTION	BARRIER	PROCEDURES
WHITE	0	1	1	0
GREEN	44	38	25	17
URI	13	6	10	0
TOTAL	57	45	37	17

White issues:

Smoke detectors inadequate in Cable Spreading Room (Palisades)

Failure to maintain fire area separation barrier between B Train switchgear room and A Train CSR as 3-hour rated (Harris)

# **SAFE SHUTDOWN / ALTERNATE SAFE SHUTDOWN**

- 
- Inadequate protection of safe shutdown components.
  - Emergency lighting deficiencies for performing alternative shutdown actions.
  - Shutdown outside control room procedure could not be performed as written.
  - Inadequate procedure for implementing alternate S/D for fire in Main Control Room.
-

# FIRE PROTECTION ISSUES

- 
- Smoke detectors inadequate.
  - Inadequate testing of sprinkler system.
  - AFW pump room Halon system inadequate.
  - Failure to maintain full area detector coverage.
  - Fire brigade receives failing grade during drill; failure to use self-contained breathing apparatus during drill.
-

---

# BARRIER ISSUES

---

- 3-hour fire barrier degraded.
  - Unsecured fire door.
  - Failure to establish compensatory measures for inoperable fire door.
  - Adequacy of HEMYC cable wrap 1-hour fire barrier. (URI - 8 plants)
-




# **FAILURE TO FOLLOW PROCEDURES**

---

- 
- Failure to control transient combustibles.
  - Failure to follow procedure associated with fire damper surveillance test.
  - Failure to follow equipment control procedure.
  - Failure to follow procedure resulting in a fire.
-

# TRADITIONAL ENFORCEMENT

- 4 Issues (impeding the regulatory process)
  - ▶ Failure to obtain approval prior to changing fire protection program.
  - ▶ Failure to provide complete and accurate information.
  - ▶ Failure to complete monthly inspections of extinguishers.
  - ▶ Failure to perform safety evaluations and submit to NRC.



# **Circuit Analysis – Insights from Industry/NRC Joint Testing**

---

**Presented to:**  
**Advisory Committee On Reactor Safeguards**  
**Fire Protection Subcommittee Meeting**  
**September 11, 2002**

**Presented by:**  
**Steve Nowlen**  
**Sandia National Laboratories**





# Background

---


- Fire-induced circuit faults remain a focus point for NRC and industry (EPRI/NEI)
- RES efforts related to fire PRA circuit analysis methods and data were presented to this subcommittee in 10/00
  - This is a follow-up presentation on new information developed since that presentation
- One of the shortcomings identified on 10/00 was that test data on cable failure modes was sharply limited
- New cable failure / circuit fault mode experiments conducted during 2000-2001 by industry
  - EPRI & NEI with utility support



## **Background (cont)**

---

- **NRC was invited to, and did, participate in tests**
  - **Test planning**
  - **Test execution**
  - **Data analysis and interpretation**
- **NRC and industry agreed to share all test data**
- **Each party to analyze and interpret all test data independently**
- **This presentation discusses our initial analysis of the test results:**
  - **Primary source: Draft NUREG/CR on circuit analysis**
    - **Undergoing internal NRC review**
  - **Supporting: NUREG/CR-6776 NRC/SNL test report**
    - **Now in NRC print shop**




## **General Test Approach**

---


- **A series of 18 fire tests conducted**
- **Gas burner diffusion flame – 70-450 kW**
- **Test conducted in a plate steel box/room**
  - **10'x10'x8'**
  - **natural ventilation**
- **One cable tray in each test, some tests also used one conduit**
- **Tests focus on multi-conductor control cables – often bundled with single conductor light power cables**
- **Thermoset and thermoplastic cables**
- **Armored and non-armored cables**

# Room Layout




# Cable Bundles Tested


---




10/c  
Bundle



8/c  
Armored  
Cable




5/c  
Cable




8/c  
Bundle




2/c  
Cable



6/c  
Cable




12/c  
Bundle




9/c  
Bundle







# Cable Raceway Arrangements




Tests #1, 2, 3, 4, 5, 7 & 13




Test #6




Test #8




Test #9




Tests #10 & 17




Test #11



Tests #12 & 15




Tests #14 & 18




Test #16

# NRC effort measured insulation resistance of the exposed cables





## Representative IR test results (Test 3)





## **IR Test Observations**

---

- **For multi-conductor cables:**
  - **In trays 80% of initial failures were intra-cable conductor-to-conductor shorts**
  - **Conductor shorting groups/combinations were complex and transient**
    - **Number of conductors in a shorted groups varied from 2 to all available conductors**
    - **Outer ring of conductors shorted first, core conductor last**
    - **Shorts generally involved nearest-neighbor groups**
    - **Often saw two separate conductor shorting groups**



## **IR Test Observations (cont)**

---

- **If the cables failed during a test, all conductors eventually shorted to ground**
  - **Transition times ranged from seconds to several minutes**
- **Various factors were seen to influence cable failure mode behavior:**
  - **Routing in conduits appears to increase likelihood of a short to ground as first failure mode**
    - **Conduit data very limited - inconclusive**
  - **Armored cables also appear to increase likelihood of a short to ground as first failure mode**
    - **Shorting to the grounded armor**



## **IR Test Results and Observations (cont)**


---

- **Inter-cable conductor-to-conductor shorts were less likely than intra-cable, but were observed**
  - **Thermoplastic cables appear more likely to experience inter-cable shorting than do thermoset cables**
  - **Cables in conduits also experienced inter-cable hot shorting behaviors**
- **DC versus AC power may impact shorting behavior, but data is inconclusive**
- **No loss of continuity conductor failures observed**
  - **Behavior associated with more intense fires and/or high potential cables**


# Surrogate 4-20mA Instrument Loop

## Also Tested Under NRC Efforts


---



# Instrument Loop Results



Thermoplastic Cable



Thermoset Cable





## **Instrument Loop Observations**

---

- **Pronounced behavioral differences observed between thermoplastic and thermoset cables**
  - **Thermoplastic cables: no signal degradation prior to the complete loss of signal**
  - **Thermoset cables: substantial signal degradation for a relatively prolonged time period prior to the total loss of signal.**



## **Complementary Industry Circuit Testing**

---

- Focus on surrogate MOV control circuit
- Data analyzed in Appendix D of our draft NUREG/CR report on circuit analysis
  - NRC was given full access to all industry test data as a part of data sharing agreement
  - Based largely on my own input to EPRI expert panel
  - Report currently under review
  - Our findings reflect our current interpretation of the test data
- EPRI Expert Panel report is published
- Industry test report is being prepared, but not yet public
  - Presentations have been made at NEI Fire Protection Information Forum 2001, 2002



## **Overall Conclusions**

---

- **Many of our previous findings were confirmed:**
  - **Multiconductor cables will initially fail conductor-to-conductor with a high probability (on the order of 80% or more)**
  - **The shorting pattern will be complex and transient**
- **A number of influence factors were verified as important to the cable failure – circuit fault behavior:**
  - **Raceway type - i.e. conduit vs. tray**
  - **Cable tray loading and cable position within raceway**
  - **Armored versus unarmored cables**
  - **Circuit to cable wiring scheme**
- **At least one new influence factor was identified:**
  - **CPTs in control circuit**



## **Overall Conclusions (cont)**

---

- **IR and MOV results are broadly self-consistent:**
  - **Embedded conductors are likely to fail later than outer ring of conductors**
  - **Conductors will likely short to nearest neighbors first**
  - **Shorting combinations complex and transient**
  - **Duration of a hot short / device actuation ranged from momentary up to ten minutes**
  - **All conductors of failed cables eventually shorted to ground given a persistent fire**



## **Overall Conclusions (cont)**

---


- **The MOV circuit testing lent a number of unique insights:**
  - **In most tests with cable failures, at least one device actuation observed**
  - **In several tests, more than one device actuation was observed**
  - **In one test all four cable bundles saw at least one device actuation**
  - **Device actuations due to intra-cable hot shorts were most common**
  - **A smaller number of device actuations due to inter-cable hot shorts were also observed**



## **Overall Conclusions (cont)**

---

- **Areas of uncertainty and challenge remain:**
  - **Combinatorial models for cable failure behavior proposed but not yet validated**
  - **DC vs. AC may be a factor but not fully explored**
  - **Behavior of conduits appears different from trays, but data is limited and somewhat contradictory**
  - **Some potential influence factors not explored in these tests**
  - **Quantification for a specific case still requires application of expert judgment**
  - **Dealing with the transient nature of the faults – e.g., simultaneous vs. concurrent vs. sequential, fault duration**




# **Detection and Suppression Analysis**

---

**Presented to:**  
**Advisory Committee On Reactor Safeguards**  
**Fire Protection Subcommittee Meeting**  
**September 11, 2002**

**Presented by:**  
**Steve Nowlen**  
**Sandia National Laboratories**





# Presentation Outline

---

- **Task Objectives**
- **Approach – task structure**
- **Results – by task**
- **General Insights**






## **Task Objectives**

---

- **Provide an improved modeling framework and data for estimating the reliability (including effectiveness, to the extent possible) of automatic and manual suppression activities**
- **Develop estimates of these conditional probabilities for currently operating nuclear plants**
- **Identify and quantify key uncertainties in these estimates**



## **Approach – task structure**

---

- **Modeling Framework**
- **Information Gathering and Data Analysis**
- **Document Results**



# Modeling Framework

---

- Review of current practice reveals predominance of two detection/suppression methods
- Method 1: Direct use of historical data
  - Advantage: inherently captures long duration events
  - Disadvantage: difficult to tailor to specific application
- Method 2: Estimation of fire brigade response time
  - Advantage: nominally case specific analysis
  - Disadvantage: results vary little and may minimize contribution of long duration fires
- Conclusion: A more mechanistic approach might capture advantages of both methods



# Example of Historical Data Approach





Figure 1: Example cummulative probability distribution curve for indoor NPP fires in the US (based on 651 events with reported fire duration times out of a database of over 1300 events).

## Modeling Framework (cont)

- Siu & Appostolakis published a mechanistic model in 1983:






## Modeling Framework (cont)

---


- **Conclusions on model applicability:**
  - **Siu/Apostolakis model includes key features of interest**
  - **Identified desirable modifications:**
    - **Add path for self extinguished fires**
    - **Combine local and remote manual detection paths**
    - **Revise/redefine manual suppression paths:**
      - **Original model:**
        - **Manual suppression by on-site personnel**
        - **Large-scale manual suppression with off-site support**
      - **Revised model:**
        - **Prompt manual suppression (e.g., fire watch)**
        - **Delayed manual suppression (i.e., fire brigade)**
    - **Add suppression path for remove power or isolate fuel source when applicable (e.g., electrical fires, gas leaks)**




## Modeling Framework (cont)

---

- **Format as network model potential barrier to acceptance (unfamiliar format)**
- **Translation to an event tree format is possible**
  - **No feedback paths**
  - **May increase acceptability/use**




# Fire Detection Event Tree




Fully General  
Fire Detection Event Tree





# Fire Suppression Event Tree

Entry From Detection Tree	Prompt Local Suppression	Fixed Suppression System Installed	Fixed Suppression System Successful	Power Source Removal Stops Fire	Fire Suppressed Manually	Sequence	OUTCOME
	PLS	FSSINS	FSSS	PSRSF	FSM		




Fully General  
Fire Suppression Event Tree



# Information Gathering and Data Analysis

---


- Based on USNRC/Houghton data base
  - Covers years 1986-1999
  - Over 350 events
- Data Parsed and analyzed – e.g.:
  - Method of detection
  - Manual vs. auto/fixed vs. self suppression
    - Manual suppression method (extinguishers, hose stream, removing power, isolating fuel source)
  - Indoor vs. outdoor fires
  - Fires for key locations (e.g., T.B., R.B., containment, etc.)
  - Fires involving key sources
- Fire duration for various event sets estimated using Bayesian analysis



## **Data Limitations Identified:**


---

- **Fire detection times not available / not reported**
  - Need independent means for detection time analysis or must treat implicitly (e.g., modeling assumptions)
- **Limited data on fixed suppression system actuation timing, reliability, effectiveness**
- **Data base does not provide insights on suppression success/failure paths**
  - May be possible by searching underlying event information – this activity not pursued
- **Data does not support ‘fine tuning’ suppression analysis based on path to detection**
  - Exception – prompt detection/suppression paths




# Simplified Det./Supp. Event Tree

Ignition	Fire Self-Extinguished	Prompt Local Detection and Suppression	Fixed Suppression System Installed	Electrical Fire (or other fuel source that can be isolated)	Fire is Suppressed	Sequence	OUTCOME
IGN	FSE	PLDS	FSSINS	ELEC	FS		



Simplified Fire Detection and Suppression Event Tree



## General Insights

---


- Limitations of event data remain an obstacle to more detailed analysis of detection and suppression
- Detection methods:
  - Nearly 25% of fires (in this data base) report prompt detection (e.g., fire watches, reports of an explosion, flash of light, etc.)
  - Only 6% of fires (in this data base) reportedly detected by fixed detection systems
  - Majority assumed to be delayed manual detection, but not all events report detection method



## **General Insights (cont)**

---

- **Suppression method – all onsite fires:**
  - **Manual suppression – 63%**
  - **Self-extinguished – 18%**
  - **Power removed / fuel isolated – 16%**
  - **Fixed system (deluge – manual or auto) – 3%**
- **Focus on manual suppression in fire PRAs appropriate**




## **General Insights (cont)**

---

- **Involvement of fixed detection and suppression systems relatively rare in event reports**
  - **Reasons for lack of involvement not clear**
  - **How we treat fixed systems in fire PRA remains a challenge**
    - **Reliability**
    - **Timing**
    - **Effectiveness**


# TECHNICAL ISSUE RESOLUTION

- Clear process to allow consideration of all views
- Strive for consensus at many points in process
- Each party maintains own point of view if consensus not reached





# Project Team



# JOINT NRC/EPRI FIRE RISK REQUANTIFICATION STUDIES

J.S. Hyslop, RES/PRAB  
Steve Nowlen, SNL

Presented to ACRS Subcommittee on Fire Protection,  
Sept. 11, 2002

# BACKGROUND

- MOU between NRC-RES and EPRI
- Fire risk addendum
- One of several elements on fire risk addendum

# OBJECTIVES

- Develop state-of-art fire risk estimates
- Determine qualitative and quantitative impact of improved methods, tools, and data on predicted fire risk
- Develop guidance for conducting FRA
- Develop guidance on strengths and weaknesses
- Technology transfer

# SCOPE

- Full power, including estimates of LERF
- Excludes
  - Low power and shutdown modes of operation
  - Spent fuel pool accidents
  - Sabotage
  - Level 3 estimates of consequence

# PARTICIPANTS

- NRC
- EPRI
- Pilot plants
  - Millstone Unit 3
  - D. C. Cook
- Six non-pilot participating plants

# TECHNICAL ISSUE RESOLUTION

- Provides clear process to allow consideration of all party's views in development of methods
- Strive for consensus at many points in process
- Each party maintains own point of view if consensus not reached

# PRODUCTS

- NRC-RES will produce NUREGs on insights, and methods
- EPRI will produce updated Fire PRA Implementation Guide (FPRAIG)
- Pilot plants will develop updated FRAs



# DEMONSTRATION STUDIES

- Analyses performed jointly by NRC and EPRI using case examples from pilot plant FRA.
- Purpose
  - Demonstrate that methods can be implemented successfully in FRA
  - Technology transfer to pilot plant
- Demonstration studies comprise NRC's full involvement in pilot plant FRA
- NRR retains its independence in review of applications based upon pilot plant FRA

# SCHEDULE

- Kickoff at Millstone in May 2002
- Kickoff at D.C. Cook in Oct 2002
- Complete Millstone in Sept 2003
- Complete Cook in Nov 2003
- EPRI update FPRAIG in Dec 2003
- NRC produce NUREGs in spring 2004
- Workshop (TBD)

# REQUANTIFICATION STUDIES

## TECHNICAL STATUS

- Current technical activities focused on two areas:
  - Defining a consistent set of analysis steps
  - Writing procedures for early analysis steps
- Analysis process being broken into manageable pieces for purposes of procedure writing
  - Example of early task elements leading to qualitative screening:
    - Plant Partitioning
    - Selection of critical equipment – the fire PRA equipment list
    - Selection of critical cables and circuits – the circuit analysis list
    - Fire PRA database development

# LEVEL OF ADVANCEMENT VARIES BY TASK

- Consolidation of existing methods, e.g.:
  - Plant partitioning
  - Screening
  - Documentation guidance
- Incremental improvements, e.g.:
  - Fire PRA database
  - Fire ignition frequency
  - Uncertainty and sensitivity analysis

# LEVEL OF ADVANCEMENT VARIES BY TASK (cont)

- Significant advancement:
  - Plant Fire-Induced Risk Model
  - Circuit Analysis Tasks
    - Identification of Critical Cables/Circuits
    - Detailed Circuit Analysis
    - Circuit Fault Mode Quantification
  - Detection and Suppression
  - HRA
  - Fire modeling




# **Risk Methods Insights from Fire Incidents – A Brief Status Update**

---

**Presented to:**  
**Advisory Committee On Reactor Safeguards**  
**Fire Protection Subcommittee Meeting**  
**September 11, 2002**

**Presented by:**  
**Steve Nowlen**  
**Sandia National Laboratories**





## **Background**

---

- **Task presented to ACRS Fire Protection Subcommittee October 2000**
  - Objectives
  - Approach
  - Results and insights
- **10/00 presentation was based on a draft for public comment of the task report**



## **Current Status**

---

- **Insights and conclusions of study remained essentially unchanged given review comments**
  - Editorial changes only
- **Report has been published – NUREG/CR-6738**
- **Positive feedback received from both domestic and international readers**



# **FIRE RISK RESEARCH PROGRAM: STATUS UPDATE**

J.S. Hyslop & Nathan Siu

Probabilistic Risk Analysis Branch  
Office of Nuclear Regulatory Research  
U.S. Nuclear Regulatory Commission

ACRS Subcommittee on Fire Protection  
September 2002

# OUTLINE

- Status
- Program objectives
- Recently initiated tasks
- Planned/potential activities
- Accomplishments (existing tasks)
- General elements of plan
- Events since plan development
- Concluding remarks

# STATUS

- Program plan being updated
  - Last version for 2001-02
- Considering 4 year plan for new version (2003-06)
  - Detailed plan for 2003-04
  - Less detail for 2005-06

## **PROGRAM OBJECTIVES\***

- Improve qualitative and quantitative understanding of the risk contribution due to fires in nuclear power plants.
- Support ongoing or anticipated fire protection activities, including the development of risk-informed, performance based approaches to fire protection
- Develop improved fire risk assessment methods and tools (in support of above objectives)

\*From FY 2001-2002 plan

## RECENTLY INITIATED TASKS

- Fire risk requantification studies (technical activities)
  - Joint NRC-RES/EPRI studies
  - Represent integration of many tasks
  - Many objectives, including new methods
  - Expected to support ANS fire risk standard
- ANS fire risk standard development
  - RES is providing two members of the writing committee
  - Kickoff meeting recently held
- Fire protection SDP revision
  - RES is supporting NRR direction to revise
  - Comprehensive review
- Providing assistance to NRR to develop risk-related guidance to support inspection of fire protection circuit analysis issues

## **PLANNED/POTENTIAL ACTIVITIES**

- Fire model benchmarking and validation (and testing)
- Fire protection for gaseous diffusion plants
- Fire risk assessment for precursor analysis
- Fire protection rulemaking support
- Fire risk assessment guidance assessment

## **ACCOMPLISHMENTS (EXISTING TASKS)**

- Tools for circuit failure mode and likelihood analysis
- Tools for fire detection and suppression analysis
- Fire modeling toolbox
  - Collection of references re: HRRs, cable fragilities, ignitability
- Frequency of challenging fires
  - Model for handling early stages of fire development (expert judgement)
- Experience from major fires
  - FRA framework captures chain of events observed in real fires
  - Some exceptions, i.e. multiple fires

## **ACCOMPLISHMENTS (EXISTING TASKS) (cont.)**

- Fire model benchmarking and validation
  - Various fire models provide consistent results for cable tray fires
- Integrated model and parameter uncertainty
  - Bayesian technique for addressing modeling uncertainty
- Significance of smoke effects (review of literature)
  - Threshold smoke level for damage for digital circuitry is very high concentration (films provide adequate protection)
  - Some evidence that high voltage is vulnerable
- Fire protection SDP support
  - Model for quantifying the effectiveness of manual actions at remote shutdown operations
- NFPA 805 development support



# **GENERAL ELEMENTS OF PLAN**

- Overall objectives
- Background (e.g. initial prioritization, RIRIP)
- Program outputs and regulatory uses
- Relationship with other programs/activities
- Specific technical objectives
- Tasks and Milestones
- Communications plan

## **EVENTS SINCE PLAN DEVELOPMENT**

- Issuance of risk-informed, performance based fire protection rulemaking plan
- Issuance of NFPA 805
- Plan to revise the fire protection SDP
- Industry development of risk-informed approach to resolve the circuit analysis issue (NEI 00-01)
- Potential needs established for non-reactor applications
- Cooperative activities initiated
  - NRC-RES/EPRI MOU
  - Fire modeling
  - COOPRA, WGRISK (in process)
- NRC Public Workshop on RES Fire Risk Research Program (Aug 2001)
  - Discussed technical progress of tasks
  - Attended by industry, user offices of NRC (including Regions)
  - Feedback very positive

## **CONCLUDING REMARKS**

- Research results are addressing ongoing regulatory technical issues
- Staff is participating in cooperative efforts with industry and international organizations
- Needs for research are evolving
- Research program is evolving to meet needs