

6.0 ADMINISTRATIVE CONTROLS

6.2 ORGANIZATION (Continued)

UNIT STAFF

6.2.2 The unit organization shall be subject to the following:

- a. Each on duty shift shall be composed of at least the minimum shift crew composition shown in Table 6.2-1
- b. At least one licensed Reactor Operator shall be in the control room when fuel is in the reactor. In addition, while the reactor is in MODE 1, 2, 3, or 4, at least one licensed Senior Reactor Operator shall be in the control room
- c. A health physics technician[#] shall be on site when fuel is in the reactor.
- d. Either a licensed SRO or licensed SRO limited to fuel handling who has no concurrent responsibilities during this operation shall be present during fuel handling and shall directly supervise all CORE ALTERATIONS.
- e. DELETED
- f. Administrative procedures shall be developed and implemented to limit the working hours of personnel who perform safety-related functions (e.g., licensed senior reactor operators (SROs), licensed reactor operators (ROs), health physicists, auxiliary operators, and key maintenance personnel). The administrative procedures shall include guidelines on working hours that ensure that adequate shift coverage shall be maintained without routine heavy use of overtime

Any deviation from the above guidelines shall be authorized by the Plant General Manager or the Plant General Manager's designee, in accordance with approved administrative procedures, and with documentation of the basis for granting the deviation. Controls shall be included in the procedures to require a periodic independent review be conducted to ensure that excessive hours have not been assigned. Routine deviation from the working hour guidelines shall not be authorized.

- g. The Operations Supervisor shall hold a Senior Reactor Operator License.

[#] The health physics technician may be less than the minimum requirement for a period of time not to exceed 2 hours, in order to accommodate unexpected absence, provided immediate action is taken to fill the required positions