

Crystal River Nuclear Plant Docket No. 50-302 Operating License No DPR-72

Ref: 10 CFR 50.90

September 20, 2002 3F0902-06

U.S. Nuclear Regulatory Commission Attn: Document Control Desk Washington, DC 20555-0001

- Subject: Crystal River Unit 3 License Amendment Request #271, Revision 1 Revised Improved Technical Specification (ITS) 3.7.18, for Two Inoperable Control Complex Chillers (TAC No. MB6189)
- Reference: FPC to NRC letter, 3F0802-03, dated August 14, 2002, "Crystal River Unit 3 License Amendment Request #271, Revision 0, One Time 24-Hour Delay for Entry into Improved Technical Specification 3.0.3 for Two Inoperable Control Complex Chillers"

Dear Sir:

Florida Power Corporation (FPC) hereby submits License Amendment Request (LAR) #271, Revision 1, which revises Improved Technical Specification (ITS) 3.7.18, CONDITION A, to add a condition for alternate cooling equipment to maintain the Control Complex temperature within acceptable limits for up to 24 hours. The proposed changes to ITS 3.7.18 also include renumbering REQUIRED ACTION A.1 to A.1.1, and the addition of REQUIRED ACTION A.1.2 to initiate actions to establish alternate cooling within one hour to maintain the Control Complex temperature within acceptable limits, AND restart a Control Complex Chiller within 24 hours. The proposed changes are being submitted as a contingency for two inoperable Control Complex Chillers during the scheduled refurbishment of the 'A' train Control Complex Chiller which will be placed out of service beginning September 30, 2002, for a complete rebuild of the unit. This revision to LAR #271 has been discussed with the NRC staff during a telephone conference on September 10, 2002.

The description of the proposed LAR, No Significant Hazards Consideration Determination, proposed Improved Technical Specifications and Bases pages, and the list of Regulatory Commitments previously provided in the referenced letter have been revised accordingly. Additionally, the No Significant Hazards Consideration Determination and Environmental Impact Evaluation have been consolidated in Attachment B, under a new section titled Regulatory Requirements. The previously provided conclusion that this request does not involve a significant hazards consideration pursuant to 10 CFR 50.92 remains unchanged.

A00

U.S. Nuclear Regulatory Commission 3F0902-06

Attachments F and G contain a summary of FPC's responses to questions posed by the NRC staff during the September 10, 2002 telephone conference. Included are a copy of Analysis/Calculation H-02-0001, CR-3 Control Complex Temperatures Utilizing Appendix R Chiller (CHHE-2) and Portable Air Conditioning (AC), and pages extracted from two loop accuracy calculations as a sample of those calculations.

If you have any questions regarding this submittal, please contact Mr. Sid Powell, Supervisor, Licensing and Regulatory Programs at (352) 563-4883.

Sincerely,

Dale & your

Dale E. Young Vice President, Crystal River Nuclear Plant

#### DEY/lvc

Attachments:

- A. Background, Description of Proposed Change, Reason for Request, and Evaluation of Request
- B. Regulatory Analysis
- C. Proposed Revised Improved Technical Specifications Pages Strikeout/Shadowed Format
- D. Proposed Revised Improved Technical Specifications Pages Revision Bar Format
- E. List of Regulatory Commitments
- F. Summary of FPC's responses to questions formulated by the NRC staff during the September 10, 2002, telephone conference
- G. Analysis/Calculation H-02-0001, CR-3 Control Complex Temperatures Utilizing Appendix R Chiller (CHHE-2) and Portable AC (Air Conditioning), and with samples of loop accuracy calculations
- xc: NRR Project Manager Regional Administrator, Region II Senior Resident Inspector

Page 2 of 3

#### **STATE OF FLORIDA**

#### **COUNTY OF CITRUS**

Dale E. Young states that he is the Vice President, Crystal River Nuclear Plant for Progress Energy; that he is authorized on the part of said company to sign and file with the Nuclear Regulatory Commission the information attached hereto; and that all such statements made and matters set forth therein are true and correct to the best of his knowledge, information, and belief.

Dale & young

Dale E. Young Vice President Crystal River Nuclear Plant

The foregoing document was acknowledged before me this  $\frac{20}{100}$  day of  $\frac{100}{1000}$ , 2002, by Dale E. Young.

Celen Deppelder

Signature of Notary Public State of Florida Ellen Deppolder My Commission DD040101 Expires July 08, 2005

(Print, type, or stamp Commissioned Name of Notary Public)

Personally Produced Known \_\_\_\_\_ -OR- Identification \_\_\_\_\_

Page 3 of 3

## FLORIDA POWER CORPORATION

## **CRYSTAL RIVER UNIT 3**

## **DOCKET NUMBER 50-302/LICENSE NUMBER DPR-72**

## ATTACHMENT A

## LICENSE AMENDMENT REQUEST #271

Background, Description of Proposed Change, Reason for Request, and Evaluation of Request

#### **Background**

Condition A of Improved Technical Specification (ITS) 3.7.18, "Control Complex Cooling System," requires that two Control Complex Cooling trains shall be OPERABLE. If one or more trains are inoperable AND at least 100% of the cooling capability of a single OPERABLE Control Complex Cooling train is available from the Operating Control Complex Cooling system, operation may continue for 7 days. The note to the Completion Time allows that, on a one-time basis, each Control Complex Cooling System (CCCS) train may be inoperable for up to 35 days to allow performance of chiller refurbishment activities. If the equipment within the CCCS is not capable of providing adequate cooling capability, Limiting Condition for Operation (LCO) 3.0.3 applies.

#### **Description of the Proposed License Amendment Request**

Florida Power Corporation (FPC) requests to revise ITS 3.7.18, CONDITION A, to add a requirement stating: "OR Alternate cooling to maintain the Control Complex temperature within acceptable limits for at least 24 hours is available. The ability to apply the alternate cooling method for the Control Complex will expire on December 31, 2002."

The proposed changes to ITS 3.7.18 also include renumbering REQUIRED ACTION A.1 to A.1.1, and the addition of REQUIRED ACTION A.1.2 stating: "OR If a second chiller becomes inoperable during the 35-day extended Completion Time, initiate actions to establish alternate cooling within one hour to maintain the Control Complex temperature within acceptable limits AND restart a Control Complex Chiller within 24 hours. The ability to apply the alternate cooling method for the Control Complex will expire on December 31, 2002."

The 24 hour time period would be adequate to diagnose and restart a Control Complex Chiller that may trip due to a number of possible causes. Based on previous experience, FPC is confident that the proposed period of 24 hours will be sufficient to restart the affected chiller.

#### **Reason for Request**

Refurbishment of the 'B' train Control Complex Chiller was completed on March 26, 2002. The 'A' train Control Complex Chiller will be placed out of service beginning September 30, 2002, for a complete rebuild of the unit. The rebuild is scheduled for a 17-day duration. During that period, Crystal River Unit 3 (CR-3) will be operating with the recently rebuilt 'B' train chiller in service providing cooling to the Control Complex. If the 'B' train chiller were to trip, it would render both Control Complex Chiller trains inoperable. Therefore, LCO 3.0.3 would apply and will require the unit be placed in MODE 3 in 7 hours, MODE 4 in 13 hours and MODE 5 in 37 hours. CR-3 will have alternative non-safety related cooling equipment staged and ready to be placed in service within one hour to serve the function of the Control Complex Chiller. During the 24-hour period at normal operating conditions, the alternative cooling systems will maintain the average bulk air temperature below 87°F in the Control Complex, and individual room temperatures will not exceed maximum design temperature limits.

## U.S. Nuclear Regulatory Commission 3F0902-06

FPC is submitting this License Amendment Request (LAR) as a contingency in the event the single operating chiller trips during the extended refurbishment period of the opposite train chiller. In the event of a chiller trip, CR-3 personnel would start the alternative cooling equipment within one hour, evaluate the cause for the chiller trip, and determine a time frame for restarting the tripped chiller. While the 'A' train chiller is being refurbished, FPC Technicians, chiller manufacturer, and Maintenance management personnel will be on site continuously, providing the best opportunity to diagnose and repair a tripped 'B' train chiller. While repairing and restarting the tripped chiller, Operations personnel will monitor the operation of the alternative cooling systems, and Control Complex temperatures. If temperatures are not maintained below administrative limits established for monitoring the performance of the alternative cooling systems, shutdown of the unit to MODE 5 will be initiated. The basis for this request is that the risk of a design basis event occurring within the 24-hour period during which CR-3 is using the alternative cooling systems is acceptably small, and is less than the risk posed by a forced shutdown of the unit.

#### **Deterministic Evaluation**

FPC has previously evaluated the design basis associated with chiller unavailabilty. The most significant functional impact to core damage from the chillers is providing heat removal for the Emergency Feedwater (EFW) control cabinets. Loss of cooling to the cabinets can cause the EFW control valves to inadvertently close. The evaluation concluded that if the operating Control Complex Chiller fails, the operators can use the Appendix R chiller for this function. The Appendix R Chilled Water System can be aligned to provide backup cooling for Control Complex vital equipment located outside the Control Room. The Appendix R chiller is non-safety related, and can be powered manually from the emergency diesel-backed 'B' train Engineered Safeguars (ES) 480 volt Bus. Under normal conditions these chillers can run simultaneously, but CR-3 loading calculations do not assume simultaneous operation of the 'B' train chiller and the Appendix R chiller during events or accident loading conditions. The same evaluation concluded that if all EFW is lost, it is still possible to cool the core using the non-safety related, diesel-backed Auxiliary Feedwater Pump (FWP-7), which is not dependent on cooling from the CCCS.

The loss of both Control Complex Chillers would result in a loss of safety related cooling equipment for the Control Complex. Alternative non-safety related cooling methods will be placed in service within one hour to provide cooling for the Control Complex. However, an increase in temperature is expected. FPC has evaluated the effect of increased temperatures on the equipment and instruments located in the Control Complex. Instrumentation and control devices are the most sensitive to ambient temperature changes. Per the Environmental & Seismic Qualification Program Manual (ESQPM), the various Control Complex rooms that house plant instrumentation experience a normal ambient temperature of 70 to 80°F. This is based on an operating Control Complex Chiller and various functioning HVAC duct heaters. While operating with alternative Control Complex cooling, it is anticipated that the temperatures will exceed the ESQPM range with local temperatures possibly up to a temperature of 104°F. An evaluation has been performed on the effect that this abnormal range of 80 to 104°F would have on plant instrumentation. The effect has been assessed with respect to the safety systems actuation setpoint accuracy, the display instrumentation uncertainty values used to monitor ITS allowable values, and display instrumentation uncertainties used for monitoring design basis operational limits.

## U.S. Nuclear Regulatory Commission 3F0902-06

The following is a list of systems that were evaluated for elevated ambient temperature conditions:

Reactor Protection setpoints Engineered Safeguards Actuation setpoints Emergency Feedwater Initiation and Control (EFIC) setpoints Control Rod Drive Position Indication Reactor Coolant (RC) Hot Leg Narrow Range Temperature RC Flow RC Narrow Range Pressure Reactor Building (RB) Narrow Range Pressure RB Temperature Pressurizer Level Makeup Tank Level and Pressure Secondary Heat Balance

All of these evaluations concluded that there would be insignificant changes to instrument loop uncertainties within the temperature range of 70 to 104°F. The following list of parameters, which do not normally vary over short intervals (24 hours), and that have loop components in the Control Complex were evaluated to be bounded by the evaluations performed above for temperature excursions up to 104°F.

Emergency Feedwater Tank Level Condensate Storage Tank Level Fire Service Water Storage Tanks Level Borated Water Storage Tank Level Borated Water Storage Tank Temperature Condenser Hotwell Level Core Flood Tank Level and Pressure Nuclear Services Closed Cycle Cooling Surge Tank Level and Pressure Decay Heat Closed Cycle Cooling Surge Tank Level

These evaluations are based on best estimate assumptions and engineering judgment applied to existing models and calculations. On this basis, FPC is confident that the setpoints of Technical Specification instrumentation that are used to meet 10 CFR 50.36(c)(2)(ii) Criterion 1 and Criterion 2 are relatively unaffected to temperatures up to 104°F. Additionally, FPC has established limiting temperatures for various areas in the Control Complex to ensure all required components can perform their design functions. Thus, there is a high degree of confidence that instrumentation needed to monitor and actuate to maintain safety limits and design bases limits will perform their functions during increased temperature conditions.

Established surveillance procedures verify instrument response to expected parameters at steady state power operation. Remaining at steady state operation while cooling is provided by the alternative cooling systems, and is a benefit in assessing proper instrument response when compared to monitoring changing parameters expected during a plant shutdown transient.

Compliance with control room habitability requirements will be maintained.

## **Risk Evaluation**

FPC has evaluated LAR #271 for its impact from a risk perspective. The 24-hour period that both chillers will be unavailable was evaluated and results in a delta Core Damage Frequency (CDF) of 3.66E-07. Combining this with the delta CDF of 6.3E-07, based on the previously approved 35-day maintenance to one chiller, yields a maximum delta CDF of 9.96E-07. Based on standard industry practice, however, CR-3 only schedules one half of the allowed outage time for maintenance. Considering this, the maximum expected delta CDF due to this change would be 5.9E-07, based on a planned 17-day maintenance of one chiller. This is less than the delta CDF of 6.3E-07 for a one-time 35-day maintenance outage as approved in License Amendment No. 200. This risk assessment does not credit the compensatory measures, which significantly reduce the risk associated with this activity.

## **Compensatory Measures**

During the period of time that chiller repairs are in progress, maintenance and surveillance activities that have the potential to impact the performance of the Appendix R Chilled Water System or required support systems will not be performed. This includes minimizing activities that could potentially cause a plant trip or a loss of offsite power.

Alternate cooling to the Control Complex will be established by the following compensatory measures:

## Startup of 20 tons of pre-staged air conditioning (AC)

The guidance for aligning temporary cooling to the Control Complex is provided in Section 4.1 of Maintenance Procedure MP-193, "Temporary Cooling to a Control Complex." During the refurbishment of the 'A' train Control Complex Chiller, 20-ton of portable AC (sensible heat removal) will be pre-staged on the 145-foot elevation of the Turbine Building, outside of the Control Room, prior to the start of Control Complex Chiller refurbishment activities. Initiation of cooling to the Control Room using the portable AC requires routing expandable ductwork (from the unit into the Control Complex through the vestibule and Control Complex Habitability Envelope (CCHE) door on the 145-foot elevation) and starting the unit. These actions will be completed within one hour of the second safety related chiller unavailability.

While the temporary cooling is in place, appropriate security measures will be taken to assure proper access control to the Control Complex.

## Alignment of the Appendix R Chilled Water System to supply cooling to the vital equipment areas in the Control Complex

The guidance for aligning Appendix R chilled water to supply dedicated loads in the Control Complex is provided in Section 4.3 of Operating Procedure OP-409, "Plant Ventilation System." Required actions in this procedure section include:

1. securing the Appendix R Chiller and isolating Appendix R chilled water to the Turbine Building Switchgear cooling units and Reactor Building penetration cooling, U.S. Nuclear Regulatory Commission 3F0902-06

- 2. isolating normal duty chilled water to the Emergency Feedwater Initiation and Control (EFIC) Room cooling units,
- 3. aligning Appendix R chilled water to the individual cooling units in the EFIC, Battery Charger, Inverter, Remote Shutdown, and 4160V and 480V Switchgear Rooms,
- 4. restarting the Appendix R Chiller, and
- 5. starting the individual cooling unit fans.

These actions will be completed within one hour of chiller unavailability.

The Control Room Emergency Ventilation System (CREVS) operates in combination with the CCCS during normal operation to distribute cooling to all areas of the Control Complex

CREVS will remain in operation to distribute the cooled air provided by the Appendix R Chilled Water System and the portable 20-ton AC to all areas of the Control Complex. If outside air is cooler than the air inside the Control Complex, CREVS will operate in normal mode with 5,000 CFM fresh air intake and discharge. If outside air is warmer, CREVS will operate in the normal recirculation mode with no intake or discharge.

The Control Complex will be adequately cooled within the requested 24-hour period as follows:

- A. CR-3 has previous experience maintaining cooling to the Control Room with portable AC; and
- B. The Appendix R Chiller and associated heat exchangers have the capacity of removing approximately 50 tons of heat from the Control Complex. This capacity in combination with 20-tons of portable AC results in 70 tons of sensible heat removal capacity, which will maintain environmental conditions in the Control Complex below design limits for a duration of 61 hours (24-hour delay for entry into ITS LCO 3.0.3 plus 37 hours to place the Unit in MODE 5).

FPC has established procedures to reduce unnecessary heat loads while operating with the alternative cooling systems.

Additional administrative compensatory controls have been established in the event of operator fatigue resulting from higher temperature conditions during the implementation of this LAR. These measures include additional personnel on shift for relief, supplemental comfort measures such as local fans for the control board area and the availability of ice vests for Control Room personnel.

#### Performance Monitoring

FPC has established procedures to monitor the temperature in the Control Complex while operating with the alternative cooling systems. Administrative limits on temperature have been established for bulk air temperature in the Control Complex and for each individual area to preserve equipment operability. If the temperature limits are exceeded within the 24-hour period, the plant will initiate shutdown to MODE 5.

## **Conclusion**

Based on the above evaluation, FPC believes that approval of the proposed change to ITS 3.7.18, due to inoperability of both chillers, will pose an insignificant risk to the plant or to the health and safety of the public.

## **Reference**

FPC to NRC letter, 3F0701-02, dated July 19, 2001, "Crystal River Unit 3 – Response to NRC Request for Additional Information Re: Proposed License Amendment Request #259, Revision 0, "Control Complex Cooling System" (TAC No. MB1617)

## FLORIDA POWER CORPORATION

## **CRYSTAL RIVER UNIT 3**

## **DOCKET NUMBER 50-302/LICENSE NUMBER DPR-72**

## ATTACHMENT B

## LICENSE AMENDMENT REQUEST #271

## **Regulatory Analysis**

No Significant Hazards Consideration Determination Applicable Regulatory Requirements Environmental Impact Evaluation

#### **No Significant Hazards Consideration Determination**

License Amendment Request (LAR) #271, Revision 1, proposed changes include a change to Improved Technical Specification (ITS) 3.7.18, CONDITION A, to add a condition requiring available alternate cooling to maintain the Control Complex temperature within acceptable limits for at least 24 hours. The proposed changes to ITS 3.7.18 also include renumbering REQUIRED ACTION A.1 to A.1.1, and the addition of REQUIRED ACTION A.1.2 to initiate actions to establish alternate cooling within one hour to maintain the Control Complex temperature within acceptable limits, AND restart a Control Complex Chiller within 24 hours.

This LAR is requested as a contingency for two inoperable Control Complex Chillers while Control Complex Cooling System chiller refurbishment is performed. This request has been evaluated against the standards in 10 CFR 50.92, and has been determined to not involve a significant hazards consideration. In support of this conclusion, the following analysis is provided:

1. Does not involve a significant increase in the probability or consequences of an accident previously evaluated.

The Control Complex Cooling System is not an initiator of any design basis accident. The basis for this request is that the risk of a design basis event ocurring within the 24-hour period during which alternative cooling will be used is acceptably small, and is less than the risk posed by a forced shutdown of the unit. The Control Complex Cooling System safety function is to provide sufficient cooling to ensure operability of safety-related equipment located in the Control Room and other portions of the Control Complex. Control Complex cooling, within the 24-hour period, is being accomplished by the compensatory measures in place which include providing alternate cooling by aligning the Appendix R Chilled Water System to supply cooling to the vital equipment areas in the Control Room. Control Complex Habitability Envelope integrity will be maintained throughout the duration of this operating condition, which will ensure that potential post-accident dose to operators is maintained within analyzed limits. Therefore, granting this LAR does not involve a significant increase in the probability or consequences of an accident previously evaluated.

2. Does not create the possibility of a new or different type of accident from any accident previously evaluated.

The proposed License Amendment Request will not result in changes to the design, physical configuration of the plant. Therefore, the proposed change will not create the possibility of a new or different kind of accident from any previously evaluated.

#### 3. Does not involve a significant reduction in the margin of safety.

During the 24-hour period of operation with two inoperable Control Complex Chillers allowed by the proposed change to ITS 3.7.18, measures will be implemented to ensure the availability of temporary and permanently installed non-safety backup systems capable of providing cooling to the Control Room and other vital equipment areas in the Control Complex within one hour. From the risk significance perspective, using installed non-safety backup systems to provide cooling to the Control Room and other vital equipment areas in the Control Complex is acceptable. Areas with essential equipment in the Control Complex will be monitored to ensure temperatures do not exceed acceptable limits. Therefore, granting this LAR does not involve a significant reduction in the margin of safety.

Based on the above, FPC concludes that the proposed LAR presents no significant hazards consideration under the standards set forth in 10 CFR 50.92(c), and accordingly, a finding of "no significant hazards consideration" is justified.

## **Applicable Regulatory Requirements**

FPC has evaluated the Regulatory Requirements applicable to the proposed changes to ITS 3.7.18 as follows:

## **10 CFR 50.36 Technical Specifications**

The discussion provided in the evaluation of request states that FPC has evaluated changes to instrument loop uncertainties within the temperature range of 70 to  $80^{\circ}$ F and found those to be insignificant. The discussion concluded that the setpoints of Technical Specification instrumentation that are used to meet 10 CFR 50.36(c)(2)(ii) Criterion 1 and Criterion 2, are unaffected to temperatures up to  $104^{\circ}$ F. Additionally, FPC has established limiting temperatures for various areas in the Control Complex to ensure all required components perform their design functions.

## **10 CFR 50.49 Environmental Qualification of Electric Equipment Important to Safety for Nuclear Power Plants**

The temperature limits required to ensure equipment qualification of electrical equipment in the Control Complex will not be exceeded during the 24-hour period when the ability to use the alternate cooling method apply. Therefore, the proposed change to ITS 3.7.18 does not require exemption or relief from this regulatory requirement.

## 10 CFR 50, Appendix A

The general Design Criteria (GDC) for nuclear power plants (Appendix A to 10 CFR 50) came into effect after the licensing of CR-3. CR-3 has been designed and constructed taking into consideration the proposed 10 CFR 50.34, Appendix A, General Design Criteria for Nuclear Power Plant Construction Permits, as published in the Federal Register (32FR10213) on July 11, 1967, and which are applicable to this unit. Thus, the GDC in 10 CFR 50, Appendix A, applicable to this proposed change to ITS 3.7.18 is Criterion 19, Control Room. The corresponding CR-3 GDC is Criterion 11.

Control Complex cooling, within the 24-hour period, is being accomplished by the compensatory measures in place which include providing alternate cooling by aligning the Appendix R Chilled Water System to supply cooling to the vital equipment areas in the Control Complex and operation of pre-staged portable air conditioning that provides cooling to the Control Room. Control Complex Habitability Envelope integrity will be maintained throughout the duration of this operating condition, which will ensure that potential post-accident dose to operators is maintained within analyzed limits.

.

FPC has determined that the proposed changes do not require any exemptions or relief from regulatory requirements other that the changes requested to ITS 3.7.18.

#### **Environmental Impact Evaluation**

10 CFR 51.22(c)(9) provides criteria for identification of licensing and regulatory actions eligible for categorical exclusion from performing an environmental assessment. A proposed amendment to an operating license for a facility requires no environmental assessment if operation of the facility in accordance with the proposed amendment would not:

- (i) involve a significant hazards consideration,
- (ii) result in a significant change in the types or significant increase in the amounts of any effluents that may be released offsite, and
- (iii) result in a significant increase in individual or cumulative occupational radiation exposure.

Florida Power Corporation has reviewed proposed License Amendment Request #271, Revision 1 and concludes it meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(c), no environmental impact statement or environmental assessment needs to be prepared in connection with this request.

## FLORIDA POWER CORPORATION CRYSTAL RIVER UNIT 3 DOCKET NUMBER 50-302/LICENSE NUMBER DPR-72

## ATTACHMENT C

## LICENSE AMENDMENT REQUEST #271

**Proposed Revised Improved Technical Specifications Pages** 

Strikeout/Shadowed Format

**Strikeout Text** Indicates Deleted Text Shadowed Text Indicates Added Text 

## Control Complex Cooling System 3.7.18

#### 3.7 PLANT SYSTEMS

3.7.18 Control Complex Cooling System

LCO 3.7.18 Two Control Complex Cooling trains shall be OPERABLE.

APPLICABILITY: MODES 1, 2, 3 and 4.

ACTIONS

	CONDITION		REQUIRED ACTION	COMPLETION TIME
Α.	One or more trains inoperable. <u>AND</u>	A.1	Ensure adequate cooling capability from the Control Complex Cooling system in operation.	Immediately
	At least 100% of the cooling capability of a single OPERABLE Control Complex Cooling train available. Alternate cooling to maintain the Controll complex temperature vichin acceptable limits for at least 24 hours is available. The ability to apply the alternate cooling method for the control complex will expire on December 34, 2002.	Artig24	UK IF a second chilller becomes inoperable during the 35-day extended completion rime, initiate actions to establish allernate cooling within one hour to maintean the control complex temperature within acceptable timpts AND restart a control complex chiller within 24 hours. The ability to apply the alternate cooling method for the control complex with expire of December 31, 2002	
		AND		7 days*
		A.2	Restore Control Complex Cooling trains(s) to OPERABLE status.	
в.	Required Action and associated Completion Time of Condition A	B.1 AND	Be in Mode 3.	6 hours
	not met.	B.2	Be in Mode 5.	36 hours

\*On a one-time basis, each Control Complex Cooling System train may be inoperable for up to 35 days to allow performance of chiller refurbishment activities. LCO 3.0.4 is not applicable during each of the one-time 35-day Completion Times. The ability to apply the one-time 35-day Completion Time to each Control Complex Cooling System train will expire on December 31, 2002.

#### BASES

APPLICABLE	personnel occupancy requirements, to ensure equipment
SAFETY ANALYSIS	OPERABILITY.
(concinaed)	The Control Complex Cooling System satisfies Criterion 3 of the NRC Policy Statement.

- LCO Two redundant trains of the Control Complex Cooling System are required to be OPERABLE to ensure that at least one train is available, assuming a single failure disables one redundant component. A Control Complex Cooling train consists of a chiller and associated chilled water pump as well as a duct mounted heat exchanger that provides cooling of recirculated control complex air. All components of an OPERABLE train must be energized by the same train electrical bus. Total system failure could cause control complex equipment to exceed its operating temperature limits. In addition, the Control Complex Cooling System must be OPERABLE to the extent that air circulation can be maintained (See Specification 3.7.12).
- APPLICABILITY IN MODES 1, 2, 3, and 4, the Control Complex Cooling System must be OPERABLE to ensure that the control complex temperature will not exceed equipment OPERABILITY requirements.

#### ACTIONS

#### A.1. Land A.1.2

The LCO requires the OPERABILITY of a number of independent subsystems. Due to the redundancy and diversity of subsystems, the inoperability of one component in a train does not render the Control Complex Cooling System incapable of performing its safety function. Neither does the inoperability of two different components, each in a different train, necessarily result in a loss of function for the Control Complex Cooling System. The intent of this Condition is to maintain a combination of equipment such that the cooling capability equivalent to 100% of a single train remains available and in operation. This allows increased flexibility in plant operations under circumstances when components in opposite trains are inoperable.

(continued)

#### ACTIONS <u>A.1.Land All</u> (continued)

With one or more components inoperable such that the cooling capability equivalent to a single OPERABLE train is not available, the facility is in a condition outside the accident analyses. Therefore, LCO 3.0.3 must be immediately entered.

With one or more Control Complex Cooling trains inoperable and at least 100% cooling capability of a single OPERABLE train available, the inoperable components must be restored to OPERABLE status within 7 days\*. In this Condition, the remaining Control Complex Cooling System equipment is adequate to maintain the control complex temperature. Adequate cooling capability exists when the control complex air temperature is maintained within the limits for the contained equipment and components. However, the overall reliability is reduced because additional failures could result in a loss of Control Complex Cooling System function. The 7 day Completion Time is based on the low probability of an event occurring requiring the Control Complex Cooling System and the consideration that the remaining components can provide the required capabilities.

\*On a one-time basis, each Control Complex Cooling System train may be inoperable for up to 35 days to allow performance of chiller refurbishment activities. LCO 3.0.4 is not applicable during each of the one-time 35-day Completion Times The ability to apply the one-time 35-day Completion Time to each Control Complex Cooling System train will expire on December 31, 2002.

IF a second chilliter becomes inopenable during the 35-day extended Completion Thme, initiate actions to establish alternate coolling within one hour to maintain the control complex temperature within acceptable limits AND restart a control complex chiller within 24 hours. The ability to apply the alternate coolding method for the control complex will externate coolding method for the control complex will externate coolding method for the control complex will

constol complex semperatures will be monitored during this 24hour period to ensure all required equipment als maintrained vithin acceptable limits.

#### B.1 and B.2

If the inoperable Control Complex Cooling System component cannot be restored to OPERABLE status within the required Completion Time, the unit must be placed in a MODE in which the LCO does not apply. To achieve this status, the unit must be placed in at least MODE 3 within 6 hours, and in MODE 5 within 36 hours. The allowed Completion Times are reasonable, based on operating experience, to reach the required unit conditions from full power conditions in an orderly manner without challenging unit systems.

#### BASES

## FLORIDA POWER CORPORATION CRYSTAL RIVER UNIT 3 DOCKET NUMBER 50-302/LICENSE NUMBER DPR-72

## ATTACHMENT D

## LICENSE AMENDMENT REQUEST #271

**Proposed Revised Improved Technical Specifications Pages** 

**Revision Bar Format** 

Control Complex Cooling System 3.7.18

#### 3.7 PLANT SYSTEMS

3.7.18 Control Complex Cooling System

LCO 3.7.18 Two Control Complex Cooling trains shall be OPERABLE.

#### APPLICABILITY: MODES 1, 2, 3 and 4.

A(	CT	IC	)N	S
יה	<b>_</b>	- L L		~

CONDITION			REQUIRED ACTION	COMPLETION TIME
Α.	One or more trains inoperable. <u>AND</u>	A.1.1	Ensure adequate cooling capability from the Control Complex Cooling system in operation.	Immediately
	At least 100% of the cooling capability of a single OPERABLE Control Complex Cooling train available. <u>OR</u> Alternate cooling to maintain the Control Complex temperature within acceptable limits for at least 24 hours is available. The ability to apply the alternate cooling method for the Control Complex will expire on December 31, 2002.	A.1.2 <u>AND</u> A.2	<u>OR</u> If a second chiller becomes inoperable during the 35-day extended Completion Time, initiate actions to establish alternate cooling within one hour to maintain the Control Complex temperature within acceptable limits AND restart a Control Complex Chiller within 24 hours. The ability to apply the alternate cooling method for the Control Complex will expire on December 31, 2002. Restore Control Complex Cooling trains(s) to OPERABLE status.	7 days*
в.	Required Action and associated Completion Time of Condition A not met.	B.1 <u>AND</u> B.2	Be in Mode 3. Be in Mode 5.	6 hours 36 hours

\*On a one-time basis, each Control Complex Cooling System train may be inoperable for up to 35 days to allow performance of chiller refurbishment activities. LCO 3.0.4 is not applicable during each of the one-time 35-day Completion Times. The ability to apply the one-time 35day Completion Time to each Control Complex Cooling System train will expire on December 31, 2002.

#### BASES

APPLICABLE	personnel occupancy requirements, to ensure equipment
(continued)	OPERABILITY.
(concinacity	The Control Complex Cooling System satisfies Criterion 3 of the NRC Policy Statement.

- LCO Two redundant trains of the Control Complex Cooling System are required to be OPERABLE to ensure that at least one train is available, assuming a single failure disables one redundant component. A Control Complex Cooling train consists of a chiller and associated chilled water pump as well as a duct mounted heat exchanger that provides cooling of recirculated control complex air. All components of an OPERABLE train must be energized by the same train electrical bus. Total system failure could cause control complex equipment to exceed its operating temperature limits. In addition, the Control Complex Cooling System must be OPERABLE to the extent that air circulation can be maintained (See Specification 3.7.12).
- APPLICABILITY In MODES 1, 2, 3, and 4, the Control Complex Cooling System must be OPERABLE to ensure that the control complex temperature will not exceed equipment OPERABILITY requirements.

#### ACTIONS <u>A.1.1 and A.1.2</u>

The LCO requires the OPERABILITY of a number of independent subsystems. Due to the redundancy and diversity of subsystems, the inoperability of one component in a train does not render the Control Complex Cooling System incapable of performing its safety function. Neither does the inoperability of two different components, each in a different train, necessarily result in a loss of function for the Control Complex Cooling System. The intent of this Condition is to maintain a combination of equipment such that the cooling capability equivalent to 100% of a single train remains available and in operation. This allows increased flexibility in plant operations under circumstances when components in opposite trains are inoperable.

(continued)

## BASES

## ACTIONS <u>A.1.1 and A.1.2</u> (continued)

With one or more components inoperable such that the cooling capability equivalent to a single OPERABLE train is not available, the facility is in a condition outside the accident analyses. Therefore, LCO 3.0.3 must be immediately entered.

With one or more Control Complex Cooling trains inoperable and at least 100% cooling capability of a single OPERABLE train available, the inoperable components must be restored to OPERABLE status within 7 days\*. In this Condition, the remaining Control Complex Cooling System equipment is adequate to maintain the control complex temperature. Adequate cooling capability exists when the control complex air temperature is maintained within the limits for the contained equipment and components. However, the overall reliability is reduced because additional failures could result in a loss of Control Complex Cooling System function. The 7 day Completion Time is based on the low probability of an event occurring requiring the Control Complex Cooling System and the consideration that the remaining components can provide the required capabilities.

\*On a one-time basis, each Control Complex Cooling System train may be inoperable for up to 35 days to allow performance of chiller refurbishment activities. LCO 3.0.4 is not applicable during each of the one-time 35-day Completion Times The ability to apply the one-time 35-day Completion Time to each Control Complex Cooling System train will expire on December 31, 2002.

If a second chiller becomes inoperable during the 35-day extended Completion Time, initiate actions to establish alternate cooling within one hour to maintain the Control Complex temperature within acceptable limits AND restart a Control Complex Chiller within 24 hours. The ability to apply the alternate cooling method for the Control Complex will expire on December 31, 2002.

Control Complex temperatures will be monitored during this 24hour delay period to ensure all required equipment is maintained within acceptable limits.

#### B.1 and B.2

If the inoperable Control Complex Cooling System component cannot be restored to OPERABLE status within the required Completion Time, the unit must be placed in a MODE in which the LCO does not apply. To achieve this status, the unit must be placed in at least MODE 3 within 6 hours, and in MODE 5 within 36 hours. The allowed Completion Times are reasonable, based on operating experience, to reach the required unit conditions from full power conditions in an orderly manner without challenging unit systems.

## FLORIDA POWER CORPORATION CRYSTAL RIVER UNIT 3 DOCKET NUMBER 50-302/LICENSE NUMBER DPR-72

## ATTACHMENT E

## LICENSE AMENDMENT REQUEST #271

List of Regulatory Commitments

## List of Regulatory Commitments

The following table identifies those actions committed to by Florida Power Corporation in this document. Any other actions discussed in the submittal represent intended or planned actions by Florida Power Corporation. They are described to the NRC for the NRC's information and are not regulatory commitments. Please notify the Supervisor, Licensing and Regulatory Programs, of any questions regarding this document or any associated regulatory commitments.

ID Number	Commitment	Commitment Date
3F0902-06-1	FPC has established procedures to monitor the temperature in the Control Complex while operating with the alternative cooling systems. Administrative limits on temperature have been established for bulk air temperature in the Control Complex and for each individual area to preserve equipment operability. If the temperature limits are exceeded within the 24- hour period, the plant will initiate shutdown to MODE 5.	During the requested 24-hour period.
3F0902-06-2	Maintenance and surveillance activities that have the potential to impact the performance of the Appendix R Chilled Water System or required support systems will not be performed. This includes minimizing activities that could potentially cause a plant trip or a loss of offsite power.	During the period of time that chiller repairs are in progress.
3F0902-06-03	Compensatory measures are identified in a plant administrative procedure.	Prior to placing the 'A'train Control Complex Chiller out of service.

## FLORIDA POWER CORPORATION

## **CRYSTAL RIVER UNIT 3**

## **DOCKET NUMBER 50-302/LICENSE NUMBER DPR-72**

## ATTACHMENT F

## LICENSE AMENDMENT REQUEST #271

Summary of FPC's Responses to Questions Formulated by the NRC Staff During the September 10, 2002, Telephone Conference

## Summary of FPC's responses to questions formulated by the NRC staff During the September 10, 2002 telephone conference

## **NRC Question**

1. State the bases for the 104°F temperature.

## **FPC\_Response**

The maximum accident temperature in the Control Complex was determined to be to be 104°F by FPC Calculation M97-0020, Control Complex Heat Load Evaluation.

## **NRC** Question

2. Provide the maximum cabinet temperature if ambient temperature is 104°F.

## FPC Response

The limiting Foxboro components were qualified by vendor testing to withstand an outside room temperature of 104°F. Attachment G provides extracted pages from Reactor Coolant pressure (wide range) Loop Accuracy calculation I-88-0020. This calculation includes pertinent data from the Foxboro qualification testing.

## NRC Question

3. Discuss quantitative results of analyses.

## FPC Response

Attachment G contains Analysis/Calculation H-02-0001, CR-3 Control Complex Temperatures Utilizing Appendix R Chiller (CHHE-2) and Portable AC (Air Conditioning). This calculation demonstrates that the Appendix R Chiller in conjunction with 20 tons capacity of portable Air Conditioning, will maintain the Control Complex temperatures below design temperature limits for a period of 61 hours.

## NRC Question

4. How do the elevated temperatures affect the qualified life of equipment?

## FPC Response

The temperature limit for the Control Complex that is required to ensure equipment qualification is 95°F for the Control Room and Emergency Feedwater Initiation and Control (EFIC) Room C, 110°F for the Mechanical Equipment Room and 104°F for all remaining Control Complex rooms. The EFIC Room C (power supplies and modules) can withstand a high temperature of 110°F (Calculation I-93-0002 of Attachment G). Therefore, the aforementioned 104°F accident temperature conservatively envelopes the specifications of the components in the Control Complex.

## FLORIDA POWER CORPORATION

## **CRYSTAL RIVER UNIT 3**

## **DOCKET NUMBER 50-302/LICENSE NUMBER DPR-72**

## ATTACHMENT G

## LICENSE AMENDMENT REQUEST #271

Analysis/Calculation H-02-0001, CR-3 Control Complex Temperatures Utilizing Appendix R Chiller (CHHE-2) and Portable AC (Air Conditioning), and with samples of loop accuracy calculations Systems Calc. Sub-Type Priority Code Quality Class AH, CH N/A 4 Non-Safety Related

#### NUCLEAR GENERATION GROUP

#### **ANALYSIS / CALCULATION**

H-02-0001 (Calculation #)

CR3 Control Complex Temperatures Utilizing Appendix R Chiller (CHHE-2) and Portable AC (Title including structures, systems, components)

BNP UNIT

CR3 HNP RNP NES ALL

APPROVAL

Rev	Prepared By	Reviewed By	Supervisor
0	Signature J.M. Guingston	Signature Dan Uni	Signature
	J.M. Livingston	Name D. Wise	G. Englert
	Date 8/01/02	Date 3/5/02	B 5 02

(For Vendor Calculations)

Vendor	Vendor Document No.	
Owners Review By		Date

Calculation No. <u>H-02-0001</u> Page <u>i</u> Revision <u>0</u>

## List Of Effective Pages

Page	Rev	Page	Rev	_	Page	3	Re	v	Page	Rev
All Pages	0									
A 41 1										
Attachmen	ts									
Attach.	Rev.	No of	Attach.	Rev		No of		Attach.	Rev.	No of
Number		Pages	Number			Pages	5	Numbe	r	Pages
1	0	1	3	0		12		5	0	20
2	0	3	4	0		1				
Amendments										
Rev	No of	Rev	No of		Rev		No	of	Rev	No of
Letter	Pages	Letter	Pages	S	Lette	er	Pag	ges	Letter	Pages

## Table Of Contents

## Page No.

	<u> </u>
List of Effective Pages	. i
Table of Contents	. i
Revision Summary	. ii
Document Indexing Tables	. iii
Record of Lead Review	. v
Record of Interdisciplinary Review	. vi
Purpose	. 1
Conclusions	. 1
Body of Calculation	. 1
1 Methodology (if appropriate)	. 1
2 Design Inputs	. 2
3 Assumptions	. 4
4 Calculations	. 5
5 Results	. 5
References	. 5

#### **Attachments**

•

!

## Total Page(s)

1	Control Complex Room Temperatures at 24 hrs and 61 hrs following loss of	1
2	Appendix R Chiller Heat Exchanger Capacities	3
3	York Ducted Direct Drive Fan Coil Air Conditioners, Form 115.36-EG1 (490)	12
4	Mechanical Equipment Room Temperatures (SP-300)	1
5	Compare input file (20ton80degFall)	20

Amendments (NA)

.

Total Page(s)

Calculation No.

H-02-0001 ii

Page \_\_\_\_\_ Revision \_\_\_\_ 0

nevision Summary				
Revision	Revision Summary			
	(Include brief description of revision and a list of EC's and other modifications incorporated into revision)			
0	This is the original issuance of calculation H-02-0001.			

Povision Summary

ł

÷

.

Calculation No.

H-02-0001

Page iii Revision 0

## **Document Indexing Tables**

The following tables have been formatted to facilitate the entry of the document reference information into PassPort in accordance with Section 9.7.2 of RDC-NGGC-0002. This Attachment is a substitute for form RDC-NGGC-0002-003 and has been customized to be applicable to CR3 calculations.

The leftmost column of each table is provided to indicate the required data entry that is required, using the following codes: A = Add, M = Modify, D = Delete; a dash (-) is used to indicate no change is required.

## **Controlled Document Revisions**

## Tab 3. Reference Numbers [TIMC011]

Reference Systems (Enter two letter codes, one per line)

Action *	System
Α	AH
Α	CH

#### **Other References**

(Enter references that are not controlled PassPort documents)

Action	Туре	Reference 2004	Sub 💸	Title Contract and the second second second second
A	NPAS	MAR 82-10-		Appendix R Control Complex Dedicated Cooling
		19-09		System
A	NPAS	Letter#		CR3, License Amendment Request #271, One Time
		3F0802-03		24 hour delay for Entry into ITS 3.0.3 fore Two
		dated 8/15/02		Inoperable Control Complex Chillers.
A	NPAS			Fundamentals of Classical Thermodynamics.

## Tab 4. Document References [TIMC012]

٢

Controlled Documents with Cross References

(Enter controlled documents referenced in calculation including CALC's, DWG's, MGEN's, POM-OPS's, SPEC's, etc)

Action ·	Facility :	Doc Type 🖙	Sub Type	Document Design of the second s	Rev
A	CR3	DWG		FD-302-769	16
A	CR3	EDBD		Tab 8/10	10
- A	CR3	EDBD		Tab 8/15	6
A	CR3	Spec.		Improved Tech. Spec.	Amend. 202
A	CR3	Calc.		H-97-0001	7
A	CR3	Calc.		M-97-0020	1
A	CR3	Calc.		EEM-01-002	0
A	CR3	IM		#1388	0
A	CR3	ED		# 48703	0

Page iv Revision 0

### **Controlled Document Information**

۰.

## Tab 5. Related Equipment [TIMC014]

(Enter ED for equipment for which design or operation is impacted by results of calculation. Also enter ID of computer software programs used to prepare calculation, as Equip Type SFTAPL)

Action	Facility	Unit	System 🗇	Equip. Type	Equipment	Comp. Type	Componen
* v.	<u> </u>			· /			t
A	CR3	3	CH	HX	CHHE-2		
<u> </u>	CR3	3	AH	HX	AHHE-46		
A	CR3	3	AH	HX	AHHE-47		
Ā	CR3	3	AH	HX	AHHE-48		
A	CR3	3	AH	HX	AHHE-49		
Α	CR3	3	AH	HX	AHHE-50		
A	CR3	3	AH	HX	AHHE-51		
A	CR3	3	AH	HX	AHHE-52		
A	CR3	3	AH	HX	AHHE-53		
A	CR3	3	AH	HX	AHHE-54		
A	CR3	3	AH	HX	AHHE-55		
A	CR3	3	AH	HX	AHHE-56		
A	CR3	3	AH	HX	AHHE-57		
A	CR3	3		SFTAPL	Compare/		
					Modt-PC,		
					1.6		

## **Controlled Document Information – New Referenced By Entries**

(Enter the ID of documents that reference this calculation but that <u>do not presently list this calculation as a reference in PassPort</u>. Use a separate table for each document)

#### Tab 1. Information

Facility		Doci	ume	nt.Ty	pe	1.1	S	ub-	Тур	e	7		5	, ú
CR3														
Document	- 11	· · ·	`	14	-	1. A.	ź	ì	r \$	Ξ,	,	٦,ſ	2	٠.
												· · · - ·		

# Tab 3. Document References Facility Doc Type Sub Type Document Rev CR3 CALC This calculation Image: Calculation

#### Concurrence of document owner for this new reference

Signature	Name	Date

Calculation No.	H-02-000

Page v Revision 0

## **Record of Lead Review**

Désign	H02-0601			Revision 0	-				
The sigr J.th J.ar - th	<ul> <li>The signature of the Lead Reviewer records that:</li> <li>J. the review indicated below has been performed by the Lead Reviewer;</li> <li>J. appropriate reviews were performed and errors/deficiencies (for all reviews performed) have been resolved and these records are included in the design package;</li> <li>the review was performed in accordance with EGR-NGGC-0003.</li> </ul>								
	esign Verification Review Design Review Alternate Calculation Qualification Testing	🛛 Engineer	ing Review 🗌	Owner's Review	1				
🗆 s <sub>i</sub>	pecial Engineering Review		······································						
	S 🛛 N/A Other Record	s are attached							
D. Wise Lead Re	viewer (print)	(sign)	~	Mechanical Design Discipline	<u>8/2/02</u> Date				
ltem No.	Deficiency	1		Resolution	-				
1)	Comments Inc	orporated							
2)									
3)									
4)	-								
5)									
6)									
7)									
8)									

FORM EGR-NGGC-0003-2-5

.

÷

This form is a QA Record when completed and included with a completed design package. Owner's Reviews may be processed as stand alone QA records when Owner's Review is completed

	11-02-0	001
Calculation No	H-02-0	001

Page vi Revision 0

## **Record of Interdisciplinary Reviews**

Discip	oline/Program Review		Scope of Review ***		
Systems Engineering		<ul> <li>Concurrence with Design Inputs and Assumptions</li> <li>Impact of Results (on designs, programs, procedures)</li> </ul>			
Reviewer (name)		Signature		Date	
J. Taylor		An 07	Ann	8/2/02	
Item .	Comme	ent 🖅 🗤 🗤 💦	Resoluti	on XXX i i	
1	Comments incorporated				
2					
3					
4					

Discip	oline/Program Review	Scope of Review	``	
Operatio	Derations Concurrence with Design Inputs and Assumption Impact of Results (on designs, programs, proce			res)
Reviewe	er (name)	Signature/	, ⊂ ,D	ate
J. Hueck	(er	· Jonath When	21	02
Item	Comme	nt 🌾 🐘 👘 👘 Resolutio	nn Alei	. 19 N M M
1	Comprant incorpor	sted.		
2				
3				
4				

Disciplin	ne/Program Review 🚲	Construction of the second	Scope of Review	NY AND AND
Licensing		Concurrence w Impact of Resu	ith Design Inputs and Assu Its (on designs, programs, j	mptions procedures)
Reviewer (	(name) 💈 🎄 🛸 👾 🚓 🌾	Signature 7 A ()	A market in the second	, <b>Date</b> ∕
S. Powell		Major	vill	8202
ltem 🔪 🗠	Comme	nt 🕤 🖉 🖓 👘	🗅 🖈 之 🖉 Resolutio	n 244 (* 1841)
1 1	JO COMMESTS			
2				
3				
4				

.

Calculation No.

H-02-0001 Page 1 of 6 Revision 0

#### **Purpose:**

The purpose of this calculation is to determine the capacity of portable Air Conditioning (AC) that is required, along with the Appendix R Chiller (CHHE-2) and associated heat exchangers, to maintain Control Complex room temperatures below design temperature limits for a period of 61 hours.

The results of this calculation will support LAR# 271 (Ref# 8). LAR# 271 seeks approval to delay entry into Improved Technical Specification (ITS) LCO 3.0.3 up to 24 hours for failure to meet the requirement of LCO 3.7.18, Condition A (two Control Complex Chillers inoperable).

LAR #271 is a contingency for two inoperable Control Complex Chillers while planned Control Complex System (CCCS) chiller refurbishment is performed. Should both Chillers (CHHE-1A/B) become inoperable the Appendix R Chiller (CHHE-2), associated heat exchangers and portable AC will be utilized for a 61-hour period (24 hour LAR period + 37 hour LCO 3.0.3 to Mode 5 period) to maintain Control Complex Room temperatures below design limits.

The long term post-LOCA case (LOCA4E) contained in calculation H-97-0001 (Ref# 5) was utilized as a basis for this calculation with the deviations identified in the Design Inputs. Compare Modt-PC, version 1.6 software was utilized in this evaluation.

### **Conclusions:**

**20 Tons of portable AC capacity (sensible heat removal)** along with the Appendix R Chiller (CHHE-2) and associated heat exchangers is required to maintain Control Complex room temperatures below design temperature limits for a period of 61 hours. This time duration would provide 24 hours to repair the inoperable chiller and to obtain Mode 5 within the 37 hour requirement specified in ITS 3.0.3.

Also, this heat removal capacity shall be delivered with Turbine building environmental conditions as specified in design input # 2.11.

## Note: Without establishing additional cooling after 61 hours, Control Complex Temperatures continue to rise above values identified on Attachment 1.

## **Body Of Calculation:**

1. <u>Methodology</u>

As identified above, the long term post-LOCA case (LOCA4E) contained in calculation H-97-0001 (Ref# 5) and associated design inputs was utilized as a basis for this calculation with the exception of the deviations identified in the following design input # 2.1.

Also, the following time line is associated with this evaluation:

J

H-02-0001 Page 2 of 6 Revision 0

At T=0 minutes

- The unit is in Mode 1.
- The Control Complex (CC) Chillers CHHE-1A and CHHE-1B are out of service.
- Control Complex Ventilation System (CCVS) is not in operation.

At T=30 minutes

• Continuous recirculation (no outside air) of the Control Complex Ventilation System (CCVS) using AHF-17, AHF-19 and AHF-54 fans is established.

At T = 60 minutes

- The Appendix R Control Complex Chiller (CHHE-2), associated pump (CHP-2) and heat exchangers are in operation.
- Portable cooling AC is aligned to the Control Complex (Control Room) and in operation.
- The chilled water outlet isolation valves for the RB Penetration cooling heat exchangers AHHE-13A/B are closed. (Ref# 11 and DI# 2.12).

At T= 24 hours

• One CC chiller has been started or LCO 3.0.3 is entered.

At T=31 hours (24 hours + 7 hours)

• Plant is in Mode 3 if LCO 3.0.3 is entered

At T= 37 hours (24 hours + 13 hours)

• Plant is in Mode 4 if LCO 3.0.3 is entered

At T=61 hours (24 hours + 37 hours)

• Plant is in Mode 5 if LCO 3.0.3 is entered

#### 2. <u>Design Inputs</u>

- 2.1) The long term post-LOCA case (LOCA4E) contained in calculation H-97-0001 (Ref# 5) was utilized as a basis for the calculation with the exception of the deviations identified below:
  - In the LOCA4E case, the Control Complex ventilation fans are restored in 30-minutes post-LOCA and the Control Complex Chiller is restored in 120-minutes post-LOCA. The Control Complex chillers (CHHE-1A/B) remain out of service for the entire run and are not credited for heat removal or heat addition to the Mechanical Equipment Room.
  - Portable AC will provide constant Control Room heat removal and is in operation 60 minutes from the loss of both chillers (T=0).
  - The Appendix R Chiller heat exchangers are modeled as temperature dependent heat removal, based on cooling coil datá and chilled water flow rates (See attachment 2), and will be in operation along with the Appendix R Chiller 60 minutes from the loss of both chillers (T=0).
  - The initial temperature for the Mechanical Equipment Room and Control Complex Emergency Fan Cooler Unit (AHF-18A/B and AHF-19A/B) is 80 °F. This DI is justified by
Calculation No.

H-02-0001 Page <u>3 of 6</u> Revision <u>0</u>

attachment 4 which identifies that the Mechanical Equipment Room has been maintained below 80 °F since 4/00 (SP-300 data).

- 2.2) The Appendix R Chiller/ associated heat exchangers and portable AC are required to remove sensible heat from the Control Complex.
- 2.3) ITS (Ref# 8), LCO 3.0.3 identifies that if a LCO can not be met the unit shall be placed in a mode or condition that the specification is not applicable. Action shall be initiated in 1 hour to place the unit in Mode 3 in 7 hours, Mode 4 in 13 hours and in Mode 5 in 37 hours.
- 2.4) Deleted
- 2.5) Control Complex cooling (CHHE-1A and CHHE-1B) is not required to maintain Mode 5 or achieve Mode 6 per LCO 3.7.18 (Ref # 8).
- 2.6) The Appendix R chiller has a rated capacity of 1,125,000 BTU/Hr (approx. 94 tons) and a required capacity of 589,458 BTU/hr (approx. 49 tons). (Reference # 3).
- 2.7) Chilled water (45 °F) is delivered by the Appendix R Chilled Water System to the EFIC rooms, Battery Charger Rooms A and B, Inverter Rooms A and B, 4160V Switchgear Rooms A and B, the Remote Shutdown Room, and the 480V Switchgear Rooms. (Reference # 3). Heat load is removed from each room by the following heat exchangers that interface with the chilled water supplied by CHHE-2. Flow rates and required cooling loads are provided. (Reference #2,3 & 4).

Room	Heat Exchanger	Heat Exchanger	Chiller Water	Cooling
	Tag	Model #'s	Flow Rate	Required,
		(York)	(GPM)	Btu/Hr.
EFIC Rooms	AHHE-44	ACH-182	37	182,358
		(Ellis & Watts)		
Batt. Charger	AHHE-46	DEV-6 (3R)	3.0	6,000
Room A				
Batt. Charger	AHHE-47	DEV-6 (3R)	3.0	6,000
Room B				
Inverter Room A	AHHE-54/55	DEV-14 (6R)	12.0/Hx	70,000
Inverter Room B	AHHE-56/57	DEV-14 (6R)	12.0/Hx	89,500
4160V	AHHE-48	DEV-12 (4R)	6.0	30,000
Switchgear				
Room A				
4160V	AHHE-49	DEV-12 (4R)	6.0	30,000
Switchgear				
Room B				
Remote	AHHE-45	DEV-6 (3R)	3.0	8,600
Shutdown Room				
480V Switchgear	AHHE-50/51	DEV-14 (6R)	8.0/Hx	83,500
Room A				
480V Switchgear	AHHE-52/53	DEV-14 (6R)	8.0/Hx	83,500

Calculation No.

H-02-0001 Page 4 of 6

Revision 0

Room B			
	Total	101+37=138	589,458 (49
			tons)

- 2.8) Per IM# 1388 (Ref # 12), the York Model DEV Air Conditioners are direct drive units where vertical discharge is needed. The model number denotes the following characteristics:
  - DEV: Ducted, Exposed Vertical discharge
  - Size: 06 = 600 CFM, 12 = 1200 CFM, 14= 1400 CFM
  - Coils: 3R = 3 row coil, 4R = 4 row coil, 6R = 6 row coil

Cooling capacities are computed in attachment 2.

- 2.9) The temperature limit for CC rooms that is required to ensure equipment qualification is 95 °F for the Control Room and EFIC Room C, 110 °F for the Mechanical Equipment Room and 104 °F for all remaining CC rooms. (Ref # 6) The Mechanical Equipment Room temperature of 110 °F is utilized based on justification in attachment 3 (Ref # 6) that identifies that AHF-17 and AHF-19 are bounded by 110 °F.
- 2.10) The Appendix R Chiller (CHHE-2), associated heat exchangers/fans and the portable AC to be utilized are non-safety components. The Appendix R.Chiller can be powered from emergency diesel generator. (Ref# 11). However, portable AC will not have this capability.
- 2.11) Portable AC will be directed through the Control Room vestibule door located on the East end of the 145' elevation of the Turbine Building. Per reference # 7, this area was recorded at 103 °F DB and 86 °F WB (approx. 50% RH). Therefore, portable AC shall be capable of supplying the required sensible capacity (Tons) at these environmental conditions.
- 2.12) Per ED 48703 (Ref # 11), RB penetration cooling can be isolated short term. If air temperatures were to exceed 200 °F actions should be taken to drive the temperatures down. However, plant shutdown should be triggered at 350 °F.
- 3. Assumptions
- 3.1) Plant configuration will be maintained through CP-140 or appropriate controls.
- 3.2) All Control Complex rooms are initially maintained at 80 deg F.
- 3.3) Discharge temperature of the Appendix R Chiller (CHHE-2) is maintained at 45 °F or below.
- 3.4) Appendix R Chilled Water System heat exchanger flow rates are maintained as specified in MAR 82-10-19-09.

Calculation No. <u>H-02-0001</u> Page <u>5 of 6</u> Revision <u>0</u>

3.5) The Appendix R Chiller and the identified portable AC can be aligned 1 hour from loss of both Control Complex Chillers (CHHE-1A/B). Utilization of plant procedures MP-193 Rev 29 Titled "Temporary Cooling to the Control Complex" and OP-409 Rev 54 titled "Plant Ventilation System" this alignment is valid per discussions with Operations personnel.

## 4. Detailed Calculations

See Methodology section above.

## 5. <u>Results</u>

The following files and attachment 1 document the results of this evaluation:

Input File	20ton80degFall
Output File	20ton80degFall.out
Plot File	20ton80degFall.plt
Graph Files	20ton80degFall.graph1
	20ton80degFall.graph2
	20ton80degFall.graph3

As identified, the Appendix R chiller, associated heat exchangers and the portable AC are required to maintain Control Complex Room temperatures below their design limits for a 61 hour period. This time duration takes into consideration the 24 hours addressed in LAR# 271 and the 37 hours required to obtain Mode 5 per ITS 3.0.3.

The tabulated results contained in attachment 1 identify that 20 tons of AC (Sensible Heat Removal) will maintain all Control Complex Rooms below their design limits specified in design input #2.9. The Control Room and the EFIC Room C will be maintained below 95 °F, the Mechanical Equipment Room will be maintained below 110 °F and the remaining Control Complex rooms are maintained below 104 °F.

Also, the 20 Tons of AC shall be delivered with Turbine building environmental conditions as specified in design input # 2.11.

## **<u>References:</u>**

- 1.) FD-302-769 Rev 16, Appendix R Chilled Water.
- 2.) DBD Tab 8/10 Rev 10, Titled "Control Complex Air Handling System"
- 3.) DBD Tab 8/15 Rev 6, Titled "Chilled Water System"
- 4.) MAR 82-10-19-09, Titled "Appendix R Control Complex Dedicated Cooling System".

Calculation No. H-02-0001 Page 6 of 6 Revision 0

- 5.) Calculation H-97-0001 Revision 7, Titled "Control Complex Transient Temperature Response"
- 6.) Calculation M-97-0020 Rev 1, Titled "Control Complex Heat Load Evaluation"
- 7.) Engineering Evaluation EEM-01-002 Rev 0, Titled "Refined Inputs for H97-0001/ MECH-0094 Rev 6
- 8.) Improved Technical Specification (ITS), Through Amendment 202.
- 9.) Florida Power Letter 3F0802-03 dated 8/15/02. CR3, License Amendment Request # 271, One time 24 hour delay for Entry into ITS 3.0.3 for Two Inoperable Control Complex Chillers.
- 10.) Fundamentals of Classical Thermodynamics, Wylen & Sonntag, Second Edition.
- 11.) ED 48703, Evaluation of Control Complex Chiller for NOED during CHHE-1B refurbishment.
- 12.) IM # 1388 Revision 0, Titled "Fan Coil Air Conditioners".
- 13.) Compare Modt-PC version 1.6 software.

#### Calculation H-02-0001 Rev 0 Control Complex Temperatures Attachment 1

Control Complex Room Temperatures								
		Tomp E @	Temp - F,					
		24 hrs.	Mode 5.					
Volume		20 ton AC	20 ton AC					
Number	Description							
1	Control Room (Elev. 145')	85.5	94.4					
2	Kitchen, Break, Corridor (Elev. 145')	90.8	100.3					
3	Cable Spreading Room (Elev. 134')	88.4	97.1					
4	CRD (Relay) Room (Elev. 124')	89.6	95.3					
5	EFIC Room A (Elev. 124')	87.6	91.5					
6	EFIC Room B (Elev. 124')	85.3	89.3					
7	EFIC Room C (Elev. 124')	82.8	86.5					
8	EFIC Room D (Elev. 124')	89.4	93.5					
9	480V Switchgear Room A (Elev. 124')	80.9	85					
10	480V Switchgear Room B (Elev. 124')	82.5	86.7					
11	General Area by Elevator (Elev. 108')	87.6	94.9					
12	Remote Shutdown Room (Elev. 108')	71.8	75.4					
13	Battery Room A (Elev. 108')	91.0	98.6					
14	Battery Room B (Elev. 108')	92.0	99.5					
15	Battery Charger Room A (Elev. 108')	86.4	91.6					
16	Battery Charger Room B (Elev. 108')	88.6	94.5					
17	Inverter Room A (Elev. 108')	82.5	86.2					
18	Inverter Room B (Elev. 108')	84.2	88.4					
19	4160V Switchgear Room A (Elev. 108')	83.3	88.8					
20	4160V Switchgear Room B (Elev. 108')	85.3	91.7					
21	Stairwell (Elev. 95' to 198')	89.6	97.9					
22	Supply Air Plenum Above Control Room	91.4	100.1					
25	Mechanical Equipment Room (El. 164')	101.4	108.9					
	Bulk Average Temperature	86.9	92.9					

,

#### Calculation H-02-0001 Revision 0 Appendix R Heat Exchanger Capacites Attachment 2

The method utilized to determine the sensible heat removal capabilities for the following York Direct Drive AC Units has been taken from vendor Form 115.36-EG1 (490). (Attachment 3). Cooling Capacities are determined by the specified GPM method.

Attached cooling selection curves, the known entering water flow rate and the following formula are utilized to obtain the sensible heat capacity using an iterative process.

GPM = TMBH/(WTR X .5)

\* ...

GPM = Entering water flow rate TMBH = Total heat removal capacity (x 1000), Btu/hr WTR = Water Temperature Rate. SMBH = Sensible heat removal capacity (x 1000), Btu/hr SBS = Sensible heat removal capacity, Btu/sec

Capacities for each unit is determined under the following Control Complex Room temperatures:

Room Temp., DB Temp. °F	WB Temp °F	% RH
72	63	65
84	67	45
92	71	35
104	75	26

## Calculation H-02-0001 Revision 0 Appendix R Heat Exchanger Capacites Attachment 2

## 1). York AC Unit DEV-6 (3R), 600 CFM, 3 gpm @ 45 °F

Control Complex Rooms:

Battery Charger Room A, Tag # AHHE-46 Battery Charger Room B, Tag # AHHE-47 Remote Shutdown Room, Tag # AHHE-45

Room Temp, DB (°F)	Room Temp, WB (°F)	WTR, °F	TMBH	GPM	SMBH	SBS
72	63	8	11.7	2.93	9.4	2.61
84	67	10	14.4	2.88	13.1	3.63
92	71	12	18.4	3.06	15.6	4.33
104	75	15	20.6	2.74	19.8	5.5

2). York AC Unit DEV-12 (4R), 1200 CFM, 6 gpm @ 45 °F

Control Complex Rooms:

4160V Switchgear Room A, Tag # AHHE-48 4160V Switchgear Room B, Tag # AHHE-49

Room Temp, DB (°F)	Room Temp, WB (°F)	WTR, °F	TMBH	GPM	SMBH	SBS
72	63	10	27	5.4	21.5	5.97
84	67	12	35.5	5.91	31.5	8.75
92	71	15	42.5	5.6	35	9.72
104	75	17	50.5	5.94	44	12.22

## Calculation H-02-0001 Revision 0 Appendix R Heat Exchanger Capacites Attachment 2

3). York AC Unit DEV-14 (6R), 1400 CFM, 8 gpm @ 45 °F

Control Complex Rooms:

480V Switchgear Room A, Tag # AHHE-50/51 480V Switchgear Room B, Tag # AHHE-52/53

Room Temp, DB (°F)	Room Temp, WB (°F)	WTR, °F	TMBH	GPM	SMBH	SBS
72	63	11	44	8	58 (2 x 29)	16.11
84	67	14	52	7.42	82 (2 x 41)	22.77
92	71	16	64	8	98 (2 x 49)	27.22
104	75	19	74	7.79	136 (2 x 68)	37.77

4). York AC Unit DEV-14 (6R), 1400 CFM, 12 gpm @ 45 °F

Control Complex Rooms:

Inverter Room A, Tag # AHHE-54/55 Inverter Room B, Tag # AHHE-56/57

Room Temp,	Room Temp,	WTR,	TMBH	GPM	SMBH	SBS
	WB (-F)	-F				
72	63	8	49	12.25	62	17.22
					(2 x 31)	
84	67	10	59	11.81	90	25
					(2 x 45)	
92	71	12	72	12	104	28.88
					(2 x 52)	
104	75	14	85	12.14	142	39.44
					(2 x 71)	

TEL-813 626 8807



FORM 115.35-EG1 (490)



YORK TAMPA

P. 002/008

## EXPOSED MODEL FEATURES



## MODEL DE

The Model DE Ducted exposed unit is designed for installations where the unit and its ductwork are visible to the occupants, such as in work areas and commercial areas The unit has an 18-gauge galvanealed steel enclosure with 1/2inch coated glass fiber insulation meeting NFPA-90A requirements. The unit has a completely removable bottom panel for access to the valves and piping. The front panel has a 1-inch supply air duct collar and the rear panel has a 1-inch return air duct collar with an integral filter rack.

The fan assembly, consisting of either one or two directdrive, motor-blower assemblies, with large-diameter, forward-curved blower wheels, is statically and dynamically balanced. Torsion-flex-mounted motors and balanced fan wheels assure smooth, quiet performance.

The drain pan is made of 18-gauge galvanized steel. Its interior and exterior surfaces are sprayed with a closed-cell, polyurethane insulation. A drip lip is available for control of condensate from valves and piping.

A throwaway-type 1-inch glass fiber filter is standard. Cleanable filters are also available.

The Model DEL unit is the DE unit as described above except with supply and return air grilles and low static motor(s). The Model DEL is finished in an attractive oven baked paint. The Model DEL is not available with filters.



The Model DEV exposed vertical unit is designed for installations where vertical discharge is needed, such as in a utility closet. The unit is completely enclosed in an 18-gauge gelvanized steel cabinet. The top panel has a 1-inch supply air duct collar. The cabinet is acoustically and thermally insulated with 1/2-inch coated glass fiber insulation meeting NFPA-90A requirements. The front panel is easily removed to provide complete access to the coil and the motor-blower assembly, and to allow removal of the standard 1-inch glass fiber throwaway filter. Cleanable filters are available as an option.

The drain pan is made of 18-gauge galvanized steel, sprayed inside and outside with a closed-cell, polyurethane insulation.

The fan assembly, consisting of either one or two directdrive motor-blower assemblies, with large-diameter, forwardcurved blower wheels, is statically and dynamically balanced. The motor-blower assembly may be easily removed for complete servicing. Removal of the motor-blower assembly exposes the entire entering face of the coil for cleaning. Low-RPM torsion-flex-mounted motors and balanced fan wheels assure smooth, quiet performance.

	Calc. H-02-0001 Rev 0	-
ł	Attachment 3	
i	Page Z of 1Z	•-

YORK APPLIED SYSTEMS

3

TEL·813 626 8807

# MECHANICAL SPECIFICATIONS

### PERFORMANCE DATA

CAPACITIES – Unit capacities are certified in compliance with Air Conditioning and Refrigeration Institute Standard 440.

SAFETY – Units listed with Underwriters Laboratory (6) Standard 883 and Canadian Standards Association (7).

#### **BASIC UNIT**

The basic DC is fabricated of galvanized steel. Provision for hanging the unit is provided by slots in the top of the housing. A one inch discharge duct collar is furnished.

The condensate drain pan is lined with closed cell, fire retardant, foam insulation. Water never touches the metal pan, thus the possibility of corrosion is minimized. Every horizontal unit is available with an optional drip lip at the coll header end of the unit to provide positive control of condensate when control valves are used. The motorblower assembly is designed for easy removal from the basic unit for servicing. This also provides access to the entering air face of the coil for easy cleaning.

#### CABINET

Horizontal and Vertical Cabinet Models DE and DEV have galvanized steel panels acoustically and thermally insulated with ½ inch glass fiber.

Horizontal Model DE Units have removable side panels for access to motor blower assembly, valves and piping. The front and rear panels have one inch duct collars for return air and supply air duct connections.

Vertical Model DEV Units have a removable front access panel to provide access to coil and motor blower sections. The top panel is provided with a one inch discharge duct flange.

#### COILS

Coils have ½ Inch O.D. copper tubes with aluminum fins mechanically bonded to the tubes. All Coils are leak tested air under water and are suitable for design working pressures of 250 psig @ 200 degrees F and 400 psig @ 100 degrees F.

A variety of coll selections are available. The standard coil provides adequate capacity for most installations with an eight to ten degree design water temperature rise. A high capacity coll is offered for those installations requiring the higher latent heat capabilities or those designed for a twelve-degree water temperature rise. Also offered is a four-pipe coll consisting of standard or high capacity cooling with one and two rows of heating surface.

Optional steam coils are available and are suitable for working pressures of 15 psig.

#### FILTERS

All cabinet model units have 1 inch throwaway filters furnished as standard equipment. Cleanable filters are optional except on DEL.

#### FANS

The fans are centrifugal, forward-curved, double-width wheels. Blower housings are gaivanized steel with special rolled perimeter seams to provide added rigidity

#### MOTORS

All motors are resilient mounted, three speed, with UNDER-WRITERS listed thermal overload protection. Motor bearings are of the sleeve type or ball bearing type with oversized oil reservoirs provided to assure positive lubrication with minimum servicing required. Positive speed reduction is assured through careful matching of motor torque to blower loading. Standard motors are permanent split capacitor.

> Calc. H-02-0001 Rev 0 Attachment 3 Page 3 of 12



Calc. H-02-0001 Rev 0

Attachment 3

Page 4 of 12

## COOLING SELECTION HYDRONIC COOLING UNIT

NOTE All capacities (Ot and Os) in these examples are expressed in thousands of BTU/hr. (MBH)

A. SELECTION FOR SPECIFIED TOTAL COOLING

Specified Performance 450 CFM at 0.10" ESP 13.8 TMBH/9.2 SMBH 75 DB/65 WB Entering Air 3.5 GPM (Max.) at 42 Entering Water

- 1. From Air Delivery table, page 10, a Unit Size 06 will deliver the specified 450 CFM at .10 ESP. (A DC unit, for example, is capable of as much as 740 CFM at that condition, operating at high speed. with a 3 row coil.
- 2. The Hydronic Capacity Correction Factors are determined from the chart on page 11 using the Unit Size and specified air delivery. 1 . . .

Example:

Size 06 Unit at 450 CFM -Ct=0.82 Cs=0.80

З. Determine the base total capacity by dividing the specified total capacity by Ct

Example: 13.8 TMBH Qt (base) = Qt<sub>b</sub> = ----- = 16 8 TMEH 0.82

- 4. First, try using the 3 row coil. Enter the capacity chart'(reproduced on page 7) at the base total capacity (16.8 TMBH) and read up to the entering wet bulb temperature (65 EWB in example).
- 5 Read horizontally to the right to the entering water temperature (42 EWT in the example).
- 5. Read up to the Water Temperature Rise scale to determine the water temperature rise (WTR = 7.9).
- 7. Determine the actual sensible cooling capacity by reading from the intersection point of the base total capacity (Qt<sub>b</sub>) and the entering wet bulb temperature (EWB) horizontally to the entering dry bulb temperature (75 EDB in example).
- Read down to the MBH capacity scale to determine the 8 base sensible capacity ( $Qs_b = 12 SMBH$ ).
- 9 Calculate the actual sensible capacity (Qs) by multiplying the base sensible capacity by Cs

$$Qs = Qs_b \times Cs$$

Qs = 12 SMBH x 0.80 = 9.6 SMBH

10. Calculate the actual GPM by using the formula below:

11. The water pressure drop (WPD) may now be read from the pressure drop curves (page 25).

3.48

#### **B. SELECTION FOR SPECIFIED SENSIBLE COOLING**

Specified Performance 450 CFM at 0.10" ESP 11.0 TMBH/8.4 SMBH 75 DB/65 WB Entering Alr 2.5 GPM (Max.) at 42 EWT

Select a unit and determine the actual unit air delivery 1. and total and sensible air delivery correction factors. using the methods outlined in Steps 1 and 2 for the total cooling selection procedure (A).

Example: Unit Size 06 delivering 450 CFM at 0.10" ESP

Ct = 0.82	
Cs = 0.80	

2. Determine the base sensible capacity by dividing the specified sensible capacity by Cs.

Example:

Qs (base) = 
$$Qs_b = \frac{8.4 \text{ SMBH}}{0.80} = 10.5 \text{ SMBH}$$

- 3. , Enter the capacity chart (reproduced on page 7) at the base sensible capacity (10.5 SMBH) and read up to the entering dry bulb temperature (75 EDB in example).
- Read right horizontally to the entering water tempera-4 ture (42 EWT).
- 5. Read up to the Water Temperature Rise scale to determine the water temperature rise (WTR = 12).

6



![](_page_48_Figure_1.jpeg)

MAR -13'02 (WED) -15 -45

![](_page_48_Figure_2.jpeg)

6 From the intersection point of the base sensible capacity and the entering dry bulb temperature found In Step 3 read horizontally to the entering wet bulb temperature (65 EWB in example).

YORK TAMPA

- 7. Read down to the MBH capacity scale to determine the base total capacity (Qt, = 13.6 TMBH).
- 8. Calculate the actual total capacity by multiplying the base total capacity by Ct.

$$Qt = Qt_b \times Ct$$

Qt = 13.6 TMBH x 0.82 = 11.2 TMBH

9. Calculate the actual GPM by using the formula below.

![](_page_48_Figure_9.jpeg)

10. The water pressure drop (WPD) may now be read from the pressure drop curves (page 25).

TEL: 813 626 8807

## C. UNIT RATING FOR SPECIFIED GPM

40

Specified Performance. Unit Size 06 450 CFM at 0.10" ESP 75 DB/65 WB Entering Air 3.0 GPM at 42 Entering Water

1. Determine the actual unit CFM and the total and sensible air delivery correction factors as in Steps 1 and 2 for the total capacity selection procedure (A).

Example: Unit Size 06 delivering 450 CFM at 0.10" ESP

٠.,

$$Ct = 0.82$$
  
 $Cs = 0.80$ 

## **COOLING SELECTION**

Calc. H-02-0001 Rev 0 Attachment **3** Page **6** of **12** 

## NOMINAL 600 CFM - 3 ROW COIL

![](_page_49_Figure_6.jpeg)

TOTAL & SENSIBLE CAPACITY - MBH

 Arbitrarily select a TMBH and apply Ct to obtain a beginning base total capacity (Qt<sub>b</sub>).

Example: Assume TMBH = 12.3

 $Qt_{b} = \frac{12.3 \text{ TMBH}}{0.82}$ 

 $Qt_b = 15.0 \text{ TMBH}$ 

- Enter the capacity chart reproduced above at the selected base total capacity (15.0 TMBH) and read up to the entering wet bulb temperature (65 EWB in example).
- 4. Read right horizontally to the entering water temperature (42 EWT in the example).
- 5 Read up to the Water Temperature Rise scale to determine the water temperature rise (WTR = 10.3).
- 6. Calculate the actual GPM for the selected TMBH by using the formula.

$$GPM = \frac{12.3 \text{ TMBH}}{12.3 \text{ CPM}} = 2.39$$
$$10/3 \times .5$$

- Since 2.39 does not match the specified 3.0 GPM, another TMBH must be selected and Steps 2 through 6 must be repeated until the required GPM calculated in Step 6 matches the specified GPM. (A TMBH of 13.3 results in a GPM = 3.0, the specified GPM).
- 8. Once the specified GPM is matched and the total cooling capacity is known, the actual sensible capacity may be determined using Steps 7, 8, and 9 of the total capacity selection procedure (A).
- 9. The water pressure drop (WPD) may be read from the water pressure drop curves (page 26).

![](_page_49_Picture_21.jpeg)

c

Calc. H-02-0001 Rev 0 Attachment 3 Page 7 of 12

D. UNIT RATING FOR SPECIFIED WATER TEMPERATURE RISE

> Specified Performance: Unit Size 06 450 CFM at 0.10" ESP 75 DB/65 WB Entering Air 15 WTR at 42 Entering Water

 Determine the actual unit CFM and the total and sensible air delivery correction factors as in Steps 1 and 2 for the total capacity selection procedure.

Example: Unit Size 06 delivering 450 CFM at .10" ESP

$$Qt = 0.82$$
  
 $Qs = 0.80$ 

- Enter the capacity chart (reproduced on page 8) at the specified water temperature rise (15 WTR) and read down to the entering water temperature (42 EWT).
- 3. Read left to the entering dry bulb and wet bulb temperatures then down to the MBH scale to determine the base sensible and total capacities respectively  $(Qt_b = 11.4 \text{ TMBH})$  and  $(Qs_p = 9.4 \text{ SMBH})$ .
- 4. Calculate the actual total and sensible capacities by applying the air delivery correction factors

Total:  $Qt = Qt_b \times Ct$ 

Qt = 11.4 TMBH x 0.82 = 9.3 TMBH

Sensible:  $Qs = Qs_b x Cs$ 

 $Qs = 9.4 \text{ SMBH} \times 0.80 = 7.5 \text{ SMBH}$ 

5 Calculate the actual GPM by the formula:

Example:

$$GPM = \frac{Qt}{WTR \times .5}$$

$$GPM = \frac{9.3 \text{ TMBH}}{15 \times .5} = 1.24$$

 The water pressure drop (WPD) may be read from the water pressure drop curves (page 25).

YORK TAMPA - TEL: 813 626 8807 - TEL: 813 626 Calc.

W -12. 05 (MED) 10 25

Page 8 of 12 Attachment 3-Calc. H-02-0001 Rev 0

872

....

\_..\_

YAAVIJAD AIA

	and res. F. The retings above include filter and/or grifter where applicable, i.e. DCP, DE, and DEV. 2. The retings above include filter and/or grifte where applicable, i.e. DCP, DE, DEL and DEV.												
-	- 1	-	- 1	0531	029.	(A 41	QF61	0031	6771				
	2. 书,注云:	/	<u>2 * 2 -</u>	-pite	1150	1 0051		1950: 2 19	3601		00	<u>_</u>	
				1500	1500	1450	0150	UIUI	048			<u>*</u>	
5-2 E.	Z ID HIT	<u> </u>	1= m2 = m		0011	1310 - 1	UUVI		7 599 7	•,-	31	<u></u>	
	-	-		900	0001	0311	0611	959	944	- won		<u>is</u>	
		51 100 mm		· 012	092	- 088	- 046.	592-	1 1 1		5 015		
1.75				P30	202	072	002	610 F	191		80	्य	
There are					F . 1120	009	059	- 0497.	- Stilt -		90 -		
1.2	3			0021	0971	G161	0002	0441	1500		50	~	
	<u> </u>	<u> </u>			- DPSL	0291	1.0021	- · · SBPL7	-1 UP11		- 181		
1					08.1	0871	0251	0201	080		91		
				0501	0201	0/11	0571	- 0601-	069		· · p1	-	
i		····	1-1	DOB-		- 005	066	316	362		15	חבר 🗋	
	-			069	130	0/2	0000	068	579:	- *	01		
1	21.14 3	1 = 2.5			005		0/9	999	094		80		
	-	-		09/1	OLRI	0161	5010				90	21	
	41 Tet-	•		1250	0051	. 00/1.	0061	5055		_{	50	_	
			-	0901	1420	0151	0651	5901	299		- 81 /	4	
	·········	<u> </u>	<u>a</u>	0971	2 01Ci	1100	0171	SDIL		-	91	-	
				1080	1150	0611	1540	096	018	woĦ	71		
- Anna		··· [ -··· -·· -··	<u> </u>	, -010	- 000	056	10201	1- 509	r +D99 -	- E	01	-1	
tom. att.				012	012	022	620	949	061		90	4	
	0/21	0151	0/41	0011	009			- 425	. 401-		- 190 - 2	ゴ	
· ·	0111	: , 0/CI	DPST.	1. 10191	0441	0261	5130	0921	0461		50	1	-
	070	1580	11(9)	1250	0801	0171	1 0061.,	5291/	99212	-1		]	
		1. 0211.	1 0001,	1300. 1	. 1450 .	0101	////	15921	56/		16	1	
	087	085	1150	0811	1540	1 0901	1480	Coll	002		P1	4	
	- 850, °S	1 092	- 098 -	830 -	060	01.01	0201	249	- 069		21	-	
	007	065	007	0172	061	998	046	021	095	4 1	80	-{	
	· · · · · · · · · · · · · · · · · · ·	017,	- <u>- 209.</u>	. 0+5 .,	025	1 . 019	012 .	- 025	/· 500-	<b>.</b>	5 90 11	-	
	0001	0291	0221	0581	1920	5050	5550	01.81	1400		DZ	-	
	1500	001	0161			0061.	5030	. 6C91	1 0001 -	7	· . 84	1	
= -= -= -= -= -= -= -= -= -= -= -= -=	10201	1540 2	ORCL -	0081	0291	CORT	0191	5185	832		91	1	
501	350	0201	1300	0/21	0091	1 0291	- 100/1 -	1305	825	- won	· • •	ΔEV	
- 090			. 096	0101	0/01	0501	0651	1515	5001		15	DE	- 1
096	055	029	092	062	079	I DOIN	0/1	0000-	- 514	_		006	1
- 082	-1- U8C	025,	· · · · · · · · ·	085	, ' 620	259	08/ / .		525	-	80	1	1
0271	0151	0291	0681	OUD F	0961	5100	5710	0081	SIVI			4	
3 11 15	07EL*	1- 0191	- D881 4		QLBL.	OPGI	C103>	. 1230 1.	1330			{ ·	
	0811	000	DHSI	1910	0121	1610	0/61	SPEL	6C0	-	91	ł	
084	086	0211	0093		1 0241	. 0991	. 08LL .	1332 .		7	N . 14	1	
	018. 1	016	006	0001	091.1	1480	1000	1510	5101	พอม	15		1
027	DP2	004	08/	079	0041	CY11 .	. 0211	. 558-	- 552	_ c	- + 0L: 1, 4	1	
			D/S. /	- 009	1 099	017	086	010	065	1	60		
-	1430	0291	1850	0891	0261	0907	1 001	01.9	985	·	90, * .		
	028L.,	. 0931.;	+ 0244 5	- 0621	0581	0861	1 0112	0.001	5261	4	50		7
	0111	0581	0151	0651	0091	0181	04-1	1 0.521 r	Fr. 2364 14	-	e1		
J - P. V.	+ - 016	- +0211-	-1310 - 1-	1.1380	- 0581	0691-4	DELL	0051	-1- D29	4	91		
	058	Dep	0601	CCLI	6911	0231	1 0901	5501	500	4 ~~08			
	1 150-	T -089	1. 4030+	- 0601	J CTLI	0211		- 920	- 992	e 1			
energi ma r	L. 1050	1 012	009	078	018	070	0101	916	009	1.			
1300	0091	DR/1	0061	- 065. ACL:	. 029	//85 .	- 002 1	566-4	- 505	1			
1510	- 0001	-0/96	D191 -		0.02	5212	5270	O#B1	5001		50		
1000	1580	DATI .	0191	0891	()C71	0602	~ 5500	0081	0211. 1	]	B1-+ -		
12 088 - 14	4.5.,0111	2 0/21		- COPL-		0081	5030	SOLI	5/P	ł	91		1
· 062	056	0901	0511	0071	Grai	0101		1 95LL -	90V : *				1
1 00L/72	~ QTR	···· 028 1		2 0911	. 0121	0021	- 0021 -	0011	576		13	20	1
CIVS	049	022	OSU	C69	056	Den	0461	0204	<u>'*-'#UB デ</u>	7	01-: -,		
1. 1996 . P.	·		<:V09:		. 099	0.2					60		
1430	0294	1950	0761	0661	5020	5160	0122	5/84	SEPT	<b>-</b>			
- 0581,51	. 0331 ~	-1120 -	<u></u>	1250	<u> </u>	2120	. 2220-	4681	5511				
300		0151	0991	0021	0081	0701	0R0Z	0751	000	ł			
059	000	ريني المالية مع المحمد المحمد الم		- 0.41	- 0631 -	0621	- 0/91			ļ.	915		1
	- LIH	0001	DITL 2 ONLE	1520	0.21	0961	US#1	5211	508	wofi	15		
065	011	009	0/8	216	1540	0961	- 1300	3 SIDI 1	- 509-	c i	10172		1
	- 04		- 020	050 .	000	0101	DAGI	506	249	ł	60		
09.0		<u></u>		<u> </u>	- 408	U72 :	, COS	31.9	SV5	ſ	90 -		1
	100	070	050	52.0	02.0	010	HOIH	MED	MOT	COIL	3ZIS	NODEL	1
		DETA	DIGNI 'd'	5'3 @			CHIED		S NHJ				1
		CEW	<b>U334S-H</b>	HICH							TINU		1
								ເວສູບູບ@	UEW			1	1 -

![](_page_51_Picture_5.jpeg)

Calc. H-02-0001 Rev 0 Attachment 3 Page 9 of 12

## **CORRECTION FACTORS**

## HYDRONIC CAPACITY CORRECTION FACTORS – TOTAL ( $C_t$ ) and SENSIBLE ( $C_s$ )

		1	UNIT SIZE															
i				<u> </u>		T			,								_	
	ACTUAL	AL 08		80			10		12		14		16					٦
	CFM	C	1 Ce		1 0-	+	17	+				_			10		20	
	1.07		1 1 2 2 3	1	1.477	1 Ct	C3		Cs	Ct	Cs	Ct	. Cs	Ct	Cs	Ct	L Ca	7
			1 SSE							4 33			1	1232	1157	ice:	19630	đ
	150	1251		1.1.1.				12.5										1
Ī	175		<u>, 12 ( </u>		1:-2:		· · · · · · · · · · · · · · · · · · ·	<u> </u>		14-28				17-2	1-22			1
	200	0.46	0 41	1 =			-	-	-	-	-	1 -	-	- 1	- 1			7
	225	051	0 45	-	- 1			1 -		-	-	-	-	-	-	_	_	
ļ.	250	0.56	0.49	1.5	192250		12.52		L Partiers	12720	1 12-1-2-2	1 3945	-		<u>  -</u>	-	-	
ľ	e	×0'58	0.53	0.47	0.42 ,							4823			No.		L'ART CAL	1
┢		- 0 827	10.67	120 51	0 45	· 0 43 -	70:35	-12 M					出示	1.5				
	350	0.89	0.65	0.57	0.50	0.48	046	-	-				1211-12-12	efelet in	口的层			1
	450	076	073	0.62	0.57	0 63	0 47	0.46	041	- 1		1 -	1 - 1		-	-	-	
	500 500	10.02		007	1 0 6 3	0.58	0.52	051	0 45	-				_	1 -			l
	550	0.95	20.02	0.77-	0.69	0,62	-0.57.4	- 0.55 -	-0.47		6-1-1-1		1.42		····	11-2-34	1.12.18	
11 1	-`***600 <sup>-</sup> *;∃¥;	1:501:	7.00	0.32	-080	-020,- -0707	1067	0.54	0.53	0.57:	1:0.47	1.2		-16-				
•	700	111	1.12	0.92	0.91	0.79	0.70	10 02 4	-0.27	7068	-0.53				1.11	2.41	會理會	1
	800	1.18	1.22	1.00	1.00	0.86	0.85	076	0.65	0 62	0 57	0.57	0 50	-	-	-	- ]	ĺ
Ŀ	800			1 08	108	C 94	0.93	0.82	080	0.88	0.54	062	.0 57	0 57	0.51	-	-	l
È	1000		194.75	118	1,15.	100	11.00	C BG	687	N.43"	10.00	1.8 25-	1003	0.02	0.57	0.58	0 52	
E	19369 800 as 20	€ ji - ji -	100		2.6-32	1.13	31.14		1.00	0.90	0.89.7	0.82	0.69	0.684	0.65	+0.62	0.57.	
	1600	- <u>1</u>		<u>'''''''''''''''''''''''''''''''''''''</u>	Jean- 261		<u>, (</u>	~1.11-2	-1:12	-1.00	1.00	0 92	10.91	0.84	10.14	임·영원 이 제품	2067.2	
	1800	=	Ξ	-	-	-	-	1.18	1.22	1 10	1.11	1.00	1.00	0.93	0.02	0.99	44.45.56	
L	2000	_	-	_	-	2	-	-	-	-	-	1.08	1.08	1.00	1.00	0.94	0.85	
	2200			100071	र सुरहात	as n and	4.15 PA257			-	-	1.16	1.18	107	1.07 .	1 00-	100	
ويست	2400		記に展開	性語的					20.0	, <b>-</b>	52 S	관람에				107-1	ULOZ.	
						فلتشبيه		5. <u>5</u>	1.100.00	10-110	e - T 55	<u> </u>	できて見いれい	\$-74 E	ar is it	125.678	1423	

## ALTITUDE CORRECTION FACTORS

ELEVATION	TOTAL HEAT	SENSIBLE HEAT
1000	0 99	0.96
2000	0.98	0.93
3000	0.97	0.69
4000	0 9ā	0 83
5000	0 94	0 83
6000	0.£3	0 80

![](_page_53_Figure_0.jpeg)

-- -- -

![](_page_54_Figure_0.jpeg)

MAR -13' 02 (WED) 16 27

P 002/002

![](_page_55_Figure_0.jpeg)

![](_page_56_Figure_0.jpeg)

Mechanical Equipment Room Temperature (SP-300)

Calc. H-02-0001 vev 0 Attachment 4 Page 1 of 1

CRYSTAL RIVER-3 CONTROL COMPLEX TEMP. RESPONSE (LOCA4E.INP) INITIAL RUN /AA LOCA/LOOP-extended 100 hrs, FANS @30 MIN, Walls init @77.5 41 47 0 209 38 0 0 0 0 1 12 31 0 0 0 12 0 41 0 /R 1 0 0.0001 10 0 0 /B1 10000000 1 5 0.0 518400 0.5 0.0 /C1 600.0 0.1 3000 3000 11 /C2 1800.0 0.1 4000 8000 1 1 /C2 18000 0.2 45000 90000 1 1 /C2 86400 0.2 535000 1070000 /02 1 1 518400 0.2 535000 1070000 1 1 /c2 33330. 14.7 80.0 0.54 0. 0. 0. 0. 0. 0. 0. 0 0. /D1 24465. 14.7 80.0 0.65 0. 0. 0. 0. 0. 0. 0. 0. 0 0. /D2 48908. 14.7 80.0 0.58 0. 0. 0. 0. 0. 0. 0. 0. 0 0. /D3 28013. 14.7 80.0 0.62 0. 0. 0. 0. 0. 0. 0. 0. 0 0. /D4 14.7 80.0 1507. 0.61 0. 0. 0. 0. 0. 0. 0. 0. 0 0. /D5 1901. 14.7 80.0 0.60 0. 0. 0. 0. 0. 0. 0. 0. 0 0. /D6 2128. 14.7 80.0 0.64 0. 0. 0. 0. 0. 0. 0. 0. 0 0. /D7 14.7 80.0 0.55 0. 0. 0. 0. 0. 0. 0. 0. 0 0. 1348. /ח8 3223. 14.7 80.0 0.43 0. 0. 0. 0. 0. 0. 0. 0. 0 0. /D9 3164. 14.7 80.0 0.59 0. 0. 0. 0. 0. 0. 0. 0. 0 0. /D10 4123. 14.7 80.0 0.51 0. 0. 0. 0. 0. 0. 0. 0. 0 0. /D11 2194. 14.7 80.0 0.51 0. 0. 0. 0. 0. 0. 0. 0. 0 0. /D12 8214. 14.7 80.0 0.45 0. 0. 0. 0. 0. 0. 0. 0. 0 0. /D13 8393 0.45 0. 0. 0. 0. 0. 0. 0. 0. 0 0. 14.7 80.0 /D14 3869. 14.7 80.0 0.47 0. 0. 0. 0. 0. 0. 0. 0. 0 0. /D15 4035. 14.7 80.0 0.55 0. 0. 0. 0. 0. 0. 0. 0. 0 0. /D16 6191. 14.7 80.0 0.45 0. 0. 0. 0. 0. 0. 0. 0. 0 0. /D17 5917. 14.7 80.0 0.46 0. 0. 0. 0. 0. 0. 0. 0. 0 0. /D18 12570. 14.7 80.0 0.49 0. 0. 0. 0. 0. 0. 0. 0. 0 0. /D19 12911. 14.7 80.0 0.56 0. 0. 0. 0. 0. 0. 0. 0. 0 0. /D20 34618, 14.7 80.0 0.50 0. 0. 0. 0. 0. 0. 0. 0. 0 0. /D21 28267. 14.7 60.4 0.50 0. 0. 0. 0. 0. 0. 0. 0. 0 0. /D22 14.7 115.0 0.50 0. 0. 0. 0. 0. 0. 0. 0. 1 0. 1.E9 /D23 TB 164. 1.E9 14.7 99.0 0.50 0. 0. 0. 0. 0. 0. 0. 0. 2 0. /D24 83663 14.7 80.0 0.50 0. 0. 0. 0. 0. 0. 0. 0. 0 0. /D25 14.7 80.0 1.E9 0.50 0. 0. 0. 0. 0. 0. 0. 0. 3 0. /D26 1.E9 14.7 178.2 0.50 0. 0. 0. 0. 0. 0. 0. 0. 4 0. /D27 E 14.7 80.0 0.50 0. 0. 0. 0. 0. 0. 0. 0. 0 0. 5.E3 /D28 5.E3 14.7 86.7 0.50 0. 0. 0. 0. 0. 0. 0. 0. 0 0. /D29 196.4 14.7 98.0 0.45 0. 0. 0. 0. 0. 0. 0. 0. 0 0. /D30 260.5 14.7 98.0 0.46 0. 0. 0. 0. 0. 0. 0. 0. 0 0. /D31 600.0 14.7 98.0 0.43 0. 0. 0. 0. 0. 0. 0. 0. 0 0. /D32 14.7 98.0 0.59 0. 0. 0. 0. 0. 0. 0. 0. 0 0. 552.0 /D33 1.E9 14.7 189.2 0.50 0. 0. 0. 0. 0. 0. 0. 0. 5 0. /D34 W 14.7 136.1 0.50 0. 0. 0. 0. 0. 0. 0. 0. 6 0. 1.E9 /D35 S 1.E9 14.7 237.3 0.50 0. 0. 0. 0. 0. 0. 0. 0. 7 0. /D36 Horz 1.E9 80.0 0.50 0. 0. 0. 0. 0. 0. 0. 0. 8 0. 14.7 /D37 (not used) 1.E914.7 80.0 0.50 0. 0. 0. 0. 0. 0. 0. 0. 9 0. /D38 Mach shop 1.E9 14.7 110.0 0.50 0. 0. 0. 0. 0. 0. 0. 0. 10 0. /D39 TB 145' 1.E9 14.7 105.0 0.50 0. 0. 0. 0. 0. 0. 0. 0. 11 0. /D40 TB 119' 1.E9 14.7 100.0 0.50 0. 0. 0. 0. 0. 0. 0. 0. 12 0. /D41 TB 95 0000 /DD 6 22 1 0 -1 0 0 /E-1 /F-1 NO /FF-1 6 28 2 0 -2 0 0 /E-2 /F-2 NO /FF-2 6 28 3 0 -3 0 0 /E-3 /F-3 NO /FF-3 6 28 4 0 -4 0 0 /E-4/F-4 NO /FF-46 29 5 0 -5 0 0 /E-5 /F-5 NO /FF-5 6 29 6 0 -6 0 0 /E-6 /F-6 NO /FF-6 6 29 7 0 -7 0 0 /E-7/F-7 NO /FF-7 6 29 8 0 -8 0 0 /E-8 /F-8

Calc. H-02-0001 Rev 0 Attachment 5 Page 1 of 20

Calc. H-02-0001 Rev 0 Attachment 5 Page 2 of 20

NO	0	Λ.																	/FF-8 /F-9
10 20	ດັ	0 -	0	່ດັ	-2	Ο.	ο.	٥.	ο.	0	Ο.	Ο.	n	0	0	٥.	0	0	/E-9 /F-9
NO.	••	••	••	••		•.	•••	•••	•••	•••	••	•••	٠.	•••	•••	••	••	••	/FF-9
6 28	10	0 (	-10	0 (	0														/E-10
10.	Ο.	Ο.	Ο.	0.	-2.	Ο.	Ο.	Ο.	Ο.	0.	Ο.	Ο.	Ο.	0.	Ο.	Ο.	Ο.	Ο.	/F-10
NO	• •	•	• •	0	^														/FF-10
0 28	. TI	. U	-11	. 0	-2	٥	0	Ω	0	Λ	0	0	n	0	٥	٥	0	0	/E-11 /E-11
NO.	0.	۰.	υ.	۰.	۰.	0.	0.	۰.	۰.	۷.	۰.	۰.	۰.	0.	0.	۰.	۰.	0.	/FF-11
6 28	12	2 0	-12	2 0	0														/E-12
10.	0.	Ο.	Ο.	0.	-2.	Ο.	Ο.	Ο.	Ο.	0.	0.	Ο.	Ο.	Ο.	0.	Ο.	0.	Ο.	/F-12
NO					~														/FF-12
6 28	013	5 0	-13	50	0 _2	^	^	0	0	^	0	0	0	0	^	0	0	0	/E-13
NO.	0.	۰.	0.	υ.	-2.	ν.	0.	0.	0.	۰.	۰.	υ.	0.	υ.	υ.	υ.	0.	0.	/FF-13
6 28	14	1 0	-14	1 0	0														/E-14
10.	0.	Ο.	Ο.	Ο.	-2.	Ο.	Ο.	Ο.	Ο.	Ο.	Ο.	0.	Ο.	Ο.	0.	Ο.	0.	0.	/F-14
NO					~														/FF-14
6 28	1:	20	-15	20	0	~	^	^	0	0	~	0	^	~	~	~	0	•	/E-15
NO	υ.	υ.	υ.	υ.	-2.	υ.	υ.	υ.	υ.	0.	υ.	0.	υ.	0.	υ.	υ.	υ.	υ.	/FF-15
6 28	1	50	-16	5 0	0														/E-16
10.	0.	Ο.	Ο.	Ο.	-2.	Ο.	Ο.	Ο.	Ο.	Ο.	Ο.	Ο.	/F-16						
NO					•														/FF-16
6 28	1	/ 0	-17	/ 0	0	~	0	0	0	^	~	~	~	^	^	^	^	•	/E-17
NO	υ.	0.	0.	0.	-2.	υ.	υ.	0.	0.	0.	0.	0.	0.	0.	0.	υ.	υ.	υ.	/FF-17
6 28	3 18	3 0	-18	3 0	0														/E-18
10.	0.	Ο.	Ο.	Ο.	-2.	Ο.	Ο.	0.	0.	0.	Ο.	Ο.	/F-18						
NO					•														/FF-18
5 28	5 T 7	, U	-15	, U	-2	0	^	0	0	0	Δ	^	0	0	•	^	0	0	/E-19
NO.	۰.	υ.	0.	υ.	-2.	υ.	υ.	0.	0.	0.	υ.	0.	υ.	υ.	υ.	υ.	0.	0.	/FF-19
6 28	3 21	0 0	~20	0 (	0														/E-20
10.	0.	0.	Ο.	Ο.	-2.	0.	Ο.	Ο.	Ο.	0.	Ο.	0.	0.	Ο.	Ο.	Ο.	Ο.	Ο.	/F-20
NO					•														/FF-20
10	. Z.		-21	0		0	0	0	0	0	0	Δ	0	0	0	0	0	0	/E-21 /E-21
NO.	۰.	۰.	0.	0.	-2.	۰.	۰.	0.	۰.	0.	0.	0.	۰.	υ.	υ.	υ.	0.	0.	/FF-21
6 28	3 23	20	-1	0 0	כ														/E-22
10.	0.	Ο.	Ο.	Ο.	-2.	Ο.	Ο.	0.	٥.	Ο.	Ο.	Ο.	/F-22						
NO	20	~	~ ~	~ /	•														/FF-22
10.	28	n.	-23	0.	-2	٥.	٥.	ο.	٥.	0	0	0	0	0	0	n	٥	٥	/E-23 /F-23
NO	•••	•••	•••	•••		•••	•••		•••	•••	•••	••	••	••	••	••	••	•••	/FF-23
64	29	0	-24	0 0	כ														/E-24
10.	0.	Ο.	0.	0.	-2.	0.	0.	0.	Ο.	0.	Ο.	Ο.	Ο.	Ο.	Ο.	Ο.	Ο.	Ο.	/F-24
NO 6 5	8		25 (	<b>`</b> ^															/FF-24 /E-25
10.	ŏ.	0.	Ő.	ο.	-2.	ο.	ο.	ο.	ο.	ο.	ο.	ο.	/F-25						
NO																			/FF-25
65	7 (	0 -3	26 (	0 0															/E-26
10.	0.	0.	ο.	0.	-2.	0.	0.	С.	0.	0.	ο.	ο.	ο.	0.	0.	Ο.	0.	0.	/F-26
NU 67	6	n _ '	27 (	n n															/88-20
10.	ŏ.	0.	ō.	ο.	-2.	Ο.	ο.	Ο.	ο.	Ο.	ο.	0.	/F-27						
NO									_							- •			/FF-27
68	6	D -:	28 (	0 0					_										/E-28
10.	0.	Ο.	Ο.	0.	-2.	0.	Ο.	ο.	Ο.	0.	0.	0.	Ο.	0.	0.	0.	0.	0.	/F-28
66	4	n	29 1	n n															/55-28
10.	ō.	Ő.	Ő.	ο.	-2.	Ο.	ο.	٥.	Ο.	Ο.	ο.	Ο.	/F-29						
NO																			/FF-29
6 7	4	0	30 (	0_0	-				-	_	-	_	_				_		/E-30
10.	0.	0.	0.	0.	-2.	0.	Ο.	0.	Ο.	0.	0.	0.	0.	0.	0.	0.	0.	0.	/F-30
6.2	1 2	0	-21	0 1	n														/88-30
10.	0.	ŏ.	0.	0.	-2.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	/F-31
NO								- •							2.				/FF-31
61	28	0	-1 (	0_0															/E-32
10.	Ο.	0.	0.	0.	-2.	0.	0.	0.	0.	0.	Ο.	0.	0.	٥.	0.	0.	0.	0.	/F-32
NO 6 2	20	0		o 4	n														/FF-32
10.	<u> </u>	Ő.	0	0.	-2.	Ο.	0.	0.	۵.	Q.	0.	0.	0.	0.	0.	0.	0.	0.	/E-33 /F-33
NO							••					- •							/FF-33

÷

Calc. H-02-0001 Rev 0 Attachment 5 Page 3 of 20

6 3 28 10, 0,	0 -	-3 0.	00	-2	. (	<b>.</b>	Ο.	0.	0.	0.	0.	٥.	0.	0	0	0	0	0		/E-3/	4
NO	 	 	^	-	•		••	•••	•••	••	••	••	••	•••	••	••	••	•.	,	/FF	-34
10. 0.	0.	, O.	ō.	-2	. (	э.	ο.	0.	0.	0.	0.	ο.	ο.	0.	ο.	ο.	0.	ο.		E-35 /F	-35
NO 6 10 4	0 -	-10	0	0																/FF /E-	-35
10. 0. NO	0.	0.	0.	-2	. (	ο.	0.	0.	0.	0.	0.	٥.	٥.	0.	0.	0.	0.	Ο.		/F	-36
6 14 28	B 0	-1	40	0																/FF	-36 2-37
10. 0. NO	0.	0.	0.	-2	. (	ο.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.		'/F	-37 -37
6 15 28	8 0	-1	5 0	0	,	n	^	٥	^	0	0	0	0	0	0	0	0	0		/E	-38
NO		0.		-2	• •		0.	υ.	0.	0.	0.	0.	υ.	υ.	υ.	0.	υ.	υ.		/FF	-38
6 16 28 10. 0.	во 0,	-1 0.	60 0.	0 -2	. (	ο.	ο.	ο.	ο.	ο.	ο.	ο.	ο.	ο.	ο.	ο.	٥.	ο.		/E /F	-39 -39
NO	R U	-2	0 0	Λ																/FF	-39
10. 0.	ο.	0.	°0.	-2	. (	ο.	Ο.	Ο.	ο.	٥.	Ο.	٥.	٥.	0.	ο.	ο.	٥.	٥.		/E /F	-40
NO 6 19 28	B 0	-1	90	0																/FE /E	2-40 2-41
10. 0. NO	0.	0.	0.	-2	. (	Ο.	0.	0.	Ο.	0.	0.	0.	0.	0.	0.	0.	0.	0.		/F	-41
6 18 28	во	-1	8_0	0		_		-		-	_	-			_	_	_	_		/1	5-42
10. U. NO	0.	0.	0.	-2	•	υ.	0.	0.	0.	0.	0.	0.	0.	0.	Ο.	0.	0.	0.		/E /FE	7-42 7-42
6 17 2	B 0	-1	70	0		ο.	0.	ο.	0.	0.	0.	0.	0	0	0	n	0	0		/ E	5-43 -43
NO		•••	•••	_		••	•.	••	•••	•••	••		•••	۰.	•••	•••	•••	••		/FE	-43
10.0.	0.	0.	20.	-2	. (	ο.	ο.	ο.	ο.	ο.	ο.	ο.	ο.	ο.	ο.	ο.	ο.	0.		/E /E	2-44 7-44
NO 6 13 2	во	-1	30	0																/FE	-44 -45
10. 0.	0.	ο.	0.	-2	. (	0.	0.	0.	Ο.	Ο.	0.	0.	Ο.	0.	٥.	ο.	0.	0.		/1	-45
6 28 2	50	-3	1 0	0																/FE /E	2-45 2-46
10. 0. NO	0.	0.	0.	-2	. (	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	Ο.	0.	0.		/H /FF	-46 -46
6 25 2	8 0	-3	1 0	0		n	0	0	0	•		0	0	0	0	0	^	^		/1	5-47
NO NO	0.	۰.	υ.	-2	•	0.	۰.	0.	0.	υ.	υ.	0.	0.	0.		0.	υ.	υ.		/FE	-47
5 0.0	14	1.7	11	5.0	0	.50	0.	. 0	. 0	. 0	. 0	. 0	. 0								
1800.0	14 . 14	$\frac{1.7}{1.7}$	12 12	2.0		.50	0.	. 0	. 0	. 0	. 0	. 0	. 0	•							
345600	. 14	1.7	-9	5.0	Ō	.50	0	. 0	. ŏ	. ŏ	. ŏ	. 0									
1.0E7 3	Τ¢	4./	9	5.0	0	.50	. 0	. 0	. 0	. 0	. 0	. 0	. 0	•			7	11			
0.0 1800.0	14	.7	99. 115	0	0.9	50 50	0. 0.														
1.0E7 5	14	.7	115	.0	0.	50	0.	0.	0.	0.	0.	0.	٥.				K	J2			
0.0	14	4.7	8	0.0		0.5	60 (	). (	0.	0. (	D. (	0. 0	o. (	).							
259200	14 . 14	$\frac{1.7}{1.7}$	10	0.0	) ( ) (	0.5	50 ( 50 (	). ( ). (	0. I 0. I	0. ( 0. (	0. I 0. I	0. ( 0. (	D. ( D. (	). ).							
345600 1.0E7	. 14	$\frac{1.7}{4.7}$	8	5.0		0.5	50 ( 50 (	). ( ). (	0. I	0. ( 0. (	0. ( 0. (	0. ( 0. (	D. ( D. (	). 1			13	T3 (	cc	951	
2	-		1 7 0										· · ·								
1.0E7	$14 \\ 14$	.7	178	.3	0	.50	0	. o	. 0	. 0	. 0	. 0	. 0	•			13	J4			
2 0.0	14	.7	189	.2	0.	50	ο.	ο.	ο.	ο.	0.	ο.	ο.								
1.0E7	14	.7	189	. 2	0	.50	0	. 0	. 0	. 0	. 0	. Ö	. 0	•			13	J5 '	W		
0.0	14	.7	136	.1	0	.50	0	. 0	. 0	. 0	. 0	. 0	. 0								
1.0E7 -13	14	.7	136	.1	0	.50	0 0	. 0	. 0	. 0	. 0	. 0	. 0	•			/.	J6	S		
0.0		14	.7	237	.3	0.	50	0.	0.	0.	0.	0.	0.	0.							
14400.	0	14	.7	154	.6	ō.	50	Ŏ.	0.	ō.	ō.	ō.	ō.	ŏ.							
21600.	0 0	14 14	.7 .7	80 72	1.5	0.	50	0. 0.	0. 0.	0. 0.	0. 0.	0. 0.	0. 0.	0. 0.							
36000.	0	14	.7	69	.3	Ő.	50	Ó.	Ó.	<u>0</u> .	<u>0</u> .	Ő.	Ő.	<u>0</u> .							
50400.	0	14	:7	65	.7	0.	50	0. 0.	о. 0.	о. 0.	0. 0.	о. о.	0. 0.	0. 0.							

.

.

## Calc. H-02-0001 Rev 0 Attachment 5 Page 4 of 20

.

.

57600.0 14 64800.0 14 72000.0 14 79200.0 14 86400.0 14 2	.7       64.9       0.50       0.0.0.0.0.0.0.0.0.0.0.0.0.0.0.0.0.0.0.	/J7 Horz
0.0 14.7 1.0E7 14.7	70.0 0.50 0. 0. 0. 0. 0. 0. 0. 0. 70.0 0.50 0. 0. 0. 0. 0. 0. 0. 0.	/J8 not used
0.0 14.7 7200.0 14.7 259200. 14.7 345600. 14.7 1.0E7 14.7 5	$\begin{array}{cccccccccccccccccccccccccccccccccccc$	/J9 mach shop
0.0 14.7 1800.0 14.7 259200. 14.7 345600. 14.7 1.0E7 14.7 5	$\begin{array}{cccccccccccccccccccccccccccccccccccc$	/J10 TB 145'
0.0 14.7 1800.0 14.7 259200. 14.7 345600. 14.7 1.0E7 14.7	$\begin{array}{cccccccccccccccccccccccccccccccccccc$	/J11 TB 119'
5           0.0         14.7           1800.0         14.7           259200.         14.7           345600.         14.7           1.0E7         14.7           -1         4	$\begin{array}{cccccccccccccccccccccccccccccccccccc$	/J12 TB 95'
-2 4 0. -3 4 0. -4 4 0. -5 4 0. -6 4 0.		
$\begin{array}{cccccccccccccccccccccccccccccccccccc$		
$\begin{array}{cccccccccccccccccccccccccccccccccccc$		
$\begin{array}{cccccccccccccccccccccccccccccccccccc$		
-25 4 0. -26 4 0. -27 4 0. -28 4 0. -29 4 0.		
$-30 \ 4 \ 0.$ $-31 \ 4 \ 0.$ $0. \ 0.00$	/κ	
1800. 13.350 1.0E7 13.350 0. 0.00 1800. 0.00	/L-1	
1800. 1.146 1.0E7 1.146 0. 0.00 1800. 0.00 1800. 0.209	/L-2	
1.UE/ 0.209 0. 0.00	/L-3	

Calc. H-02-0001 Rev 0 Attachment 5 Page 5 of 20

1800. 1800. 1.0E7	0.00 8.608 8.608	/L-4
1800. 1800. 1.0E7	0.00 1.4625 1.4625	/1-5
1800. 1800. 1.0E7	0.00 0.00 1.800 1.800	/L-6
0. 1800. 1800. 1.0E7	0.00 0.00 2.5875 2.5875	/L-7
0. 1800. 1800. 1.0E7	0.00 0.00 0.900 0.900	/L-8
0. 1800. 1800. 1.0E7	0.00 0.00 2.748 2.748	/L-9
0. 1800. 1800. 1.0E7	0.00 0.00 2.814 2.814	/L-10
0. 1800. 1800. 1.0E7	0.00 0.00 1.219 1.219	/L-11
0. 1800. 1800. 1.0E7	0.00 0.00 0.161 0.161	/L-12
0. 1800. 1800. 1.0E7	0.00 0.00 0.248 0.248	/L-13
0. 1800. 1800. 1.0E7	0.00 0.00 0.294 0.294	/L-14
0. 1800. 1800. 1.0E7	0.00 0.00 0.190 0.190	/L-15
0. 1800. 1800. 1.0E7	0.00 0.00 0.574 0.574	/L-16
0. 1800. 1800. 1.0E7	0.00 0.00 2.366 2.366	/L-17
0. 1800. 1800. 1.0E7	0.00 0.00 2.858 2.858	/L-18
0. 1800. 1800. 1.0E7	0.00 0.00 2.044 2.044	/L-19
0. 1800. 1800. 1.0E7	0.00 0.00 3.756 3.756	/L-20
0. 1800. 1800. 1.0E7	0.00 0.00 1.380 1.380	/L-21
0. 1800. 1800. 1.0E7	0.00 0.00 2.526 2.526	/L-22
υ.	0.00	

-

1

Calc. H-02-0001 Rev 0 Attachment 5 Page 6 of 20

1800. 1800. 1.0E7 0. 1800.	0.00 14.170 14.170 0.00 0.00	/L-23
1800. 1.0E7 0.	6.750 6.750 0.00	/L-24
1800. 1800. 1.0E7 0.	0.50 0.5913 0.5913 0.00	/L-25
1800. 1800. 1.0E7 0.	0.8712 0.8712 0.00	/L-26
1800. 1800. 1.0E7 0.	0.6674 0.6674 0.00	/L-27
1800. 1800. 1.0E7 0.	0.00 1.4913 1.4913 0.00	/L-28
1800. 1800. 1.0E7 0.	0.00 3.9587 3.9587 0.00	/L-29
1800. 1800. 1.0E7 0.	0.00 2.7913 2.7913 0.00	/L-30
1800. 1800. 1.0E7 1 2	4.720 4.720 0. 0. 0. 0	/L-31
2 2 3 2 4 2 5 2	$\begin{array}{cccccccccccccccccccccccccccccccccccc$	
6 2 7 2 8 2 9 2	$\begin{array}{cccccccccccccccccccccccccccccccccccc$	
10 2 11 2 12 2 13 2	$\begin{array}{cccccccccccccccccccccccccccccccccccc$	
14 2 15 2 16 2 17 2	$\begin{array}{cccccccccccccccccccccccccccccccccccc$	
18 2 19 2 20 2	$\begin{array}{cccccccccccccccccccccccccccccccccccc$	
21 2 22 2 28 7 -29 3	$\begin{array}{cccccccccccccccccccccccccccccccccccc$	
28 4 25 6 -28 6 -29 6	0. 0. 0. 0 0. 0. 0. 0 1.0E7 0. 0. 0 1.0E7 0. 0. 0	
1 4 -15 4 -16 4 -17 4	$\begin{array}{cccccccccccccccccccccccccccccccccccc$	
-18 4 -19 4 -20 4	4         3600. 0. 0. 0           4         3600. 0. 0. 0           4         3600. 0. 0. 0           4         3600. 0. 0. 0           4         3600. 0. 0. 0	
-9 4 -10 4 0.	3600.0.0.0         0.0           3600.0.0.0         0.0           3600.0.0         0.0           0.2.43         0.0	/Q
1.UE/ 0.	0. 2.43	/R-1

1.0E7 0	. 2.29	/R-2	
0. 0.	. 4.09	(D. 3	
0. 0	. 18.21	78-3	
1.0E7 0	. 18.21	/R-4	
1.0E7 0	. 0.00	/R-5	
0. 0	. 0.00		
1.0E7 0	. 0.00	/R-6	
1.0E7 0	. 0.00	/R-7	
0. 0.	. 0.00		
0. 0	. 0.00	, , , , , , , , , , , , , , , , , , , ,	
1.0E7 0	. 0.00	/R-9	
1.0E7 0	. 0.00	/R-10	
0. 0.	. 0.054	15 11	
0. 0	. 0.188	/R-11	
1.0E7 0.	. 0.188	/R-12	
1.0E7 0	. 1.28	/R-13 R	
0. 0.	1.68		
1.0E7 0.	. 1.68	/R-14 R	
1.0E7 0	. 3.93	/R-15	
0. 0. 1.0E7 0	. 4.39 4.39	/P-16	
. 0. 0.	0.00	/	
1.0E7 0	. 0.00	/R-17	
1.0E7 0	. 0.00	/R-18	
	. 2.5	(D. 10	
0. 0.	. 2.5	7R-19	
1.0E7 0	. 2.5	/R-20	
1.0E7 0	. 0.0	/R-21	
0. 0.	. 2.03		
0.0	0. 0.0	/R-22	
7200.	0. 0.0		
7800.	0.0.0		
12000.	0. 0.0		
15275. 1.0E7	0.0.0	(R-23 v28 f(t) 5)	
60. 0.	-12.81		
100. 0.	41.35	/R-24 v29 f(t) 43/44	
0. 0.	. 0.0		
1800. 0.	. 0.0		
1.0E7 0.	50.32	/R-25 v28	
1800. 0.	11.11		
1800. 0.	. 17.37		
7200. 0.	. 17.37		
1.0E7 0.	17.37	/R-26 fan + chiller load	v25
53.2 O.	-79.301		
57.5 0.	-250.190		
59.4 O.	-334.109		
160.0 0.	-366.837	/R-27 v28 (not used)	
53.0 0.	-12.814		
56.6 0.	-41.348		
58.4 0.	-54.896		
160.0 0.	-60.179	/R-28 v29	
0. 0.	0.		
3600.01 0	U. )66.		

.

.

.

~

Calc. H-02-0001 Rev 0 Attachment 5 Page 7 of 20

.

Calc. H-02-0001 Rev 0 Attachment 5 Page 8 of 20

.

,

1E+7	0.	-66. /R-29 v1	
72.	0.	-2.61	
84. 92.	0.	-3.63	
104.	ö.	-5.50 /R-30 v15	
72.	0.	-2.61	
84.	0.	-3.63	
92.	0.	-4.33	
72.	0.	-17.22	
84.	ō.	-25.00	
92.	0.	-28.88	
104.	0.	-39.44 /R-32 v17	
84.	0.	-17.22	
92.	ō.	-28.88	
104.	0.	-39.44 /R-33 v18 '	
72.	0.	-5.97	
92	0.	-9.72	
104.	ŏ.	-12.22 /R-34 v19	
72.	Ο.	-5.97	
84.	0.	-8.75	
92.	0.	-9.72	
72.	0.	-12.22 /R-35 V20 -2.61	
84.	ō.	-3.63	
92.	0.	-4.33	
104.	0.	-5.50 /R-36 v12	
84.	0.	-10.11	
92.	ō.	-27.22	
104.	0.	-37.77 /R-37 v9	
72.	0.	-16.11	
92.	0.	-22.77	
104.	ŏ.	-37.77 /R-38 v10	
HEAT	SINK 1	- WALL BETWEEN CTRL RM (1) AND AUX BLDG (24)	
122	411	$\begin{array}{cccccccccccccccccccccccccccccccccccc$	L
0.92	145.0	0.156	
202	4.5 82	.1 81.5 2 0.0 0.0 1 0 2 /Z-1	
0.42	100.0	0.20 /23-1	
HEAT	SINK 2	- WALL BTWN CTRL RM (1) AND CORRIDOR (2)	
6024	4.077	251.10.0500.00.00.000.0000.0000000000000	
0.92	145.0	0.156 /Z3-2	
2024	4.5 77	.5 77.5 2 0.0 0.0 1 0 2 /2-2	
0.42	100.0	0.20 /Z3-2	
122	1 1 1	= WALL BIWN CIRL RM (1) AND BREAK RM (2) 249.1 0.0 500.0 0.0 0 0 0 0 0 0 3 /Y=3	
4 0 12	2.077	.5 77.5 2 0.0 0.0 1 0 2 /Z-3	
0.92	145.0	0.156 /23-3	
2 0 1	2.5 77 100 0	.5 77.5 2 0.0 0.0 1 0 2 /Z-3	
HEAT S	SINK 4	- WALL BTWN CTRL RM (1) AND TURB BLDG 145' (39)	
1 2 3	911	1 552.3 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 3 /x-4	ł
602	4.0 10	3.9 84.5 2 0.0 0.0 1 0 2 /Z-4	
0.92	145.0		
0.42	100.0	.5 85.6 2 0.0 0.0 1 0 2 /2-4 0.20	
HEAT S	SINK S	- WALL BTWN CTRL RM (1) AND EAST SOLAIR (27)	
1 2 2'	7 11 1	1 585.0 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 3 /x-	·5
0 92	4.0 12 145 0	4.7 84.7 2 0.0 0.0 1 0 2 /Z-5	
2 0 24	4.5 84	.7 83.8 2 0.0 0.0 1 0 2 /7-5	
0.42	100.0	0.20 /Z3-5	
HEAT	SINK 6	- SUSP CEILING ABOVE CTRL RM (1) BELOW PLENUM (22)	
1 1 1 3 0 2	2 22	2 3336.4 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-6	)
0.021	0.7 0	.20 /23-6	
HEAT S	SINK 7	- CONTROL RM (1) FLOOR	
113	2 1 3	3297.1 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0 3 /x -7	
0.92	.0 77.		
HEAT S	SINK 8	- WALL BTWN CORRIDOR (2) AND AIR PLENUM (22)	

٠

Calc. H-02-0001 Rev 0 Attachment 5 Page 9 of 20

1 1 2 1 22 1 256.6 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. /X-8 3 6 0 24.0 74.2 63.7 2 0.0 0.0 1 0 2 /Z-8 0.92 145.0 0.156 /Z3-8 HEAT SINK 9 - WALL BTWN BREAK RM/OFFICE (2) AND AIR PLENUM (22) 1 1 2 1 22 1 256.6 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-9 4 0 12.0 72.7 65.2 2 0.0 0.0 1 0 2 (z - 9)0.92 145.0 0.156 /Z3-9 HEAT SINK 10 - WALLS BTWN BREAK RM/OFFICE (2) AND AUX BLDG (24) 1 1 24 1 2 1 500.0 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-10 6 0 24.0 94.8 81.7 2 0.0 0.0 1 0 2 17 - 100.92 145.0 0.156 /Z3-10 HEAT SINK 11 - WALLS BTWN CORRIDOR/OFFICE (2) AND STAIRWELL (21) 1 1 2 1 21 1 724.2 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 3 /x-11 4 0 24.0 77.5 77.5 2 0.0 0.0 1 0 2 /2-11 0.92 145.0 0.156 /Z3-11 HEAT SINK 12 - WALL BTWN CORRIDOR (2) AND TURB BLDG 145'(39) 1 1 2 1 39 1 163.9 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 0. з /x-12 6 0 24.0 83.8 103.7 2 0.0 0.0 1 0 2 /Z-12 0.92 145.0 0.156 /73-12 HEAT SINK 13 - FLOOR BTWN CORRIDOR (2) AND EQPT RM EL 164' (25) 1 1 2 2 25 3 475.7 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 3 /X - 133 0 8.0 82.2 87.8 2 0.0 0.0 1 0 2 /z-13 0.92 145.0 0.156 123-13 HEAT SINK 14 - FLOOR BTWN CABLE GALLERY (3) AND CORRIDOR (2) 1 1 3 2 2 3 1303.4 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 0. 3 /x-14 3 0 8.0 77.5 77.5 2 0.0 0.0 1 0 2 /Z-14 0.92 145.0 0.156 /23-14 HEAT SINK 15 - WALL BTWN CABLE GALLERY (3) AND EAST SOLAIR (27) 1 1 3 1 27 11 77.8 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. З /X-15 6 0 24.0 84.1 124.5 2 0.0 0.0 1 0 2 /z-15 0.92 145.0 0.156 /23-15 HEAT SINK 16 - WALLS BTWN CABLE GALLERY (3) AND AUX BLDG (24) 1 1 3 1 24 1 1265.9 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-16 6 0 24.0 81.7 94.8 2 0.0 0.0 1 0 2 /Z-16 0.92 145.0 0.156 /Z3-16 HEAT SINK 17 - WALLS BTWN CABLE GALLERY (3) AND STAIRWELL (21) 1 1 3 1 21 1 395.4 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-17 6 0 24.0 77.5 77.5 2 0.0 0.0 1 0 2 /7 - 170.92 145.0 0.156 /23-17 HEAT SINK 18 - WALL BTWN CABLE GALLERY (3) AND TURB BLDG 119'(40) 1 1 3 1 40 1 664.1 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-18 6 0 24.0 82.8 99.7 2 0.0 0.0 1 0 2 /z-18 0.92 145.0 0.156 /23-18 HEAT SINK 19 - FLOOR BTWN CABLE GALLERY (3) AND CRD RM (4) 1 3 4 2 3 3 2835.9 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. /X-19 3 1 0 0.250 77.5 77.5 2 0.0 0.0 1 0 2 /Z-19 27.0 490.0 0.12 /23-19 1 0 0.5625 77.5 77.5 2 0.0 0.0 1 0 2 /Z-19 0.025 5.7 0.20 /23-19 1 0 0.6875 77.5 77.5 2 0.0 0.0 1 0 2 /Z-19 98.0 174.0 0.156 /Z3-19 HEAT SINK 20 - FLOOR BTWN CABLE GALLERY (3) AND EFIC RM A (5) 1 3 5 2 3 3 171.5 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-20 1 0 0.250 77.5 77.5 2 0.0 0.0 1 0 2 /Z-20 27.0 490.0 0.12 /Z3-20 1 0 0.5625 77.5 77.5 2 0.0 0.0 1 0 2 /Z-20 0.025 5.7 0.20 173-20 1 0 0.6875 77.5 77.5 2 0.0 0.0 1 0 2 /Z-20 98.0 174.0 0.156 /Z3 - 20HEAT SINK 21 - FLOOR BTWN CABLE GALLERY (3) AND EFIC RM B (6) 1 3 6 2 3 3 216.2 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 0. 3 /x - 211 0 0.250 77.5 77.5 2 0.0 0.0 1 0 2 /Z-21 27.0 490.0 0.12 1 0 0.5625 77.5 77.5 2 0.0 0.0 1 0 2 /23-21 /Z-21 0.025 5.7 0.20 /Z3-21 1 0 0.6875 77.5 77.5 2 0.0 0.0 1 0 2 /Z-21 98.0 174.0 0.156 /Z3-21 HEAT SINK 22 - FLOOR BTWN CABLE GALLERY (3) AND EFIC RM C (7) 1 3 7 2 3 3 240.8 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-22 1 0 0.250 77.5 77.5 2 0.0 0.0 1 0 2 /Z-22 27.0 490.0 0.12 /23-22 1 0 0.5625 77.5 77.5 2 0.0 0.0 1 0 2 /Z-22 0.025 5.7 0.20 /23-22 1 0 0.6875 77.5 77.5 2 0.0 0.0 1 0 2 /Z-22 98.0 174.0 0.156 /23-22 HEAT SINK 23 - FLOOR BTWN CABLE GALLERY (3) AND EFIC RM D (8)

Calc. H-02-0001 Rev 0 Attachment 5 Page 10 of 20

1 3 8 2 3 3 150.4 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-23 1 0 0.250 77.5 77.5 2 0.0 0.0 1 0 2 /Z-23 27.0 490.0 0.12 /23-23 1 0 0.5625 77.5 77.5 2 0.0 0.0 1 0 2 12-23 0.025 5.7 0.20 /23 - 231 0 0.6875 77.5 77.5 2 0.0 0.0 1 0 2 /Z-23 98.0 174.0 0.156 /23-23 HEAT SINK 24 - FLOOR BTWN CABLE GALLERY (3) AND 480V SWGR RM A (9) 1 3 9 2 3 3 358.7 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 1 0 0.250 77.5 77.5 2 0.0 0.0 1 0 2 ٦ /X-24 /Z-24 27.0 490.0 0.12 /Z3-24 1 0 0.5625 77.5 77.5 2 0.0 0.0 1 0 2 17-24 0.025 5.7 0.20 123 - 241 0 0.6875 77.5 77.5 2 0.0 0.0 1 0 2 12 - 2498.0 174.0 0.156 /23-24 HEAT SINK 25 - FLOOR BTWN CABLE GALLERY (3) AND 480V SWGR RM B (10) 1 3 10 2 3 3 354.8 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-25 1 0 0.250 77.5 77.5 2 0.0 0.0 1 0 2 12-25 27.0 490.0 0.12 1 0 0.5625 77.5 77.5 2 0.0 0.0 1 0 2 /23-25 /Z-25 0.025 5.7 0.20 /23-25 1 0 0.6875 77.5 77.5 2 0.0 0.0 1 0 2 12-25 98.0 174.0 0.156 /Z3-25 HEAT SINK 26 - WALL BTWN CRD RM (4) AND MACH SHOP (38) 1 1 4 1 38 1 516.8 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. /X-26 6 0 24.0 78.0 79.5 2 0.0 0.0 1 0 2 /Z-26 0.92 145.0 0.156 123 - 26HEAT SINK 27 - WALLS BTWN CRD RM/CORRIDOR (4) AND AUX BLDG (24) 1 1 24 1 4 1 445.2 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 0.3 /X-27 6 0 24.0 94.8 81.7 2 0.0 0.0 1 0 2 /2-27 0.92 145.0 0.156 123-27 HEAT SINK 28 - WALL BTWN CRD RM/CORRIDOR (4) AND TURB BLDG 119'(40) 1 1 4 1 40 1 251.8 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-28 6 0 24.0 82.8 99.7 2 0.0 0.0 1 0 2 /Z-28 0.92 145.0 0.156 123-28 HEAT SINK 29 - WALLS BTWN CRD RM/CORRIDOR (4) AND STAIRWELL (21) 1 1 4 1 21 1 319.8 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-29 6 0 24.0 77.5 77.5 2 0.0 0.0 1 0 2 /Z-29 0.92 145.0 0.156 /Z3-29 HEAT SINK 30 - WALL BTWN CRD RM/CORRIDOR (4) AND EFIC RM A (5) 1 1 4 1 5 1 127.4 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. ٦ /X-30 6 0 24.0 77.5 77.5 2 0.0 0.0 1 0 2 /z-30 0.92 145.0 0.156 /Z3-30 HEAT SINK 31 - WALLS BTWN CRD RM/CORRIDOR (4) AND EFIC RM B (6) 1 1 6 1 4 1 262.1 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 0. /X-31 3 4 0 12.0 77.5 77.5 2 0.0 0.0 1 0 2 /Z-31 0.92 145.0 0.156 /Z3-31 HEAT SINK 32 - WALL BTWN CRD RM/CORRIDOR (4) AND EFIC RM C (7) 1 1 7 1 4 1 127.4 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-32 4 0 12.0 77.5 77.5 2 0.0 0.0 1 0 2 /2-32 0.92 145.0 0.156 /23-32 HEAT SINK 33 - WALL BTWN CRD RM/CORRIDOR (4) AND EFIC RM D (8) 1 1 4 1 8 1 73.0 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-33 4 0 12.0 77.5 77.5 2 0.0 0.0 1 0 2 /Z-33 0.92 145.0 0.156 /z3-33 HEAT SINK 34 - WALL BTWN CRD RM/CORRIDOR (4) AND EFIC RM D (8) 1 1 4 1 8 1 113.7 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-34 6 0 24.0 77.5 77.5 2 0.0 0.0 1 0 2 /Z-34 0.92 145.0 0.156 /Z3-34 HEAT SINK 35 - WALLS BTWN CRD RM/CORRIDOR (4) AND 480V SWGR RM A (9) 1 1 9 1 4 1 323.9 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-35 4 0 12.0 77.5 77.5 2 0.0 0.0 1 0 2 /2-35 0.92 145.0 0.156 /Z3-35 HEAT SINK 36 - WALL BTWN CRD RM/CORRIDOR (4) AND 480V SWGR RM B (10) 1 1 10 1 4 1 193.6 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-36 4 0 12.0 77.5 77.5 2 0.0 0.0 1 0 2 /Z-36 0.92 145.0 0.156 /23-36 HEAT SINK 37 - FLOOR BTWN CRD RM/CORRIDOR (4) AND BATTERY RM A (13) 1 1 13 2 4 3 537.2 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-37 3 0 8.0 77.5 77.5 2 0.0 0.0 1 0 2 /z-37 0.92 145.0 0.156 /23-37 HEAT SINK 38 - FLOOR BTWN CRD RM/CORRIDOR (4) AND BTTRY CHGR RM A (15) 1 1 15 2 4 3 249.3 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-38 3 0 8.0 77.5 77.5 2 0.0 0.0 1 0 2 /z-38 0.92 145.0 0.156 /23-38 HEAT SINK 39 - FLOOR BTWN CRD RM/CORRIDOR (4) AND INVERTER RM A (17)

Calc. H-02-0001 Rev 0 Attachment 5 Page 11 of 20

1 1 17 2 4 3 404.6 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-39 3 0 8.0 79.3 78.5 2 0.0 0.0 1 0 2 /Z-39 0.92 145.0 0.156 /Z3-39 HEAT SINK 40 - FLOOR BTWN CRD RM/CORRIDOR (4) AND INVERTER RM B (18) 1 1 18 2 4 3 385.4 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 0. 3 /x - 403 0 8.0 79.3 78.5 2 0.0 0.0 1 0 2 /z-40 0.92 145.0 0.156 /Z3-40 HEAT SINK 41 - FLOOR BTWN CRD RM/CORRIDOR (4) AND 4160V SWGR RM A (19) 1 1 19 2 4 3 430.4 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-41 3 0 8.0 77.5 77.5 2 0.0 0.0 1 0 2 /Z-41 0.92 145.0 0.156 723 - 41HEAT SINK 42 - FLOOR BTWN CRD RM/CORRIDOR (4) AND 4160V SWGR RM B (20) 1 1 20 2 4 3 458.1 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-42 3 0 8.0 77.5 77.5 2 0.0 0.0 1 0 2 /Z-42 0.92 145.0 0.156 /23-42 HEAT SINK 43 - FLOOR BTWN CRD RM/CORRIDOR (4) AND CORRIDOR-201 (11) 1 1 11 2 4 3 270.0 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-43 3 0 8.0 77.5 77.5 2 0.0 0.0 1 0 2 /Z-43 0.92 145.0 0.156 123-43 HEAT SINK 44 - FLOOR BTWN CRD RM/CORRIDOR (4) AND REMOTE SDWN RM (12) 1 1 12 2 4 3 143.1 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 0. 2 /X-44 3 0 8.0 77.5 77.5 2 0.0 0.0 1 0 2 /Z-44 0.92 145.0 0.156 /Z3-44 HEAT SINK 45 - WALL BTWN EFIC RM A (5) AND TURB BLDG 119'(40) 1 1 5 1 40 1 105.1 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-45 6 0 24.0 82.8 99.7 2 0.0 0.0 1 0 2 /Z-45 0.92 145.0 0.156 /23-45 HEAT SINK 46 - WALL BTWN EFIC RM A (5) AND EFIC RM C (7) 1 1 5 1 7 1 108.1 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-46 2 0 3.0 77.5 77.5 2 0.0 0.0 1 0 2 /2-46 0.166 100.0 0.20 /23-46 HEAT SINK 47 - WALL BTWN EFIC RM A (5) AND EFIC RM D (8) 1 1 5 1 8 1 71.5 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-47 2 0 3.0 77.5 77.5 2 0.0 0.0 1 0 2 /Z-47 0.166 100.0 0.20 /23-47 HEAT SINK 48 - FLOOR BTWN EFIC RM A (5) AND BATTERY RM B (14)1 1 14 2 5 3 171.5 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-48 3 0 8.0 77.5 77.5 2 0.0 0.0 1 0 2 /Z-48 0.92 145.0 0.156 /23-48 HEAT SINK 49 - WALL BTWN EFIC RM B (6) AND EFIC RM C (7) /X-49 2 0 3.0 77.5 77.5 2 0.0 0.0 1 0 2 /z-49 0.166 100.0 0.20 /23-49 HEAT SINK 50 - WALL BTWN EFIC RM B (6) AND EFIC RM D (8) 1 1 8 1 6 1 61.7 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-50 2 0 3.0 77.5 77.5 2 0.0 0.0 1 0 2 /2-50 0.166 100.0 0.20 /23-50 HEAT SINK 51 - FLOOR BTWN EFIC RM B (6) AND BATTERY RM B (14)1 1 14 2 6 3 68.0 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-51 3 0 8.0 77.5 77.5 2 0.0 0.0 1 0 2 /2 - 510.92 145.0 0.156 /23-51 HEAT SINK 52 - FLOOR BTWN EFIC RM B (6) AND BTRY CHARGER RM B (16) 1 1 16 2 6 3 131.5 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-52 3 0 8.0 77.5 77.5 2 0.0 0.0 1 0 2 /z - 520.92 145.0 0.156 /Z3-52 HEAT SINK 53 - WALL BTWN EFIC RM C (7) AND TURB BLDG 119 (40) 1 1 7 1 40 1 148.3 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 0. /X-53 3 6 0 24.0 82.8 99.7 2 0.0 0.0 1 0 2 /Z-53 0.92 145.0 0.156 /Z3-53 HEAT SINK 54 - FLOOR BTWN EFIC RM C (7) AND BATTERY RM B (14) 1 1 14 2 7 3 242.1 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-54 3 0 8.0 77.5 77.5 2 0.0 0.0 1 0 2 12-54 0.92 145.0 0.156 /23-54 HEAT SINK 55 - FLOOR BTWN EFIC RM D (8) AND BATTERY RM B (14) 1 1 14 2 8 3 48.1 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. /X - 553 3 0 8.0 77.5 77.5 2 0.0 0.0 1 0 2 12 - 550.92 145.0 0.156 123-55 HEAT SINK 56 - FLOOR BTWN EFIC RM D (8) AND BTRY CHARGER RM B (16) 1 1 16 2 8 3 89.3 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-56 3 0 8.0 77.5 77.5 2 0.0 0.0 1 0 2 /Z-56 0.92 145.0 0.156 /23-56 HEAT SINK 57 - WALL BTWN 480V SWGR RM A (9) AND AUX BLDG (24) 1 1 24 1 9 1 246.1 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-57 6 0 24.0 94.8 81.7 2 0.0 0.0 1 0 2 /z-57 0.92 145.0 0.156 123-57 HEAT SINK 58 - WALL BTWN 480V SWGR RM A (9) AND 480V SWGR RM B (10)

Calc. H-02-0001 Rev 0

Attachment 5 Page 12 of 20

1 1 10 1 9 1 111.3 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. ٦ /X~58 4 0 12.0 77.5 77.5 2 0.0 0.0 1 0 2 12-58 0.92 145.0 0.156 /23-58 HEAT SINK 59 - FLOOR BTWN 480V SWGR RM A (9) AND 4160V SWGR RM A (19) 1 1 19 2 9 3 365.9 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. /X-59 З 3 0 8.0 77.5 77.5 2 0.0 0.0 1 0 2 /2 - 590.92 145.0 0.156 /23-59 HEAT SINK 60 - WALLS BTWN 480V SWGR RM B (10) AND AUX BLDG (24) 1 1 24 1 10 1 359.2 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-60 6 0 24.0 94.8 81.7 2 0.0 0.0 1 0 2 /Z-60 0.92 145.0 0.156 /23-60 HEAT SINK 61 - FLOOR BTWN 480V SWGR RM B (10) AND 4160V SWGR RM B (20) 1 1 20 2 10 3 359.1 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-61 3 0 8.0 77.5 77.5 2 0.0 0.0 1 0 2 /Z - 610.92 145.0 0.156 /23-61 HEAT SINK 62 - WALL BTWN CORRIDOR (11) AND TURB BLDG 119' (40)1 1 11 1 40 1 126.6 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-62 6 0 24.0 82.8 99.7 2 0.0 0.0 1 0 2 /Z-62 0.92 145.0 0.156 /23-62 HEAT SINK 63 - WALL BTWN CORRIDOR (11) AND REMOTE SHUTDOWN RM (12) 1 1 12 1 11 1 97.7 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-63 2 0 3.0 77.5 77.5 2 0.0 0.0 1 0 2 /Z-63 0.166 100.0 0.20 /Z3-63 HEAT SINK 64 - WALL BTWN CORRIDOR (11) AND STAIRWELL (21) 1 1 11 1 21 1 271.1 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. ٦ /X-64 4 0 24.0 77.5 77.5 2 0.0 0.0 1 0 2 /Z-64 0.92 145.0 0.156 /Z3-64 HEAT SINK 65 - WALL BTWN CORRIDOR (11) AND 4160V SWGR RM B (20) 1 1 20 1 11 1 133.5 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-65 3 0 12.0 77.5 77.5 2 0.0 0.0 1 0 2 /Z-65 0.92 145.0 0.156 /23-65 HEAT SINK 66 - WALL BTWN CORRIDOR (11) AND BATTERY RM B (14) 1 1 11 1 14 1 237.5 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 0. ٦ /X-66 4 0 12.0 77.5 77.5 2 0.0 0.0 1 0 2 /Z-66 0.92 145.0 0.156 /Z3-66 HEAT SINK 67 - WALL BTWN CORRIDOR (11) AND BTRY CHARGER RM B (16) 1 1 11 1 16 1 110.0 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 0. ٦ /X-67 4 0 12.0 77.5 77.5 2 0.0 0.0 1 0 2 /Z-67 0.92 145.0 0.156 /23-67 HEAT SINK 68 - FLOOR BTWN CORRIDOR (11) AND HP AREA EL 95' (26)1 1 26 2 11 3 270.0 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-68 3 0 18.0 77.5 77.5 2 0.0 0.0 1 0 2 /Z-68 0.92 145.0 0.156 /73-68 HEAT SINK 69 - WALL BTWN REMOTE SHDWN RM (12) AND AUX BLDG (24) 1 1 24 1 12 1 130.3 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-69 4 0 24.0 94.8 81.7 2 0.0 0.0 1 0 2 /Z-69 0.92 145.0 0.156 /23-69 HEAT SINK 70 - WALL BTWN REMOTE SHDWN RM (12) AND STAIRWELL (21) 1 1 12 1 21 1 258.1 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 0. 4 0 24.0 77.5 77.5 2 0.0 0.0 1 0 2 3 /X-70 /Z-70 0.92 145.0 0.156 /23-70 HEAT SINK 71 - WALL BTWN REMOTE SHDWN RM (12) AND 4160V SWGR RM B (20) 1 1 20 1 12 1 247.9 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-71 4 0 12.0 77.5 77.5 2 0.0 0.0 1 0 2 /Z-71 0.92 145.0 0.156 /23-71 HEAT SINK 72 - FLOOR BTWN REMOTE SHDWN RM (12) AND HP AREA EL 95' (26) 1 1 26 2 12 3 143.1 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. ٦ /x-72 4 0 18.0 77.5 77.5 2 0.0 0.0 1 0 2 /Z-72 0.92 145.0 0.156 /23-72 HEAT SINK 73 - WALL BTWN BATTERY RM B (14) AND TURB BLDG 119'(40) 1 1 14 1 40 1 444.3 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-73 6 0 24.0 82.8 99.7 2 0.0 0.0 1 0 2/Z-73 0.92 145.0 0.156 123 - 73HEAT SINK 74 - WALL BTWN BATTERY RM B (14) AND BTRY CHARGER RM B (16) 1 1 16 1 14 1 412.7 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-74 4 0 12.0 77.5 77.5 2 0.0 0.0 1 0 2 /Z-74 0.92 145.0 0.156 123-74 HEAT SINK 75 - WALL BTWN BATTERY RM B (14) AND BATTERY RM A (13) 1 1 14 1 13 1 228.5 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-75 2 0 12.0 77.5 77.5 2 0.0 0.0 1 0 2 /2-75 0.92 145.0 0.156 /Z3-75 HEAT SINK 76 - FLOOR BTWN BATTERY RM B (14) AND HP AREA EL 95' (26) 1 1 26 2 14 3 544.1 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-76 3 0 8.0 77.5 77.5 2 0.0 0.0 1 0 2 /Z-76 0.92 145.0 0.156 /23-76 HEAT SINK 77 - WALL BTWN BATTERY RM A (13) AND TURBINE BLDG 119'(40)

Calc. H-02-0001 Rev 0 Attachment 5 Page 13 of 20

1 1 13 1 40 1 434.9 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. /x-77 ٦ 6 0 24.0 82.8 99.7 2 0.0 0.0 1 0 2 /Z-77 0.92 145.0 0.156 /23-77 HEAT SINK 78 - WALL BTWN BATTERY RM A (13) AND GROUND adiab 1 1 13 1 0 0 206.3 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-78 6 0 24.0 77.5 77.5 2 0.0 0.0 1 0 2 /z-78 0.92 145.0 0.156 /23-78 HEAT SINK 79 - WALL BTWN BATTERY RM A (13) AND BTRY CHARGER RM A (15) 1 1 15 1 13 1 408.0 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 3 /X-79 4 0 12.0 77.5 77.5 2 0.0 0.0 1 0 2 12-79 0.92 145.0 0.156 /Z3-79 HEAT SINK 80 - FLOOR BTWN BATTERY RM A (13) AND HP AREA EL 95' (26) 1 1 26 2 13 3 535.7 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-80 3 0 8.0 77.5 77.5 2 0.0 0.0 1 0 2 17 - 800.92 145.0 0.156 /73-80 HEAT SINK 81 - WALL BTWN BTRY CHARGER RM A (15) AND GROUND adiab 1 1 15 1 0 0 99. 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 6 0 24.0 77.5 77.5 2 0.0 0.0 1 0 2 /X-81 - 3 /Z-81 0.92 145.0 0.156 /Z3-81 HEAT SINK 82 - WALL BTWN BTRY CHGR RM A (15) AND BTRY CHGR RM B (16) 1 1 16 1 15 1 104.6 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 0. /X-82 3 4 0 12.0 77.5 77.5 2 0.0 0.0 1 0 2 /Z-82 0.92 145.0 0.156 /Z3~82 HEAT SINK 83 - WALL BTWN BTRY CHGR RM A (15) AND INVERTER RM A (17) 1 1 17 1 15 1 185.7 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-83 4 0 12.0 79.3 78.2 2 0.0 0.0 1 0 2 /Z-83 0.92 145.0 0.156 /Z3-83 HEAT SINK 84 - WALL BTWN BTRY CHGR RM A (15) AND INVERTER RM B (18) 1 1 18 1 15 1 175.2 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-84 4 0 12.0 79.3 78.2 2 0.0 0.0 1 0 2 12-84 0.92 145.0 0.156 /23-84 HEAT SINK 85 - FLOOR BTWN BTRY CHGR RM A (15) AND HP AREA EL 95' (26) 1 1 26 2 15 3 258.2 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 0. /X-85 3 3 0 8.0 77.5 77.5 2 0.0 0.0 1 0 2 12-85 0.92 145.0 0.156 /Z3-85 HEAT SINK 86 - WALL BTWN BTRY CHGR RM B (16) AND 4160V SWGR RM A (19) 1 1 19 1 16 1 426.6 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. /X-86 4 0 12.0 77.5 77.5 2 0.0 0.0 1 0 2 12-86 0.92 145.0 0.156 /23-86 HEAT SINK 87 - FLOOR BTWN BTRY CHGR RM B (16) AND HP AREA EL 95' (26) 1 1 26 2 16 3 263.8 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-87 3 0 8.0 77.5 77.5 2 0.0 0.0 1 0 2 /2-87 0.92 145.0 0.156 /Z3-87 HEAT SINK 88 - WALL BTWN INVERTER RM A (17) AND AUX BLDG (24) 1 1 24 1 17 1 213.7 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-88 6 0 24.0 95.3 83.7 2 0.0 0.0 1 0 2 /Z-88 0.92 145.0 0.156 /23-88 HEAT SINK 89 - WALL BTWN INVERTER RM A (17) AND GROUND adiab 1 1 17 1 0 0 316.3 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 6 0 24.0 80.0 80.0 2 0.0 0.0 1 0 2 3 /X-89 /z-89 0.92 145.0 0.156 /23-89 HEAT SINK 90 - WALL BTWN INVERTER RM A (17) AND INVERTER RM B (18) 1 1 18 1 17 1 403.2 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-90 4 0 12.0 80.0 80.0 2 0.0 0.0 1 0 2 12-90 0.92 145.0 0.156 /23-90 HEAT SINK 91 - FLOOR BTWN INVERTER RM A (17) AND HP AREA EL 95' (26) 1 1 26 2 17 3 407.3 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-91 3 0 8.0 78.2 79.0 2 0.0 0.0 1 0 2 /Z-91 0.92 145.0 0.156 /Z3-91 HEAT SINK 92 - WALL BTWN INVERTER RM B (18) AND AUX BLDG (24) 1 1 24 1 18 1 187.9 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. /x - 926 0 24.0 95.3 83.7 2 0.0 0.0 1 0 2 /Z-92 0.92 145.0 0.156 /Z3-92 HEAT SINK 93 - WALL BTWN INVERTER RM B (18) AND 4160V SWGR RM A (19) 1 1 19 1 18 1 403.8 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 0. 4 0 12.0 78.2 79.3 2 0.0 0.0 1 0 2 /X-93 3 /Z-93 0.92 145.0 0.156 /Z3-93 HEAT SINK 94 - FLOOR BTWN INVERTER RM B (18) AND HP AREA EL 95' (26) 1 1 26 2 18 3 389.9 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. /X-94 3 3 0 8.0 78.2 79.0 2 0.0 0.0 1 0 2 /Z-94 0.92 145.0 0.156 /23-94 HEAT SINK 95 - WALL BTWN 4160V SWGR RM A (19) AND AUX BLDG (24) 1 1 24 1 19 1 420.5 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. /X-95 3 6 0 24.0 94.8 81.7 2 0.0 0.0 1 0 2 /Z-95 0.92 145.0 0.156 /Z3-95 HEAT SINK 96 - WALL BTWN 4160V SWGR RM A (19) AND 4160V SWGR RM B (20)

## Calc. H-02-0001 Rev 0

Attachment 5 Page 14 of 20

1 1 20 1 19 1 380.3 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. /X-96 3 4 0 12.0 77.5 77.5 2 0.0 0.0 1 0 2 /Z-96 0.92 145.0 0.156 173-96 HEAT SINK 97 - FLOOR BTWN 4160V SWGR RM A (19) AND HP AREA EL 95' (26) 1 1 26 2 19 3 824.8 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-97 3 0 8.0 77.5 77.5 2 0.0 0.0 1 0 2 /Z-97 0.92 145.0 0.156 /23-97 HEAT SINK 98 - WALL BTWN 4160V SWGR RM B (20) AND AUX BLDG (24) 1 1 24 1 20 1 873.8 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 0. /x - 983 6 0 24.0 94.8 81.7 2 0.0 0.0 1 0 2 /Z-98 0.92 145.0 0.156 /23-98 HEAT SINK 99 - FLOOR BTWN 4160V SWGR RM B (20) AND HP AREA EL 95' (26) 1 1 26 2 20 3 840.5 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. ٦ /X-99 5 0 18.0 77.5 77.5 2 0.0 0.0 1 0 2 17-99 0.92 145.0 0.156 /23-99 HEAT SINK 100 - FLOOR BTWN STAIRWELL (21) AND GROUND (ADIABATIC) 1 1 0 0 21 3 336.1 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. З /X-100 2 0 24.0 77.5 77.5 2 0.0 0.0 1 0 2 /z-100 0.92 145.0 0.156 /Z3-100 HEAT SINK 101 - WALLS BTWN STAIRWELL (21) AND EAST SOLAIR (27) 1 1 21 1 27 11 180.0 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. /x - 101਼ 3 0 24.0 84.1 124.5 2 0.0 0.0 1 0 2 /2 - 1010.92 145.0 0.156 /23-101 HEAT SINK 102 - WALL BTWN STAIRWELL (21) AND TURBINE BLDG 164'(23) 1 1 21 1 23 1 1770.2 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 3 /x - 1022 0 24.0 84.7 107.8 2 0.0 0.0 1 0 2 /7-102 0.92 145.0 0.156 773 - 102HEAT SINK 103 - WALL BTWN STAIRWELL (21) AND AUX BLDG (24) 1 1 24 1 21 1 1726.9 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-103 3 0 24.0 94.8 81.7 2 0.0 0.0 1 0 2 /Z-103 0.92 145.0 0.156 /Z3-103 HEAT SINK 104 - WALLS BTWN STAIRWELL (21) AND HP AREA EL 95' (26) 1 1 21 1 26 1 412.8 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 0. 3 /x - 1042 0 24.0 77.5 77.5 2 0.0 0.0 1 0 2 /z-104 0.92 145.0 0.156 17.3 - 104HEAT SINK 105 - WALLS BTWN STAIRWELL (21) AND EQPT RM EL 164' (25) 1 1 21 1 25 1 693.9 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. ٦ /X-105 2 0 24.0 80.9 91.6 2 0.0 0.0 1 0 2 /Z-105 0.92 145.0 0.156 /23-105 HEAT SINK 106 - WALL BTWN CTRL RM PLENUM (22) AND TURB BLDG 145' (39) 1 1 22 1 39 1 508.3 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-106 6 0 24.0 70.0 100.4 2 0.0 0.0 1 0 2 /Z-106 0.92 145.0 0.156 /Z3-106 HEAT SINK 107 - WALL BTWN CTRL RM PLENUM (22) AND EAST SOLAIR (27) 1 1 22 1 27 11 513.1 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-107 6 0 24.0 70.3 121.2 2 0.0 0.0 1 0 2 /Z-107 0.92 145.0 0.156 /Z3-107 HEAT SINK 108 - WALL BTWN CTRL RM PLENUM (22) AND AUX BLDG (24) 1 1 22 1 24 1 508.3 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. /x - 1083 6 0 24.0 67.9 91.5 2 0.0 0.0 1 0 2 /z-108 0.92 145.0 0.156 /23-108 HEAT SINK 109 - FLOOR BTWN EQUPT RM 164' (25) AND CTRL RM PLENUM (22) 1 1 22 2 25 3 2497.6 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-109 3 0 8.0 72.8 82.6 2 0.0 0.0 1 0 2 /z-109 0.92 145.0 0.156 /Z3-109 HEAT SINK 110 - FLOOR BTWN CORRIDOR (2) AND EQPT RM EL 164 (25) 1 1 2 2 25 3 825.7 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-110 3 0 24.0 80.4 90.6 2 0.0 0.0 1 0 2 /z-110 0.92 145.0 0.156 /Z3-110 HEAT SINK 111 - FLOOR BTWN EQUPT RM 164' (25) AND CTRL RM PLENUM (22) 1 1 22 2 25 3 833.6 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-111 6 0 24.0 66.1 86.4 2 0.0 0.0 1 0 2 /Z-111 0.92 145.0 0.156 /23-111 HEAT SINK 112 - OPENINGS IN SUSP CEILING ABOVE CTRL RM (1) 1 1 1 12 22 10 54.1 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0 3 /X-112 1 0 0.10 60.4 60.4 2 0.0 0.0 1 0 2 /Z-112 10000.0 0.01 0.01 /Z3-112 HEAT SINK 113 - MCB FRAME & POWER-STRUTS IN CTRL RM (1) 1 1 1 1 0 0 1000.0 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0 3 /X-113 2 0 0.151 80.0 80.0 2 0.0 0.0 1 0 2 /Z-113 27.0 490.0 0.12 /23-113 HEAT SINK 114 - MISC CONCRETE BLOCK + DRYWALL IN CTRL RM (1) 1 3 1 1 1 1 168.8 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-114 2 0 0.5 77.5 77.5 2 0.0 0.0 1 0 2 /Z-114 0.42 100.0 0.20 /23-114 2 0 8.5 77.5 77.5 2 0.0 0.0 1 0 2 /Z-114

Calc. H-02-0001 Rev 0 Attachment 5

123-114 Page 15 of 20 /Z-114 /x - 115/Z-115 /X-116

0.42 100.0 0.20 /23-114 HEAT SINK 115 - DOOR BTWN CTRL RM (1) AND CORRIDOR (2) 1 1 1 1 2 1 35.9 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0 3 1 0 0.125 80.0 80.0 2 0.0 0.0 1 0 2 0.0114 490.0 0.12 /23-115 HEAT SINK 116 - GRILLE BTWN 480V SWGR RM A (9) AND CRD RM (4) 1 1 9 13 4 10 7.5 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0 3 1 0 0.10 80.0 80.0 2 0.0 0.0 1 0 2 /Z-116 10000.0 0.01 0.01 /Z3-116 HEAT SINK 117 - GRILLE BTWN 480V SWGR RM B (10) AND CRD RM (4) 1 1 10 13 4 10 7.5 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0 1 0 0.10 80.0 80.0 2 0.0 0.0 1 0 2 3 /X-117 /Z - 11710000.0 0.01 0.01 /23-117 HEAT SINK 118 - GRILLE BTWN CORRRIDOR (2) AND STAIRWELL (21) 1 1 2 14 21 10 7.5 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0 3 /X - 1181 0 0.10 80.0 80.0 2 0.0 0.0 1 0 2 /Z-118 10000.0 0.01 0.01 /23-118 HEAT SINK 119 - GRILLE BTWN CORRRIDOR (11) AND STAIRWELL (21) 1 1 11 14 21 10 7.5 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0 3 /X~119 1 0 0.10 80.0 80.0 2 0.0 0.0 1 0 2 /z-119 10000.0 0.01 0.01 /23-119 HEAT SINK 120 - DOOR BTWN CTRL RM (1) AND TURB BLDG 145' (39) 1 1 1 1 39 1 24.7 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-120 1 0 0.125 88.3 102.8 2 0.0 0.0 1 0 2 17 - 1200.0114 490.0 0.12 /23-120 HEAT SINK 121 - DOOR BTWN CORRIDOR (2) AND STAIRWELL (21) 1 1 2 1 21 1 39.4 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 3 /x-121 1 0 0.125 80.0 80.0 2 0.0 0.0 1 0 2 /Z-121 0.0114 490.0 0.12 /Z3-121 HEAT SINK 122 - DOOR BTWN CABLE SPRD RM (3) AND STAIRWELL (21) 1 1 3 1 21 1 24.8 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 3 /x-122 1 0 0.125 80.0 80.0 2 0.0 0.0 1 0 2 /Z-122 0.0114 490.0 0.12 /23-122 HEAT SINK 123 - DOOR BTWN CRD RM (4) AND STAIRWELL (21) 1 1 4 1 21 1 39.4 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. /X-123 1 0 0.125 80.0 80.0 2 0.0 0.0 1 0 2 /Z-123 0.0114 490.0 0.12 /23-123 HEAT SINK 124 - DOOR BTWN CRD RM (4) AND EFIC RM D (8) 1 1 4 1 8 1 32.1 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 0. /x - 1241 0 0.125 80.0 80.0 2 0.0 0.0 1 0 2 /2-124 0.0114 490.0 0.12 /23-124 HEAT SINK 125 - DOOR BTWN CRD RM (4) AND 480V SWGR RM A (9) 1 1 4 1 9 1 36.6 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 0. /X-125 3 1 0 0.125 80.0 80.0 2 0.0 0.0 1 0 2 /Z~125 0.0114 490.0 0.12 /23-125 HEAT SINK 126 - DOOR BTWN CRD RM (4) AND 480V SWGR RM B (10) 1 1 4 1 10 1 36.6 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-126 1 0 0.125 80.0 80.0 2 0.0 0.0 1 0 2 12-126 0.0114 490.0 0.12 /23-126 HEAT SINK 127 - DOOR BTWN EFIC RM A (5) AND EFIC RM D (8) 1 1 5 1 8 1 24.0 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-127 1 0 0.125 80.0 80.0 2 0.0 0.0 1 0 2 /2-127 0.0114 490.0 0.12 /23-127 HEAT SINK 128 - DOOR BTWN EFIC RM B (6) AND EFIC RM C (7) 1 1 6 1 7 1 24.0 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-128 1 0 0.125 80.0 80.0 2 0.0 0.0 1 0 2 /Z-128 0.0114 490.0 0.12 /23-128 HEAT SINK 129 - DOOR BTWN EFIC RM B (6) AND EFIC RM D (8) 1 1 6 1 8 1 42.7 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-129  $1 \ 0 \ 0.125 \ 80.0 \ 80.0 \ 2 \ 0.0 \ 0.0 \ 1 \ 0 \ 2$ /Z-129 0.0114 490.0 0.12 /Z3-129 HEAT SINK 130 - DOOR BTWN CORRIDOR (11) AND REMOTE SHTDN RM (12) 1 1 11 1 12 1 21.5 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-130 1 0 0.125 80.0 80.0 2 0.0 0.0 1 0 2 /Z-130 0.0114 490.0 0.12 /23-130 HEAT SINK 131 - DOOR BTWN CORRIDOR (11) AND STAIRWELL (21) 1 1 11 1 21 1 39.4 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 3 /x - 1311 0 0.125 80.0 80.0 2 0.0 0.0 1 0 2 /Z-131 0.0114 490.0 0.12 /23-131 HEAT SINK 132 - DOOR BTWN CORRIDOR (11) AND 4160V SWGR RM B (20) 1 1 11 1 20 1 39.4 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 0. 3 /x - 1321 0 0.125 80.0 80.0 2 0.0 0.0 1 0 2 12-132 0.0114 490.0 0.12 /23-132 HEAT SINK 133 - DOOR BTWN CORRIDOR (11) AND BATTERY RM B (14)

0.33 38.0 0.2

2 0 9.0 77.5 77.5 2 0.0 0.0 1 0 2
Calc. H-02-0001 Rev 0 Attachment 5 Page 16 of 20

1 1 11 1 14 1 46.9 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 3 /x - 1331 0 0.125 80.0 80.0 2 0.0 0.0 1 0 2 /Z-133 0.0114 490.0 0.12 123-133 HEAT SINK 134 - DOOR BTWN CORRIDOR (11) AND BTRY CHGR RM B (16) 1 1 11 1 16 1 24.7 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-134 1 0 0.125 80.0 80.0 2 0.0 0.0 1 0 2 /Z-134 0.0114 490.0 0.12 /23-134 HEAT SINK 135 - DOOR BTWN BATTERY RM A (13) AND BTRY CHGR RM A (15) 1 1 13 1 15 1 24.7 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-135 1 0 0.125 80.0 80.0 2 0.0 0.0 1 0 2 /Z-135 0.0114 490.0 0.12 /23-135 HEAT SINK 136 - DOOR BTWN BATTERY RM A (13) AND BATTERY RM B (14) 1 1 13 1 14 1 46.7 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 0. /X-136 3 1 0 0.125 80.0 80.0 2 0.0 0.0 1 0 2 /Z-136 0.0114 490.0 0.12 /23-136 HEAT SINK 137 - DOOR BTWN BATTERY RM B (14) AND BTRY CHGR RM B (16) 1 1 14 1 16 1 24.7 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-137 1 0 0.125 80.0 80.0 2 0.0 0.0 1 0 2 /Z~137 0.0114 490.0 0.12 /23-137 HEAT SINK 138 - DOOR BTWN BTRY CHGR RM A (15) AND BTRY CHGR RM B (16) 1 1 15 1 16 1 24.7 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-138 1 0 0.125 80.0 80.0 2 0.0 0.0 1 0 2 /2-138 0.0114 490.0 0.12 /23-138 HEAT SINK 139 - DOOR BTWN BTRY CHGR RM A (15) AND INVERTER RM A (17) 1 1 15 1 17 1 24.7 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-139 1 0 0.125 78.3 79.3 2 0.0 0.0 1 0 2 12-139 0.0114 490.0 0.12 /23 - 139HEAT SINK 140 - DOOR BTWN BTRY CHGR RM A (15) AND INVERTER RM B (18) 1 1 15 1 18 1 24.7 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-140 1 0 0.125 78.3 79.3 2 0.0 0.0 1 0 2 /z-140 0.0114 490.0 0.12 /23-140 HEAT SINK 141 - DOOR BTWN INVERTER RM A (17) AND INVERTER RM B (18) 1 1 17 1 18 1 24.7 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-141 1 0 0.125 80.0 80.0 2 0.0 0.0 1 0 2 /Z-141 0.0114 490.0 0.12 123-141 HEAT SINK 142 - DOOR BTWN INVERTER RM B (18) AND 4160V SWGR RM A (19) 1 1 18 1 19 1 24.7 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-142 1 0 0.125 79.3 78.3 2 0.0 0.0 1 0 2 /Z-142 0.0114 490.0 0.12 723 - 142HEAT SINK 143 - DOOR BTWN 4160V SWGR A (19) AND 4160V SWGR B (20) 1 1 19 1 20 1 39.4 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-143 1 0 0.125 80.0 80.0 2 0.0 0.0 1 0 2 /2 - 1430.0114 490.0 0.12 /Z3-143 HEAT SINK 144 - DOOR BTWN STAIRWELL (21) AND EAST SOLAIR (27) 1 1 21 1 27 11 24.7 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-144 1 0 0.125 84.1 124.5 2 0.0 0.0 1 0 2 /2-144 0.0114 490.0 0.12 /Z3-144 HEAT SINK 145 - DOOR BTWN STAIRWELL (21) AND TURBINE BLDG 145'(39) 1 1 21 1 39 1 118.1 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-145 1 0 0.125 87.2 100.3 2 0.0 0.0 1 0 2 12-145 0.0114 490.0 0.12 /23-145 HEAT SINK 146 - DOOR BTWN STAIRWELL (21) AND HP AREA (26) 1 1 21 1 26 1 39.4 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 0. /X-146 3 1 0 0.125 80.0 80.0 2 0.0 0.0 1 0 2 12 - 1460.0114 490.0 0.12 /23-146 HEAT SINK 147 - DOOR BTWN STAIRWELL (21) AND EQUIP RM EL 164' (25) 1 1 21 1 25 1 39.4 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. /X-147 3 1 0 0.125 82.7 89.8 2 0.0 0.0 1 0 2 /Z-147 0.0114 490.0 0.12 /Z3-147 HEAT SINK 148 - CONCRETE PILLAR + DRYWALL IN CTRL RM (1) 1 3 1 1 1 1 60.0 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. /X-148 3 2 0 0.5 77.5 77.5 2 0.0 0.0 1 0 2 /Z-148 0.42 100.0 0.20 /23-148 3 0 18.5 77.5 77.5 2 0.0 0.0 1 0 2 /Z-148 0.92 145.0 0.156 /23-148 2 0 19.0 77.5 77.5 2 0.0 0.0 1 0 2 /Z-148 0.42 100.0 0.20 /23-148 HEAT SINK 149 - WALL BET CORRIDOR (2) & WEST SOLAIR (34) 1 1 2 1 34 11 496.2 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0 /X-149 ٦ 6 0 24.0 84.2 134.0 2 0.0 0.0 1 0 2 /Z-149 0.92 145.0 0.156 /Z3-149 HEAT SINK 150 - GRILLE BTWN EFIC RM A (5) & EFIC RM C (7) 1 1 5 15 7 10 4.0 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0 3 /x - 1501 0 0.10 80.0 80.0 2 0.0 0.0 1 0 2 /Z-150 10000.0 0.01 0.01 /23-150 HEAT SINK 151 - GRILLE BTWN EFIC RM A (5) & EFIC RM D (8)

Calc. H-02-0001 Rev 0 Attachment 5 Page 17 of 20

1 1 5 10 8 15 4.0 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0 3 1x - 1511 0 0.10 80.0 80.0 2 0.0 0.0 1 0 2 /2-151 10000.0 0.01 0.01 /23-151 HEAT SINK 152 - GRILLE BTWN EFIC RM B (6) & EFIC RM D (8) 1 1 6 15 8 10 4.0 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0 3 /x - 1521 0 0.10 80.0 80.0 2 0.0 0.0 1 0 2 /2-152 10000.0 0.01 0.01 /Z3-152 HEAT SINK 153 - GRILLE BTWN EFIC RM C (7) & EFIC RM B (6) 1 1 7 15 6 10 4.0 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0 3 /X-153 1 0 0.10 80.0 80.0 2 0.0 0.0 1 0 2 17-153 10000.0 0.01 0.01 /Z3-153 HEAT SINK 154 - GRILLE BTWN EFIC RM C (7) & CRD RELAY RM (4) 1 1 7 15 4 10 4.0 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0 3 /X-154 1 0 0.10 80.0 80.0 2 0.0 0.0 1 0 2 /Z-154 10000.0 0.01 0.01 /23-154 HEAT SINK 155 - GRILLE BTWN EFIC RM B (6) & CRD RELAY RM (4) 1 1 6 15 4 10 4.0 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0 3 /X-155 1 0 0.10 80.0 80.0 2 0.0 0.0 1 0 2 /Z-155 10000.0 0.01 0.01 /23 - 155HEAT SINK 156 - MISC STEEL IN INVERTER RM A (17) 1 1 17 1 0 0 144.4 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0 - 3 /X-156 1 0 0.075 80.0 80.0 2 0.0 0.0 1 0 2 /Z-156 27.0 490.0 0.12 /Z3-156 HEAT SINK 157 - MISC STEEL IN INVERTER RM B (18) 1 1 18 1 0 0 122.8 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0 3 /X-157 1 0 0.075 80.0 80.0 2 0.0 0.0 1 0 2 /Z-157 27.0 490.0 0.12 /73-157 HEAT SINK 158 - MISC STEEL IN 480V SWGR RM A (9) 1 1 9 1 0 0 74.5 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0 3 /X-158 1 0 0.075 80.0 80.0 2 0.0 0.0 1 0 2 /Z-158 27.0 490.0 0.12 /23-158 HEAT SINK 159 - MISC STEEL IN 480V SWGR RM B (10) 1 1 10 1 0 0 70.2 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0 3 /X-159 1 0 0.075 80.0 80.0 2 0.0 0.0 1 0 2 /Z-159 27.0 490.0 0.12 /Z3-159 HEAT SINK 160 - WALL BET EQUIP RM (25) & AUX BLDG (24) 1 1 25 1 24 1 1760.0 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0 3 /X-160 6 0 24.0 95.8 98.2 2 0.0 0.0 1 0 2 17 - 1600.92 145.0 0.156 /Z3-160 HEAT SINK 161 - WALL BET EQUIP RM (25) & EAST SOLAIR (27) 1 1 25 1 27 11 1160 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 0 3 /X-161 6 0 24.0 98.2 127.9 2 0.0 0.0 1 0 2 /Z-161 0.92 145.0 0.156 /23-161 HEAT SINK 162 - WALL BET EQUIP RM (25) & TURB BLDG 164'(23) 1 1 25 1 23 1 1353.4 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 0 3 /X-162 6 0 24.0 98.9 111.1 2 0.0 0.0 1 0 2 /Z-162 0.92 145.0 0.156 /Z3-162 HEAT SINK 163 - CEILING BET EQUIP RM (25) & HORZ SOLAIR (36) 1 1 25 3 36 3 4735.0 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0 3 /X-163 6 0 36.0 95.3 121.5 2 0.0 0.0 1 0 2 /Z-163 0.92 145.0 0.156 /23-163 HEAT SINK 164 - STEEL ELECT PANELS IN CRD/RELAY RM (4) 1 1 4 1 4 1 2064.0 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0 3 /X - 1641 0 0.178 80.0 80.0 2 0.0 0.0 1 0 2 /2-164 27.0 490.0 0.12 /Z3 - 164HEAT SINK 165 - WALLS WITHIN EQUIP RM (25) 1 1 25 1 25 1 2550.0 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0 3 /X-165 6 0 24.0 95.0 95.0 2 0.0 0.0 1 0 2 /2-165 0.92 145.0 0.156 /23-165 HEAT SINK 166 - HEAT SOURCE WITHIN INVERTER A CABINETS (30) 1 1 30 0 30 5 343.2 0.0 500.0 0. 0. 0. 0. 0. 0. 0 3 /X-166 2 0 0.814 108.0 108.0 2 2097.8 2097.8 1 0 2 /Z-166 27.0 490.0 0.12 /23-166 HEAT SINK 167 - HEAT SOURCE WITHIN INVERTER B CABINETS (31) 1 1 31 0 31 5 374.0 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0 3 /X-167 2 0 1.008 108.1 108.1 2 1713.5 1713.5 1 0 2 /Z-167 27.0 490.0 0.12 173-167 HEAT SINK 168 - STEEL BEAMS IN 480V SWGR RM A (9) 1 1 9 1 0 0 322.0 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0 3 /X-168 1 0 0.198 80.0 80.0 2 0.0 0.0 1 0 2 /Z-168 27.0 490.0 0.12 /23 - 168HEAT SINK 169 - HEAT SOURCE WITHIN 480V SWGR A CABINETS (32) 1 1 32 0 32 8 518.0.0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0 3 /X-169 2 0 0.70 108.0 108.0 2 1475.5 1475.5 1 0 2 /Z-169 27.0 490.0 0.12 /23-169 HEAT SINK 170 - HEAT SOURCE WITHIN 480V SWGR B CABINETS (33)

Calc. H-02-0001 Rev 0 Attachment 5 Page 18 of 20

1 1 33 0 33 8 437.0 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0 3 /X-170 2 0 0.763 110.7 110.7 2 1854.4 1854.4 1 0 2 /Z-170 27.0 490.0 0.12 /23-170 HEAT SINK 171 - STEEL BEAMS IN 480V SWGR RM B (10) 1 1 10 1 0 0 322.0 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0 3 /X-171 1 0 0.198 80.0 80.0 2 0.0 0.0 1 0 2 /2-171 27.0 490.0 0.12 /23-171 HEAT SINK 172 - STEEL BEAMS IN CRD ROOM (4) 1 1 4 1 0 0 2726.6 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0 3 /X - 1721 0 0.199 80.0 80.0 2 0.0 0.0 1 0 2 /Z-172 27.0 490.0 0.12 /23-172 HEAT SINK 173 - HEAT SOURCES IN EFIC ROOM A (5) 1 1 5 0 5 16 220.1 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0 3 /X-173 2 0 0.295 108.0 108.0 2 3834.3 3834.3 1 0 2 /z-173 27.0 490.0 0.12 /23-173 HEAT SINK 174 - STEEL BEAMS IN EFIC RM A (5) 1 1 5 1 0 0 147.6 0.0 500.0 0. 0. 0. 0. 0. 0. 0 3 /X-174 1 0 0.190 80.0 80.0 2 0.0 0.0 1 0 2 /Z-174 27.0 490.0 0.12 /23-174 HEAT SINK 175 - DUCTS IN EFIC RM A (5) 1 1 5 1 5 1 46.0 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0 3 /x-175 1 0 0.03 80.0 80.0 2 0.0 0.0 1 0 2 /z-175 27.0 490.0 0.12 /23-175 HEAT SINK 176 - HEAT SOURCES IN EFIC ROOM B (6) 1 1 6 0 6 16 332.7 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0 3 /X-176 2 0 0.269 98.4 98.4 2 2392.3 2392.3 1 0 2 /2-176 27.0 490.0 0.12 /23-176 HEAT SINK 177 - STEEL BEAMS IN EFIC RM B (6) 1 1 6 1 0 0 94.7 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0 1 0 0.140 80.0 80.0 2 0.0 0.0 1 0 2 З. /X-177 /2-177 27.0 490.0 0.12 /23-177 HEAT SINK 178 - DUCTS IN EFIC RM B (6) 1 1 6 1 6 1 209.0 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0 3 /X-178 1 0 0.03 80.0 80.0 2 0.0 0.0 1 0 2 /Z-178 27.0 490.0 0.12 /23-178 HEAT SINK 179 - HEAT SOURCES IN EFIC ROOM C (7) 1 1 7 0 7 16 243.0 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0 1 0 0.3175 104.8 104.8 2 3018.2 3018.2 1 0 2 3 /X-179 /Z-179 27.0 490.0 0.12 /23 - 179HEAT SINK 180 - STEEL BEAMS IN EFIC RM C (7) 1 1 7 1 0 0 144.7 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0 3 /X-180 1 0 0.200 80.0 80.0 2 0.0 0.0 1 0 2 /Z-180 27.0 490.0 0.12 /Z3-180 HEAT SINK 181 - DUCTS IN EFIC RM C (7) 1 1 7 1 7 1 209.0 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0 3 /X-181 1 0 0.03 80.0 80.0 2 0.0 0.0 1 0 2 /Z-181 27.0 490.0 0.12 /Z3-181 HEAT SINK 182 - HEAT SOURCES IN EFIC ROOM D (8) 1 1 8 0 8 16 113.8 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0 1 0 0.355 118.1 118.1 2 4800.7 4800.7 1 0 2 3 /X-182 /Z-182 27.0 490.0 0.12 /23-182 HEAT SINK 183 - STEEL BEAMS IN EFIC RM D (8) 1 1 8 1 0 0 94.7 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0 3 /X-183 1 0 0.140 80.0 80.0 2 0.0 0.0 1 0 2 /Z-183 27.0 490.0 0.12 /23-183 HEAT SINK 184 - DUCTS IN EFIC RM D (8) 1 1 8 1 8 1 26.0 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0 3 /X-184 1 0 0.03 80.0 80.0 2 0.0 0.0 1 0 2 /Z-184 27.0 490.0 0.12 /23-184 HEAT SINK 185 - CABINET (30) TO INVERTER RM A (17) 1 1 30 6 17 18 35.25 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 0 3 /X-185 1 0 0.10 80.0 80.0 2 0.0 0.0 1 0 2 /Z-185 10000.0 0.01 0.01 /Z3-185 HEAT SINK 186 - CABINET (31) TO INVERTER RM B (18) 1 1 31 6 18 18 38.9 0.0 500.0 0. 0. 0. 0. 0. 0. 0 3 /X-186 1 0 0.10 80.0 80.0 2 0.0 0.0 1 0 2 /Z-186 10000.0 0.01 0.01 /23-186 HEAT SINK 187 - XFMRS IN INVERTER ROOM A (17) 1 1 17 0 17 7 40.0 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0 3 1 0 1.224 100.0 100.0 2 2991.2 2991.2 1 0 2 /X-187 /Z-187 27.0 490.0 0.12 /Z3-187 HEAT SINK 188 - XFMRS IN INVERTER ROOM B (18) 1 1 18 0 18 7 40.0 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-188 1 0 1.224 101.5 101.5 2 3300.0 3300.0 1 0 2 /Z-188 27.0 490.0 0.12 /23-188 HEAT SINK 189 - CABINETS (32) TO 480V SWGR RM A (9)

Calc. H-02-0001 Rev 0

Attachment 5 Page 19 of 20

1 1 32 9 9 18 88.0 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0 3 /X-189 1 0 0.10 80.0 80.0 2 0.0 0.0 1 0 2 /Z-189 10000.0 0.01 0.01 723 - 189HEAT SINK 190 - CABINETS (33) TO 480V SWGR RM B (10) 1 1 33 9 10 18 101.9 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-190 1 0 0.10 80.0 80.0 2 0.0 0.0 1 0 2 /Z-190 10000.0 0.01 0.01 /Z3-190 HEAT SINK 191 - MISC STEEL PANELS IN BTRY CHGR RM A (15) 1 1 15 1 15 1 228.0 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0 /X-191 3 1 0 0.226 80.0 80.0 2 0.0 0.0 1 0 2 /7-191 27.0 490.0 0.12 /Z3-191 HEAT SINK 192 - MISC STEEL PANELS IN BTRY CHGR RM B (16) 1 1 16 1 16 1 228.0 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0 /X-192 1 0 0.226 80.0 80.0 2 0.0 0.0 1 0 2 17-192 27.0 490.0 0.12 /Z3 - 192HEAT SINK 193 - HEAT SOURCE CONTROL ROOM (1) CABINETS 1 1 1 0 1 4 6634.0 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0 3 /X-193 1 0 0.1229 98.0 98.0 2 1551.5 1551.5 1 0 2 /2-193 27.0 490.0 0.12 123-193 HEAT SINK 194 - SWGR CABINETS IN 4160V SWGR RM A (19) 1 1 19 1 19 1 735.0 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0 /x-194 1 0 0.400 80.0 80.0 2 0.0 0.0 1 0 2 /Z-194 27.0 490.0 0.12 173-194 HEAT SINK 195 - SWGR CABINETS IN 4160V SWGR RM B (20) /X-195 /z-195 1 0 0.400 80.0 80.0 2 0.0 0.0 1 0 2 27.0 490.0 0.12 /23-195 HEAT SINK 196 - HEAT SOURCE CONTROL ROOM (1) MCB 1 1 1 4 1 4 1885.3 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0 3 /X-196 1 0 0.128 94.57 94.57 2 2247.0 2247.0 1 0 2 /Z-196 27.0 490.0 0.12 /23-196 HEAT SINK 197 - SUPPLY DUCTS 1 1 28 19 0 0 5006.0 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0 3 /X-197 1 0 0.0326 60.0 60.0 2 0.0 0.0 1 0 2 /Z-197 27.0 490.0 0.12 /23-197 HEAT SINK 198 - RETURN DUCTS 1 1 28 19 0 0 4647.0 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0 3 /X-198 1 0 0.0327 80.0 80.0 2 0.0 0.0 1 0 2 12 - 19827.0 490.0 0.12 /23-198 HEAT SINK 199 - COOLING COIL AHHE-5 1 2 28 19 0 0 518.0 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0 3 /X-199 1 0 0.143 60.9 60.9 2 0.0 0.0 1 0 2 /Z - 199220.0 558.0 0.091 /Z3-199 1 0 0.275 53.1 53.1 2 0.0 0.0 1 0 2 /Z-199 0.34 62.0 1.0 /Z3-199 HEAT SINK 200 - CONCRETE COLUMN IN PLENUM 1 1 22 1 22 1 609.5 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0 3 /X - 2002 0 28.9 60.4 60.4 2 0.0 0.0 1 0 2 /Z-200 0.92 145.0 0.156 /23-200 HEAT SINK 201 - WALL BTWN CABLE GALLERY (3) AND MACH SHOP (38) 1 1 3 1 38 1 526.5 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-201 6 0 24.0 78.0 79.5 2 0.0 0.0 1 0 2 /2-201 0.92 145.0 0.156 /23-201 HEAT SINK 202 - WALL BTWN BATTERY RM A (13) AND MACH SHOP (38) 1 1 13 1 38 1 81.2 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-202 6 0 24.0 78.0 79.5 2 0.0 0.0 1 0 2 /Z - 2020.92 145.0 0.156 /Z3-202 HEAT SINK 203 - WALL BTWN BTRY CHARGER RM A (15) AND MACH SHOP (38) 1 1 15 1 38 1 39.0 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 3 /X-203 6 0 24.0 78.0 79.5 2 0.0 0.0 1 0 2 /2-203 0.92 145.0 0.156 /23-203 HEAT SINK 204 - WALL BTWN INVERTER RM A (17) AND MACH SHOP (38) 1 1 17 1 38 1 124.5 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 0. /X-204 3 6 0 24.0 80.0 80.0 2 0.0 0.0 1 0 2 /Z-204 0.92 145.0 0.156 /23-204 HEAT SINK 205 - CEILING BTWN STAIRWELL (21) AND HORZ SOLAIR (36) 1 1 21 2 36 3 336.1 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 0. /X-205 3 3 0 36.0 81.3 120.1 2 0.0 0.0 1 0 2 /Z-205 0.92 145.0 0.156 /23-205 HEAT SINK 206 - WALLS BTWN STAIRWELL (21) AND SOUTH SOLAIR (35) /X-206 3 0 24.0 81.8 107.9 2 0.0 0.0 1 0 2 /z-206 0.92 145.0 0.156 /23-206 HEAT SINK 207 - WALLS BTWN STAIRWELL (21) AND WEST SOLAIR (34) 1 1 21 1 34 11 160.4 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 3 /X-207 3 0 24.0 84.2 134.0 2 0.0 0.0 1 0 2 /Z-207

0.92 145.0 0.156 /23-207 HEAT SINK 208 - WALL BET CORRIDOR (2) & INTER BLDG (AUX) (24) 1 1 2 1 24 11 152.7 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0 /X-208 3 6 0 24.0 81.7 94.8 2 0.0 0.0 1 0 2 /z-208 0.92 145.0 0.156 /Z3-208 HEAT SINK 209 - WALL BET EQUIP RM (25) & WEST SOLAIR (34) 1 1 25 1 34 11 757 0.0 500.0 0. 0. 0. 0. 0. 0. 0. 0. 0 3 /X-209 6 0 24.0 98.3 137.4 2 0.0 0.0 1 0 2 /Z-209 0.92 145.0 0.156 /23-209 3 1.46 8\*0 /ZZ1-1 CONST HTC WALLS /ZZ1-2 CONST HTC HORIZ W/ HEAT FLOW UP /ZZ1-3 CONST HTC HORIZ W/ HEAT FLOW DOWN 3 1.63 8\*0 3 1.08 8\*0 13 0 0 0.3369 0.333 5\*0 /ZZ1-4 CONTROL ROOM CABINETS & MCB 3 14.22 8\*0 /ZZ1-5 CONST HTC INVERTER HEAT SOURCE 3 76.94 8\*0 /ZZ1-6 CONST HTC INVERTER CABINETS 13 0 0 5.622 0.333 5\*0 /ZZ1-7 XFMRS IN INVERTER ROOMS 13 0 0 3.990 0.333 5\*0 /ZZ1-8 480V SWGR HEAT SOURCE 13 0 0 10.727 0.333 5\*0 /ZZ1-9 480V SWGR CABINETS 4 1 4 7\*0 /ZZ1-10 TIME DEP HTC 3 1.46 8\*0 /ZZ1-11 CONSTANT HTC still air OUTSIDE walls 13 0 0 1.1 0.55 5\*0 /ZZ1-12 TEMP DEP HTC - CTRL RM CEILING 13 0 0 6.0 0.50 5\*0 /ZZ1-13 TEMP DEP HTC - 480V SWGR RM GRILLES 13 0 0 4.6 0.50 5\*0 /ZZ1-14 TEMP DEP HTC - STAIRWELL GRILLES 13 0 0 5.0 0.50 5\*0 /ZZ1-15 TEMP DEP HTC - EFIC ROOMS 13 0 0 1.107 0.333 5\*0 /ZZ1-16 EFIC ROOM CABINETS HEAT SOURCE 13 0 0 1.23 0.55 5\*0 /ZZ1-17 TEMP DEP HTC - TEMP CTRL RM OPENINGS 3 10000.0 8\*0 /ZZ1-18 CONST HTC INVTR & SWGR CABINETS 4 2 4 7\*0 /ZZ1-19 TIME DEP HTC - INSIDE DUCTS 0.0 10000.0 1800. 10000.0 1800. 0.0 1.0E7 0.0 /ZZ2-1 0.0 0.0 1800. 0.0 1800. 1.0 1.0E7 /222-2 1.0 /ZZP 123 0 /

Calc. H-02-0001 Rev 0 Attachment 5 Page 20 of 20



## INTEROFFICE CORRESPONDENCE A-C-XMTL FRM

Design Engineering Office

NA1E MAC

240-3415

Telephone

SUBJECT. Crystal River Unit 3

Quality Record Transmittal - Analysis/Calculation

TO. Records Management - SA2A

The following analysis/calculation package is submitted as the QA Record copy

			r
DOCNO (FPC DOCUMENT IDENTIFICATION NUMBER)	REV 11	SYSTEM(S) RC	TOTAL PAGES TRANSMITTED
1-00-0020			

TITLE

RC PRESSURE (WIDE RANGE) LOOP ACCURACY CALCULATION

KWDS (IDENTIFY KEYWORDS FOR LATER RETRIEVAL)	REMOTE SHUTDO		FLORIDA POWER CORPORATION UCLEAR ENGINEERING DEPARTMENT CRYSTAL RIVER UNIT 3 REVIEWED AND ACCEPTED BY.		
DXREF (REFERENCES OR FILES - LIST PRIMARY FILE F SP-161C	IRST)	ENGINEER A Samand DATE 11/9/19			
I-89-0004, I-94-0012, I-88-0006, I-88-0015		SUPERVISOR S.Z. BOPKUER AND DATE 11/9/99			
VEND (VENDOR NAME) Framatome	VENDOR DOCUMENT NUMBER (DXREF)		SUPERSEDED DOCUMENTS (DXREF) I-88-0020 Revision 10		
		TAG			
See Attached Sheet					
	F	PART NO.			
COMMENTS (USAGE RESTRICTIONS, PROPRIETARY,	ETC)	E/COPM de La	ATB   99		

Incorporate revised 430PM This calculation was revised to correct the Zone 58 accident-temperature in the Design Inputs, and correct

Typographical errors in the CEloop equations No changes to the calculated uncertainties resulted.

### NOTE:

Use Tag number only for valid tag numbers (i e , RCV-8, SWV-34, DCH-99); otherwise, use Part number field (i e., CSC14599, AC1459). If more space is required, write "See Attachment" and list on separate sheet.

\*\*FOR RECORDS MANAGEMENT USE ONLY \*\*

Quality Record Transmittal received and information entered into SEEK.

Date Entered by: \_

(Return copy of Quality Record Transmittal to DE Support Specialist.)

DATE SUPERVISOR, DESIGN ENG DATE VERIFICATION ENGINEER DATE DESIGN ENGINEER 11-3-99 22/9 m m. LESNIA, Robert H Ficke Edwin D. Lee

Nuclear Projects (If MAR/CGWR/PEERE CC: Return to Service Related) 🗌 Yes 🛛 No Supervisor, Config Mgt Info

Mgr., Design Engineering (Original) w/attach

Mgr., Radiological Emergency Planning w/attach 🔲 Yes 🔀 No

Calculation Review form Part III actions required TYes X No (If Yes, send copy of the Calculation to the Responsible Organization(s) Identified In Part III on the Calculation Review form )

D M Porter w/attach

1999



Crystal River Unit 3 DESA-C FRM

	Page	<u> </u>	or	
DOCUMENT IDENTIFICATION NO I-88-0020		REVISION	11	

## I. <u>PURPOSE</u>:

The purpose of this calculation is to determine the instrument loop accuracy of the RC Wide Range Pressure loops (transmitters RC-158-PT and RC-159-PT) that provide Control Room indication and recording for Normal and Post-Accident Monitoring (Technical Specification 3.3.17.2.(3) - Reference 2), RECALL/SPDS, Remote Shutdown Indication (Technical Specification 3.3.18.2.(2a) - Reference 2) and input to ATWS.

The RCS Wide Range Pressure Indication is a Reg. Guide 1.97 Type A variable (Reference 4.a). Therefore, per Attachment 5 of the I&C Design Criteria for Instrument Loop Uncertainty Calculations (Reference 1), this calculation will be developed as a Category B Loop.



ſ



Crystal River Unit 3

Page 29 of 73

DOCUMENT IDENTIFICATION NO I-88-0020 REVISION

## IV. ASSUMPTIONS (A):

1. The modules and indicators located in Control Complex EQ Zones 13 and 58 will be calibrated at a temperature between 70° and 80°F, based on the Normal Temperature range stated in Design Inputs(DI) 6, 10, and 13, and on the M&TE accuracy selected in DI 31(2).

The modules and indicators located in EQ Zones 13 and 58 will be operated over a normal temperature range of  $60^{\circ}$  to  $80^{\circ}$ F. This range is based on the maximum Normal Temperature stated in DI 6, 10, and 13 and an assumed minimum temperature. The maximum temperature is maintained at the DI 6, 10, and 13 stated value of  $80^{\circ}$ F since the Control Complex Heat Load Evaluation calculation M-97-0020 (reference 10.j) assumes this to be the maximum initial temperature for evaluation. The minimum temperature is assumed to be  $60^{\circ}$ F, since this bounds the minimum Normal Temperature stated in DI 6, 10, and 13 and also allows for continued analyzed plant operations during HVAC equipment problems when the temperature may decrease below the minimum value stated in DI 6, 10, and 13.

The modules and indicators located in EQ Zones 13 and 58 will be operated over an accident temperature range of 60° to 104°F. This range is based on the minimum assumed temperature discussed in the paragraph above. The maximum accident temperature in the control complex was determined by calculation M97-0020 (Reference 10.j) to be 104°F, experienced during a LOCA in conjunction with a Loss of Offsite Power. This maximum temperature also allows for continued analyzed plant operations up to the vendor stated limit for the lowest maximum temperature rated component in the loop. The Foxboro components are limited to 104°F per Product Specification PSS 9-7A1A page 4 located in Instruction Manual 586 (reference 17.b), which states a 104°F ambient limit for racks fully loaded with one power supply and no fans, the configuration which exists in the Remote Shutdown Auxiliary Equipment Cabinet.

Considering the above paragraphs, the module and indicator/recorder temperature effects will be calculated for the maximum change in temperature of the component from the temperature at which it was calibrated to the temperature at which it will be operated. For normal conditions, the component will be assumed to be calibrated at 80°F and operated at  $60^{\circ}F$  for a  $20^{\circ}F$  change (80-60) and for accident conditions, the component will be assumed to be calibrated at  $104^{\circ}F$  for a  $34^{\circ}F$  change (104-70).

2. Assume that the pressure transmitters located in EQ Zone 66 can be calibrated at either 70°F (minimum temperature for this Zone) or 109°F (maximum temperature for this Zone). Therefore, a 39°F change will be used in the calculation. This will ensure that any temperature effects are conservatively calculated.

) (



)

1.

**DESIGN ANALYSIS/CALCULATION** 

Crystal River Unit 3

			Page	<u>    47    </u>	of	73
DOCUMENT IDENTIFICATION N	10			REVISION	11	
E	=	Seismic Effect = $\pm 0.0\%$			DIS	<b>.</b> 4
s E	=	Radiation Effect = $\pm$ (1.5% URL + 1.0% span)				
FAD	=	±[(1.5 x 3000 psig) + (1.0 x 3000 psig)]/3000 psig ±2.5% span				
E <sub>pta</sub>	=	$\pm [(E_{REF})^{2} + (E_{P/T})^{2} + (E_{RAD})^{2}]^{\frac{1}{2}}$				
		$ \begin{array}{l} \pm [(0.25)^2 + (3.0)^2 + (2.5)^2]^{\frac{1}{8}} \\ \pm [(0.0625) + (9.0) + (6.25)]^{\frac{1}{8}} \\ \pm [15.3125]^{\frac{1}{8}} \\ \pm 3.91\% \underline{span} \end{array} $				
<u>Device I/V</u>	<u>/</u> :	Foxboro N2AI-I2V Current-to-Voltage Converter $(E_{IV})$			Ĩ	)17
<u>Normal</u> E <sub>ref</sub>	-	Reference Accuracy = $\pm$ 0.25% span				
E,	=	Temperature Effect = $\pm 0.5\%$ span/45°F				
		±(0.5/45°F) x (20°F) ±0.22% span				A1
E <sub>IN</sub>	=	$\pm [(E_{REF})^{2} + (E_{T})^{2}]^{x}$				
	11 11	±[(0.25) <sup>2</sup> + (0.22) <sup>2</sup> ] <sup>k</sup> <u>±0.33% span</u>				
<u>Acciden</u> E <sub>REF</sub>	<u>it</u> =	Reference Accuracy = $\pm$ 0.25% span				
- E,	=	Temperature Effect = $\pm 0.5\%$ span/45°F				
	=	´±(0.5/45°F) x (34°F) ±0.38% span				A1
E <sub>r/v</sub>	=	$\pm [(E_{REF})^2 + (E_T)^2]^{\frac{1}{2}}$				
	=	±[(0.25) <sup>2</sup> + (0.38) <sup>2</sup> ] <sup>%</sup> <u>±0.45%_span</u>				
Device V/V	<u>/</u> :	Foxboro N2AO-VAI Signal Converter/Isolator (E <sub>v/v</sub> )			1	<b>SI8</b>
<u>Normal</u> E <sub>ref</sub>	=	Reference Accuracy = $\pm$ 0.5% span				
E <sub>r</sub>	=	Temperature Effect = $\pm$ 0.5% span/45°F				
	2	±(0.5/45°F) x (20°F) ±0.22% span				A1

## **P**Foduct Specifications



# SPEC 200 SEISMIC RACKS AND RACK-MOUNTED EQUIPMENT

# Seismically type-tested and subject to the stringent controls required for nuclear applications

### NUCLEAR SERVICE QUALIFICATION

The SPEC 200 Racks and Rack-Mounted Equipment covered in this specification are subjected to type testing and/or analysis to provide a basis for nuclear power plant qualification. The products offered for Class 1E service are evaluated in accordance with the Foxboro interpretation of IEEE Standards 323-1974 and 344-1975. Other products offered are evaluated for structural integrity per IEEE Standard 344-1975. N-Series equipment is virtually identical to the corresponding non-nuclear equipment, although certain mechanical modifications result from seismic requirements

## STRINGENT QUALITY ASSURANCE PROGRAM

The Foxboro quality assurance program meets the requirements of 10CF350, Appendix B; ANSI N45.2; MIL-Q-9858A; and CSA Z299.2. The program has been audited by the U.S. Nuclear Regulatory Commission and by a number of users in the nuclear power industry.

### SIMPLIFIED INSTALLATION

Modular design permits assembly of up to five doublefaced racks into one shippable section. The interconnecting wiring within a section can be installed and checked prior to shipment to the user. Connections to remote SPEC 200 display instruments are made by standard flame-retardant cables with plug connectors at both ends. Optional terminal block assemblies for field wiring can occupy either or both faces of any rack. Provision is made for top and/or bottom entry of cable to the racks. In addition, racks can be specified for either bolting or welding to the user's support structure.

DOCUMENT CONTROL C2E



© 1982 by The Foxboro Company

FEB 10 1988 REVISION 5



QOAAA04 - Seismic Vibration Test Procedure for

- Part 3 Current Production Rack-Mounted Modules for Class 1E Qualification per IEEE 344-1975.
- QOAAA05 Qualification by Similarity of SPEC 200 Rack-Mounted Modules and Power Supplies for Class 1E Functions under Seismic Environments.
- QOAAA06 Similarity of SPEC 200 Rack-Mounted Modules of Current Production Design to Type-Tested, Naturally Aged Modules.
- QOAAA07 Simulation of Advanced Life Condition of 2ARPS-A6, Style D Multi-Nest Power Supplies for Class 1E Qualifications.
- QOAAA08 Environmental Test of Fully-Loaded N-2ES Rack.
- QOAAA19 Determination of Seismic Vibration Test Response Spectra for Possible Loading Configurations of N-2ES Style B Rack.

## **Test Results Documents**

- QOAAA16 Seismic Testing of N-2ES Style B Racks for Structural Integrity Qualification per IEEE 344-1975.
- QOAAA20
   Seismic Testing of SPEC 200 Current

   Part 1
   Production Model Rack-Mounted Modules

   in an N-2ES Style B Rack.
- QOAAA20 Seismic Testing of N-2ES Style B Rack Part 2 and Naturally-Aged Modules for Class 1E Qualification for IEEE 344-1975.
- QOAAA20 Appendix A, Determination of SSE Floor Level Response Spectra to which SPEC 200 Modules have been qualified in specific N-2ES Rack Loading Configurations.
- QOAAA24 Heat Rise Test on N-2ES Racks.
- QOAAB01 Class 1E Qualification of SPEC 200 Instrumentation Equipment to Generic Service Conditions per IEEE 323-1974 and IEEE 344-1975 (Summary).

Type Test Reports for individual system components are tabulated with the descriptions of the various components in a later section.

#### **Generic Values**

IEEE Standard 323-1974 requires that a product to be qualified for Class 1E service must be subjected to all influences of normal, abnormal, and Design Basis Event (DBE) conditions, allowing for margin.

The Foxboro qualification test program first established a data base at reference conditions. This data was then compared to data obtained from tests at the normal operating limits specified for each parameter. The normal operating limit specifications are listed later in this document.

Foxboro believes that the specified normal operating limits encompass both the normal and abnormal conditions specified in most nuclear power plant locations for equipment of this type. Next, testing was extended to encompass seismic (DBE) operating conditions, and to satisfy margin requirements. The following are the limits used , where applicable during qualification testing

**Temperature Limits**—5 and 60°C (40 and 140°F) at the nest-mounted equipment. The maximum value, considering temperature rise in the rack and margin, is not exceeded when:

- a) rack is fully loaded, has two power supplies per face, is equipped with fan(s), and the outside room temperature is 40°C (104°F) maximum;
- b) rack is fully loaded, has only one power supply per face, is equipped with fan(s), and the outside room temperature is 44°C (110°F) maximum;
- c) rack is fully loaded, has only one power supply per face, is equipped with top louvers, and the outside room temperature is 40°C (104°F) maximum
- Relative Humidity-50 and 95% at 30°C (86°F) max-

imum wet bulb temperature.

## Radiation-None

Mains Supply Voltage—Reference +10 and -15%. System dc power supply outputs do not vary more than  $\pm 5\%$  for +10 and -15% variation in mains supply voltage.

Mains Supply Frequency-47 and 53 Hz, or 57 and 63 Hz.

dc Supply Voltage-Reference + 5 and - 5%.

Vibration—Operating Basis Earthquake (OBE) and Safe Shutdown Earthquake (SSE) as described below.

### Seismic Testing

Generic floor-level SSE and OBE required response spectra were established which conservatively enveloped control room required response spectra for a number of nuclear power generating stations. The generic required response spectra which represented target qualification levels were applied as seismic inputs to N-2ES Racks to provide a basis for Class II (structural integrity) qualification as documented in Test Report QOAAA16.

Testing was conducted with random multi-frequency input applied biaxially for each of four rack orientations using a 45-degree vectored drive. Five tests at the OBE level and one test at the SSE level were run in each of the four orientations following the procedures of IEEE 344-1975.

Test response spectra at equipment locations obtained in the above tests were used as a basis for establishing target required response spectra for Class 1E qualification of rack-mounted components. A variety of rack loading configurations also were tested with the generic (target) floorlevel SSE input to provide test response data at locations significant to such configurations. Test procedures are detailed in Document QOAAA19. Test results are presented in QOAAA20, Appendix A.

Class 1E seismic testing of the rack-mounted nest equipment was performed using N-2ES Racks as test fixtures Results of this testing are reported in Test Reports OOAAA20, Parts 1 and 2. DOCUMENT CONTROL C2E In general, the test response spectra for the nest devices enveloped those obtained at device locations of the desired rack loading configurations with generic (target) floor-level seismic inputs.

In the few instances where complete enveloping was not obtained, the designated seismic qualification level for the rack configuration in question was reduced below that of the target floor-level response spectra by the factor of undertesting determined. This is detailed in Foxboro Test Report QOAAA20, Appendix A. In turn, generic OBE and SSE floor-level test response spectra were developed which were enveloped by the designated seismic qualification levels of the several rack configurations of Test Report QOAAA20, Appendix A. These generic qualification levels as shown in Figures 1 and 2 are applicable to all configurations of Class 1E rackmounted components listed and illustrated later in this document. Response spectra are given for 1%, 2.5% and 5% of critical damping. Spectra for other damping values can be determined by interpolation.

#### **Operating Limits**

Parameter	Reference	Normal	
Rack Internal Temperature	21 and 25°C (70 and 77°F)	5 and 50°C * (40 and 120°F)	
Relative Humidity	30 and 50 %	10 and 95% at 30°C (86°F) maximum wet bulb	
Mains Supply Voltage	120, 220, or 240 V ac, as applicable	Reference + 10 and - 15%	
Mains Supply Frequency	50 or 60 Hz, as applicable	Reference + 3 and - 3 Hz	
dc Supply	+ 15 and - 15 V dc	Reference + 5 and - 5%	

\*Normal operating limits considering temperature rise in rack (but not margin) when room temperature is 40°C (104°F) maximum, or alternatively, when room temperature is 44°C (110°F maximum), top cover has fan inserts, and there is but one multi-nest power supply in each rack face.



Figure 1. Generic OBE Floor-Level Qualification Response Spectra, Horizontal and Vertical





DOCUMENT CONTROL C2E

> FEB 10 1988 REVISION 5

.



÷

Ĺ

# INTEROFFICE CORRESPONDENCE

CORPORATION	Design En	A-C-XMTL gineering	FRM NAIE	3415
· · · · · · · · · · · · · · · · · · ·	Offic	ce	MAC	Telephone
SUBJECT. Crystal River Unit 3 Quality Record Transr TO: Records Management The following analysis/calculation	nittal - Analysıs/Calcul - SA2A ı package is submitted	ation as the QA Record	І сору:	
DOCNO (FPC DOCUMENT IDENTIFICATION NUMI I-93-0002	BER) REV 6	SYSTEM(S) SP	TOTAL PAGES TRAI	NSMITTED
тисе EFIC –Steam Generator Level I	nstrumentation Loop S	tring Accuracy an	d Setpoints	
KWDS (IDENTIFY KEYWORDS FOR LATER RETRI Steam Generator, EFIC, Error, Natural Circulation, Inadequate	<sub>EVAL)</sub> Indication, Dry Steam Sub Cooling Margin, If	Generator, Record R and Setpoints, <b>E</b>	der, Control Valves, Bist	able, Level,
DXREF (REFERENCES OR FILES - LIST PRIMARY SP-146A, SP-146B, SP-193A, SP-4	FILE FIRST) 416	FL NUCLE	ORIDA POWER CORPOR	ATION ARTMENT
I-92-0008, I-97-0004, I-97-0003,		RE	VIEWED AND ACCEPTE	3D BY:
MAR 92-12-07-01		ENGINEER Re	HARD IWACHUN ALL AL OD-CH	DATE 09/08/9
vend (vendor NAME) Framatome	VENDOR DOCUMENT NU N/A	BER (DXREF) FOR S.	BARKATCKI SUPERSEDED DOG 1-93-0002 R	DATE 9/8/90 CUMENTS (DXREF) ev. 5
		TAG	ر به این می والد کرد. مربق این می والد کرد این می از می این این این این این این این این این ای	
See Attached Sheet				
an in the second state of the s				
	an a	ART NO.	an an search an the second	
COMMENTS (USAGE RESTRICTIONS, PROPRIET This revision replaces revision {	ARY, ETC) 5, all pages except for a	attachment 1, 2, 3	, 4, which are deleted, a	ttachments 5, 6
7, 8, 9, 10, 11, 12, 13, and 17 de	o not change. Attachm	ent 15 and 16 are	revised and replaced.	
Attachment 18 is new. NOTE	THIS CALC IN CW	DES NEW RE	CALL POINTS TO BE	INSTALLED
NOTE: BY M Use Tag number only for valid tag nu (I e , CSC14599, AC1459) If more s	$\mathcal{L}$ 92-12-07-01, umbers (i e., RCV-8, SWV space is required, write "S	9nk 9-3-99 /-34, DCH-99), othe See Attachment" and	rwise, use Part number fie I list on separate sheet.	ld
Quality Rec	**FOR RECORDS MANA cord Transmittal received Entered by	GEMENT USE ON and information ent Date	LY ** ered into SEEK.	
(Return co	opy of Quality Record Tra	nsmittal to DE Supp	oort Specialist.)	
DESIGN ENGINEER DA Randall Harmson 9.3.4	TE VERIFICATION ENGINEER	DATE 4-3-99	SUPERVISOR, DESIGN ENG	рате 9-3-99
Randall Harrison	John N Kurtz	<u>,</u>	L. M. KESNIAK	
cc Nuclear Projects (If MAR/CGWR/I Return to Service Related) Supervisor, Config Mgt Info Mgr, Design Engineering (Origina Mgr, Radiological Emergency Pla	V PEERE Yes No I) w/attach nning w/attach Yes X R E. Wagner w/attach	Calculation Review for (If Yes, send copy of th Identified in Part III on No	m Part III actions required 🕅 ne Calculation to the Responsi the Calculation Review form )	外K 9-3 49 [Yes 伝 No ible Organization(s)
999. G V. Hildebrandt w/attach R Iwachow w/attach	J R Paljug (FTI) W Chase w/attach			

Rev 3/97

SEP 14

()



**Crystal River Unit 3** DESA-C FRM

Page	 of	_234	

DOCUMENT IDENTIFICATION NO 1-93-0002

REVISION

6

#### PURPOSE 1.

Determination of instrument loop accuracy's of the EFIC - Steam Generator transmitters SP-017-LT through SP-032-LT for EFIC low level initiate, overfill, overfill reset, and emergency feedwater valve control; for post-accident monitoring and for normal surveillance requirements.

The EFIC steam generator level measurement instrumentation supports the operation of the emergency feedwater initiation and control system which is required for design basis accident mitigation. The steam generator level instrumentation is used by the control room personnel to perform manual actions as instructed by Emergency Operating Procedures (EOP's). Based on the guidance given in the I&C Design Criteria "Instrument Loop Uncertainty Calculations" (Reference 1), Attachment 5, "Graded Approach Methodology for Instrument Uncertainty", the EFIC steam generator level measurement instruments are divided into three functional areas. The first functional area deals with instruments providing the actuation signal for initiating EFIC based on a low level conditions in either steam generator. The loop uncertainty determination for these instruments follows the methodology format given for a Category A approach. The next area deals with the level instrumentation used to automatically fill the steam generators to predetermined level setpoints based on safety analysis whose uncertainty determination will follow the Category B graded approach methodology. Included in this same category are the main control board pressure instrumentation and Recall and Plant Computer points utilized by the plant operator in mitigation of the design basis events. Additional recall computer points have been added to the calculation resulting from the implementation of MAR 92-12-07-01 (Reference 110). Finally, the Category C Graded Approach methodology is applied in determination of a loop uncertainty for a portion of the steam generator level instrumentation circuit that provides an overfill protective function. The protective function outputs a closure signal to the emergency feedwater vector valves (EFV-11, EFV-14, EFV-32, EFV-33, EFV-55, EFV-56, EFV-57 and EFV-58) on a high steam generator level condition. The protective feature is a back-up in the event control power is loss to either the block valves (EFV-11, EFV-14, EFV-32, and EFV-33) or the control valves (EFV-55, EFV-56, EFV-57 and EFV-58). The overfill protective feature is cleared when the high level condition recedes to a predetermined setpoint allowing the re-opening of the valves. The Graded Approach criteria classifies this type of plant operating mode as characteristic of a Category C determination method.

Refer to Figures 1, 2 and 3 for the depiction of the steam generator level loop strings. Figure 1 represents EFIC Low Level Range Channels A and B. Figure 2 represents EFIC High Level Range Channels A and B. Figure 3 represents both EFIC High and Low Level Ranges Channels C and D.



Crystal River Unit 3

Page 64 of 234

DOCUMENT IDENTIFICATION NO 1-93-0002

REVISION

## IV ASSUMPTIONS (A)

1. The modules and indicators located in Control Complex EQ Zones 13 and 58 will be calibrated at a temperature between 70° and 80°F, based on the Normal Temperature range stated in Design Inputs(DI) #8, #11, and #14, and on the M&TE accuracy selected in DI 33c and 33d.

The modules and indicators located in EQ Zones 13 and 58 will be operated over a normal temperature range of 60° to 80°F. This range is based on the maximum Normal Temperature stated in DI #8, #11, and #14 and an assumed minimum temperature. The maximum temperature is maintained at the DI #8 and #11 stated value of 80°F since the Control Complex Heat Load Evaluation calculation M-97-0020 (Reference 105) assumes this to be the maximum initial temperature for evaluation. The minimum temperature is assumed to be 60°F; since this bounds the minimum Normal Temperature stated in DI #8, #11, and #14 and also allows for continued analyzed plant operations during HVAC equipment problems when the temperature may decrease below the minimum value stated in DI #8, #11, and #14.

The modules and indicators located in EQ Zones 13, and 58 will be operated over an accident temperature range of 60° to 104°F. This range is based on the minimum assumed temperature discussed in the paragraph above. The maximum temperature is assumed to be 104°F experienced during a LOCA in conjunction with Loss of Offsite Power.

The level indicating recorders (DI#17,#18) are Foxboro Model N227 are tested to 135°F to meet Class 1E requirements (Reference 58). Their power supplies (DI 19) are Foxboro Model TI-2AX with a maximum operating temperature of 120°F (Reference 58). The level indicators (DI #8, #9, #10, #14, #15 #16) are International Instruments Model 1251 series with an operating temperature of 122°F (Reference 42). The EFIC Cabinets (power supplies and modules, DI #11) withstand a high temperature of 110°F (Reference 40). Thus, the aforementioned 104°F accident temperature conservatively envelopes the required/listed component specifications in the Control Complex.

Considering the above paragraphs, the module and indicator/recorder temperature effects will be calculated for the maximum change in temperature of the component from the temperature at which it was calibrated to the temperature at which it will be operated. For normal conditions, the component will be assumed to be calibrated at 80°F and operated at 60°F for a 20°F change (80-60) and for accident conditions, the component will be assumed to be calibrated at 70°F and operated at 104°F for a 34°F change (104-70).

- 2. Assume that the differential pressure transmitters located in EQ Zone 66 are calibrated at 70°F, which is the lowest ambient temperature condition expected for this zone. This will ensure that any temperature effects are conservatively calculated.
- The tested cable insulation leakage resistance at a temperature of 300° F will be used for a HELB event within the Intermediate Building, for the following reasons, (cable qualification test data is from Tab F1 of VQP CABL-B365, Reference 18). In addition, the:
  - (1) The test data shows that the cable is subjected to a LOCA event pressure of up to 105 psig and that the cable is above ambient pressure for approximately 3-days. The IB HELB pressure peaks at 6.2 psig, two seconds into the HELB event (zones 21, 53, 57) and then decreases to 0.5 psig at 40 seconds into the event. The pressure is further reduced to 0.1 psig, 17 minutes into the event. The 0.1 psig pressure can be assumed to be ambient pressure.

I-93-0002 REV.6 ATTACHMENT IE PAGE I DE I

Connection of the EFIC cabinet instrument ground is not recommended although connection of the cabinet safety (chassis) ground to a suitable earth ground is recommended.

## 5.4 PHYSICAL LIMITATIONS

The EFIC cabinets are freestanding cabinets designed to be installed as a single-bay or dual-bay cabinet configuration. Cabinet mounting hardware is 5/8 - 11 UNC, SAE Grade 5, ASTM A449, hexagon socket head cap screws, plain washers and helical spring lock washers, 6 places per cabinet. The Switch Panel is designed to be mounted with four 1/4-20 UNC hexagon socket head screws, plain washers and helical spring lock washers. The Remote Hand/Auto Station is designed to be mounted with eight 1/4-28 UNF slotted hexagon head machine screws. The Switch Panel and Hand/Auto Station are designed for mounting in a 0.12 to 1.00 inch thick vertical panel.

Up to 20.1 pounds of customer cabling may be added to channel C and 21.3 pounds may be added to channel A. For a dual-bay cabinet configuration a total of 41.4 pounds of customer cabling may be added.

The EFIC cabinet is designed to operate in an environment of  $40^{\circ}-110^{\circ}$ F and 10% to 90% relative humidity. The control room mounted equipment (i.e. SG Bypass Switch, Switch Panel, Remote Hand/Auto Station) is designed for  $40^{\circ}-140^{\circ}$ F and 10% to 90% relative humidity.