

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.7.3.1	Verify the REC surge tank water level is within limits.	24 hours
SR 3.7.3.2	Verify the temperature of the REC supply water is $\leq 100^{\circ}\text{F}$.	24 hours
SR 3.7.3.3	<p><u>NOTE</u></p> <p>Isolation of flow to individual components does not render REC System inoperable.</p> <p>Verify each REC subsystem manual, power operated, and automatic valve in the flow paths servicing safety related cooling loads, that is not locked, sealed, or otherwise secured in position, is in the correct position.</p>	31 days
SR 3.7.3.4	Verify each REC subsystem actuates on an actual or simulated initiation signal.	18 months