

Sep. 26, 2002

Page 1 of 1

MANUAL HARD COPY DISTRIBUTION

DOCUMENT TRANSMITTAL 2002-44227

50-387/388

USER INFORMATION:

~~FLAIM\*LAUREL B~~ EMPL#:23244 CA#: 0363

~~Address: NUCSA2~~

Phone#: 254-3658

TRANSMITTAL INFORMATION:

~~TO: FLAIM\*LAUREL B~~ 09/26/2002

LOCATION: DOCUMENT CONTROL DESK

FROM: NUCLEAR RECORDS DOCUMENT CONTROL CENTER  
(NUCSA-2)

THE FOLLOWING CHANGES HAVE OCCURRED TO THE HARDCOPY  
OR ELECTRONIC MANUAL ASSIGNED TO YOU:

200 - 200 - RECOVERY MANAGER (RM): EMERGENCY PLAN-  
POSITION SPECIFIC PROCEDURE

REMOVE MANUAL TABLE OF CONTENTS DATE: 08/26/2002

ADD MANUAL TABLE OF CONTENTS DATE: 09/25/2002

CATEGORY: PROCEDURES TYPE: EP

ID: EP-PS-200

ADD: PCAF 2002-1590 REV: N/A

UPDATES FOR HARD COPY MANUALS WILL BE DISTRIBUTED  
WITHIN 5 DAYS IN ACCORDANCE WITH DEPARTMENT  
PROCEDURES. PLEASE MAKE ALL CHANGES AND  
ACKNOWLEDGE COMPLETE IN YOUR NIMS INBOX UPON  
RECEIPT OF HARD COPY. FOR ELECTRONIC MANUAL USERS,  
ELECTRONICALLY REVIEW THE APPROPRIATE DOCUMENTS AND  
ACKNOWLEDGE COMPLETE IN YOUR NIMS INBOX.

A045

51

Manager can delegate ENR approval r

NTS	9. <b>PORC MTG#</b>
-----	---------------------

## PROCEDURE CHANGE PROCESS FORM

1. PCAF NO. <u>2002-1590</u>	2. PAGE 2 OF <u>4</u>	3. PROC. NO. <u>EP-PS-200</u> REV. <u>15</u>
------------------------------	-----------------------	--

11. This question documents the outcome of the 50.59 and 72.48 Review required by NDAP-QA-0726. Either 11a, b, c or d must be checked "YES" and the appropriate form attached or referenced.

a. This change is an Administrative Correction for which 50.59 and 72.48 are not applicable.	<input type="checkbox"/> YES	<input checked="" type="checkbox"/> N/A
b. This change is a change to any surveillance, maintenance or administrative procedure for which 50.59 and 72.48 are not applicable.	<input checked="" type="checkbox"/> YES	<input type="checkbox"/> N/A
c. This change is bounded by a 50.59/72.48 Screen/Evaluation, therefore, no new 50.59/72.48 Evaluation is required. Screen/Evaluation No. _____	<input type="checkbox"/> YES	<input checked="" type="checkbox"/> N/A
d. 50.59 and/or 72.48 are applicable to this change and a 50.59/72.48 Screen/Evaluation is attached.	<input type="checkbox"/> YES	<input checked="" type="checkbox"/> N/A

12. This change is consistent with the FSAR or an FSAR change is required. ☒ YES  
Change Request No. \_\_\_\_\_

13. Should this change be reviewed for potential effects on Training Needs or Material? ☐ YES ☒ NO  
If YES, enter an Action Item @ NIMS/Action/Gen Work Mech/PICN

14. Is a Surveillance Procedure Review Checklist required per NDAP-QA-0722? ☐ YES ☒ NO

15. Is a Special, Infrequent or Complex Test/Evolution Analysis Form required per NDAP-QA-0320? (SICT/E form does not need to be attached.) ☐ YES ☒ NO

16. Reviews may be documented below or by attaching Document Review Forms NDAP-QA-0101-1.

REVIEW	REVIEWED BY WITH NO COMMENTS	DATE
QADR	_____	_____
TECHNICAL REVIEW	_____	_____
REACTOR ENGINEERING/NUCLEAR FUELS *	_____	_____
IST **	_____	_____
OPERATIONS	_____	_____
NUCLEAR SYSTEMS ENGINEERING	_____	_____
NUCLEAR MODIFICATIONS	_____	_____
MAINTENANCE	_____	_____
HEALTH PHYSICS	_____	_____
NUCLEAR TECHNOLOGY	_____	_____
CHEMISTRY	_____	_____
OTHER <u>10 CFR 50.545q</u>	<u>William A. Chou</u>	<u>9-25-02</u>

\* Required for changes that affect, or have potential for affecting core reactivity, nuclear fuel, core power level indication or impact the thermal power heat balance. <sup>(58)</sup>

\*\* Required for changes to Section XI Inservice Test Acceptance Criteria.

**MAJOR TASK:**

Reclassify the emergency based on continuing assessment of the situation.

**SPECIFIC TASKS:**

**HOW:**

- |  |  |
|--|--|
| 1. Monitor conditions to determine if the classification should change.        | 1a. You must reclassify within fifteen minutes of receiving information indicating the need to reclassify.   |
| 2. Evaluate current and projected off-site radiological and plant information. | <p>2a. Obtain and evaluate the following data:</p> <ul style="list-style-type: none"><li>(1) Plant conditions and prognosis received from the Emergency Director.</li><li>(2) Field radiation data received from the Dose Assessment Supervisor or Field Team Director.</li><li>(3) Plant conditions, prognosis and release status received from the Engineering Support Supervisor.</li><li>(4) Fuel integrity and prognosis received from the Fuels Lead Engineer.</li></ul> |
| 3. Reclassify the emergency.   | <p>3a. If the emergency action level is a specific, measured value, reclassify the emergency.</p> <p>3b. If the emergency action level is based on an assessment and is judgmental:</p> <ul style="list-style-type: none"><li>(1) Coordinate an evaluation of the situation among the ED, RM and, if present, the NRC, PEMA, and DEP/BRP.</li><li>(2) Determine the change in classification.</li></ul>  |

**SPECIFIC TASKS:**

**HOW:**

**NOTE:**

If you upgrade to a **GENERAL EMERGENCY**, you must make a **Protective Action Recommendation within fifteen minutes.** (see TAB E)

- 3c. If downgrading from a Site Area or General Emergency, you must obtain concurrence from:
- (1) NRC \_\_\_\_\_
  - (2) DEP/BRP \_\_\_\_\_
  - (3) PPL Senior Management \_\_\_\_\_
4. Ensure changes in classification are communicated to all off-site agencies.
- 4a. Identify the specific number used to reclassify the emergency.
- 4b. Sign, (date and time), the Emergency Notification Report to document your decision.
- NOTE:**  
The Recovery Manager can delegate ENR approval responsibility to another qualified RM located in the facility.
- He can also delegate approval responsibility to the EOF Support Supervisor except for a change in classification.
- 4c. Return the Emergency Notification Report to the EOF Support Supervisor or EOF Communicator for required notification to off-site agencies:
- (1) PEMA
  - (2) LCEMA
  - (3) CCDPS
  - (4) NRC
5. Ensure changes in classification are communicated to the PPL emergency organizations.
- 5a. Notify the:
- (1) Emergency Director
  - (2) Public Information Manager
  - (3) EOF Staff
  - (4) Off-site agencies present in the EOF