

3.8 ELECTRICAL POWER SYSTEMS

3.8.4 DC Sources - Operating

LCO 3.8.4 Both Division 1 and Division 2 125 VDC electrical power subsystems and the 250 VDC electrical power subsystem shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3

ACTIONS

CONDITION		REQUIRED ACTION	COMPLETION TIME
A	One 125 VDC electrical power subsystem inoperable.	A.1 Restore 125 VDC electrical power subsystem to OPERABLE status.	8 hours
	<u>OR</u> <u>NOTE:</u> May be used on a one-time-only basis for each battery division.	A.2.1 Declare required feature(s), supported by the inoperable 125 VDC source, inoperable when the redundant required feature(s) are inoperable. <u>AND</u> A.2.2 Restore 125 VDC electrical power subsystem to OPERABLE status.	4 hours from discovery of Condition A concurrent with inoperability of redundant required feature(s) 10 days
B	Required Action and Associated Completion Time of Condition A not met.	B.1 Be in MODE 3.	12 hours
		<u>AND</u> B.2 Be in MODE 4.	36 hours
C.	250 VDC electrical power subsystem inoperable.	C.1 Declare associated supported features inoperable.	Immediately
D.	Two or more DC electrical power subsystems inoperable.	D.1 Enter LCO 3.0.3	Immediately