

RECEIVED

2002 OCT -4 PM 3:41

Rules and Directives
Branch
VEPCO

4/25/02
67FR 20555
③

From: "Shehab,Oula"
To: Andrew Kugler, Eva Hickey, Tara Eschbach
Date: 9/30/02 2:39PM
Subject: Comments to Draft EIS-Surry Power Station

Mr. Kugler:

I received the Draft Plant-Specific Supplement 6 to the Generic EIS Regarding License Renewal for the Nuclear Plants-Surry Power Station.

I reviewed the information in regards to the NPDES permit (I wrote the current VPDES permit -VA0004090). I found that the information stated in the Draft did not reflect the contents of the current VPDES permit.

I talked to Mr. Tony Banks with Dominion-Virginia Power who in turn conferred with Mr. Michael Holland, the Environmental Compliance Coordinator at Surry Power Station, and we came to the conclusion that the following corrections should be made to the Draft:

Page 2-18
Lines 29-32

Delete: Lines 29-32.

Replace the paragraph to read as follows:

"Sanitary wastes generated at the facility receive treatment provided by an on-site activated sludge treatment plant (design flow of 0.085 MGD). The wastewater goes through flow equalization, screening, grinding, activated sludge treatment, settling and disinfection. The treated wastewater is finally discharged into the effluent discharge canal. Sludge is aerobically digested, then pumped and hauled by a local contractor for final disposal."

Page 2-18
Lines 39-40

Delete: "The NPDES permit.....However,"

The next sentence should read: "The permit requires VEPCo to take immediate steps to achieve a non-detectable chlorine concentration in the final effluent if detectable chlorine concentrations are noted."

If you have any questions, please let me know.

Oula Shehab, Ph.D.
Environmental Specialist
Department of Environmental Quality
Piedmont Regional Office
4949-A Cox Road
Glen Allen, VA 23060
(804) 527-5069

Template = ADM-013

E-RTDS = ADM-03
Call = A. Kugler (ASK1)