•

.

Attachment 1

Inovision Qualification Report 950.366

.

Qualification Report 950.366Section 1Page 1 of 2

May 15, 2001

Rochester Gas and Electric Corporation 89 East Avenue Rochester, NY 14649-0001

Radiation Measurements, LLC

Reference: Purchase Order 4500008671

This is to certify the Qualification Test Report and Data is true and accurate to the best of my knowledge. In addition, it is further certified that the qualification requirements of the above referenced Purchase Order have been fulfilled. The Qualification Test Report, Data and Appendices are intended to substantiate these statements.

David P. Warner Reliability Engineer

Link Constant

Zísimos Giatís Manager, Quality Assurance

Qualification Report 950.366 Section 1 Page 2 of 2

Ş

.

This page intentionally blank

Qualification Report 950.366 Section 2 Page 1 of 2

1.0 Objectives

- 1.1 This report shall demonstrate that the Model 955A GM Area Monitor System is capable of operation prior to, during and after a Design Basis Event. This object will be accomplished using previously performed qualifications type tests on identical and equivalent equipment specimens.
- 1.2 This report shall demonstrate that the Model 955A GM Area Monitor System meets the contract specified environmental requirements. For the 956A-201, previous qualification type tests will be used. In the case of the 897A-210 detector, temperature and humidity requirements exceed levels tested in prior qualification reports for this device. To meet these requirements, type testing will be performed on two of the three detectors to be supplied under the contract.
- 1.3 This report shall demonstrate that the Model 955A GM Area Monitor System meets the contract specified Electromagnetic Compliance in accordance with EPRI TR-102323-R1. This will be accomplished by type testing actual and equivalent equipment specimens.
- 1.4 To demonstrate that the combined 955A radiation rate dependency and energy dependency are within ± 20% of actual dose over the nominal rate range of the detector (0.01 – 1000 mR/h) from 80 keV to 1.5. Determination of low energy response shall be provided using X-ray techniques while upper energy response shall be determined using Cs-137 and Co-60. All X-ray and solid source techniques shall be NIST traceable.
- 1.5 To demonstrate stability of the detectors, ascending and descending plateaus shall be performed on all detectors to be supplied. In addition, repeated fixed voltage count rate tests shall be performed on all detectors.

Qualification Report 950.366Section 2Page 2 of 2

ş

-~ ę

...

This page intentionally blank

1.0 Customer Requirements

- *

1.1 Seismic

2

The following six pages contain the Operating Basis Event and Safe Shut-Down Event seismic response spectra for elevation 289' of the Ginna Nuclear Power Station Control Building.

1.2 AC Power Supply

1.3 Environmental

1.3.1 Control Room

104° F maximum, 0 PSIG, 60% RH , negligible background radiation.

1.3.2 Intake Duct

-10° F to 122° F, 0 PSIG , 0 - 100% RH

1.4 Electromagnetic Interference

EPRI TR-102323-R1 : Guidelines for Electromagnetic Interference Testing in Power Plants

1.5 Radiation Monitor Range

Gamma Radiation from 1.0E-2 mR/h to 1E3 mR/h over an energy range of 80 keV to 1500 keV

Qualification Report 950.366Section 3Page 2 of 8

1

5

Ŧ

This page intentionally blank:



!

: •



Qualification Report 950.366 Section 3 Page 4 of 8

<u>ب</u>ر

X



Qualification Report 950.366 Section 3 Page 5 of 8



èe

- T

(S, S) KOLLYNSTEDDY

Figure 4





Qualification Report 950.366 Section 3 Page 8 of 8

-

6.0

.

Qualification Report 950.366Section 4Page 1 of 2

1.0 Standards

The following Specification and Purchase Order apply to this report :

Rochester Gas & Electric Corporation Specification PCR 99-004, EE-171 Revision 1, dated 2/25/00

Rochester Gas & Electric Corporation Purchase Order 4500008671, Revision 4, 1/30/01

í

The preceding Specification and Purchase Order list the following Guidelines and Standards as requirements :

American National Standards Institute

ANSI N45.2.2, 1972 : "Packing, Shipping, Receiving, Storage and Handling of Items for Nuclear Power Plants"

ANSI N42.3, 1969 : "ANSI/IEEE Standard Test Procedure for Geiger-Muller (GM) Counters"

Institute of Electrical and Electronic Engineers

IEEE 344 – 1975 : "Recommended Practices for Seismic Qualification of Class 1E Equipment for Nuclear Power Generating Stations"

Additionally the following Regulatory Guide applies :

United States Nuclear Regulatory Commission

Regulatory Guide 1.100, Revision 1, August 1977: "Seismic Qualification of Electric Equipment for Nuclear Power Plants"

Qualification Report 950.366Section 4Page 2 of 2

-1

;

2

This page intentionally blank

Qualification Report 950.366 Section 5 Page 1 of 10

1.0 Identification of Equipment

1.1 Equipment qualified under this report are listed below :

1.1.1 956A-201-M1 Universal Digital Ratemeter - modified

1.1.2 897A-210 Low Range Aluminum Housing GM Detector

1.1.3 948B-1-5 Rack Chassis

1.1.4 S157033A2 Surge Suppressor Assembly

Pages 3 through 10 of this section contain the Bills of Material which provide a detailed description of the equipment listed above.

- 1.2 The following paragraphs detail differences in equipment to be qualified under this report as compared to type tested specimens listed in referenced qualification type tests.
 - 1.2.1 The 956A-201-M1 differs from the 956A-201 specimen qualified under Seismic Test Report 950.353 in that the K1 auxiliary alarm relay is utilized as an additional contact set in the –M1 version. No mass or assembly changes associated with this modification as this relay is also installed in the standard 956A-201 unit as a nonfunctional "spare".

The 956A-201-M1 differs from the 956A-200 specimen qualified under Environmental Test Report 950.360 in that the check source drive voltage is 15 VDC rather than 120 VAC as was used in the model 956A-200. The information in paragraph 1.2.1 also applies in that the K1 relay is not active in the 956A-200 unit. There are no weight or assembly differences between the 956A-201 and 956A-200.

1.2.2 The 897A-210 Detector differs from the 897A-220 specimen qualified under Seismic Test Report 950.353 in that it utilizes a low range rather than mid range GM tube. There is no difference mass or design.

Qualification Report 950.366 Section 5 Page 2 of 10 -

1.2.3 The S157033A2 Surge Suppressor Assembly consists of subcomponents of the Model 876A-1 High Range Containment Monitor and the 960PD-100-5 Power Distribution Assembly, a subassembly of the 960WM-203-5 Wall Mount Enclosure. Seismic Qualification of the Model 876A-1 is detailed in Seismic Test Report 950.352. Qualification of the 960WM-203-5 is detailed in Seismic Test Report 950.338.

1

	7							
PS0150R	30	0	AN300	QPADEV000N	Inovision Radiation Measurements, LLC Product Structure	3/16/01	7.19.03	PAGE
Product No.	. 05	<u>د ۸</u> -	201-41		ALARM OUTPUT			

Product No: 956A-201-H1 UDR W/AUXILARY HI ALARM OUTPUT Rev: 001 ECN: 4JR8-96 Drawing Number:

.

Item

No.	Product Number	DrawingNo.	Siz	Description	Quantity		ECN	Rev	Übs	Act
1 2 3	956A-201 956A-201-M1MS 200-135	200-135	B	RATEMETER DIGITAL AREA HONITOR Modification sheet for 956A-20 Name Tag	1.000 E/ 1.000 E/ 1.000 E/	A PS A A	2CR7-97 1590 1392	5 1 5	N N N	Y Y Y

*** END OF REPORT ***

•

1

×

• •

:

Inovision Radiation Measurements, LLC Product Structure

Product No: 956A-201-5 ASSEMBLY, DIGITAL RATEMETER Rev: 002 ECN: 10CR40-95 Drawing Number:

Item										
No.	Product Number	DrawingNo.	Siz	Description	Quantity		ECN	Rev	Obs	Act
1 2 4 5 6 7 8 9 10 11 12 13 14 16 18	956A-100-20 942A-100-30 956A-201-55 956-200-10 942-200-60 942A-100-24 942-100-25 5-532 5-706 5-186 5-836 200-135 5-710 92-9124-A 50-89	200-135 50-89	C B B	ASSY, FRONT PANEL ASSY, REAR PANEL ASSEMBLY, POWER SUPPLY ASSEMBLY, MAIN PC 1E ASSEMBLY, HIGH VOLTAGE BOARD TOP RAIL RAIL, BOTTOM SCREW, MACH, PH, 4-40 X .38, NUT, HEX, 4-40, NY, BO SCREW, MACH, PH, 4-40 X .31, WASHER, SPLIT, 4, SS NAME TAG WASHER, FLAT, 4, NY, BO COUPLER, FEMALE COAXIAL CABLE	1.000 EA 1.000 EA 1.000 EA 1.000 EA 2.000 EA 2.000 EA 4.000 EA 1.000 EA 8.000 EA 1.000 EA 1.000 EA 1.000 EA 1.000 EA 1.000 EA	PS PS PS PS	11CR10-89 9CR23-93 3JR4-95 8CR8-99 1379 1590 1590 1590 1590 1590 1590 1590 159	2 2 1 12 2 1 5 5 3		, , , , , , , , , , , , , , , , , , ,
		Loc: 5"	LON	G			1,0,	4	п	T
19 20 21 22 25	30-91-1 30-91-2 67-83-1P 92-9103-A MSB-0072-35	Loc; 5"	LON	PIN, COAX FERRULE INSERT,CONNECTOR,M,24-20 WIRE Connector, 4 Position, Fehale WIRE, Hook-UP, 22 AWG, Yel/GRN G	1.000 EA 1.000 EA 5.000 EA 1.000 EA .001 FT		1590 1590 1590 1590 1590	3 1 5	N N N N	Y Y Y Y Y
26	MSB-0069	Loc: 3"	LON	WIRE, HV, LEAD WIRE, 22, 10K V G	.001 FT		1200		N	Y
27 28 29 30 31 32 33 34 35	36-96-1 MSH-6222 67-78-2 942-100-35A 942-100-35B 942A-100-35C 942-100-35D 942-100-35E MSB-0072-31	67-78-ТАВ Loc: 5"	C	TERMINAL, LUG, SOLDER, FEMALE TUBING, 3/16, BLACK CONNECTOR, FEMALE (2 PIN) HARNESS, POWER SUPPLY TO PCB HARNESS, MAIN PCB TO RELAY BOAR HARNESS, MAIN PCB/ANALOG OUT HARNESS, DETECTOR POWER SUPPLY HARNESS WIRE, HOOK-UP, 22 AWG, YEL/BLK	1.000 EA .001 FT 1.000 EA 1.000 EA 1.000 EA 1.000 EA 1.000 EA 1.000 EA .001 FT	PS PS PS PS PS	1590 1590 1585 35R19-90 9CR5-90 1590 10CR10-94 1590	1 7 1 2 2 3 5	* * * * * * * * *	Y Y Y Y Y Y
36	HSB-0072-32	Loc: 5"	LONG	WIRE, HOOK-UP, 22 AWG, YEL/BRN G	.001 FT		1590 -	5	N	Y
37 38 39 40 41 42	SM-2202 942-100-28 5-953 5-678 MSH-6228 MSB-0072-2			SLEEVE, SPIRAL-WRAP .06"5"0D OPTION BOARD SUPPORT MOUNT SCREW,TYPE 25,#4X.44LG,FH,PHIL SCREW, MACH, RH, 4-40 X .31 TUBING, 1/4, BLACK WIRE, HOOK-UP, 22 AWG, BLACK	.001 FT 1.000 EA 2.000 EA 1.000 EA .001 FT .001 FT		1590 9CR34-98 1590 1590 1590 1590	5 1 1 5	~~~~	Y Y Y Y Y

Qualification Report 950.366 Section 5 Page 4 of 10

¥

PS0150R 300 AN300 QPADEVO	DOON Inovision Radiati Product Str	on Measurements, ucture		3/16/01	7.21.46 F	AGE 2
Product No: 956A-201-5 ASSEMBLY Rev: 002 ECN: 10CR40-95 Drawing Number:	, DIGITAL RATEHETER					
Item No. Product Number DrawingNo. Si:	z Description	Quantity	ECN	Rev Obs Act		
43 5-193	SCREW, MACH, FH, 4-40 X .38,	4.000 EA	1590	N Y		
*** END OF REPORT ***						
	1					
	1 1 1 1					
						ኒላት
	·					
	, ,				•	
	, 1	•				ိုလိုည်
					₹ G	ualifi ection
						n 5
			· -			n Re
						Page
						950.: 95 of
	:					366 10
	i					
	;					

Inovision Radiation Measurements, LLC Product Structure

-

.

٠

Product No: 897A-210 DETECTOR, AREA HON., GH, ALUH, LOW Rev: 003 ECN: 4CR3-96 Drawing Number:

.

Item

No.	Product Number	DrawingNo.	Siz	Description	Quantity		ECN	Rev	0b s	Act
	897A-210-5A GEL897A-2X0 CAL-GM6 92-7005-9A 92-7005-12A 92-7005-17A 843-6-26 HB95-1008	PER PRINT PER PRINT PER DWG	ם ם ם	DET. MAIN ASSY,AL.HOUS.LOW RNG Detector, dihensional outline 897A GM Det. Calibration proc. Clamp Bushing Connector, female Wall support, detector Matntenance Builetin	1.000 EA .001 EA .001 EA 1.000 EA 1.000 EA 1.000 EA 1.000 EA	PS	2CR7-99 1590 1590 1587 1587 1587 9CR34-98	3 2 1 8 8 8 2	*****	YYYYYY
	92-7005-17A 843-6-26 MB95-1008	PER DWG	ם	CONNECTOR, FEMALE Wall Support, Detector Maintenance Bulletin	1.000 EA 1.000 EA .001 EA		1587 9CR34-98 1590	8 2 1		N N N

.

*** END OF REPORT ***

11

¥.

PS0150R 300 AN300

QPADEVOOON

Inovision Radiation Measurements, LLC Product Structure

.

3/16/01 7.21.22 PAGE

.

1

DET. MAIN ASSY, AL. HOUS.LOW RNG Product No: 897A-210-5A Rev: 003 ECN: 2CR7-99 Drawing Number:

Item

LTOM									.	
No.	Product Number	DrawingNo.	Siz	Description	Quantity		ECN	Rev	UDS	ACT
	GT3			TRAVELER FOR MECHANICAL ASSYS	1.000 EA		1590	2	N	Y
	TP897A			TEST PROCEDURE	.001 EA		1590	1	N	Y
1	857-210-18	857-210-18		HOUSING PROCESSED	1.000 EA	PS	12CR1-98	2	N	Y
2	857-10-25			COVER PLATE PROCESSED (SA)	1.000 EA	PS	2CR7-99	2	N	Y
3	897A-211-30			CHECK SOURCE MTG. ASSEMBLY	1.000 EA	PS	4CR8-96	2	N	Y
	897A-210-10	PER DWG	В	ASSEMBLY DETECTOR PC BOARD	1.000 EA	PS	1795	3	N	Y
5	857-210-20	857-210-20	B	TUBE & SHIELD ASSEMBLY LOW	1.000 EA	PS	1629	6	N	Y
6	857-1-18			HOUSING INSULATOR PAD	1.000 EA		1590		N	Y
7	857-10-22			SCREW, SEEL, PH 6-32 SLOT .50 SS	4.000 EA		1590		N	Y
8	MSB-0072-2			WIRE, HOOK-UP, 22 AWG, BLACK	.001 FT		1590	5	N	Y
9	46-77			O-RING, 3.489ID,.07 THK	1.000 EA		1590	3	N	Y
10	200-135	200-135	B	NAME TAG	1.000 EA		1392	5	N	Y
11	92-7005-20A	PER PRINT	D	CONNECTOR, 12 PIN, HALE	1.000 EA		1587	8	N	Y
12	897-110-28			MOUNTING BLOCK	2.000 EA		1590		N	Y
13	36-3			TERM, LUG, SOLDER, LOCK EYELET	1.000 EA		1590		N	Ŷ
14	5-837			WASHER, SPLIT, 6, SS	14.000 EA		1590		H	Ŷ
15	5-288			SCREW, MACH, PH, 6-32 X .62,	6.000 EA		1590		N	Y
16	5-280			SCREW, MACH, PH, 6-32 X .50,	4.000 EA		1590		N	Y
17	5-838			WASHER, FLAT, 6, SS	4.000 EA		1590		N	Ŷ
18	5-853			NUT, HEX, 6-32, SS	4.000 EA		1590		N	Ŷ
19	5-1011			SCREW, SEEL, PH, 4-40 X .31	2.000 EA		1590	-	N	Ŷ
21	MSA-0007			SOLDER, CORE, 60/40, .031 DIA	.001 LB		1303	2	N	Y
22	897A-210-13	PER PRINT	p	SCHEMATIC DIAGRAM, DETECTOR	.001 EA		1712	2	N	Y
23	857-10-7			GASKET, 2.0 SQ X .031 THK	1.000 EA		1590	2	N	Y
24	MSJ-4372			CEMENT, CONTACT, FASTBOND 10	.001 EA		1590	_	N	Y
27	MSH-6221	NONE	PN	TUBING, 1/8, BLK	.001 FT		1727	2	Y	Ŷ
28	40-164			SPACER, .12, .14ID/.250D, RND	2.000 EA		1590	1	N	Ŷ
29	MSB-0072-16			WIRE, HOOK-UP, 22 AWG, WHT/GRN	.001 FT		1590	5	N	Ŷ
30	MSB-0072-3			WIRE, HOOK-UP, 22 AWG, RED	.001 FT		1590	5	N	Ŷ
31	MSB-0072-15			WIRE, HOOK-UP, 22 AWG, WHT/RED	.001 FT		1590	5	N	Ŷ
32	MSB-0072-4			WIRE, HOOK-UP, 22 AWG, GREEN	.001 FT		1590	5	N	Ŷ
33	MSB-0069			WIRE, HV, LEAD WIRE, 22, 10K V	.001 FT		1200	_	N	Ŷ
34	200-122	200-122	Α	"WIPE TEST" LABEL	.001 EA		1599	2	N	Ŷ
35	5 200-53			LABEL, CAUTION	.001 EA	L .	1590		N	Ŷ
36	5-712			WASHER, FLAT, 6, NY, NAT	8.000 EA		1590		N	Ŷ
37	5-852			NUT, HEX, 6-32, SS, SM	2.000 EA	1	1590		N	Ŷ

*** END OF REPORT ***

~

Qualification Report 950.366Section 5Page 8 of 10

:

ŧ

14:59:53 300	VICTOREEN, INC.			PAGE 1
PART: 9498-1	DESC: CHASSIS ASSY, UDR, 2	BAY, 3.5"	REV: ECN:	8 SCR18-94
ITEM NBR. PART NUMBER	DESCRIPTION	QUANTITY		ECN
0 9485-1-5	ASSEMBLY, 2 BAY CHASSIS LOC:	1.000	EN	BM 6JR1-93
0 109-30	EXTENDED BACK PANEL SUPPORT	1.000	ΕΛ	5CR 18-94

FILE COPY

i



Qualification Report 950.366 Section 5 Page 10 of 10

14:35 TODAY PART:	5:08 300 (: 11/17/92 : 9468-1-5	VICTOREEN. INC. COMPONENT BILL OF MATERIAL DESC: ASSEMBLY, 2 BAY CHASSIS	5	REV: ECN:	PAGE 1 0F1 A 11JR2-92
ITEM NBR.	PART NUMBER	DESCRIPTION	QUANT I TY		ECN
1	9488-1-3	CHASSIS, 2 BAY, AREA MONITOR LOC:	1.000	EA	11JR2-92
2	844-7-7	GUIDE LOC:	4.000	EA	11JR2-92
3	5-189	SCREW, MACH, FH, 4-40 X .31. Loc:	8.000	ΕA	11JR2-92
4	845-1-33	BRACKET NUT LOC:	4.000	EA	11JR2-92
5	948-1-o	ADJUSTABLE WEDGE LOC:	2.000	EA	11JR2-92
6	5-261	SCREW. MACH, PH. 6-32 X .25. LOC:	2.000	EA	11JR2-92
7	5-837	WASHER, SPLIT, 6, SS LOC:	2.000	EA	11JR2-92
8	948-1-4	RACK CHASSIS REAR MOUNT BRACKE LOC:	2.000	EA E	SM 11JR2-72
0	5-361	SCREW. MACH. PH. 8-32 X .38. LOC:	4.000	EA	11JR2-92
10	5-704	WASHER. SPLIT. 8. SS LOC:	4.000	EA	11JR2-92
11	5-825	NUT. HE 2-32, SS Loc:	4.000	EA	11JR2-92

۰, ۰

• •

i

11/18-92 11/A 21-30-72 N/A TEST

QPADEVOOON

Inovision Radiation Measurements, LLC Product Structure

,

Product No: S157033A2 Rev: OO1 ECN: 1686 Drawing Number: S157033A2 FILTER/SURGE SUPPRESSOR ASS'Y

Item

No.	Product Number	DrawingNo.	Siz	Description	Quantity		ECN	Rev	Obs	Act
1	92-9015-A			FILTER POWER LINE	2.000 EA		1590	5	N	Y
2	96055-200	PER BON	BM	SURGE SUPPRESSOR	2.000 EA	PS	1744	3	N	Y
· 3	92-7041-2A	92-7041-2A	B	12 POLE BARRIER STRIP WITH	1.000 EA	PS	1625	3	N	Y
4	92-7044-4		-	FUSE BLOCK, 2 POSITION	2.000 EA		1590	1	N	Y
5	S157033421	S157033A21	D	CHASSIS, PROCESSED	1.000 EA		1686	1	N	Y
5	MSB-0071-1		-	WIRE, HOOK-UP, 18 AWG, WHITE	.000 FT		1590	1	N	Y
7	HSB-0071-2			WIRE, HOOK-UP, 18 GA, BLACK	.000 FT		1590	1	N	Y
8	MSB-0071-3			WIRE, HOOK-UP, 18 GA, RED, TFE	.000 FT		1590	1	N	Y
ğ	36-86			TERM, LUG, CRIMP, 22-16, #6-8	28.000 EA		1590	1	N	Y
10	19-2			FUSE, 2A 250V, 3AG	4.000 EA		1590	1	N	Y
<u> </u>	57-112			TERMINAL STRIP. 6 POINT	1.000 EA		1590	1	Y	Y
12	S157033A-105	PER PRINT	С	SCHEMATIC, SURGE SUPPRESSOR	1.000 EA		1740	1	N	Y
13	5-277	/ ====	-	SCREW, MACH. FH. 6-32 X .44	4.000 EA		1590		N	Y
ĩã	5-304			SCREW, MACH, PH, 6-32 X 1.00.	4.000 EA		1590		N	Y
15	5-261			SCREW, MACH, PH, 6-32 X .25,	8.000 EA		1590		N	Y
16	5-853			NUT. HEX. 6-32. SS	16.000 EA		1590		N	Y
17	39-48			STANDOFF, M/F, 6-32 X .38, HEX	4.000 EA		1590		N	Y
18	5-766			WASHER, INT. 6. SS	16.000 EA		1590		N	Y
19	14-235	NONE	PN	FERRITE CUBE	2.000 EA		1686	1	. N	Y

.

*** END OF REPORT ***

Qualification Report 950.366 Section 5 Page 9 of 10

1.6

Qualification Report 950.366 Section 6 Page 1 of 74

1.0 Test Results

This section contains the test data required to substantiate that the objectives set forth in Section 2 have been met.

1.1 Seismic Qualification of 955A and S157033A2 Components

Appendix I, Qualification Type Test for Digital RMS Components, Report 950.353 details generic testing performed the 956A-201 Ratemeter, 897A-220 Detector and 948B-1 Rack Chassis. Pages 5 through 7 of this section show Ginna Required Response Spectra for SSE conditions plotted against Tested Response Spectra envelope from Report 950.353.

Appendix II, Seismic Qualification Type Test 950.338 for Containment Atmosphere Monitor, for the Korea Electric Power Company's Kori 1, Kori 2 and Wolsung 1 Units. Report 950.338 details testing performed on the components of the S157033A2 Surge Suppressor Assembly. This report is applicable for all but the Line Filter (p/n 92-9015-A) sub-component of the S157033A2 assembly. Pages 8 through 10 of this section show Ginna Required Response Spectra for SSE conditions plotted against the Tested Response Spectra envelope from Report 950.338.

Appendix III, Seismic Qualification Type Test for Analog RMS Components, Report 950.352 detail generic testing performed on the Model 876A-1 HRCM Readout Module. This module contains the Line Filter sub-component (92-9015-A) of the S157033A2 assembly. Pages 11 through 13 of this section show Ginna Required Response Spectra for SSE conditions plotted against the Tested Response Spectra envelope from Report 950.352.

1.2 Temperature and Humidity Tests

1.2.1 956A-201-M1 Ratemeter

Appendix IV, Environmental Qualification Report for the Victoreen Digital Ratemeter, Report 950.360 details generic testing performed on 956A-200 series ratemeters. This report substantiates a qualified temperature range of –2.8° F to 125° F at 90% RH (noncondensing). In addition, Report 950.360 substantiates a qualified AC input power range of 90VAC/50Hz to 127VAC/63Hz for the 956A-200 series ratemeter.

Qualification Report 950.366 Section 6 Page 2 of 74 3

1.2.2 897A-210 Detector

The temperature and relative humidity profile that the two specimen detectors were subjected to is shown in Figure 1, page 15 of this section. Both detectors were subjected to three 40-hour cycles of this profile. Detector performance was monitored via the analog output of its associated 956 series ratemeter and logged on a multichannel recorder along with the environmental chamber temperature and humidity. A Cs-137 solid source was placed equidistant between the detectors provided a nominal 2 mR/h rate. Pages 16 through 28 of this section contain the entire strip chart record on the detector temperature and humidity test. No change in count rate (drift) was noted for either of the detectors at any point in the test cycles. These recordings provide substantive evidence that the Model 897A-210 detector meets all contractual environmental requirements.

1.3 Electromagnetic Compliance

EMC testing, in accordance with EPRI Guide TR-102323-R1, was performed by an independent testing laboratory. The test specimen was an operating channel of 955A Area Monitor consisting of 75 feet of terminated 50-100 composite cable, 897A-210 Low Range GM Detector, 956A-201 Digital Ratemeter and the prototype S157033A2 Surge Suppressor. The ratemeter and surge suppressor were installed in a model 948B-1 rack chassis. A second non-operational ratemeter was installed in rack chassis to complete the equipment complement.

Pages 29 through 52 contain F-Squared Laboratories Report No. CLE 033100-01 R1 detailing EMC testing and test results. The equipment, as tested, complied with the requirements of MIL-STD-461D, CS 101, IEC 801-2, IEC 801-3, IEC 801-4, IEC 801-5 and IEC 801-6.

Drawing S157033A-104 defines the 50-100 composite cable shield grounding requirements that must be followed to achieve same level of electromagnetic immunity as tested. This configuration requires that the overall shield be grounded at both the control room and detector location.

Qualification Report 950.366 Section 6 Page 3 of 74

1.4 Radiation Rate and Dose Dependency

19. 1.

Energy dependency tests were performed on two of the three 897A-210 detectors to be supplied under the purchase order. Serial numbers 131 and 132 were profiled in both the radial and axial modes using x-ray techniques equivalent to the following energies : 45, 68,100,148 and 180 keV. Solid sources were used for the 662 and 1200 keV. Page 53 through 58 provide the energy response curves as well as the raw data collected for both of the referenced detectors.

Rate dependency for all detectors is provided as part of the standard range calibration procedure CAL-GM1. Pages 59 through 64 contain the factory data sheets as well as raw range data.

1.5 Detector Stability

Ascending and descending plateaus for all contractually supplied detectors are provided. A graphical plot of this data is included for each detector's ascending plateau. Additionally, repeated counts were taken for each detector at a fixed high voltage to demonstrate the stability of the selected operating point. Pages 65 through 70 of this section contain the raw plateau data and the graphical representations of this data. Pages 71 through 74 contain the repetitive count tests performed at a fixed high voltage value of 575 VDC. Testing performed utilized the internal operation check source of the detector as the radiation source for both plateau and repetitive count tests.

The GM tube utilized in the 897A-210 detector (TGM ZP1320) has a manufacturer specified maximum slope of 8% over a 100 volt range from 525 to 625 VDC. The determination of % slope is obtained by the formula below :

$$\frac{(C_2 - C_1)}{(C_2 + C_1)/2} X \frac{100}{(V_2 - V_1)} X 100$$

Where $: V_1$ and V_2 are the plateau end points

 C_1 is the count rate at V_1

 C_2 is the count rate at V_2

Qualification Report 950.366 Section 6 Page 4 of 74

5

The results of testing are summarized in the Table below :

Detector Serial Number	% Slope of Ascending Plateau	% Slope of Descending Plateau	Standard Deviation for Repeated Counts at Fixed High Voltage
131	0.89%	0.45%	67.5
132	2.16%	1.73%	81.6
100762	0.84%	0%	42.2













Vertical Axis TRS vs. SSE RRS

•






Qualification Report 950.366 Section 6 Page 14 of 74 3

This page intentionally blank



1 1	۰ •
6:20 Section 6 Page 16 of 74 10:00 10:00 10:00 10:00 2:00 2:00 2:00 2:00 10:00 2:00 2:00 2:00 10:00 2:00 2:00 2:00 10:00 2:00 2:00 2:00 10:00 2:00 2:00 2:00 10:00 2:00 2:00 5:00 10:00 2:00 2:00 5:00 10:00 2:00 2:00 5:00 10:00 2:00 5:00 5:00 7:00 10:00 2:00 2:00 5:00 5:00 7:00 10:00 2:00 2:00 5:00 5:00 7:00 7:00 10:00 2:00 2:00 2:00 5:00 5:00 7:00 7:00 10:00 2:00 2:00 2:00 5:00 5:00 7:00 7:00 10:00 2:00 2:00 2:00 2:00 1:00 1:00 1:00 10:00 3:00 3:00 <td< td=""><td></td></td<>	
	- 🖷
$ \frac{1}{249} + \frac{1}{19} + \frac{1}{19$	
	: 1
	e la
	Ġ
$ \begin{array}{c c c c c c c c c c c c c c c c c c c $	d
	1325c
	(1
	C
	Ć.
	Ē
	e e
	¢
CHERON RANGE SCHEE CHITTER TOUR FARE	G
CHU2	
	к 💻
	13

										· 		5: -		• , 1		2	3					
	<u> </u>			 	 }	-	124			··· <u> </u>		· >	 נו	۰۰ <u> </u>	·` 4	·~	`` u) : 7	·		بہ گ—تو —	8
						[]					• • • • • • • • • • • • • • • • • • • •									-0		30.00
	·					-	·						• • • • • • • •		p				·			5.13 5.13 5.13
	- <u>-</u>		,							·	· · · · · · · · · · · · · · · · · · ·			-631-								-0.34
																						-0
		•					<u> </u>								•••							
						<u> </u>												· · · · · · · · · · · · · · · · · · ·		. 53		
																				0		
1																						
						=		- <u>w</u>												- - -		
							 	- <u></u>														1
																						<u> </u>
							 	- <u>*</u>												4		
in the	Jucine row	***	-			-m	eru						-m.m								Antonia	
								-01												<u>-9</u>		
1									r												22	
																		-				
		1	· · · · · · · · · · · · · · · · · · ·	-		-	<u> </u>	6												60		\geq
				÷								-									1	
				12						-						-					1	
					`														.wi	2	(O	0
						E																ງບa
					-					·											l -	lific
						=													•	8		atic
					-																· · · ·	э т
																					- P a	٩ep
																				8	ge	94
						5												<u> </u>			7	95C
						É						-									<u></u>).36
'n e	0 0	- 25 1	<u>0 0</u>	NUKOCYMY +) (1)	<u>(</u>)	ŧ0,) ()	0 0	O f		<u>, j</u> Ú	η ⁴))	\bigcirc	+ W, 70040	- <u>(</u>]			4	<u>ด</u> ั

	Ĭ							[I								İ	İ			5					İ		i.			•	•														١			, 80
	ļ	\prod					i	Ī						-									2						Ìİ	İİ				(uai	lifi	ca	itio 8	on	R		pc	ort	9	50).3	866 ; 7	5
	417			<u> </u> .		<u></u>		<u>.</u> .	; ; ;			+-	,						!														: : i :			:	<u>i i</u>	· · ·	- i	•	.		a <u>c</u>					_	+
	ė					• •		:					:		<u> </u>	-				-															: 1	<u>.</u>		. : . : . :	+	· · ·	:	!			•				
مع مدين مايين المعادي المعادي المعادي المعادي	6																				6													:								:	:	•	'		•	•	
<u>م</u> مر الملكية مع المعرفة المعرفة المعرفة المعرفة المعرفة المعرفة المعرفة المعرفة المعرفة المعرفة المعرفة المعرفة ا معرفة المعرفة	6 16	ļ.			Ī									i						Ī							Ī		-		•			1	;;;			; 1 ;		: : '		,	¦ .		. '				
1998 S	ļ		, ni Bi		- 5		:												+		Ĭ											1	•		<u>';</u>		; ;	<u>; -</u>					1	; :			15	Ŋ.,	
	 	250 Hu	hiv hi	1n 36 1	-id (j j					- 												Ž											!	<u> </u>					1		-				!			
1																							Ļ																										C
										╢																Ħ		Ì					++													- 			
] -14																					<u> </u> 2											<u> </u> 															<u> </u> 11	3
•] 																					Ş							5																				NAC 15
	ן 																						2																					$\ $		Π	$\ $		
	13							1		··· ·· !			:																																				
•	}		 																																													 	
يوني ۽ اور يوني ۽ اور پرين ۽ اور	 2				lı q				20					30					40			ſ		5(e	60					70					30				9	d				10	ت مستد
and a start of the			0.0																				İ																					$\ $					
sinti e s		57N 25n	Ň	32 h	hd				Ì			I																								Ť										Ĭ	T		
and an est]		niñ 						 													2			.: .																							┦	şœ
:	KOKUSA	<u></u>								1															ļ	1																							
	CHART												 .															5																					E.
	10					':'	! !		:	;;;		'	;; ;]					;;									;								· · ·														Ē
i				<u>.</u>	<u> </u>	• ; ; •	<u>;</u> ;				; ; ;	•											:: :				<u> </u> 						 		<u>.</u>					:				-				$\frac{1}{1}$	
	. 9					<u>.</u>		<u>.</u>	1,									<u> </u> 		· · ·			2				· ·		<u> </u>				•					; ; ; ; ;				<u> </u>	<u> </u>]]	<u> </u>	<u> </u>	ļĮ	۲ ۲
				:,			i'	:	.						,																																		
.		•	1				•	•	:		 			1				; ;							1		1					:	; 1 										İ				İİ		
	8	; ; ; ; ;	1:	· ·	<u> </u> .				. :	:! :!	<u> </u> -				!			• 		 							* [1		<u></u>		::	1 1 . 1		<u>;</u>						<u> </u>		<u> </u> 	<u> </u> 	<u> </u> 		<u> </u> 		
·										<u> </u>												Fel-						5																ļļ			Ц Ц		C
.	- - -																																					 											
	7	• • j	1:	• ;	1		<u>,</u>	11	1	11			1	11	11	1	1		Ħ	ţ	Ħ	Į			1	ij	11	i Ì	N	U	ij	11	ij	ţ		ļi	ŢÌ	T	!!	ŢŢ	İİ	ij	İ	ŢŢ	İİ	İİ	ii	H	•

14050 22 N ω

						~		~ ~		22	с ——)) нуна нус	אמא הא	2	24	020	· —	-	Ň)	ິພ		*
			-0		ーエリフミ					· · · · · · · · · · · · · · · · · · ·			יניטיבני							F	活跃	<u> </u>
			· · · · · · · · · · · · · · · · · · ·	·	ມສາວັດ		•													F		0-
	·				··· · · · · · · · · · · · · · · · · ·									•••							2.2	g
					in c								<u></u>								그러그다	
- 1		_			-0:21:		•															
														P							<u> </u>	
					<u></u>	<u>↓</u>								B							_ 	
													[[]			t
																			[]		i!	
										1											[
·																	·		{			
																			·			
			<u>_iv:</u>											·								
			. •			·														{		·
							l]	·		·			{	{	·
								·]						1								-1
													·	-	·[{		+		1	ferrer	
··																			<u> </u>		<u> '</u>	
								·		- [+								1-
														1							· *	·
		· · · · · · · · · · · · · · · · · · ·		•						··	-				· *							그드
														-{								士:
		· · · · · · · · · · · · · · · · · · ·										1		-								-1-
											-]									1	1	
				1									-1		<u> </u>							-+-
																					-	
							۵					. [- {- 		-1			1	-	1	1	
		1								-	Levin	CVL-LA			-	معجيستجم	manue	un mar	mange		للفحيق	n fin
						· · · · · · · ·	i						- NJ	-1		1					<u> </u>	11
	<u>'×</u>																					
			-8				<u>+</u>				-	1			0	Lector			-	diam'r can yn		-
											2	1.					-	-1	-1			:1:
							t/															-+-
							<u>∔}</u> •	···										- Januaria		-		구
			·]					.					_		-	1			<u>-l</u>		<u>-l</u>	-1-
				•	- [•-		· · · · · · · · · · · · · · · · · · ·		-								-l				·+-
							[]					-{										=1-
			. <u></u>											_								ł
												·										1
								_		_						-		_				:t
			·																			· -
														_		-	_				-	
-																						
							┟┟ ╼╼╌───						_								ပ္ဆည္	
							[.]			_						-	_		_			
		-	•	}										-							포프	
						_			_							•··					- ລັບ	
				•																	ຼັດ #	
												- · -			-						. ö	
								_													- ສ	
							h-1					-									. –	
					-																· &	
							÷]·													····	· • • •	
		-					 													- ·	·ῶὄ	
	.				-{		tl	-							<u> </u>					71	:ōž	
			-[1	4.0	
							<u> </u>													I.	<u> </u>	
					-		<u> </u>							m						·· ·	· ~ 8	
													_							-	0	
•	1					P				_	_										· Ψ. Ψ.	
					1	d	<u> </u>							<u>.</u>							、ンズ	
* 4 3 4 2			0	 ۰	سي ود.	H VC15	PE ON TRA	")~ ~	. <i>.</i>	a	0 0		ŝ	12		~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~	<u> </u>	4VELS	64 UN 154	91) ~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~	▲ <u>→</u> ~~	
ſ		26°		•	"	1 7 1 4		F1 (P)問	CJ [[]	14 14		1	500	· I :	十 时	21	1 .	1	•	ł	

		3																					i		ALCONTRACTOR OF												, 		C)11	al	ifi	Ca	ati	io	n	R			nrt	q	50	י ר	36	,	
	مع ار ار	0					0					0					3(0					5	Q				6	0			ľ	7,	!	S	e 	cti		n su	6 :	<u>'</u> '	: ·	F	ם פייי	g U	9	20)	of	7 1 1	4	
	j		15																																	12															، ، ت	 31	: 			
• • ?	 				1. 1. 2.	6	Ū																			2		in and the																										1		
2																																																						ICH CHERNIN 4	- 1	
		THAT																			T				at waine											6																			୍ବ କ୍	
		[-																	×					ŀ								5]	¢•	
: • .																										2		lina interest																												
	 						!!			; ;																			1																										,	
• • •	 																																			5																		INART NO B		
. f	Ŭ		15																						ž											9																:0		957JA		
مر میں ایک ایک ایک ایک ایک مربعہ	 7	NUTUR	19 19 19			<u> </u>																													I																			e		
]																																		1																			¢		ł
	 6	 0 -									20					ß	0				40			•			 50 +			5	6	 				7	 					 В(90					0	0¢		
																															5																							12	3	
	5				<u> </u>																					<u> </u>										+																		- • · [·]		
									:																																													0-064~si ◆		
	4								<u> </u> ;	: 		1												-												!																		£	i	
			-00	0	5			: 	i,																						5																		0	n D				ن. م		ł
	3	2: A (500 13 1	27 0		00		; ,	:¦	•	;.	• •	:	1											2														 ; 																	
!	-	•	· ' · · ·		•	; ' ; '	•	י יי +	• • • • •	 		:			1																																				1					
·				11																																																				

	Ì						2					•
			co						2010 2010	Qualificatio Section 6	n Report 9 Page 2	950.366 1 of 74
												· · ·
	(² 22										· · ·	· · · · · ·
							а 1 1 1				i , , ; ;	<u>.</u> . !!!
] 21]											
Patient Contraction (Î Î											
	1 20 											1000 Internet
	} 	9/N 132 25 AM/h Aug 27										
	19 											
				20 3	0 4	0	5,0		50	7'C	J	<u> </u> 00<
	18 											↓ ↓ ↓ ↓ ↓ ↓ ↓ ↓ ↓ ↓ ↓ ↓ ↓ ↓ ↓ ↓ ↓ ↓ ↓
4 4 	 [() () () () () () () () () () () () () (
-												
	i 10	1.0					2					
	: 15	' : ' ' 				· · · · · · · · · · · · · · · · · · ·						
	 //		:::									
		· · · · ·	 									
ľ	 ; 13		. 									
		,	-		· · · í	•••••••••••	• • • • •	W-7				

		5					 		0																																		C)u	a	lif	ic	a	ti	or	ר ר	R	e	p	0	rt	9	5	0.	3	6	6	•	
	ן זין		当 5 5 1 1			13		ii!																																		+			t		<u>,</u> 		, †	: 1			с			, <u>,</u>						+ -	, F	
	ژ ا ۱																										ſ					+	4	\$		}																								•	; ;		-	
	دار [6	ò		 										2	d						d				4'(5			þ)0 		 			6					7	q						s'q					1	9	0		 		i			~ر]	
] 	-				+						1								T										2								H		-		+						 					 					1					ונ ונ ן י	175
	 ; 5																																																	 					i							10	له کې	
	<u>ا</u> ا																																																						•	 						OGAV.A 🔶		
	 4												<u> </u>														ļ				 															-		1						;			; ; !			 				
	! I				i i U V				!		1																			2																													5				ļ	·
	j3		ų	b		8.										1			 																				-																		!		 				j Į	
	Ĭ			Ì																	+					-	10														+																							
al provide and a second	2			<u> </u>							<u> </u> 																9						<u> </u> 		Ť																				$\frac{1}{1}$							HO BYS73	9	
ا میں اللہ دو راجہ راجہ] 1						<u> </u> 										$\frac{1}{1}$																																													≧! (97 8	
· · ·	, 1			1																				<u> </u> 					<u>[</u>]																																	(c d	
·	14020				1															- २(8															74																				(
	24 								. 	-					-							; ; ;					1									<u>_</u>														1		1		ľ	Ĭ							ייינ ייינ וו	۲ ۲, 19	
•			15 7 19 19			; B	-																																																				50	q	Ċ		-	
· · ·	23 KUM	1	<u>عد</u> ، , ،	<u>0</u> ; ;						1																					╞																														TUNUM			
.	USAL CHART			· •		!					•	:			•	:		 							-																																							
.	22	1	• • • •		; ;		•	;		•			1					;					,													f																										•	ĺ	
- 				•	, 	;;;		: '		•		, 	•																																																	€ €		

	Ì						: · ·	į	;;						!!							!	!!	•					•]	1:	i	• :	<u> </u>	•		_																			
	e 				::		: .							1										-	ŀ			ŀ	K			; ; [•				G S	ec	ali cti	fic or	ca 1 (itio 6	on	F	Re Pa	۶р aç	oi ge	rt 2	95 23	;0; c	.3(of 1	66 74	i
	 ۲۱7				i.:	:			<u>.'</u>			<u>, ,</u>		; ;			11	<u> .</u> .		: !			i '.	:		•					 		i, Î	<u> </u>	<u>.</u> 		- Ë	:	1;		•			1					i						
	¢			1			:			, 		1	;		1		. :	1:	<u> </u>	: .	1		! '		}				· ·	: ;;			:	1	<u>: </u> 	-		:	::	• '	•	.	f 	 	<u>.</u>				_:		•••••••				•
	ć 				•	•	. · ا			:			: .				, , , ,					! 								:		:			::	:	Ľ		:•	!;	:,	:	1	:	• •		•		 i					•	r r
	6 16								: :			<u> </u> : :			•			1			1				1	2						1 1 1			•	;			; ; ; ·	, ,	!		:									,		י_ יי ו	e
			(<u>5</u>]) 16		· -		+ ; ;		1	<u> -</u>		; ;	1			:: <u>:</u> ::																			:		<u>.</u>	+-	: : 	•			•				+			15	Ľ,	- 50	Ċ
	¢	205		28		019		1		1† ::	T ;	, ,		! i				.				Ţ		1	1							T							;		!					-			- -	•	-	;	÷÷		c
	15]			11																																11	2																		¢
	׀ ֛֬֬							<u> </u> 	<u>+</u> 																						Ï		;;;;	<u>.</u>													<u>: </u> 				<u> </u> 		<u> </u> 		
	 4								<u> </u>																<u>}</u>																	<u> </u> 		:				11 11						; = 	
.]]; ;																														
. .	i }	İ													Ťİ											I												Ì		il				-				$\overline{\prod}$					\prod		ſ
	13							•		! : · ;		<u> </u>	<u> </u> 		 					 	 	 	<u> </u> 						1			 					<u> </u> 											$\frac{11}{11}$							
.	i			! ! · ! ·		ļ	11																																														\parallel		· .: -
		0				 0				2	0					 30					4(5	, 0					Ę P	d					 7,9					В	qi				F) D					00	· ·
en de la composition de la composition de la composition de la composition de la composition de la composition La composition de la composition de la composition de la composition de la composition de la composition de la c	」 12				 								İ			İİ		Ì														Ì	ÌÌ	Ì						Ì	Π		Ì	ÌÌ	ĪÌ	Ì		Ħ	Î		·	Π	1	1	<u>e</u>
)	50	<u>100</u> N	0 1.3	<u> </u> 2;																																								<u> </u> 			5		0 c 	0	$\frac{11}{11}$			100C
1 +* (1.	8) 					00																						1																											6
	Nox											!																		6																								OFOCAVA	C
	USVI CH	╎			, , ,	; ; · ; ·	· . 1												1																											İİ			İİ	İİ	İİ	Τİ	#	- •	Ċ;
	≦ 10		•••				<u>, '</u>		<u></u>	-							:: ::		· · ·			; ; i			F	-							<u> </u>		<u></u>			<u> - </u> !				- <u> -</u> 						<u>_</u>		<u> </u> 	<u>++</u> 11			+-	la.
			•	;	1	1;	: .		. ·									 		!		<u> </u>			2	i		1											1																C.
I					• •				, :	1				-						;																!											1				1				U. E
	9				• •		<u>.</u>					1;													-						t										1			// 		Ϊ			Í			ή		1	€
-		! 			• • 		•	, .	' . 		· · · 	 					<u>} </u>		<u>: </u> 			: ;				 					-									1												$\frac{1}{1}$		L.F.	6
			•••		•	; . ;	:			:	:				1																!										:							1						RT NO	٤
Γ	0 	;		<u>.</u>	. • 1]		'			:														101-11-10	2																										il			HVE156	- , ·
			<u>р.</u> а.			11		,			:,	<u> </u>	<u>;</u>		i) ; ;								1					<u> </u> 				!	11	i- :	<u>.</u>			<u>; </u> 	 	:			<u>, 1</u>			<u>i </u>	<u> </u> 	1	<u> </u> !	1 <u>5</u> 				•
	i 1 7			аў Л	:	j'! :		1	, , ;	;	11				!	!									<u> </u>					<u> </u>	\downarrow		;; ;; ;; ;;	 				: ·	1	1	•	; i		¦		,	• •						 -		~- -
	. (•				•		•		• 1	•	·	• •				• •	1	•	•	1		•	د :	• .	. !	2.	. (1.1	• '	1	• 1	i	1		•		•				•	1						•		·			'	

	•,	HU7.27.8	.	• :	ł	· · · · · ·		````````````````````````````````
	- 3 - 0 - 0							Qualification Report 950.366
						· · · · ·		
	2							
· · · · · · · · · · · · · · · · · · ·)							
	1 2 1							
	. 110		┥┥╷╷╷╷╷		┥╾┶┝┿┦╌┍┼╸	·		
.				20	30	40	50-160	7d Вd 9d 100⊂
	, 24 ,					2 		
··· · .	` 							
	23 KOKU							
••••	SAL CHART							5
	22							
	ļ							
ference from 3	21							1.6
ية بي ا								
	20							
								······································
	 . 19	25.nm::n 113.128.1 19.171						
			0	20	50	40	50	Б 70 В0 90 100 Ф
,*	8 					12		
	17 							
		· , ;	· · · · · · · · · · · · · · · · · · ·					
	! !	٠	•	11.111.11	11.1111	1111119		

			<u>.</u>	υ ι	. U		L.			00	61	U	で肥い	むこ	UU	-1.5 . ·	<1 K	i) (j	المنا الت		. Ç	$\Theta_{\rm ell}$	
	6 4	···]	1					MARI RO		<u></u>					YLWINGA WI								
	в С						E		<u>s</u>														_
	00		•	: :-	· · · · · ·													>					
	ត្តស្ត			•	. .		E																
	le of			•	•••••	••••						<u> </u>					iu						
	a C	•		•	•		=																_
	ዾ፝፞፟፟፟፟						 		· · ·														
	5	•			•																		
	o III											@											_
	ü r			•			E																
	tie tie	•••					 																
	ğğ						E																<u> </u>
	00	• • • • •		• • • • • •		<u> </u>			~~~~							·							
ſ	1	· ···· · ···		 -	··· ··· ···		E				•												
-		···· ·····	• .== :			<u> </u>																	
		· · · · · ·		· ····· · ·			Ξ												······································				
		· · · · ·				<u> </u>	+					pe								ເທ ເປ			
-											\equiv				ю——•				12				J.
						===	=	~~~~~			#												_
									للمنتخب فتسو فاست														
			·				1-					<u> </u>											
			1	L				1	1				h.			· · · · · · · · · · · · · · · · · · ·	N						
	7778	ANT COLLEGE	7-010-WY-	-			1771		marine	-	manfina	www.	- comment	-venner		ter and the second				minun	The second	a since	-
				-			1771 				and and a second			-								********	}
			1) · · · · · · · · · · · · · · · · · · ·				4773 - L				y Y												<u>}</u>
							477å				2												
											~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~												
											»/	0 											
												0.4											<u>}                                    </u>
											27-1-1-1-1-1-1-1-1-1-1-1-1-1-1-1-1-1-1-1	90 70 70 70 70											
												90 90 90 90											
																							<b>E</b>
												20 40											<b>E</b>
												20 40											<b>5</b>
												20 40											
																							<b>5</b>
																		23 00 00					<b>5</b>
																		23 00 14 14 12 15 14 14 15 14 14 14 14 14 14 14 14 14 14 14 14 14					<b>5</b>
																							<b>5</b>
																		SZN 132 SZN 132 Ftu 4, 291 00					<b>5</b>
													9					Picture 1132					
															S			Standard 1232			2		
																		SCM 1132 SCM 1132 Etw 41 291 000			<b>2</b>		<b>\</b>

	j	21								İ																						İ					5						-		~	•		•					-					• •	3				•	
											Ţ	ļļ																			2													) 9 	וג Se ו	Ja ∋C i i	un tic 11	nc on	:a 16 i	ti( 5 1 ;	or	ו ר ו :	F F	'a	рс ig	or e i	t 9 2	95 16	50 C	of.	36 7	56 74		
		0																																1											Ì															- i   :	•			
	1   	0	217121 217121			5		00																									77		6																				$\overline{\left \right }$				);    					
	!' !	ĺ																																		4										İ																	ا ج ا	
, 		 0 3						0					2	0					ß	0					4	0 				1		50					6( 							a					8	0					9	0						] )0	୍ ଜ୍ୟୁ	<u>}</u>
-73-1 1	<u>;</u>   																															╉		2																											+		() 108	iSc
	1	  - 					1																						The second second second second second second second second second second second second second second second se						6																												•	
					:		1																													5						   																				C+J)GAT2 ♦	el	
	]  16				:		    	1							: : :														and second													-			     																		-	•
-	j l		- 		1 1 1	ļ																					+						2 4 																									ç						
an an	<b>15</b> 		リキ 51 					1		<u> </u>   	<u>  </u>																																																			ę		ļ
8.5%p 	, [					:																					9							<u> </u>	1																				$\frac{1}{11}$				ľ					
•	14		· :   : !						•		 .   																!   			2																															<u>nu.</u>		-	
		1 1			• •		1	•	;	:		• ;	<u>; ·</u> [ · ;	•	!			1	:	· · ·	!						· · ·								 i		1	     	· ·			:	i   !   i																			ee E	ii F	
•	13		 ; :			•		 ! •			•	 : : ]	.														<u></u>						•		•						; ; ; ;																					ي ب		
	0				:		0	1				2	0					3							d						50					-  5,0		;				7	0					8(							d					0	0	₽;;'		
 	12	:	;; ;;	;		•			• • •	1 1	•	•	;		;; ; ;	; ; ; ;				: :		!											!! !!																				ÌÌ	$\left\  \right\ $		Ϊ							) 24	
1		17.5 14 1	TE 7.K 9.1	ゴンコー		0	: :. :)			•		1			:	2	•		:.	•		::	•	•	:		;		1 : -	•			1	1	 ' i !   :			- 1						; ;		, t , t	1		• •	•								5						
. :	לביימא ועד		•	ı 			;   			,				•		     			• •			;   ;	:::::::::::::::::::::::::::::::::::::::					the second		:														 		; ;	1		. : ·	1											YUKOGANA	C T	: <b> </b>	ł
-	I CHINICI			•		:	•							•		:	:											A PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PARTICULAR PART									•			   !		iT		i								<u>.</u>		T						1	•	-	ŀ	

	. <b>.</b>	T		· ·												ļ						
••	-•- <u>-</u>	0-0-	0	 )	0-0-	^*?	·? N	۰، ۲۰۰۰ ک	-^~? ∧	<u> </u>	·		<u> </u>	` <b>`</b>	-~-+.	· ·	רי יו	<u></u>	-?)?,-	(·)		
<u></u>		o 연구도의	<u>ح</u>	5			K	•	AN KOKA	) 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	حم اا	1050	·					۵۵ ۲۲	स्तरह			
		02 01 X	œ	,			'				<u></u>									n		·····
			5							שבעופ		*							្រុះ		···	
		N																				
	• • • • •	1.8		••••						- <u>ð</u>									3		· · ·	
														·								
· · · •	· ·			<u> </u>												-						
<u>ку</u>	<u></u>	<del>.</del> .										·N3										*** *** *
· · ·			1 =											· ····						-		
						=====										=			·			
		· · · · · · · · · ·																				
·8			-									3	·			_			· <u>··</u> ·····			<u> </u>
· ···																				• -		
																				·····		
																=				· ·		·····
-5						-	·			:		<u></u>							·			
																				• • •		
-		معممهم			مىبە <u>م</u> م		-			h-11.	-			mine	-	مليع			hin			learn -
<u>N</u>								<u></u>		.										1		
					-		-					-,2-,										
			-			-	-	<u> </u>														
		<u></u>			-	(£		•	<u> </u>							= =-						1
	#1										-	5				= =						
<u> </u>						-															[ . <u></u>	1 -
				·					<u>;</u>	-						_ =:			· · · · · ·		_ <u></u>	
									·									779				+
-2		-										70										
		-								-												နှစ်
													1			$\equiv$			· · ·			
															······		••	· · · ·				un fic
									-	-		-õ										o Hi
· <u> </u>	<u>F = </u>							-					-				•				{	Ч
																	•			1.	•	υÄ
			-kn																	1		ağ
		-	6								-					= =				1		e, ¥
			5			-											: :			1		26 25
••••••••••••••••••••••••••••••••••••••				1	_		-		-		5		-							5		o Ö
				]	]	-							1						·		}	22
ñ ñ	a n	ດຄ		8 ON 1841	<b>.</b>	0 (	a. A	0 0		Ĵ (Ĵ	: : : : : : : : : :	.)			۲3 אא ( ( '		<u>сну</u> и1 • <b>[[</b> ]	ገግ	ŋ	ויר	}	÷ ())

· · · ·	Ţ									: •
	<b>G</b>								Qualification Section 6	Report 950.366
in the second second	¹ 14									· · · · · · · · · · · · · · · · · · ·
	Ì		hid   hid   h	<u>                                      </u>	//////////////////////////////////////	521111				
	 		HINDIII	RANGE	ZER	0       \$	CRUE		DHEIIIPHE	
	13 ∦- 	Cita		6.						
•••	Ì			2011:19 E T	30 	20 40	50	60	2	90
	12 ا لــــــــــــــــــــــــــــــــــــ			TYPET						
1 1 1 1	ן ו			RLARKE		alarn2   -	R	L#RMJ      -		
·										
· · ·										
	10									
	1									
•	9									
							5			
₩1, 1 î	j B					2				
	. 7									
	<b>'</b>   						// 			
				20	0	10	50- 6	0	. 80	.90
	6									
			· · · · · · · · · · · · · · · · · · ·							
	5	· · · · ·						5		
   			·,	· · · · · · · · · · · · · · · · · · ·		2				
(	4	•		1					· · · · · · · · · · · · · · · · · · ·	

# **EMC TEST REPORT**

 $\frac{1}{5}$   $\mathcal{F}_{3} = \frac{1}{2}$ 

For a

eire-

# Digital Rate Meter, Detector and Cable Assembly

Manufacturer: Inovision Radiation Measurements, LLC 6045 Cochran Road Cleveland, OH 44139 -Testing Facility:------F-Squared Laboratories 16740 Peters Road Middlefield, OH 44062

The Digital Rate Meter, model 956A-201, Detector 897A-210 and Cable Assembly (consisting of 75 feet of 50-100 composite cable terminated at both ends) were tested to the following Standards and were found to be in compliance with the requirements. A line filter assembly, part number S157033A2, was utilized to achieve the required compliance. The testing commenced on 9/26/00 and was completed on 9/29/00.

# Standards:

- Military Standard Requirements for the Control of Electromagnetic Interference Emissions and Susceptibility (MIL-STD-461D and CS 101)
- Electromagnetic Compatibility-Part 4: Testing and measurement techniques Section 2: Electrostatic discharge immunity test, IEC 801-2
- Electromagnetic Compatibility-Part 4: Testing and measurement techniques Section 3: Radiated, radio-frequency, electromagnetic field immunity test, IEC 801-3
- Electromagnetic Compatibility-Part 4: Testing and measurement techniques Section 4: Electrical Fast Transient/burst immunity test, IEC 801-4
- Electromagnetic Compatibility-Part 4: Testing and measurement techniques Section 5: Surge Immunity test, IEC 801-5
- Electromagnetic Compatibility-Part 4: Testing and measurement techniques Section 6: Conducted Immunity test, IEC 801-6

Evaluation Conducted by: In Cham

Tony Masone EMC Manager **Report Reviewed by:** 

Robert Pellizze General Manager

Qualification Report 950.36 Section 6 Page 30 of Report No.: CLE 033100-01 R1

Client: Inovision Radiation Measurements, LLC Model: 956A-201

Date: 12/15/00 Revision Date: 01/03/01

# INDEX

## <u>Section</u>

**K**-

- GENERAL REPORT SUMMARY
- 1.0 ADMINISTRATIVE DATA
- 1.1 Management of Test Sample
- 1.2 Abbreviations and Acronyms
- 2.0 DESCRIPTION OF TEST CONFIGURATIONS
- 2.1 Performance Criteria
- 3.0 LIST OF EUT, ACCESSORIES AND TEST EQUIPMENT
- 3.1 Equipment Under Test
- 4.0 MODE OF OPERATION
- 5.0 METHOD OF MONITORING
- 6.0 IMMUNITY PASS/FAIL CRITERIA
- 7.0 REQUIRED MODIFICATIONS
- 8.0 EMC TEST EQUIPMENT
- 9.0 ELECTROSTATIC DISCHARGE IMMUNITY TEST PROCEDURE
- 9.1 Electrostatic Discharge Immunity Test
- 9.2 Electrostatic Discharge Immunity Test Data Sheet
- 9.3 Photographs of Electrostatic Discharge Test
- 10.0 RADIATED IMMUNITY TEST
- 10.1 Radiated Immunity Test Data Sheet
- 10.2 Photograph of Radiated Immunity Test Set-Up
- 11.0 ELECTRICAL FAST TRANSIENT/BURST IMMUNITY TEST
- 11.1 EFT Immunity Test Data Sheet
- 11.2 Photograph of Electrical Fast Transient/Burst Immunity Test Set-Up
- 12.0 SURGE IMMUNITY TEST PROCEDURE
- 12.1 Surge Immunity Test
- 12.2 Surge Immunity Test Data Sheet
- 12.3 Photograph of Surge Immunity Test Set-Up
- 13.0 CONDUCTED IMMUNITY TEST PROCEDURE
- 13.1 Conducted Immunity Test
- 13.2 Conducted Immunity Test Data Sheet
- 13.3 Photograph of Conducted Immunity Test Set-Up
- 14.0 ELECTROMAGNETIC IMMUNITY CONCLUSION

# GENERAL REPORT SUMMARY

This electromagnetic emission and immunity testing report was generated by F-Squared Laboratories. The test report is based on testing performed by F-Squared Laboratories personnel according to the measurement procedures described in the test specifications given below and in the Test-Procedures section of this report.

SECTION	TEST	RESULTS
9	Electrostatic Discharge	Pass
10	Radiated Immunity	Pass .
11	Electrical Fast Transient Burst	Pass
12	Power Surge Immunity	Pass
13	Conducted Immunity	Pass

Section 6 Page 32 of 7

Client: Inovision Radiation Measurements, LLC Model: 956A-201

Report No.: CLE 033100-01 R1 Date: 12/13/00 Revision Date: 01/03/01

### 1.0 ADMINISTRATIVE DATA

ين يد

## 1.1 Management of Test Sample

The test sample was inventoried at the F-Squared Facility and returned to Inovision according to the agreement between F-Squared Laboratories and the client.

#### 1.2 Abbreviations and Acronyms

The following abbreviations and acronyms may be used in this document

- AM Amplitude Modulation
- BCI Bulk Current Injection
- CDN Coupling/Decoupling Network
- EFT Electrical Fast Transients
- EMC Electromagnetic Compatibility
- EN European Norm
- ESD Electrostatic Discharge
- EUT Equipment Under Test
- GRP Ground Reference Plane
- HCP Horizontal Coupling Plane
- IEC International Electrotechnical Commission
- KHz KiloHertz
- LISN Line Impedance Stabilization Network
- MHz MegaHertz
- OATS Open Area Test Site
- RF Radio Frequency
- S/N Serial Number
- VCP Vertical Coupling Plane

Section 6 Page 33 of 74 Report No.: CLE 033100-01 R1 Date: 12/13/00 Revision Date: 01/03/01

# 2.0 DESCRIPTION OF THE TEST CONFIGURATIONS

#### 2.1 Performance Criteria

SPECIFICATION	PERFORMANCE CRITERIA
IEC 801-2	В
IEC 801-3	A
	B
IEC 801-5	В
IEC 801-6	A ·
MIL STD 461D, CS 101	Α

<u>Performance criteria A:</u> The apparatus shall continue to operate as intended both during and after the test. No degradation of performance or loss of function is allowed below a performance level specified by the manufacturer, when the apparatus is used as intended.

<u>Performance criteria B:</u> The apparatus shall continue to operate as intended after the test. No degradation of performance or loss of function is allowed below a performance level specified by the manufacturer, when the apparatus is used as intended.

Report No.: CLE 033100-01 R1 Date: 12/13/00 Revision Date: 01/03/01

# 3.0 LISTS OF EUT, ACCESSORIES AND TEST EQUIPMENT

# 3.1 Equipment Under Test (EUT)

2

Device	Manufacturer	Model #	Serial #
Digital Rate Meter	Inovision Radiation Measurements, LLC	956A-201	Calab 1
 G M Area Monitor Detector	Inovision Radiation Measurements, LLC	897A-210	131
Cable Assembly	Inovision Radiation Measurements, LLC	50-100	N/A
Line Filter/Surge Suppressor Assembly	Inovision Radiation Measurements, LLC	S157033A2	Prototype
Rack Chassis	Inovision Radiation Measurements, LLC	948B-1	N/A

Section 6 Page 35 of 74 Report No.: CLE 033100-01 R1 Date: 12/13/00 Revision Date: 01/03/01

## 4.0 MODE OF OPERATION

The unit was fully operational in phases of the test.

## 5.0 METHOD OF MONITORING

The display of the EUT was visually monitored.

### 6.0 IMMUNITY PASS/FAIL CRITERIA

The unit was monitored and the following criteria was used to define a non-compliance:

- 1. Rate increase above 1 mR/hr and subsequent alarm (Alarm setpoint 1 mR/hr).
- 2. Microprocessor failure/lock-up indicated by fail alarm.
- 3. Loss of setpoints/Alteration of setpoints.
- 4. Failure to respond to Check Source command.

### 7.0 REQUIRED MODIFICATIONS

The grounds of the signal line were required to be terminated at both ends of the cable.

A ferrite bead, Corcom Filter. and a Surge Suppressor were added to the AC Power lines.

This assembly is identified as the prototype S157033A2 filter assembly.

Qualification Report 950.366 Section 6 Page 36 of Report No.: CLE 033100-01 R1 Date: 12/15/00 Revision Date: 01/03/01

# 8.0 EMC Test Equipment

Equipment Type	Manufacturer	Model	Serial Number	Cal. Due Date
Shield Room	Shielding Resources	3 meter	. 001	Mar. 2001
AC Power System	California Instruments	5001IX-CTS	52840	Oct. 2001
LISN	Fisher Custom Comm	50/250-25-4	9600	Aug. 2001
Antenna 1	EMC-Test Systems	3143 Biconilog · ·	1229	Not required
OATS	Compliance Labs	NA	001	Aug. 2001
PLDCN	Fisher Custom Comm	801-M3-16A	97-12	Sept. 2001
Antenna 2	EMC Test Systems	3143 Biconilog	9609-1306	July 2001
ESD generator	Haefely Trench	PESD 1600	N/A	Dec. 2000
Humidity/Temp G	Thermo-Hygro	Radio Shack 100	N/A	Dec. 2000
Surge Generator	EM Test	VCS 500	21527	Dec. 2000
EFT generator	Haefely Trench	PEFT Junior	83818	Dec. 2000
Signal Generator	Giga-tronics	6061A	9618911	Jan. 2001
Field Probe	Chase	EMC 20	2244/29	Mar. 2001

5

#### 9.0 ELECTROSTATIC DISCHARGE IMMUNITY TEST PROCEDURE

#### 9.1 Electrostatic Discharge Immunity Test (ESD)

The ESD generator and discharge gun was used to conduct the tests outlined below. The waveform conforms to IEC 801-2. This generator was used to simulated electrostatic discharges to the EUT. The EUT was placed on a non-conductive material 0.5 mm above a horizontal coupling plane (HCP) conforming to the dimensions of IEC 801-2. The horizontal coupling plane and the vertical coupling plane were connected to the ground reference place-through two 470 KOhm resistors. During the test, three different methods were used to determine if the equipment was susceptible to ESD. They consisted of Direct Contact, Air Discharge and Indirect discharge. The direct contact method was used on all exposed conductive surfaces. Each point was contacted 10 consecutive times in the positive polarity and 10 consecutive times in the negative polarity with an electrostatic discharge from the ESD Gun. The Indirect discharge method was used on one point of the horizontal coupling plane (HCP) and to one point on the vertical coupling plane (VCP) located 10 cm from the edge of the EUT on all four sides of the EUT. The Air Discharge method was used on all exposed non-conductive materials. These materials were scanned with the tip of the ESD gun, if the gun discharged at any point, 10 consecutive discharges in both positive polarities were then made to that point.

Quainication Report 950.366 Section 6 Page 38 of 2 Report No.: CLE 033100-01 R1 Date: 12/13/00 Revision Date: 01/03/01

,

# 9.2 Electrostatic Discharge Immunity Test Data Sheet

Test Date:	9/26/00	Test Engineer:	Tony Masone
Standard:	IEC 801-2	Air Temperature:	17°C
Performance	В	Relative Humidity:	62%
Criteria:			

# **Conductive Surfaces**

۲,

Discharge Point	Laval	Mathad	
Ventional Counting Diana Di La Cita	LEVEI	Iviethod	Pass / Fail
Vertical Coupling Plane – Right Side	$\pm 4 \mathrm{kV}$	Contact	Pass
Vertical Coupling Plane – Left Side	$\pm 4 \text{ kV}$	Contact	Pass
Vertical Coupling Plane – Front Side	<u>+ 4 kV</u>	Contact	Pass
Vertical Coupling Plane – Back Side	$\pm 4 \text{ kV}$	Contact	Pass
Horizontal Coupling Plane	$\pm 4 \text{ kV}$	Contact	Pass
Conductive Surfaces	±4 kV	Contact	Pass

# 2.0 DESCRIPTION OF THE TEST CONFIGURATIONS

# 2.1 Performance Criteria

SPECIFICATION	PERFORMANCE CRITERIA
IEC 801-2	- B
IEC 801-3	A
IEC-801-4	B
IEC 801-5	В
IEC 801-6	A
MIL STD 461D, CS 101	A

<u>Performance criteria A:</u> The apparatus shall continue to operate as intended both during and after the test. No degradation of performance or loss of function is allowed below a performance level specified by the manufacturer, when the apparatus is used as intended.

<u>Performance criteria B</u>: The apparatus shall continue to operate as intended after the test. No degradation of performance or loss of function is allowed below a performance level specified by the manufacturer, when the apparatus is used as intended.

Qualification Heport 950.366 Section 6 Page 34 of 7 Report No.: CLE 033100-01 R1 Date: 12/13/00 Revision Date: 01/03/01

# 3.0 LISTS OF EUT, ACCESSORIES AND TEST EQUIPMENT

# 3.1 Equipment Under Test (EUT)

Device	Manufacturer	Model #	Serial #
Digital Rate Meter	Inovision Radiation Measurements, LLC	956A-201	Calab 1
 G M Area Monitor Detector	Inovision Radiation Measurements, LLC	897A-210	131
Cable Assembly	Inovision Radiation Measurements, LLC	50-100	N/A
Line Filter/Surge Suppressor Assembly	Inovision Radiation Measurements, LLC	S157033A2	Prototype
Rack Chassis	Inovision Radiation Measurements, LLC	948B-1	N/A

.

Section 6 Page 35 of 74 Report No.: CLE 033100-01 R1 Date: 12/13/00 Revision Date: 01/03/01

# 4.0 MODE OF OPERATION

The unit was fully operational in phases of the test.

# 5.0 METHOD OF MONITORING

The display of the EUT was visually monitored.

# 6.0 IMMUNITY PASS/FAIL CRITERIA

The unit was monitored and the following criteria was used to define a non-compliance:

- 1. Rate increase above 1 mR/hr and subsequent alarm (Alarm setpoint 1 mR/hr).
- 2. Microprocessor failure/lock-up indicated by fail alarm.
- 3. Loss of setpoints/Alteration of setpoints.
- 4. Failure to respond to Check Source command.

#### 7.0 REQUIRED MODIFICATIONS

The grounds of the signal line were required to be terminated at both ends of the cable.

A ferrite bead, Corcom Filter, and a Surge Suppressor were added to the AC Power lines.

This assembly is identified as the prototype S157033A2 filter assembly.

Qualification Report 950.366 Section 6 Page 36 of Report No.: CLE 033100-01 R1 Date: 12/15/00 Revision Date: 01/03/01

# 8.0 EMC Test Equipment

7

Equipment Type	Manufacturer	Model	Serial Number	Cal. Due Date
Shield Room	Shielding Resources	3 meter	. 001	Mar. 2001
AC Power System	California Instruments	5001IX-CTS	52840	Oct. 2001
LISN	Fisher Custom Comm	50/250-25-4	9600	Aug. 2001
Antenna 1	EMC-Test Systems	3143 Biconilog		Not required
OATS	Compliance Labs	NA	001	Aug. 2001
PLDCN	Fisher Custom Comm	801-M3-16A	97-12	Sept. 2001
Antenna 2	EMC Test Systems	3143 Biconilog	9609-1306	July 2001
ESD generator -	Haefely Trench	PESD 1600	N/A	Dec. 2000
Humidity/Temp G	Thermo-Hygro	Radio Shack 100	N/A	Dec. 2000
Surge Generator	EM Test	VCS 500	21527	Dec. 2000
EFT generator	Haefely Trench	· PEFT Junior	83818	Dec. 2000
Signal Generator	Giga-tronics	6061A	9618911	Jan. 2001
Field Probe	Chase	EMC 20	2244/29	Mar. 2001

#### 9.0 ELECTROSTATIC DISCHARGE IMMUNITY TEST PROCEDURE

#### 9.1 Electrostatic Discharge Immunity Test (ESD)

The ESD generator and discharge gun was used to conduct the tests outlined below. The waveform conforms to IEC 801-2. This generator was used to simulated electrostatic discharges to the EUT. The EUT was placed on a non-conductive material 0.5 mm above a horizontal coupling plane (HCP) conforming to the dimensions of IEC 801-2. The horizontal coupling plane and the vertical coupling plane were connected to the ground reference place through two 470 -KOhm resistors. During the test, three different methods were used to determine if the equipment was susceptible to ESD. They consisted of Direct Contact, Air Discharge and Indirect discharge. The direct contact method was used on all exposed conductive surfaces. Each point was contacted 10 consecutive times in the positive polarity and 10 consecutive times in the negative polarity with an electrostatic discharge from the ESD Gun. The Indirect discharge method was used on one point of the horizontal coupling plane (HCP) and to one point on the vertical coupling plane (VCP) located 10 cm from the edge of the EUT on all four sides of the EUT. The Air Discharge method was used on all exposed non-conductive materials. These materials were scanned with the tip of the ESD gun, if the gun discharged at any point, 10 consecutive discharges in both positive and negative polarities were then made to that point.

Report No.: CLE 033100-01 R1 Date: 12/13/00 Revision Date: 01/03/01

# 9.2 Electrostatic Discharge Immunity Test Data Sheet

Test Date:	9/26/00	Test Engineer:	Tony Masone
Standard:	IEC 801-2	Air Temperature:	17°C
Performance Criteria:	В	Relative Humidity:	62%

#### **Conductive Surfaces**

Discharge Point	Level	Method	Pass / Fail
Vertical Coupling Plane – Right Side	±4 kV	Contact	Pass
Vertical Coupling Plane – Left Side	±4 kV	Contact	Pass
Vertical Coupling Plane – Front Side	±4 kV	Contact	Pass
Vertical Coupling Plane – Back Side	±4 kV	Contact	Pass
Horizontal Coupling Plane	$\pm 4 \text{ kV}$	Contact	Pass
Conductive Surfaces	±4 kV	Contact	Pass

÷

17

Section 6 Page 39 of 74 Report No.: CLE 033100-01 R1 Date: 12/13/00 Revision Date: 01/03/01

# 9.3 Photographs of the Electrostatic Discharge Test Set-Up



Section 6 Page 40 of

Client: Inovision Radiation Measurements, LLC Model: 956A-201 Report No.: CLE 033100-01 R1 Date: 12/13/00 Revision Date: 01/03/01



Front View of the EUT during the Electrostatic Discharge Test

.

Section 6 Page 41 of 74 Report No.: CLE 033100-01 R1 Date: 12/13/00 Revision Date: 01/03/01

#### 10.0 Radiated Immunity Test

The Equipment Under Test (EUT) was placed in a fully anechoic chamber on a non-conductive turntable. A broadband antenna was placed three meters from the EUT and was used to radiate RF energy in both horizontal and vertical polarities at the EUT.

The RF energy consisted of a signal that was stepped at 1% increments through the frequency range of 80 MHz to 1000 MHz at a rate slower than the reaction time of the EUT. The signal was 80% AM modulated with a 1 KHz sine wave and had a minimum calibrated field strength of 3.0 volts/meter at the surface of the EUT. The signal was also pulsed modulated at 200 Hz in the frequency range of 895 MHz to 905 MHz. The EUT was exposed to the RF energy on four different surfaces (Front, Back, Left and Right sides).

The test set up conformed to figure 2 of IEC 801-3.
Qualification Report 950.366 Section 6 Page 42 of 7 Report No.: CLE 033100-01 R1 Date: 12/13/00 Revision Date: 01/03/01

# 10.1 Radiated Immunity Test Data Sheet

Test Date:	9/26/00	Test Engineer:	Tony Masone
Standard:	IEC 801-3	Performance Criteria:	A

Side of EUT Exposed to Antenna	Antenna Polarization	Frequency Range	Minimum Calibrated RF Field Strength	Pass/Fail
Front	Horizontal	80 MHz to 1000 MHz	10.0.v/m	Pass
Right Side	Horizontal	80 MHz to 1000 MHz	10.0 v/m	Pass
Back	Horizontal	80 MHz to 1000 MHz	10.0 v/m	Pass
Left Side	Horizontal	80 MHz to 1000 MHz	10.0 v/m	Pass
Front	Vertical	80 MHz to 1000 MHz	10.0 v/m	Pass
Right Side	Vertical	80 MHz to 1000 MHz	10.0 v/m	Pass
Back	Vertical	80 MHz to 1000 MHz	10.0 v/m	Pass
Left Side	Vertical	80 MHz to 1000 MHz	10.0 v/m	Pass

2

.

Section 6 Page 43 of 74 Report No.: CLE 033100-01 R1 Date: 12/13/00 Revision Date: 01/03/01

## 10.2 Photograph of the Radiated Immunity Test Set-Up

Client: Inovision Radiation Measurements, LLC

Model: 956A-201



 $\overline{U}$ 

Qualification Report 950.366 Section 6 Page 44 of Report No.: CLE 033100-01 R1 Date: 12/13/00 Revision Date: 01/03/01

#### 11.0 Electrical Fast Transient/Burst Immunity Test

The Electrical Fast Transient Burst generator was used to conduct the tests outlined below. The waveform conforms to IEC 801-4. This generator was used to simulate RF energy coupled onto power and data cables from switches, relays, motors, and any other device that could produce a voltage "spike".

During the testing, the product was placed on a non-conductive table conforming to the dimensions of IEC 801-4. The set-up conformed to IEC 801-4, figure 7.

The transient energy (as defined in IEC 801-4) was coupled on the cables under test at various levels and polarities as defined by the standard. (Refer to the test page for the details of this test).

During the test, all data cables that may have a practical length greater than 3 meters, and all power mains cables were tested as outlined below.

#### Data Lines

The transient energy was coupled through a capacitive coupling clamp from the EFT generator to the data lines.

#### AC Mains

The transient energy was coupled through the EFT generator coupling/decoupling network to each conductor of the power mains cable with respect to ground.

# 11.1 EFT Immunity Test Data Sheet

Test Date:	9/26/00	Test Engineer:	Tony Masone
Standard:	IEC 801-4	Air Temperature:	20°C
Performance	В	Relative Humidity:	52%
Criteria:			

#### DATA LINES

.

. •

.

- -- ---

- Description of Data-Line	- Test Level -	-Polarity-	-Test-duration-		
Signal Line	3.0 kV	+	1 minute	Pass	
Signal Line	3.0 kV	•	1 minute	Pass	

#### POWER LINES

Description of Power Line Conductor	Test Level	Polarity	Test duration	Pass/Fail	
AC Power	3.0 kV	+	1 minute -	Pass	
AC Power	3.0 kV	•	1 minute	Pass	

Report No.: CLE 033100-01 R1 Date: 12/13/00 Revision Date: 01/03/01

# 11.2 Photograph of the Electrical Fast Transient Immunity Test Set-Up



Section 6 Page 47 of 74 Report No.: CLE 033100-01 R1 Date: 12/13/00 Revision Date: 01/03/01

#### 12.0 SURGE IMMUNITY TEST

#### 12.1 Surge Immunity Test

٠.

3

The test was performed the unit as per IEC 801-5. The surge pulse duration from the combination wave generator was  $1.2 \times 50 \mu s$  voltage into an open circuit as high as 2kV and a 8 x 20  $\mu s$  current pulse into a short circuit. Each pulse was injected 10 times in each polarity with a minimum of 60 second interval between each pulse. The unit set up was similar to the schematic shown in Figure 8 of IEC 801-5.

#### AC Mains

The AC Mains lines were coupled to the Surge/EFT generators coupling/decoupling network. Surges were applied to each AC line and protective earth in both common and differential mode injections.

#### 12.2 Surge Immunity Test Data Sheet

Test Date:	9/26/00	Test Engineer:	Tony Masone
Standard:	-IEC 801-5	Performance Criteria:	В

Cable Designation AC Port Testing	Level (kV)	Phase	Pass/Fail
	Differential	Mode Injection Tests	
Line 1 to Line 2	+3.0	0 - 360	Pass
Line 1 to Line 2	-3.0	0 - 360	Pass
	Common N	Mode Injection Tests	
Line 1 to Earth	+3.0	0 - 360	Pass
Line 1 to Earth	-3.0	0 - 360	Pass
Line 2 to Earth	+3.0	0 - 360	Pass
Line 2 to Earth	-3.0	0 - 360	Pass

Ε.

Section 6 Page 48' of Report No.: CLE 033100-01 R1 Date: 12/13/00 Revision Date: 01/03/01

## 12.3 Photograph of Surge Immunity Test Set-Up



#### 13.0 CONDUCTED IMMUNITY TEST PROCUDURE

#### 13.1 Conducted Immunity Test

The Equipment Under Test (EUT) was placed in a fully anechoic chamber 10 cm above a GRP. A coupling/decoupling network was connected to the EUT's power cord and was used to couple RF energy onto all lines of the power to the EUT. A bulk current injection (BCI) was used to couple RF energy onto all data, control and I/O lines that may exceed 3 meters in length.

1-04

The RF energy consisted of a signal that was stepped at 1% increments through the frequency range of 150 KHz to 80 MHz at a rate slower than the reaction time of the EUT. The signal was 80% AM modulated with a 1 KHz sine wave and had a minimum calibrated level of 3.0 Volts.

The test set up conformed to figure 2 of IEC 801-6.

#### 13.2 Conducted Immunity Test Data Sheet

Test Date:	9/26/00	Test Engineer:	Tony Masone
Standard:	IEC 801-6, MIL-STD 461D,	Performance Criteria:	A
	CS 101		

Line Tested	Frequency Range	Minimum Calibrated RF Level	Pass/Fail	
AC Power lines	150 KHz to 80 MHz	6.3 Vrms	Pass	
Signal Line	150 KHz to 80 MHz	6.3 Vrms	Pass	

Line Tested	Frequency Range	Minimum Calibrated RF Level	Pass/Fail	
AC Power lines	30 Hz to 50 kHz	136 dBµV	Pass	

•.'

Section 6 Páge 50 of 7 Report No.: CLE 033100-01 R1 Date: 12/13/00 Revision Date: 01/03/01

ncano

200.00

### 13.3 Photograph of the Conducted Immunity Test Set-Up



.....

•

### 14.0 ELECTROMAGNETIC IMMUNITY CONCLUSION

The Digital Rate Meter, model 956A-201, Detector 897A-210 and Cable Assembly (consisting of 75 feet of 50-100 composite cable terminated at both ends) complied with all of the requirements of the IEC 801-2, IEC-3, IEC 801-4, IEC 801-5, IEC 801-6, and MIL-STD-461D. CS 101.

201

Qualification Report 950.366Section 6Page 52 of 74

•

,

This page intentionally blank



.

.

Qualification Report 950.366 Section 6 Page 54 of 74

۰.

Date:	9/21/00			1	1		····	T		<u> </u>
	HVL	nC	857 Reading	kV	mA	Time	Dist	ВЛС	m D/h m	
	·		(mR/hr)	1		(min)	(cm)		meunr	% Error
				1			(011)			
<u>H60</u>	6	2.852	14.1	60	5	1.5	300	1 7505 02	100.04	
		2.851	14.2	60	5	1.5	300	1.7505-03	199.64	-92.94%
H100	13.5	0.9388	41	100	3	1.5	300	1.7000-03	199.57	-92.88%
	l	0.9342	41	100	3	15	300	1.2005-03	45.0624	-9.02%
H150	17	5.735	225	150	3	1.5	300	1.200E-03	44.8416	-8.57%
		5.721	226	150	3	15	300	1.100E-03	266.1346197	-15.46%
H200	19.8	3.903	195	200	3	15	300	1 2565 02	265.484945	-14.87%
		3.902	195	200	3	15	300	1.3502-03	211.69872	-7.89%
H250	22	5.86	291	250	3	15	300	1.350E-03	211.64448	-7.86%
		5.877	291	250	3	15	300	1.259E-03	295.1096	-1.39%
					- <b>-</b>		300	1.259E-03	295.96572	-1.68%
								·		
		Energy	Relative Resp	onse						
		68	0.91							
		100	0.85							
		148	0.92						[.	
		180	0.98							
		662	1							
		1200	0.99			<u> </u>				
			0.00	(				1		1

٠

Uualitication Report 950.366 Section 6 Page 55 of 74

Date:	9/21/00						1		<u> </u>
	nC	897 Reading	kV	mA	Time	Dist.	R/TC	mR/hr	% Error
	<u> </u>	(mR/hr)			(min)	(cm)			70 21101
	ļ								[··
<u>H60</u>	2.82	29	60	5	1.5	300	1.750E-03	197.4	-85 31%
	2.835	29	60	5	1.5	300	1.750E-03	198.45	-85 30%
<u>H100</u>	0.9301	46.9	100	3	1.5	300	1.200E-03	44 6448	5 05%
	0.9409	47.4	100	3.	1.5	300	1.200E-03	45 1632	1 05%
H150	5.844	. 242	150	3	1.5	300	1.160F-03	271 1928017	-10 769/
	5.847	242	150	3	1.5	300	1.160E-03	271 3320177	-10.70%
H200	3.856	186	200	3	1.5	300	1.356F-03	209 14944	-10.01%
	3.852	186	200	3	1.5	300	1.356E-03	208 93248	-10.099/
7H250	6.224	263	250	3	1.5	300	1.259E-03	313 44064	-16.00%
	6.221	263	250	3	1.5	300	1.259E-03	313,28956	-16 05%
		1							10.0070
<u> </u>									
						,		ł	
	·····					-	•		
•	Energy	<b>Relative Resp</b>	onse						
				•					
	45	0.15							
	68	1.05							
	100	0.89							
2 m.	148	0.89	1.						
·	180	0.84						•	
	662	1							
	1200	0.95							·

· ',..

ĵ

1

Through Top

,

1 ,

٠

.



### 897A-210-132

### - * *

Auaiiiicatioii nepuri sou.soo Section 6 Page 57 of 74

.

.

Date:		9/21/00						,		
	HVL	nC	857 Reading	kV	mA	Time	Dist.	R/TC	mR/hr	% Error
			(mR/hr)			(min)	(cm)			
H60	6	4.692	59.1	60	5	1.5	300	1.750E-03	328.44	-82.01%
		4.716	59.3	60	5	1.5	300	1.750E-03	330.12	-82.04%
H100	13.5	1.62	90.2	100	3	1.5	300	1.200E-03	77.76	16.00%
		1.5903	88.9	100	3	1.5	300	1.200E-03	76.3344	16.46%
H150	17	5.933	287	150	3	1.5	300	1.160E-03	275.3228769	4.24%
		5.96	287	150	3	1.5	300	1.160E-03	276.575821	3.77%
H200	19.8	3.863	220	200	3	1.5	300	1.356E-03	209.52912	5.00%
		3.84	219	200	3	1.5	300	1.356E-03	208.2816	5.15%
H250	22	6.435	322	250	3	1.5	300	1.259E-03	324.0666	-0.64%
-14 <u>-14</u>		6.44	324	250	3	1.5	300	1.259E-03	324.3184	-0.10%
								· · · · · · · · · · · · · · · · · · ·		
					· · ·					
		Energy	<b>Relative Resp</b>	onse						
		· · · · · · · · · · · · · · · · · · ·		<u> </u>			_			
		45	0.18							
		68	1.16							
		100	1.04							
		148	1.05							
		180	1.00							
5.5.		662	1							
14.) *		1200	0.984375							

#### 897A-210-132

Aualification Report 950.366 Section 6 Page 58 of 74

,

.

.

Sec. 2 ......

5

Date:	9/21/00			1	1			ſ		
	HVL	nC	857 Reading	kV	mA	Time	Dist.	R/TC	mR/hr	% Error
			(mR/hr)			(min)	(cm)			70 LITUI
										· <u> </u>
<u>H60</u>	6	1.9015	20.5	60	5	1.5	300	1.750E-03	133,105	-84 60%
		1.91	20.5	60	5	1.5	300	1.750E-03	133.7	-84 67%
H100	13.5	0.7098	32.5	100	3	1.5	300	1.200E-03	34.0704	-4 61%
		0.7095	32.5	100	3	1.5	300	1.200E-03	34.056	-4 57%
H150	17	3.979	172	150	3	1.5	300	1.160E-03	184.6468443	-6.85%
		3.985	172	150	3	1.5	300	1.160E-03	184.9252763	-6.99%
H200	19.8	3.733	185	200	3	1.5	300	1.356E-03	202.47792	-8.63%
		3.7354	185	200	3	1.5	300	1.356E-03	202.608096	-8.69%
H250	22	6.378	259	250	3	1.5	300	1.259E-03	321.19608	-19.36%
	L	6.344	258	250	3	1.5	300	1.259E-03	319,48384	-19.24%
Co-60							· · · · · · · · · · · · · · · · · · ·			
		Energy	<b>Relative Resp</b>	onse						
<u></u>										
		45	0.15							
		68	0.95					· · · · · · · · · · · · · · · · · · ·		
		100	0.93							
		148	0.91							
		180	0.81							
		662	1							
		1200	0.96484375							

INOUS				Qualification	n Report 950 Page 59	0.366 of 74
Radiation Mea	asurements			•	( C Pt	6045 Cochran Road Neveland OH 44139 None: 440 248-9300
TITLE: GM D DOCUMENT:	etector Cal: CAL-GM6	ibration f 897A-X1X	or Area Mo REV. A DETECTOR D	nitoring Sys ATA SHEET	stems ATTACHMEN	www.inovision.com T A
Customer	Rochester	Gas & Ele	ctric	F'.O. #	45000086	71
F'roject	NZA	s.o. #	157033	W.O. #	N/A	
Detector	Model #	897A-210	Serial #	131	Tag #	NZA
Readout	Model #	956A-201	Serial #	117	Cal Date	10-Jan-01
	6.3 Dete	ector Disc	riminator	NZA	volts (	897 ONLY )
6.5 An	ti-Jam Duty	Cycle Ver	ification	Pass	(Pass/Fa	il)
Intensity (mR/h)	Position & Of Attenua [.]	No. ters	Count Time (sec)	Accumulated Counts	Gross Counts (_cpm )	Net Count Rate ( cpm )
	TRI SOUF	RCE CALIBR	ATION INFOR	MATION (20	Ci Cs-137)	)
ACKGROUND	200 cm & d	6 Attn's	3.00E+02	8.30E+01	1.66E+01	NZA
1.04	200 cm & é	6 Attn's	2.40E+02	1.15E+03	2.87E+02	271
3.21	250 cm & 5	ð Altnís	2.40E+02	3.29E+03	8.23E+02	. 806
9.55	200 cm & 4	Attn's	2.40E+02	2.85E+03	2.46E+03	2446
20.3	250 cm & C	5 Attn's	1.20E+02	1 .50E+04	7.50E+03	7483
91.6	200 cm & 2	? Attn's	1.20E+02	4.38E+04	2.19E+04	21883
303	250 cm & 1	Attn's	1.20E+02	1.31E+05	6.55E+04	65483
971	200 cm & 0	Attn's	1.20E+02	3.66E+05	1.83E+05	182983
3107	300 cm & 2	Attn's	6.00E+01	Anti Jam	2.59E+06	NZA
	6.10 Ch	eck Sourco	e Response	87.30	mR∕h	
Conversion Constant	3.98E-93	a 0		Dead Time Cc	prrection	1.43E-06
Conducted By	AUIul	op/		Q.A. F	leview By (	20

225:GM1-6

Date 4/18/01

Cal Date 01-Mar-01

\$

.

**ous** 

## **Radiation Measurements**

Qualification Report 950.366 Section 6 Page 60 of 74

> 6045 Cochran Road Cleveland OH 44139 Phone: 440 248-9300 FAX: 440-349-2307 www.inovision.com

DETECTOR CURVE FIT PROGRAM - GM AREA MONITORS 94085701 Rev B

Model number is 897A-210 Serial number is 131

DATA FROM CALIBRATION RANGE Field CPM Calc field % Deviation mR/hr 1.04 271 1.07817 3.66997 3.21 3.20911 806 -0.0276075 9.56 2446 9.76178 2.1107 30.3 7483 30.0818 -0.720002 91.6 21883 89.8434 -1.91764 303 287.377 65483 -5.15603 971 182983 986.203 1.56567 CC1 = 0.00397693TAU = 1.43242e - 006Root sum of the squares of the deviation is 7.15236 Background CFM: 17

Date Calibrated: 3/1/01 Calibrated by: Bruce Mahood Customer: Rochester Gas & Electric Sales order number: 157033 Customer tag number: N/A

Qualification Report 950.366 Section 6 Page 61 of 74

INOUS	IGH .	s - s ¥ ⁱ **			Page 61 0	¥74 •••
TITLE: GM D	asurements etector Cal CAL-GM6	ibration f	or Area Mor REV. A	nitoring Sy	( C Pi stems ATTACHMEN	6045 Cochran Road leveland OH 44139 none: 440 248-9300 FAX: 440-349-2307 www.inovision.com
Customer	Rochester	Gas & Ele	ectric	F'.O. #	45000086	71
Project	NZA	s.o. #	157033	W.D. #	NZA	
Detector	Model #	897A-210	Serial #	132	Tag #	NZA
Readout	Model #	956A-201	Serial #	117	Cal Date	10-Jan-01
942 - 444 - 444 - 644 - 644 - 644 - 644 - 644 - 644 - 644 - 644 - 644 - 644 - 644 - 644 - 644 - 644 - 644 - 644	6.3 Det	ector Disc	riminator	N/A	volts ( )	B97 ONLY )
6.5 An	ti-Jam Duty	Cycle Ver	ification	Fass	(Pass/Fa	il)
Intensity (mR/h)	Position & Of Attenua	No. ters	Count Time (sec)	Accumulated Counts	l Gross Counts ( cpm )	Net Count Rate ( cpm )
	TRI SOU	RCE CALIER	ATION INFOR	MATION (20	Ci Cs-137	
BACKGROUND	200 cm & 0	5 Attn's	3.00E+02	9.30E+01	1.86E+01	NZA
1.04	200 cm & a	6 Attn's	2.40E+02	1.21E+03	3.02E+02	284
3.21	250 cm &	ö Attn's	2.40E+02	3.60E+03	9.00E+02	. 881
9.56	200 cm & 4	4 Attn's	2.40E+02	1.07E+04	2.68E+03	2656
30.3	250 cm & 3	3 Attn's	1.20E+02	1.65E+04	8.25E+03	. 8231
91.6	200 cm & 2	? Attn's	1.20E+02	4.79E+04	2.40E+04	23931
	250 cm & 1	l Attn's	1.20E+02	1.44E+05	7 <b>.</b> 20E+04	71981
971	200 cm & (	) Attn's	1.20E+02	4.01E+05	2.01E+05	200481
3107	300 cm & 2	2 Attn's	6.00E+01	Anti Jam	2.60E+06	NZA
	6.10 Cł	eck Source	e Response	81.40	mR∕h	
		•				

Conversion Constant 3.67E-03 Malon Conducted By Cal Date 01-Mar-01

-

3

Dead Time Correction 1.26E-06 Q.A. Review By ( <u>8) 61</u> Date 4 1 225:GM1-6



**Radiation Measurements** 

Qualification Report 950.366 Section 6 Page 62 of 74

> 6045 Cochran Road Cleveland OH 44139 Phone: 440 248-9300 FAX: 440-349-2307 www.inovision.com

DETECTOR CURVE FIT PROGRAM - GM AREA MONITORS 94085701 Rev B Model number is 897A-210 Serial number is 132 DATA FROM CALIBRATION RANGE Field CPM % Deviation Calc field mR/hr 1.04 284 1.04201 0.19305 3.21 881 3.23485 0.774222 9.56 2656 9.77411 2.23966 30.3 8231 30.5046 0.675126 91.6 23931 90.4933 -1.20814303 71981 290.257 -4.20564 971 200481 982.883 1.22378 CC1 = 0.00366773TAU = 1.2564e - 006Root sum of the squares of the deviation is 5.17235 Background CFM: 19 Date Calibrated: 3/1/01 Calibrated by: Bruce Mahood Customer: Rochester Gas & Electric Sales order number: 157033 Customer tag number: N/A

Qualification Report 950.366 Section 6 Page 63 of 74

•
•
<u>.</u>
l l

÷ •

Radiation M	easureme	ents				C Pl	6045 Cochran Road Neveland OH 44139 none: 440 248-9300
TITLE: GM DOCUMENT:	Detector CAL-GM	Cali 6 8	bration 397A-X1X	for Area Mo REV. A DETECTOR Da	nitoring Sys ATA SHEET	stems ATTACHMEN	Www.inovision.com
Custome	r Roche	ster (	Gas & El	ectric	F.O. #	45000086	71
Projec	t N/A	Ş	3 <b>.0.</b> #	157033	W.D. #	ыла	
Detecio	r Model	# 8	397A-210	Serial #	100762	. Tag #	NZA
Readou	t Model	ŧŧ ș	756A-201	Serial #	117	Cal Date	10-Jan-01
	6.3	Deter	tor Dis	criminator	NZA	volts (	897 ONLY )
6.5 A	nti-Jam 1	Duty C	Cycle Ve	rification	Pass	(Pass/Fa	il)
Intensity (mR/h)	Positi Of Att	on & h enuate	lo. ers	Count Time (sec)	Accumulated Counts	Gross Counts ( cpm )	Net Count Rate ( cpm )
· · ·	TRI	SOURC	E CALIER	RATION INFOR	MATION (20	Ci Cs-137)	)
BACKGROUND	200 ci	m & 6	Attn's	3.00E+02	8.10E+01	1.62E+01	NZA
1.0	4 200 cr	n & 6	Attn's	2.40E+02	1.15E+03	2.87E+02	271
3.2	1 250 ci	n & 5	Attn's	2.40E+02	3.40E+03	8150E+02	834
9.5	5 200 cr	n & 4	Attn's	2.40E+02	1.01E+04	2.53E+03	2509
30.	3 250 cr	n & 3	Attn's	1.20E+02	1.56E+04	7.80E+03	7784
91.	5 200 cr	n & 2	Attn's	1.20E+02	4.54E+04	2.27E+04	22684
20	3 250 cr	n & 1	Attn's	1.20E+02	1.J6E+05	6.80E+04	67984
97	1 200 cm	n & O	Attn's	1.20E+02	3.76E+05	1.88E+05	187984
310	7 300 cr	n 8 2	Attn's	6.00E+01	Anti Jam	2.60E+06	NZA
	6-10	) Che	cl: Sourc	e Response	43.40	mR∕h	

Conversion Constant	3.875-03 1	Dead Time Correction	1.38E-⁄0¢
Conducted By	1 Muhas	Q.A. Review By	a
Cal Date	02-Mar-01	Date	28/13/2

225:GM1-6

Qualification Report 950.366 Section 6 Page 64 of 74

nusi

#### **Radiation Measurements**

6045 Cochran Road Cleveland OH 44139 Phone: 440 248-9300 FAX: 440-349-2307 www.inovision.com

DETECTOR CURVE FIT PROGRAM - GM AREA MONITORS 94085701 Rev B Model number is 897A-210 Serial number is 100762 DATA FROM CALIBRATION RANGE Field CPM Calc field 2 Deviation mR/hr 1.04 271 1.04907 0.872394 3.21 834 3.23103 0.655042 9.56 9.74278 2509 1.91191 30.3 7784 30.4491 0.491939 91.6 22684 90.6205 -1.06931303 67984 290.356 -4.17282 971 982.757 187984 1.2108 CC1 = 0.00386967TAU = 1.38204e-006Root sum of the squares of the deviation is 5.01093 Background CPM: 16 Date Calibrated: 3/2/01 Calibrated by: Bruce Mahood Customer: Rochester Gas & Electric Sales order number: 157033 Customer tag number: N/A

# Plateau Data

•

897A-210 Serial Number 131

	Ascendin	g Plateau		Desending Plateau			
time	HV.	counts	CPM	time	H.V.	counts	CPM
	375	4.13E+04	2.07E+04	10:26	650	4.50E+04	2.25E+04
9.49	400	4.37E+04	2.19E+04	10:29	625	4.50E+04	2.25E+04
9.52	425	4.42E+04	2.21E+04	10:32	600	4.50E+04	2.25E+04
9.55	450	4.44E+04	2.22E+04	10:36	575	4.46E+04	2.23E+04
9.00 10:01	475	4.44E+D4	2.22E+04	10:45	550	4.51E+04	2.26E+04
10:01	500	4.43E+04	2.22E+04	10:48	525	4.47E+04	2.24E+04
10.03	525	4 46E+04	2.23E+04	10:51	500	4.47E+04	2.24E+04
10.07	550	4 46E+04	2.23E+04	10:54	475	4.46E+04	2.23E+04
10.10	575	4 44F+04	2.22E+04	10:57	450	4.43E+04	2.22E+04
10.13	600	4 48E+04	2 24E+04	11:01	425	4.43E+04	2.22E+04
10.10	625	4 50F+04	2 25E+04	11:04	400	4.37E+04	2.19E+04
10:18	620	4 52E+04	2 26E+04	11:07	375	4.15E+04	2.08E+04
10:20	000	7.026.04					•

All counts taken with the detector's operational check source activated.

Nominal Check Source response is 88 mR/h

______Date_____/09/01 en Performed by



Qualification Report 950.366 Section 6 Page 67 of 74

部行物。

# Plateau Data

897A-210 Serial Number 132

<u> </u>	Ascendin	g Plateau		Desending Plateau			
 time	H.V.	counts	CPM	time	H.V.	counts	CPM
13:14	375	4.28E+04	2.14E+04	13:51	650	4.66E+04	2.33E+04
13:17	400	4.51E+04	2.26E+04	13:54	625	4.65E+04	2.33E+04
13:20	425	4.55E+04	2.28E+04	13:56	600	4.61E+04	2.31E+04
13:23	450	4.56E+04	2.28E+04	13:59	575	4.61E+04	2.31E+04
13:26	475	4.56E+04	2.28E+04	14:01	550	4.62E+04	2.31E+04
13:30	. 500	4.56E+04	.2.28E+04	14:04	525	_4.58E+04	2.29E+04
13:33	525	4.58E+04	2.29E+04	14:07	500	4.57E+04	2.29E+04
13:35	550	4.60E+04	2.30E+04	14:10	475	4.55E+04	2.28E+04
13:40	575	4.60E+04	2.30E+04	14:12	450	4.56E+04	2.28E+04
13:43	600	4.64E+04	2.32E+04	14:14	. 425	4.52E+04	2.26E+04
13:46	625	4.67E+04	2.34E+04	14:17	400	4.50E+04	2.25E+04
13:49	650	4.65E+04	2.33E+04	14:19	375	4.26E+04	2.13E+04

All counts taken with the detector's operational check source activated.

水之情。

Nominal Check Source response is 84 mR/h

_Date_02/09/01 Performed by_



ς,

# Plateau Data

٢

And the second

资料

897A-210 Serial Number 100762

	Ascendin	o Plateau		••••••	Desendin	g Plateau	•
time	HV.	counts	CPM	time	H.V.	counts	CPM
12.56	375	0.00E+00	0.00E+00	13:48	650	2.34E+04	1.17E+04
12.00	400	2.14E+04	1.07E+04	13:50	625	2.34E+04	1.17E+04
12.00	425	2 28E+04	1.14E+04	13:56	600	2.35E+04	1.18E+04
13.02	450	2 32E+04	1.16E+04	13:59	575	2.33E+04	1.17E+04
12.00	475	2.31F+04	1.16E+04	14:01	550	2.33E+04	1.17E+04
13.12	500	2 32E+04	1.16E+04	14:04	525	2.33E+04	1.17E+04
12.10	525	2 35E+04	1.18E+04	14:06	500	2.31E+04	1.16E+04
13.18	550	2 35 5+04	1 18E+04	14:09	475	2.32E+04	1.16E+04
13.24	575	2.35E+04	1 18F+04	14:12	450	2.31E+04	1.16E+04
13.37	600	2 35 - + 04	1 18F+04	14:15	425	2.27E+04	1.14E+04
13:40	625	2.332+04	1 19E+04	14:17	400	2.16E+04	1.08E+04
13:43	620	2.37E+04	1 19E+04	14:20	375	0.00E+00	0.00E+00

All counts taken with the detector's operational check source activated.

Nominal Check Source response is 45 mR/h

_Date_<u>3/</u>* 101 Performed by



Qualification Report 950.366 Section 6 Page 71 of 74

.

# Repeated Count Rate Data

897A-210 Serial Number 131

γ,

time	counts	СРМ
9:05	4.45E+04	2.23E+04
9:08	4.43E+04	2.22E+04
9:10	4.42E+04	2.21E+04
9:12	4.43E+04	2.22E+04
9:15	4.45E+04	2.23E+04
9:26	4.44E+04	2.22E+04
9:30	4.44E+04	2.22E+04
9:33	4.46E+04	2.23E+04
9:42	4.44E+04	2.22E+04
9:45	4.45E+04	2.23E+04

٦,

All data taken at 575 VDC operating voltage

All data taken using detector's operational check source

a. Wm Performed by_ Date 2-9-0/

化建建

Qualification Report 950.366 Section 6 Page 72 of 74 ų. ÷

# Repeated Count Rate Data

### 897A-210 Serial Number 132

time	counts	CPM
11:14	4.66E+04	2.33E+04
11:17	4.67E+04	2.34E+04
11:20	4.63E+04	2.32E+04
11:23	4.67E+04	2.34E+04
11:27	4.66E+04	2.33E+04
11:32	4.66E+04	2.33E+04
11:35	4.63E+04	2.32E+04
11:38	4.63E+04	2.32E+04
11:40	4.67E+04	2.34E+04
11:43	4.66E+04	2.33E+04

All data taken at 575 VDC operating voltage

All data taken using detector's operational check source

Date 2-9-01 Performed by_

Qualification Report 950.366 Section 6 Page 73 of 74

.

# **Repeated Count Rate Data**

* 1

897A-210 Serial Number 100762

time	counts	CPM
10:12	2.31E+04	1.16E+04
10:14	2.33E+04	1.17E+04
10:18	2.31E+04	1.16E+04
10:38	2.33E+04	1.17E+04
11:09	2.31E+04	1.16E+04
11:12	2.31E+04	1.16E+04
11:14	2.32E+04	1.16E+04
11:16	2.31E+04	1.16E+04
11:24	2.31E+04	1.16E+04
11:27	2.31E+04	1.16E+04

All data taken at 575 VDC operating voltage

All data taken using detector's operational check source

Jan Date 3/5/01 Performed by

1

ĩ

10.27

Qualification Report 950.366 Section 6 Page 74 of 74 ù,

.

- -

This page intentionally blank

#### Attachment 2

DA-EE-2001-009 Electrical Factors Analysis for PCR 99-004 (FMEA for CREATS Actuation Instrumentation) D0960977

:_1

**Design Analysis** 

**Ginna Station** 

PCR 99-004 Electrical Factors Analysis

**Rochester Gas & Electric Corporation** 

**89 East Avenue** 

**Rochester, New York 14649** 

DA-EE-2001-009

**Revision 2** 

5/2/02

**Effective Date** 

**Prepared By:** 

**Reviewed By:** 

Paul W Surft Design Engineer

 $\frac{5/1/02}{\text{Date}}$ 

Reviewer

# **Revision Status Sheet**

Revision <u>Number</u>	Affected <u>Sections</u>	Description of Revision	
0	A11	Original.	
1	Throughout	Incorporate design changes, such as isolator addition, fuse addition, wire size changes. Additional technical detail added for single failure analysis, separation, and isolation.	
2	Throughout	Incorporate design changes for PCR Revision 1.	

-

а а а
#### 1.0 <u>Purpose</u>

ł

ł

- 1.1 The purpose of this analysis is to demonstrate that electrical factors associated with the construction of PCR 99-004 meet the requirements for electrical design for Ginna Station and Generic Design Criteria Ref. 3.2. The following sections list the factors that will be analyzed in this document. PCR 99-004 Revision 1 changes are incorporated.
- 1.1.1 All circuits, existing and new, that are impacted by this design will be analyzed to show appropriate cable properties, including sizing, shielding, grounding, and insulation. (See Section 7.1)
- 1.1.2 Cable separation and isolation between Class 1E and non-Class 1E equipment will be shown to be appropriate for the related equipment. (See Section 7.2)
- 1.1.3 Conduit sizes will be shown to be adequate to meet the cable fill requirement specifications. (See Section 7.3)
- 1.1.4 The selection of relays to be used will be shown to have the proper electrical parameters, including coil voltage rating, contact voltage and current ratings, and adequate amount of contacts. (See Section 7.4)
- 1.1.5 Switches selected for use will be shown to have appropriate contact configuration and ratings for the applications. (See Section 7.5)
- 1.1.6 The instrumentation will be shown to have appropriate ratings for input and output parameters, including operating voltage, output contact ratings, and signal outputs. (See Section 7.6)
- 1.1.7 Overcurrent protection will be analyzed to show proper fusing and coordination with other protective devices. (See Section 7.7)
- 1.1.8 Panel loading will be evaluated to demonstrate that no load ratings will be exceeded, and any impact on the loading of upstream supplies is addressed. (See Section 7.8)
- 1.1.9 The design will be reviewed to ensure that there are no adverse effects from electrical noise on the performance of the equipment, including surge suppression requirements for relay coils. (See Section 7.9)
- 1.1.10 The control logic for the design will be reviewed to ensure that it fails in the safe position for postulated power failures. (See Section 7.10)
- 1.1.11 The electrical design will be reviewed to demonstrate that no single failure can cause the loss of both trains of isolation logic or prevent the system from isolating. (See Section 7.11)

#### 2.0 <u>Conclusions</u>

1

2.1 The design and all electrical components specified in the design of the modification for PCR 99-004 Revision 0 with associated MDCNs, and Revision 1, are adequate and appropriate, consistent with design requirements for the electrical factors described in Section 1.0 of this analysis.

#### 3.0 Design Inputs

- | 3.1 PCR 99-004 Revision 1 and associated attachments, including circuit schedules issued for construction and Bill of Material.
  - 3.2 Generic Design Criteria, Electrical/I&C Plant Changes, EWR 10275, Rev. 0.
  - 4.0 <u>Referenced Documents</u>
  - 4.1 Drawings

#### **RG&E Drawings:**

Drawing # Sheet SK21946-0546SH1-1 SK21946-0546SH2-1 SK33013-2784-1 SK33013-1618SH1-2 SK33013-2004-1 SK33013-1860-4

#### 4.2 Circuit Schedules

<u>C.S.#</u>	<u>C.S. #</u>
R4522	R4523
C5529	C5530
C5545	C5551
C5552	AU0235
AU0235A	AU0235B
AU0239	AU0239A
AU0239B	C3505
	C2621

### 4.3 Codes And Standards

- 4.3.1 Ginna Station Updated Final Safety Analysis Report (UFSAR).
- 4.3.2 IEEE 141-1986, "Recommended Practice for Electric Power Distribution for Industrial Plants".
- 4.3.3 IEEE 384-1981, "Standard Criteria for Independence of Class 1E Equipment and Circuits".
- 4.3.4 IEEE 446-1980, "Recommended Practice for Emergency and Standby Power Systems for Industrial and Commercial Applications".
- 4.3.5 IEEE 946-1985, "IEEE Recommended Practice for the Design of Safety-Related DC Auxiliary Power Systems for Nuclear Power Generating Stations".

#### 4.4 Equipment Information

- 4.4.1 Vendor Manual, VTD-A4057-4001, Analytical Technology, Inc. vendor literature, publication SS-B14RC, (1/97), and O&M manuals Series B-14 Monitor System Rev. R, and UniSens Rev. G.
- 4.4.2 Vendor Manual, VTD-I2677- 4101 and VTD-V0115-4101, Inovision (Victoreen), Model 956A-201 series Ratemeter and Model 897A series GM Detector.
- 4.4.3 Cutler-Hammer Quick Selector Catalog 25-000, Type BF and BFD Relays, July 1995.
- 4.4.4 Square D, Type KA-1, Class 9001 Auxiliary contacts for SE with Type K push-button switches.
- 4.4.5 Brand-Rex Industrial Wire and Cable, publication PC-8101.
- 4.4.6 Buss Fuses, Full-Line Condensed Catalog FLC, January, 1989.
- 4.4.7 OT2 Switches, Westinghouse Electric Catalog, 25-000, March 1977.
- 4.4.8 WESCO Lamp, information contained in DA-EE-99-047 Attachment 5, DC Load Survey.
- 4.4.9 Potter & Brumfield, attached data sheet (Attachment 5) from unidentified catalog.
- | 4.4.10 NUS Instruments, Specifications for Analog Isolator Modules, Spec.: Data sheet attached (Attachment 6).

#### 4.5 Correspondence

4.5.1 Letter from James P. Brozek of Bussmann to Joseph E. Pacher, "DC Voltage/AIC Rating of Fuses", dated 12/10/90.

4.5.2	Bussmann Correspondence, Steve Shaffer to John Kowal, "AC/DC Fuse Spec", dated 1/3/91.
4.6	Plant Procedures
4.6.1	GC-76.9, Installation and Inspection of Electrical Equipment, Raceway and Electrical Supports.
4.6.2	GC-76.10, Installation, Testing, and Inspection of Wire and Cable.
4.7	Miscellaneous References
4.7.1	National Electric Code, NFPA 70, 1999.
4.7.2	PCR 98-097, Control Room Radiation Monitor Noise Suppression, Rev. 0.
4.7.3	Design Analysis, DA-EE-98-157, Cable Sizing Criteria, Rev. 0.
4.7.4	Ginna Procedure PT-17.4, Control Room Radiation R-36, R-37, R-38 and Toxic Gas Monitor Operability Test.
4.7.5	Ginna Alarm Response Procedure AR-E-11, Control Room HVAC Isolation.
4.7.6	Design Analysis, DA-EE-99-063, PCR 99-001 Electrical Factors Analysis.
4.7.7	Design Analysis, DA-EE-2001-047, Instrument Bus Electrical System Evaluation.
4.7.8	Topical Design Basis - Electrical Independence, Rev. 0, 6/19/97.
4.7.9	Design Analysis, DA-EE-99-047, 125 VDC System Loads and Voltages, Rev. 1.
5.0	<u>Assumptions</u> None
6.0	Computer Codes
6.1	None
7.0	Analysis

# 7.1 Cable Properties

Cable selection and sizing will be per Ref. 4.7.3, "Cable Sizing Criteria Design Analysis", which specifies the factors and derating amounts to consider in sizing and selecting conductors and routing through trays and conduits. Those factors will be

;

ī ¹

1

Page 6 of 17

adhered to throughout section 7.1.

#### 7.1.1 Power and Control Cables

I

I

1

1

ľ

1

I

1

The total power consumption requirements of all components in the new 120 vac circuits are tabulated in DA-EE-2001-047 on the appropriate Twinco Panel tables. Attachment 8 breaks out the loading to the portions of the circuits fed by each portion of the circuits shown on drawings SK21946-0546SH1-1 and SK21946-0546SH2-1. The maximum possible current to any individual portion of the circuit is 1.93 amps. The cable specified in the circuit schedules for power and control is #12 copper conductor. The new power cable is routed in conduit between the RMS rack and the Aux Benchboard. In accordance with reference 4.7.3 the tables in the National Electric Code shall be utilized for cables this size. In accordance with NEC Table 310-16 the rated ampacity for #12 AWG cable in a 104 degree F ambient is 27.3 amps (30 amps*0.91 temp derating factor). Therefore, the proposed new power cables have adequate ampacity for the expected current requirements.

To accommodate pin connectors on the back of the ratemeter, the control circuit to the output contacts of the ratemeter were changed to #16 awg SIS wire. Per NEC 310-16, the rated ampacity in 104 degree F ambient is 16.4 amps (18 amps *0.91 derating). This has adequate ampacity (above the 2 amp maximum current) for this circuit.

The existing power cables from the Twinco distribution panels to the RMS racks (Circuit Schedules C2621 and C3505) are #12 and #14 copper respectively. They are routed in tray and conduit, so must be derated by a factor of 0.35 per reference 4.7.3.

C2621 (#12 awg @ 30 amps*0.91 temp derating factor * 0.35 tray derating) results in an ampacity of 9.55 amps.

C3505 (#14 awg @ 25 amps*0.91 temp derating factor * 0.35 tray derating) results in an ampacity of 7.96 amps.

Per reference 4.7.7, the existing maximum load on either of these circuits is 5.7 amps, which already includes the above loads, except the isolators were upgraded from SCA100 to SCA300, resulting in 0.09 additional amps. The additional load of 0.09 amps results in a new total load of 5.8 amps, which is within the ampacity of the existing cables.

Grounding will be performed per procedure GC-76.9. The grounding has been reviewed and is consistent with the vendor recommendations.

All specified cables are rated 600 volts. All power and control circuits are 120 Vac or 125 VDC. Therefore, all cables have an adequate voltage rating for the specified applications.

7.1.2 Detector/Ratemeter Instrumentation and Power Cables

The cable used to provide power and signal between the ratemeter and the detector is a special cable supplied by the vendor, specifically for this equipment. It has been sized and tested by the vendor for use in this application. Installation and connections will be made per vendor instructions and drawings, to be included in the PCR package outputs.

#### 7.1.3 PPCS Cables

1

١

All PPCS cables will be wired using #16 twisted shielded pair cable (#16TSP), including connections between isolators and ratemeters. This is adequate for the 4 - 20 mA currents that are carried by these cables from the instrument to the MUX connections. Internal RMS rack wiring requires the use of #22 awg for the pin connectors to P6, the ratemeter analog output connection. The #22 wire will go from the connector approximately three feet to the terminal deck where it transitions to the #16. The #22 wire is appropriate for use for a 4 - 20 ma signal.

Cables to PPCS will have the shields appropriately connected for analog points to ensure no impact on the 4-20 ma signal, consistent with plant computer wiring practices.

#### 7.2 Cable Separation

- 7.2.1 A review of the design of the electrical systems associated with the proposed design has been performed to demonstrate that compliance with the requirements of IEEE Std 384, "IEEE Standard Criteria for Independence of Class 1E Equipment and Circuits". A and B train components have been separated into separate compartments in the Auxiliary Benchboard and the RMS racks, so there is physical separation between A and B train redundant components.
- Redundant trains of wiring are routed in separate train-specific conduits for the 7.2.2 interconnection of all equipment where the cables have to route outside of cabinets. When cables enter enclosures, such as the Auxiliary Benchboard or Radiation Monitoring System (RMS) racks, wiring is installed to maintain physical separation between redundant trains of wiring. Where cables are routed through the cabinets to the compartments containing components of the opposite train, the minimum 6" separation is maintained. The "defense-in-depth" design concept that results in the cross-connection of the redundant trains has resulted in a number of cables that are associated with both trains. Separation is maintained up to the points of interconnection between the two logic circuits (relays and terminal blocks). In the RMS racks, the cables have been designated as being associated with the train in which they are logically connected to the isolation initiation relay (if in the R81A circuit, then A train cable). These cables are designated associated to that train and separation from the other train is maintained except at the point of termination at terminal blocks.
- 7.2.3 In the Auxiliary Benchboard, the cross train logic is encountered where contacts are

connected in series from R81A to R81B for signals to the individual isolation devices (dampers, fan, MCB annunciator). The connecting cables go directly from an A train device to a B train device, and since they are not train specific at those points, separation cannot be maintained, so the cables are routed together, separate from all other train specific cables. Since the points of connection between the two trains is the relay contacts, isolation can be credited since relay contacts are considered qualified isolators per IEEE 384 section 6.2.2.2).

- There is no physical way to separate the wires to these non-train specific points at the 7.2.4 contact terminals from the train specific wires to the relay coils. This has been determined to be acceptable per a review of the logic and the Auxiliary Benchboard layout as follows: The wiring in the Auxiliary Benchboard cabinet is for the logic to the isolation relays. A review of that logic wiring demonstrates that any fault in the cabinet that causes failure of a wire will result in an opening of the associated circuit. Any open circuit will result in the isolation relay to drop out, automatically causing the initiation of the safety function to perform and put the CREATS in isolation. This is true for either a single train failure or a failure that propagates between both trains due to less than optimal separation. There is not a credible failure mode that would result in a condition in which faulted or failed wires in the Auxiliary Benchboard would prevent the safety system from performing its execute function if an actuation signal was present. The only way to prevent the system from performing this function would be for 120 VAC being applied to the logic circuits of both trains within this cabinet, energizing the relays even after the output contacts of the initiating devices (ratemeter or manual pushbutton) have opened. There are only a few wires that are still energized after an initiation signal in a manner that could cause this type of unlikely "hot short" in either logic train, where a wire could be disconnected and contact the relay with 120 VAC. Since the two R81 relays are in separate compartments in the Auxiliary Benchboard, there are no points where such a condition could also cause a second wire of the other train to fail and energize the opposite train's R81 relay. In addition, failure of any wires in the Auxiliary Benchboard due to inadequate separation between the trains can not propagate back to the ratemeters and cause them to fail in a manner that would prevent the system from performing its safety function.
- 7.2.5 Wiring for the radiation monitoring cabling, for power to the ratemeters, and for signal wiring between detector and ratemeter, maintains the minimum separation criteria of IEEE 384 between wiring of redundant trains. Outside of enclosures, the cable is inside of conduits that provide the physical separation between trains. There are only A Train or B Train cables in any conduit, and any non-1E circuits are routed with either train in the conduits carrying safety related circuits are train specific associated circuits that are physically separated from or electrically isolated from the opposite train. In the RMS racks, the minimum 6 inches of physical separation is maintained between redundant trains for power and signal wiring.
- 7.2.6 No new power or control cables are run in cable tray. A Train components are powered from an A Train power supply (IBPDPCBE from INVTCVTA) and B Train components are powered from a B Train power supply (IBPDPCBC from

INVTCVTB). Existing cables from IBPDPCBC and IBPDPCBE to RMS racks were not moved, existing separation criteria for these cables remains.

7.2.7 New PPCS circuits will go through an optical isolator to provide isolation from SR to SS systems, but will be installed safety related from the RMS rack to the CREP panels in the Turbine Building. To that point, they will be meet the separation requirements of the Safety Related portion of the design as they will be treated as associated circuits for the train they are associated with. When these circuits reach the CREP panels, they will be terminated on fuses to provide electrical isolation so that the two trains can be run in the same conduit as non-Safety Related cables. The optical isolators are qualified safety related devices, and they are rated to protect the radiation monitors from damage due to fault, short circuit, or open circuit. The non-safety portion of the circuit downstream of the isolation devices to the MUX equipment share a common conduit. This is acceptable because they are beyond the fuses providing electrical isolation, and there is no requirement for redundancy to the PPCS equipment.

#### 7.3 Conduit Fill

1

ł

ł

ł

I

1

1

1

Conduit fill will meet the specifications in the National Electric Code Ref. 4.7.1, Chapter 9 Tables 1 and 4. Power and instrument cable diameters and areas are from vendor documentation Ref. 4.4.5. 10/C special cable provided by Inovision has 0.675" o.d. per reference 4.4.1.

Conduit Sizing / Fill Determinations

Conduit fill limits are listed in NEC Chapter 9 tables 1 and 4. In attachment 4 the calculated cable fill for each conduit being installed is calculated. Cable diameters were taken from Cabletrak database which lists cables used in the plant and specifications taken from purchase orders and vendor documentation.

Attachment 4 shows that all conduits are within the fill limits.

### 7.4 Relays

Two additional AC relays (R81A and R81B) will be installed in the control circuits for this modification. These relays require 120 VAC coils. The contacts from these relays will be installed in 125 VDC circuits and 120 VAC circuits, so their contacts need to be appropriately rated.

A review of the control logic demonstrates that the maximum DC load on the relay contacts will be on contact number 1, which supplies control power to MCC K position 1F circuit for the control room air handling unit supply fan. This circuit has a maximum DC load of 0.38 amps, consisting of a motor starter, solenoid, and a lamp (Load values taken from Reference 4.7.9). The AC relay contacts will be subjected to a maximum load of a single BF relay coil, with a

power requirement of 0.6 amps. Type BF relays have been selected for this application. The coils are rated for 120 VAC + 10% - 15% and the contacts on these relays are rated for 1.1 amps at 125 VDC, and 6 amps at 120 VAC (reference 4.4.3, attachment 2). These rating are acceptable for the specified application.

Existing relay R80B will still have one contact in the 120 VAC circuit. A review of the control logic demonstrates that the maximum load on the relay contacts will now be 1 BF relay which has a power requirement of 72 VA (0.6 Amps) at 120 VAC. R80B is a Potter & Brumfield Type KRP11DY relay, with a contact rating of 5 Amps at 120 VAC (attachment 5). This rating is acceptable for the specified application.

#### 7.5 Handswitch Ratings

l

The selected handswitches, Westinghouse OT2 switches, have contacts rated for 6 amps at 120 VAC, and are rated up to 600 volts. As the table in 7.1 demonstrates, the maximum current on any circuit could be 2.07 amps. Therefore, these switch contacts are adequate for this application. See Reference 4.4.7.

#### 7.6 Instrumentation Ratings

The A17 Power Supply modules being used to power the existing Toxic Gas System instrumentation has an input voltage range from 85 to 270 volts, AC or DC, per Ref. 4.4.1. This system will now be supplied from Instrument Bus power via the RMS racks, at 120 VAC, so the change in power source does not impact the Toxic Gas equipment.

The Radiation Monitoring equipment requires 120 VAC power, +/- 10% (108 - 132 VAC) per Attachment 1. That is within the regulation range of the Instrument Bus Twinco constant voltage power supplies, which by Tech Spec are required to have an output voltage of 115.6 to 124.4 VAC. Ref. 4.7.7 contains voltage drop calculations for the existing circuits. The voltage drop from the Twinco to the RMS racks is much less than 1 volt, and the small load being added by this modification will not significantly impact that calculation, so power supply voltage will remain appropriate for the connection of the new ratemeters.

Alarm relay contacts in Model 956A-201 ratemeters are rated 5 A at 120 volts AC, per attachment 1. These contacts will be subjected to a maximum possible load of 1 BF relay, which is 0.6 amps (see 7.4 above). Therefore, these contacts are adequately rated for their expected load.

The ratemeter analog outputs are rated 4-20 ma. Each of the two outputs on each ratemeter will drive a single input on the isolators RY-A and RY-B. Each isolator input channel has an input impedence of 249 ohms. The ratemeters are rated to

I

drive 500 ohms maximum load. Therefore, the ratemeters are adequately rated for the analog output devices they are connected to. The isolator outputs are rated to drive 1050 ohms on the 4-20 mA signals. The PPCS output point has a 250 ohm resistor at the MUXATP. The isolator is therefore adequately rated to drive the PPCS point. This is consistent with the existing connections to the PPCS in the MUX Auxiliary Terminal Panel.

#### 7.7 Coordination / Isolation and Fuse Sizing

ł

I

1

I

1

1

I

I

1

I

I

1

I

I

Safety related fuses will provide isolation between the safety related equipment (R-45, R-46, R-10A, R-11, R-12, R-29, R-30, RK-78) from non-safety/safety significant equipment (toxic gas, isolators RY-A and RY-B, plus radiation monitors R-10B, R-13, R-14 and associated isolators and relays). The fuse sizing was shown to be appropriately designed in reference 4.7.6, and the new power source does not change any of the analyzed characteristics. The 3 amp fuses used for each circuit and circuit section are adequately smaller than the next upstream protective device, the breakers in IBPDPCBC (15 amp) and IBPDPCBE (20 amp) supplying the new system, so there is coordination between these devices. The 3 amp fuses are also adequately sized to carry the loads as shown on Atttachment 8 (maximum load on any fused section is 1.93 amps, which is less than 80% of fuse size).

Attachment 3 shows the coordination of protective devices between the fuses, breaker, and conductors.

Isolation of the Safety Significant PPCS from the Safety Related Radiation Monitors, which are connected at the analog output port, will be provided by optical isolation devices rated to protect the radiation monitors from damage due to fault, short circuit, or open circuit. The power supplying the isolators is supplied by the instrument bus circuits described above, and are electrically isolated by fuses. The new fuses used for isolation of power to the PPCS isolation devices (RY-A and RY-B) are also rated 3 amps and will coordinate with the breakers and conductors as described above.

#### 7.8 Panel Loading

Panel IBPDPCBC is supplied by 2.0 Kva Twinco voltage regulator MQ-400C, and panel IBPDPCBE is supplied by 2.0 Kva Twinco voltage regulator MQ-400E. Design analysis DA-EE-2001-047, reference 4.7.7, has detailed equipment rating and loading information, which already incorporates the loading added in Rev. 0 of the PCR. Rev. 1 of the PCR only adds more load due to RY-A and RY-B having 0.09 amps additional. The loading on Atttachment 8 shows the loads of each individual device, where it is supplied from, and the total loading to each fuse. MQ-400C and MQ-400E have maximum allowable loadings of 16.9 amps each. The existing load is 14.31 amps on MQ-400C, with 2.59 amps of margin. There is 11.89 amps on MQ-400E, resulting in 5.01 amps margin. The addition of the new SCA300 isolator with an additional 0.09 amps of load will not exceed these margins.

DA-EE-2001-047 shows a maximum load of 1.72 amps to RMS-3 on breaker IBPDPCBC/11, and5.70 amps to RMS-1 on IBPDPCBE/1. With the addition of the new style SCA300 isolators, they remain well below the 15 and 20 amp breaker ratings of those positions.

#### 7.9 Electrical Noise Reduction

1

I

1

1

ł

1

1

1

I

Instrumentation cabling has been provided by the vendor. Per Electrical Specification EE-171, the system has been tested to meet the EMI/RFI testing in accordance with EPRI TR-102323-R1. The equipment will be shipped with a test report demonstrating the equipment with supplied cabling meets that standard. PCR package outputs reference the vendor documents which provide instructions for configuration and connection of all cables and shields to maintain the configuration used to meet these standards.

PPCS connections for analog signals will also use shielded cable and connections per normal construction practices utilized for PPCS inputs. These measures should adequately address instrumentation noise issues.

To avoid potential disturbances caused by the actuation of isolation signals, Quencharc surge suppressors will be installed across the coils of relays R81A and R81B in the control circuits to dissipate energy from relay coils when the contacts open. The Quencharcs across the contacts installed previously will be removed as the single Quencharc in each logic string on the relay coil will provide the appropriate surge suppression for each circuit. This is consistent with installation on related circuits in PCR 98-097, Ref. 4.7.2.

#### 7.10 Control Circuit Logic

The overall control circuitry has been designed to maintain the fail-safe operability of the original Control Room HVAC Isolation system, including inputs from both the toxic gas monitors and the new radiation monitors. In all modes, failure of a component due to loss of power (which typically causes a component to return to its de-energized state) will result in the controlling contacts to open, resulting in de-energization of the controlled device, ultimately resulting in the CR isolation dampers returning to their de-energized position, which is in the isolation mode. Loss of power to any component, or to the total circuit, will result in a CR HVAC isolation being initiated.

#### 7.11 Single Failure

Attachment 7 is a block diagram of the control logic for actuation of a control room isolation. The design incorporates both redundancy and cross-train initiation. In summary, there are two redundant trains of isolation logic, each with a manual and automatic isolation device. Any device (A or B manual or A or B automatic) will initiate a CR isolation in BOTH trains. In this way, for any actuation, if any downstream device fails, the opposite train will still receive an actuation signal. The following sections were taken from the document attached to the Tech Spec Amendment RAI, titled "Conformance to IEEE Std 603 for Modifications Associated with License Amendment Request", dated April 26, 2002.

#### 7.11.1 Single Failure Criterion.

The proposed safety system will perform all required safety functions for a design basis event in the presence of (1) any single detectable failure within the safety systems concurrent with all identifiable but non-detectable failures; (2) all failures caused by the single failure; and (3) all failures and spurious system actions which cause or are caused by the design basis event requiring the safety functions. The guidance of Reg. Guide 1.53 and IEEE Std 379 was used to evaluate the system design for single-failure adherence.

- 7.11.2 The safety function reviewed under the scope of this modification is the initiation of a Control Room isolation signal. The portion of the system enveloped by this review is from the radiation detectors in the air intake duct through the output contacts on the isolation relays in the Auxiliary Benchboard. It includes the power supplies and all inter-connected non-Safety related components. It will not include the isolation dampers and charcoal filter units controlled by the isolation relays - they are beyond the scope of the modification and their design has not been changed by this modification. Final post-modification functional testing does include testing of these devices to ensure that they perform their safety function and were not impacted by the changes.
- 7.11.3 The protective action that is a result of the proper operation of this system is to provide initiating isolation signals to the isolation devices from the isolation relays upon detection of radiation levels above the setpoints.
- 7.11.4 There are two redundant safety groups, A train and B train, that are capable independently of performing that function. Each functioning component in each group has a redundant component in the other train. There are two detectors, two ratemeters, two initiation relays, and two manual isolation pushbuttons, with power provided by two separate power supplies. The redundant relays result in two separate output contacts to each of the isolation devices, each contact capable of providing the signal to the isolation device to go to the isolation position.
- 7.11.5 The design of the system demonstrates that independence between the two safety groups has been established. For initiation of the signals, there are no shared

components. Each train is powered by a separate power supply, cables run in separate train-dedicated conduits, each relay will operate irrespective of the state of the other relay, manual isolation pushbuttons will provide isolation signals irrespective of the other button or of the status of the automatic isolation signals.

- 7.11.6 The design of the logic includes cross-train signal connection so that an initiating event on A train (automatic or manual) will initiate an isolation signal to both relays, and likewise for B train. This was incorporated in the design to provide additional redundancy, so that failure of one relay would not prevent a high alarm from the detector of the other train from initiating an isolation. The points of train cross-connection only add redundancy , and there is no resultant single-failure point caused. The points of cross- connections are limited to the wiring of normally open device output contacts into the actuation circuit of the other train. There is no manner in which the normally open contacts can fail that will disable the opposite train's actuation logic.
- 7.11.7 Mounting of all redundant components in the same structures (such as both detectors in the duct, both trains of logic in Auxiliary Benchboard, both trains of conduit sharing conduit supports) has been performed in a manner to preclude a single component failure (mounting bolt, etc.) from causing both trains to fail, including design basis seismic events.
- 7.11.8 The power supplies to the separate trains are independent, separated, and highly reliable, being fed from completely independent UPS systems. There is no common wiring point from the ratemeter location back to the ultimate supply source. Electrical protection in the form of breakers and current limiting transformers have been analyzed in design analysis DA-EE-2001-047 to be appropriately sized to protect all equipment, further reducing the potential for failure on one train of power propagating to devices on the other train. DA-EE-2001-047 also demonstrates the capability of both power supplies to independently supply power adequate for the operation of all equipment required to perform the safety functions. For further protection, all devices powered by the power supplies are configured so that on a loss of power, the output of the devices goes to the isolation initiation state.
- 7.11.9 System Portions Analysis (section 6.2 of IEEE 379)
- 7.11.9.1 Both trains of equipment have outputs that supply a signal to the non-1E Plant Process Computer System (PPCS) and non-1E radiation recorders. These signals are analog outputs from each ratemeter to communicate radiation levels to the PPCS and the recorders, and this is a non-safety related function. A failure in either the PPCS or a recorder is prevented from causing a common failure in both ratemeters by insertion of independent qualified 1E optical isolators in the circuits that connect the ratemeters to PPCS and the recorders. The isolators themselves are isolated from the 1E power supply to them by putting 1E fuses in the supply

circuit.

- 7.11.9.2 Both trains of isolation actuation logic have signals from the non-1E toxic gas monitoring system (contacts from the toxic gas system processing modules). These signals and power to the toxic gas power supplies are all isolated from the safety related portion of the design by qualified fuses.
- 7.11.9.3 A review of the logic demonstrates that there is no single failure point in the circuitry. Refer to Attachment 7 for a block diagram of the system design. The conclusion is that there is no single failure in the system logic that will cause failure in the channels or actuation circuits that would cause loss of the safety functions.
- 7.11.9.4 Devices in the isolation logic circuits are configured to fail so that any deenergized equipment will fail to the position that provides an isolation actuation signal. Power cannot be maintained incorrectly on the actuator system terminals and cause a loss of safety function because multiple normally open contacts in series provide the actuation signal to the isolation relays, and the isolation relays output contacts likewise are normally open in the control circuits of the associated dampers.
- 7.11.9.5 SK21946-0546SH1-1 and SK21946-0546SH2-1 diagrams of this design, and the series of normally open contacts is apparent. This series of open contacts, coupled with the cross-train connection of the output contacts to each isolation device, provides assurance that even the mechanical failure of contacts to open upon a loss of power in one relay will not prevent the isolation function from occurring due to the opening of the contact in the other train of isolation initiation.
- 7.11.9.6 The connection of electrical power supplies is completely independent. The malfunction of a power supply in a manner that results in a high voltage would only impact a single train, again due to the cross connection only being via normally open contacts so that no voltage is being supplied from one train to the other.
- 7.11.10 All other systems or components that are coupled to these safety systems have been integrated so that they cannot fail in a manner to degrade the safety system. Maintenance bypass switches are designed and installed in the circuit so that a contact block failure will be detected by the indicating lamp associated with each switch. The bypass functions for each train have been connected with separation from the opposing train, and all components qualified and installed safety related.
- 7.11.11 SRP Appendix 7.1-C Section 6 contains discussion of scope of review beyond IEEE 603 Single Failure Criterion as it pertains specifically to digital I&C equipment. The concerns with digital equipment in that section are centered around the sharing of data, functions, and process equipment inputs such that a design using shared databases and process equipment has the potential to

propagate a common-mode failure of redundant equipment. This design feature is not applicable to the radiation monitors that are being installed as part of this modification. The redundant monitors do not share any data or process equipment inputs. The two monitors operate independently, with train-specific inputs from the detectors. The output alarm contacts that provide the protective functions will operate independently of the status or signals associated with the redundant train. Therefore, the digital nature of these monitors does not lead to the propagation of a common-mode failure of this type. The second concern of digital I&C systems is that software programming errors can defeat the redundancy achieved by the hardware architectural structure. In the application of digital technology for this installation, the software functions are very limited in how they impact the system. The digital functions that are part of the safety functions are 1) the calculation of a dose rate based on input signal from the detector, and 2) the signal to the alarm relay to operate to change output contact states, based on user-set alarm setpoint. These two functions have no other inputs or variables other than the dedicated detector signal for that ratemeter. Both of these functions are completely tested before installation by the manufacturer, at the time of installation by post-modification calibration and functional testing, and at normal operating intervals via Technical Specification required channel checks, channel operability tests, and scheduled calibrations. All of this monitoring and testing throughout the operating range of the unit provides assurance that the software functions utilized to initiate the protective functions are properly programmed and operating for each unit, and that there is not a software programming error that will occur that will prevent the equipment from performing its safety function in a manner to cause both units to fail at the same time.

#### 8.0 <u>Conclusions</u>

8.1 The design shown in PCR 99-004 Revision 1 construction package as defined above meets technical operational requirements. The electrical factors described in section 1 above have been evaluated and have been demonstrated to be adequate and appropriate for installation and operation.

**Revision 2** 

Specifications (U	niversal Digital Ratemeter)	Power ON/OFF	Alternate action pushbutton for AC power to the unit
The Victoreen Mo meter (UDR), when 2XY Geiger-Muel monitoring system range. The UDR p tion functions for t readings in the ran	adel 956A-201 Universal Digital Rate- n connected to a Victoreen Model 897A- ller (GM) tube detector, comprises a n which operates over a five decade rovides display, control, and annuncia- he monitoring system, and will display ge of $10^{-2}$ to $10^{5}$ mR/h.	Relay Outputs (Failsafe operation)	HIGH Alarm - 1 set. DPDT rated 5 A @ 120 Vac (one set 120 Vac powered for use with optional local alarm) WARN Alarm - 2 sets. DPDT rated 5 A @ 120 Vac
Standard features for display of the radial indicator which co- bargraph will chang	or the instrument consist of a three digit tion value and a multi-colored bargraph vers the entire range of the UDR. The ge color in the event of an alarm condi-		FAIL Alarm - 2 sets. DPDT rated 5 A @ 120 Vac DC. Contact raung for all relays is 5 A @ 29 VDC
uon (green for nor high). Front panel	alarm indicators and rear panel relay	HV Output	300 Vdc - 1800 Vdc @ 0.4 mA
outputs for alarm a panel pushbuttons	are provided to apply power, display	Check Source PWR	+15 Vdc @ 20 mA
alarm limit set poin the check source.	0 - 10  Vdc(1) and $4 - 20  mA(2)$ are	Analog Outputs	410 20 mA (2) (500 ohms Max.) and 010 10 Vdc (1k ohm Min.), logarith- mic May be scaled for any one
provided for record outputs may also be (i.e. near the detector	ling and computer monitoring. The used to drive a remote meter or a local or) indicator.		decade (Min.) to the full range of the unit (Max.)
All electronics requi	red to interface with the VICTOREEN cotor are included within the 956A-201	Alarm Ack Input	Optically isolated DC input
UDR. The electron supply, low voltage	nics consist of a high voltage power DC power supply and the hardware/	Detector Input	Digital pulse, up to 2000 feet from UDR, 50 ohm input impedance
software required to includes an overrang of on-scale readings range of the detector	br UDK operation. The system also ge indicator to preclude the possibility when the radiation field is beyond the r.	Accuracy (electronic)	$\pm$ 1% digit ( $\pm$ 1% of the displayed value), exclusive of the detector energy response
Main Display	Three digits with backlighted radia- tion units display and floating deci- mal point. Three digits plus expo-	Dimensions (H x W x D)	3.5 in. x 5.6 in. x 13.5 in. (8.9 cm x 14.2 cm x 34.3 cm)
Bargraph Display	nent for data entry/display.	Weight	Approximately 3.7 lb. (1.67 kg)
(Dynamic Range)	Three segments per decade, 10 ⁻² to 10 ⁶ mR/h (24 segments), tri-color, indicating channel status.	Power	120 Vac ±10%, 50/60 Hz, 28 wans (240 Vac optional)
Alarm Indicators	HIGH, WARN, FAIL, RANGE	Operating & Storage Temp.	32° F to 122° F ( 0° C to + 50° C )
Pushbuttons	Pushbuttons HIGH, High Alarm lunit WARN, Warn Alarm lunit		0 to 95% non-condensing
Check Source Activates radioactive Check Source and associated green LED indica- tor. "Momentary Non-Latching		Compatible Detector Heat Loading	897A Series, GM (Geiger Mueller tube) Approximately 96 BTU/h
Alarm Ack.	ATarm acknowledgment: causes alarm indicators to go to a steady on state after acknowledgment	Accessories & Aux. Equipment	Please Contact our Systems Sales Dept.

6000 Cochran Road • Cleveland, Ohio 44139 - 3395 • Phone 216 - 248-9300 • Fax 216 - 248-9301

Attachment

of <u>3</u> Page_

DA-EE-2001-009 Rev. BH

The Model 897A GM Detector is designed to operate with the Victoreen Model 956A-201 Universal Digital Ratemeter (UDR) or with other Victoreen readouts. Each detector measures a five decade range. Three measurement ranges are available: low, medium, and high. The low range covers 10⁻² to 10³ mR/h, the medium covers 10⁻¹ to 10⁻ mR/ h, and the high covers 10° to 10° mR/h. The Model 897A detector may also be used with the Victoreen Model 960 Digital Radiation Monitoring System equipment or the Victoreen Model 856 Analog Readout.

.

Victoreen Model 856 A	nalog Readout.	897A-210, 897A-211	45 microseconds
		897A-220, 897A-221	28 microseconds
Detector		897A-230, 897A-231	20 microseconds
Dimensions	7 1/8 X 3 mones (18.1 X 7.0 cm/	Measurable Radiation	
Weight	1 16. (0.45 kg)	897A-210, 897 <b>A-21</b> 1	$10^{-2}$ to $10^{-1}$ mR/h
Housing Material		897A-220, 897A-221	10 ⁻¹ to 10 ⁴ mR/h
897A-210, 897A-220,	Aluminum, weatherproof	8974-230, 8974-231	10° 10 105 mR/h
897A-230	Aluminum, weatherproof	<b>c</b> ,,,,,,,, .	
897A-211, 897A-221,	Stainless Steel, weauterproof	Detector Element Life	Exceeds 1000 hours at full-scale
	Cusinlass Steel weatherproof	Energy Dependence of	
897A-231	Stamless Sicel, weatherproof	Reading	+/-15% from 100 keV to 1.5
			McV
Fill Gas	Neon / Argon / Halogen	Detector Accuracy	± 20% of actual dose for Cs-
897A-210, 897A-211	Helium / Neon / Halogen		137
897A-220, 897A-221	Helium / Neon / Halogen	<b>Radiation Detected</b>	Gamma rays, X-rays
897A-230, 897A-231	11010011110011110000		
Well Thickness (hart t	ube)	Preamplifier	
807A-710 897A-211	$32-40 \text{ mg/cm}^2$		
8074-770, 897A-221	80-100 mg/cm ²	Input Impedance	>100 k-ohms
897A-230, 897A-231	80-100 mg/cm ²	Output Impedance	50 ohms
Mounting	Wall mount	Output Pulse Polarity	Positive
Mating Connectors	897A-2x0:	Output Signal (50 ohm)	+5 Vdc square-wave
Manual Competition	92-7005-17A, 12 Pin Female	Low Voltage	+15 Vdc (Optional +10 Vdc is
	92-7005-12A. Bushing		jumper selectable)
	92-7005-9A, Clamp	Power Requirements	+15 Vdc @ 20 mA
	897A-2x1 (stainless steel):	Maximum Cable	
	92-7005-15A, 12 Pin Female	Length	1700 1001
	92-7005-12A, Bushing	Electronic Exposure	A a manimum 100 made
	92-7005-13A, Bushing		Adjustable from 0 to ±7 Vdc
Required Cable	Victoreen P/N 50-100 of	Discriminator Level	(coming) value = 0.5 Vdc)
	equivalent with two coaxial con-		(nominal value = $0.5 + 0.5$ )
	ductors, two twisted pairs, and	Anti-Jam Level	Adjustable moure to +5 vice
	overall shield.		Approximately 50 kHz
External Pressure Limi	t 30 psig	Usculator r req.	Approximately 50 kinz
Storage Temperature	-10 to 122 F (-23 to 50 C)	Analog & Digital	Divide by 2 square wave out.
		MODIOF COMISSING	Divide of 2, square wave out
Operating Temperature	e -10 10 122 r (-23 10 50 C)	Ontional Monitor	pu,
	0 to 95% non condensing	Configuration	Raw milse outmit
Relative Humidity	To to 22% Hou-condensing	Comilaryan	(iumper selectable)
			VF

**Operating Voltage** 

897A-210, 897A-211

897A-220, 897A-221

897A-230, 897A-231

Dead Time (Approximate)

Plateau Length

Plateau Slope

6000 Cochran Road • Cleveland, Ohio 44139 - 3395 • Phone 216 - 248-9300 • Fax 216 - 248-9301

Attachment Т Page 2_of___

DA-EE-2001-009 Rev. DIPS

 $\overline{N}$ 

500-650 Vdc (supplied by digi-

(al ratemeter)

100 - 150 Vdc

45 microseconds

0.1%/V

0.2%/V

0.3%/V

# Area Radiation Monitor GM Detector Model 955A

#### VICTOREEN



#### Features

- Range: 5 decade between 10⁻² and 10⁴ mR/h
- Energy Response: 15% from 100 keV to 1.5 MeV
- Life Expectancy: Up to 10⁵ Rads
- No external power needed at detector location
- Preamplifier integral with detector
- Seismic tested with high reliability
- Readout may be remotely located up to 1700 feet
- Single cable between readout & detector
- 8 micro Curie *Cl check source

#### Introduction

The Victoreen Model 955A is a single-channel area radiation monitoring system capable of operating over the ranges of 10⁻² to 10³ mR/h. 10⁻¹ to 10⁴ mR/h, or 10⁰ to 10⁵ mR/h, depending on the detector selected The system monitors gamma radiation over a 5-decade range and provides indication when the radiation level decreases below a fail threshold, exceeds a warn set point, exceeds a high set point, or exceeds an overrange set point. The over range feature provides two significant benefits. First, it prevents the system from displaying an on-scale, but inaccurate, reading should the detector become saturated. Second, it lessens the risk of damaging the detector by disabling it during an overrange condition. Relay outputs are available to activate alarm annunciators. Analog outputs are available for trend display on a strip chart recorder or computer. In addition, the monitoring system has an integral check source to verify operational integnty.

3

Page

З

of

The system consists of a Model 897A series Geiger-Mueller (G-M) Tube Detector with integral preamplifier and the Model 956A-201 Universal Digital Ratemeter (UDR).

#### Application

Area monitoring is used for the detection of X-Ray or gamma radiation in a selected area. The monitor should be used in any area location where personnel may be exposed to an adverse amount of radiation. Applications include nuclear reactors, accelerators, hot cells, irradiators and any area where radiation sources are handled. These monitors can be used as single channel monitors or grouped together as a multi-channel area monitoring system.

#### Specifications (Ion Chamber & Preamplifier)

Victoreen 897A-series GM detectors use a thin walled Geiger-Mueller tube to detect ionizing radiation. Each 897A-series detector has a GM tube, a check source, and a preamplifier. The check source is a low-level radioactive source actuated by a +15VDC meter movement. The preamplifier provides the pulse conditioning and cable driving capability necessary to drive a Victoreen 956A-201 series digital ratemeter.

All 897A-series detectors are functionally identical. They differ only in housing material, tube type, and range. The 897A series detectors operate in the voltage range between 500 - 650 Vdc.

6000 Cochran Road • Cleveland, Ohio 44139 - 3395 • Phone 216 - 248-9300 • Fax 216 - 248-9301 DA-EE-2001-009 Rew 24 Attachment



# INDUSTRIAL CONTROL RELAYS Fixed Contacts Cat. Nos. BF and BFD

BF 300 Volt Ac

BFD 250 Volt Dc

COMPLETE RELAY

# WHEN ORDERING SPECIFY

Catalog number of basic relay.

• If a coil voltage other than listed is required, select the suffix code from the Coil Voltage Table and substitute it for the last letter in the catalog number.

Example: BF80V for a 110/60 ac coil.

# DESCRIPTION

Type BF and BFD relays are compact industrial control relays ideally suited for machine tool and similar applications where size is a factor. Type BF is ac operated, 300 volts maximum, and the BFD is dc operated, 250 volts. Fixed contact relays are available in any combination of NO and NC from two to twelve poles. The NO and NC contacts are electrically isolated and both can be used without regard to polarity.

BF and BFD relays have captive clamp terminals fully accessible from the front, a molded coil with low operating temperature, and silver alloy contacts suitable for low voltage circuits. Overlap contacts are available. All contacts feature the exclusive knife-edge design which provides a "self-wiping" action on every closure.

Type BF



Type BFD

#### UL/CSA

UR, UL File No. E19223 CSA certified, File No. LR39402-6, LR28548-10, 11

#### **OPTIONS**

Description	Code Letter or Catalog Number	Price Adder	
FASTON Push-on Terminals — insert letter 'F' after relay type designation in listed catalog number. Example. BFF20F or BFDF20S	F	\$ 1,50 per pole	
Overlapping contacts — NO contact closes before corresponding NC contact opens — supplied as NO/NC set(s) In- sert letter "A" after relay type designation in histed catalog number. Example: BFA22F or BFDAF22S	A	18 per set	
Filler Relay — empty relay case for mounting a timer on a BF mounting strip, Cat. No. BFMS, when other relays cannot be used	BFOO	18	

#### COIL VOLTAGE TABLE

**DISCOUNT SCHEDULE 1CD-1** 

	<b>BF Coils</b>		BFC	) Coils
Volts Ac	H2 -	Suffix Code	Volts Dc	Suffix Code
12 24 48 110 208 240/220 440	60 60 60 60 60 60 60/50 60	H	6 12 24 48 95 130 240	C D L M B U T

	Number	Type of Contact		pe of Contact Basic Relays		Basic Relays 120 Dc Coil		
	Poles	NO (Form A)	NC (Form B)	Catalog Number	Price	Catalog Number	Price	
•	2	2 1 0	0	BF20F 11F 02F	\$ 72. 72. 72. 72.	BFD20S 11S 02S	\$ 102. 102. 102.	
-	3	3 2 1 0	0 1 2 3	8F3 <u>0F</u> 21F 12F 03F	84. 84. 84. 84.	BFD30S 21S 12S 03S	114. 114. 114. 114. 114.	ISTRIAL
-	4	4 3 2 1 0	0 1 2 3 4	BF40F 31F 22F 13F 04F	96. 96. 84. 96, - 96.	BFD40S 31S 22S 13S 04S	126. 126 114. 126. 126.	BF, BFD INDL Rei avs
-	6	6 5 4 3 2 0	0 1 2 3 4 6	BF60F 51F 42F 33F 24F 06F	108. 108. 108. 96. 108. 108.	BFD60S 51S 42S 33S 24S 06S	138. 138. 138. 126. 138. 138.	CAT. NOS.
•	8	8 7 6 5 4 0	0 1 2 3 4 8	BF80F 71F 62F 53F 44F 08F	132. 132. 132. 132. 132. 108. 132	BFD80S 71S 62S 53S 44S 08S	162. 162. 162. 162. 138. 162.	
-	10	10 8 7 6 5 4 2	0 2 3 4 5 6 8	BF100F 82F 73F 64F 55F 46F 28F	156. 156. 156. 132. 132 156 156.	BFD100S 82S 73S 64S 55S 46S 28S	186. 186 186. 162 162 186 186.	-
	12	12 8 7 6	0 4 5 6 7	BF120F 84F 75F 68F 57F	180 156 180. 156. 180	BFD120S 84S 75S 66S 57S	210. 186. 210. 186. 210.	
		1	8	48F	180.	485	210.	

NOTE Relays listed above with equal number of NO and NC contact poles are specially priced — 1 NO and 1 NC pole are supplied at no additional charge.

#### SPECIFICATIONS

	B	F RELAY	ELECT	RICAL RA	TINGS -	- NEMA	A300		
Valta	Maxi	mum Cu	irrent	ent Maximum VA					
VOILS	Cont.	Make	Break	Make		Make Break			Break
120	10	60	_6	5 7200 720		720			
240	10	30	3	7200 720					
HP RATINGS (UL RECOGNIZED)				DC RATING - NEMA P300					
	Ac V	olts	Volte	Maximum Current		Maximum Make			
Phase	115	230	VUILS	Cont.	Make	Break	or Break VA		
1 3	1/6	1/2	125 250	5.0 5 0	1,1 0.55	1.1 0.55	138 138		
	RESISTIVE RATING COIL POWER REDUIREMENTS					UIREMENTS			
125V dc: 3 amperes Ac: 72 VA open 12 VA clo 250V dc: 1.5 amperes Dc: 12 watts, 250 volts ma				losed					

U T	Atta	achment	~		
 	•			CONTINUE	D NEXT PAGE
DIMENSI	ONS, Page 426	· · · · / ·	f	_2	F.T.N
	rai		0		
		DANEE-2	001-009	Rex. Et 3	L-21
				2.05	

July 1995



# CONTACT ARRANGEMENTS FOR BF, BFD RELAYS

N O. = 1	N O. = Normality Open N.C. = Normality Closed						
2 Poles		3 Poles			4 Poles		
2 N O.	1 N.O. 0 N.O	. 3 N.O. 2 N.C	). 1 N.O.	0 N.O.	4 N.O. 3	N.O. 2 N.O.	1 NO. 0 N.O.
2 N.C.	1 N.C. 2 N C.	ONC. 1NC	. <u>2 N.C.</u>	<u> 3 N C.</u>	0 N.C. 1	N.C. 2 N.C.	3NC. 4NC.
1991	199:199:	199:919:92	2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2	11:11	19999199	[[[]]]]]]]	
İİİ				1:11	IIIIII		
1001							
6	Poles			. 8 Pol	<del>o</del> s		
6	N.O. 5 N.O. 4	N.O. 3 N.O. 2	N.O.	8 N.	0. 7 N.O.	6 N.O. 5 N.	0.4 N.O. 0 N.O.
Ö	N.C. 1 N C T	N.C 3N.C. 4	NC	<u>0 N</u>	CINC.	<u>2 N.C. 3 N.</u>	C. 4 N.C. 8 N.C
- P	99999999	9999999999		111	20121211	<u> 111111111111111111111111111111111111</u>	1111111111
Rear 1	ŢŢŢĬŢŢŢĬŢ	<i>ŦŦĪĬŢŢŢĬĬ</i>	itt ne	ĴĪĪ	I I I I I I	1111111	111111111
5	110101100	1 1 0 0 1 2 0	10	000	000000	999999	9999999999
Front 🖞	ĮĮĮĮĮĮĮ	┋┋╪╢╪┋┋╪╢┿	Fro	ont 🕂 🛉 🛔	┊╪╎╪╪╴╪╪╎╡	┊╡┊┊╎┊╡	<i>╪</i>   <del>╪</del> ╪ <del>╡</del>   <i>╪ ╪ ╪</i>
ę	1991999	1 9 9 9 9 9 9 9	:6	699	9999999	0000000	6 6 6 6 6 6 6 6 6 6 6 6 6 6 6 6 6 6 6 6
	10 Poles		12 Pole	s			
	6 N.O. 15 N.O	4 N.O.	12 N.O.	8 N.O.	7 N.O. 6 N	I.O. 5 N.O.	4 N.O.
	4 N.C. 5 N.C.	6 N.C	ONC	4 N C.	5N.C. 6 N	I.C. 7 N.C.	8 N.C.
_	199:199	1:11	9999	9999	999999	2999999	9999
Rear		111	ĪĪĪĪ	ĪĪĪĪ	ĪĪĪĪĪĪĪ	ŦĪlŦĪĪ	<u> </u>
	1001	100.00	0000	0000	0000000	0000000	0000
Center	ĨĨĨĨĨĬĬ	ļĮĮĮ	ĮĮĮĮ	ĮĮĮĮ	ĮĮĮĮĮ	ĮĮĮĮĮĮĮĮ	ĮĮĮĮ
Conten	79799999	6999	9999	9999	9999999	9999999	9999
<b>_</b> .	999999999	19999	9999	2999	2999999	1999999	1111
Front	****	<u>1</u> 111	ĪĪĪĪ	III	IIIIII	iiiiii	<u> </u>
	000010000	10000	0000		2220100		

Attachm	ent	2	
Page	2	_of	2

DA-EE-2001-009 Rev. 242

CAT. NOS. BF, BFD INDUSTRIAL CONTROL RELAYS

Ż

E:T.N L-22

July 1995





;

# Attachment 4

Conduit	Conduit . Size	Circuits	Cable Size	Cable Area (sq. in.)	Total Fill (sq. in.)	Allowable Fill (sq. in)			
Existing conduits with new cables in <b>bold</b>									
C5529	1 ½"	C5529 C5530 C5543 C5544	1-2-12 1-2-12 1-2-12 1-2-12	0.138 0.138 0.138 0.138 0.138	0552"	0.814"			
C5529_1	1 1⁄2"	C5529 C5530 C5543 C5544	1-2-12 1-2-12 1-2-12 1-2-12	0.138 0.138 0.138 0.138 0.138	0.552"	0.814"			
C5539	1 1/2"	C5539 C5545 C5546	1-2-12 1-2-12 1-2-12	0.138 0.138 0.138	0.414"	0.814"			
C5539_1	1 1⁄2"	C5539 C5545 C5546	1-2-12 1-2-12 1-2-12	0.138 0.138 0.138	0.414"	0.814"			
			New Conduits and	d Cables					
C5551	2"	C5551 AU0235A R4522	1-4-12 1-2TSP-16 10/C special	0.185 0.078 0.358	0.621"	1.342"			
C5552	2"	C5552 AU0239A R4523	1-4-12 1-2TSP-16 10/C special	0.185 0.078 0.358	0.621"	1.342"			
R4522	1 1/2"	R4522 AU0235A	10/C special 1-2TSP-16	0.358 0.078	0.436"	1.079"			
R4522_1	1 1/2"	R4522 AU0235A	10/C special 1-2TSP-16	0.358 0.078	0.436"	1.079"			
R4522-2	1 1/2"	R4522	10/C special	0.358	0.358	1.079			
R4523	1 ½"	R4523 AU0239A	10/C special 1-2TSP-16	0.358 0.078	0.436	1.079"			
R4523_1	1 1⁄2"	R4523 AU0239A	10/C special 1-2TSP-16	0.358 0.078	0.436	1.079"			
R4523_2	1 1/2"	R4523	10/C special	0.358	0.358	1.079			
AU0235A	1 1/2"	A0235A	1-2TSP-16	0.078	0.078	1.079			
AU0239	1 1/2"	A0239A	1-2TSP-16	0.078	0.078	1.079			

DA-EE-2001-009 Rev. 2 4 Attachment 4 p. 1 of 1

•

•,

# Siemens Electromechanical Components



#### Features

- Industry standard octal-type termination for quick installation
- · Contact arrangements from 1 Form A (SPST NO) to 3 Form C (3PDT)
- Indicator lamp and push-to-test options available on certain models
- The KRPA series is the automated manufactured version of the KRP
- series Hermetically sealed option available with KR UL recognized for Class I Drv 2 Hazardous locations, Groups A. B. C. D

#### Contact Data @ 25°C

Arrangements: See Ordering Information Table Materials: Silver or silver-cadmium oxide, with or without gold flashing

Expected Life: 10 million operations min , mechanical, 100,000 operations min @ rated loads

#### KA, KRP, KRPA

UL/CSA Contact Ratings @ 25°C (Excent KR)

	1 LACOPI TO	4
Contact	Arrangement	Contact Rating
Y&L (Silver)	1, 2, 3 Poles _	5A @ 120VAC 3A @ 240VAC 1/10HP @ 120VAC 1/6HP @ 240VAC
G&N (Silver-Cad Oxide)	1, 2, 3 Poles	10A @ 240VAC 1/2 HP @ 240VAC 1/3HP @ 120VAC

#### **Factory Ratings** KRP. KRPA

Contact Code	Amagement	Contact Reting
Y&L	1, 2, 3 Poles	5A @ 28VDC, 120VAC, 80% PF
G&N	1, 2, 3 Poles	10A @ 28VDC, 120VAC, 80% PF 6A @ 250VAC

#### KA UL Contact Ratings

Contact Code	Series	Contact Ratings
Y	KA1	5A @ 120VAC, 3A @ 240VAC, 1/10 HP @ 120VAC, 1/6 HP @ 240VAC
G	KA2	10A @ 120VAC. 6A @ 240VAC 1/6 HP @ 120VAC, 1/3 HP @ 240VAC

Attachment 5

Listed by C.S.A. for SA @ 120VAC 80% PF 2Listed by C.S.A. for 10A @ 120VAC 80% PF

#### Initial Dielectric Strength

Between Open Contacts: 500V ms Between All Elements: 1,500V rms

Nota: See KRPA, KRP, KA, KR-E Ordering Information table on page 108

2 -EE-2001 -009 Rev. \$42

# KRPA, KRP, KA, KR series

#### 5 to 10 Amp **General Purpose Relay**

**SI** File E29244, E22575, E81558 (KR Hermetic) File LR15734

#### Coll Data @ 25°C

(*	1	Nominal Power	Maximum Power		
KRP	AC	2VA	Open Models - 5VA Enclosed Models - 4VA		
KRPA	DC	12W	Open Models - 4W Enclosed Models - 3W		
KA	AC	2VA	Open Models - 4VA		
	DC	125mW per movable arm	Open Models - 4W		

Duty Cycle: Continuous

Initial Insulation Resistance: KRP KRPA - 1000 Megohms, mm KA - 100 Megohms, min

#### Coll Data @ 25°C

	Nominal Voltage	DC Resistance (D)	Nominel Coll® Current (mA)
	6 12	32 120	188 100
DC Colla	24 48 110	472 1,800 10,000	51 26 6 11 5
	220	Use 110V relay with 10 000	D 5W Resistor in series
AC	6 12 24		335 168 84
	120 240	2,250 9,110	175 B 75

#### Operate Data @ 25°C

Must-Operate Voltage:

DC: 75% or less of normal voltage

AC: 85% or less of norminal voltage

**Operate Time (Excluding Bounce): -**

15 milliseconds typical @ nominal voltage

Release Time (Excluding Bounce):

10 milliseconds typical @ nominal voltage

#### **Environmental Data**

Temperature Range: Open Models: AC: -45°C to +70°C DC: -45°C to +85°C Enclosed Models: AC: -45°C to +55°C DC: -45°C to +70°C

#### **Mechanical Data**

٩ı

Open Models: Solder terminals Enclosed Models: Octal-type plug Enclosures: Transparent polycarbonate (except KR) Hermetically sealed metal case available with KR only Weight: KA: 17 oz (48 2g) approximately

KRPA, KRP: 3 0 oz (85g) approximately

# **NUS** Instruments

# SPECIFICATIONS FOR ANALOG ISOLATOR MODULES

The analog isolator module, model number as listed below, is a solid state signal conditioning and isolaton module with one to eight inputs which provides from one to eight outputs electrically isolated from the inputs. All units use the same basic circuits for isolation and signal conditioning. All multi-channel FCA units use the same isolator PC board. The SCA and FIA use PC boards unique to their applications. The FIA has separate DC power supplies for each channel and therefore has electrical separation between the outputs.

#### MODELS AVAILABLE:

Model Channels	Model	Channels	Model	Channels	Model	Channels	Model	Channels
SCA100 1 SCA101 1 SCA102 1	FCA300 FIA350 OCA300	4, 3, 2 4, 3, 2 1	FCA500 FIA500 OCA500	4, 3, 2 4, 3, 2 1	ECA600 FCA600 OCA600	0 8 0 4 0 1	FCA800 FIA800 OCA800	4, 3, 2 4, 3, 2 1
304103	1	NPUT, OUT	PUT AND P	OWER RA	NGE CO	DES		-
IN	PUT			OUTI	PUT		POWER	SOURCE
CODE RANGE		IMPEDANCE YY	CODE	RANGE		IMPEDANCE ZZ	CODE	RANGE
00 Not Loaded 01 0 to 100 m 02 0 to 51 mV0 03 0 to 1 Vdc 04 0 to 5 Vdc 05 1 to 5 Vdc 06 0 to 10 Vdc 07 4 to 20 mAd 10 to 50 mAd 11 0 to 20 mAd 13 50 to 10 m 14 Variable 15 0 to 8 Vdc 16 -10 to 10 Vdc 17 -2 to 15 Vdc 19 3.6 to 11.2 20 2 to 10 Vdc 19 3.6 to 11.4 20 2 to 2 Vdc 23 N/A 24 1 to 2 Vdc 26 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 31 M 10 to 32.4 10 to 32.4 10 to 32.4 10 to 31 M 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4 10 to 32.4	/dc 100M 100M 100M 5.2M 5.2M 5.2M 400k 249 Adc 100 5 50 dc 249 dc 100 5 249 dc 100 Mdc 210 Mdc 2.4M 100M 6 Vdc 3.7M 100M 6 Vdc 77k c 3.5M mAdc 249 3.2M	ohms 00 ohms 01 ohms 02 ohms 03 ohms 04 ohms 04 ohms 06 ohms 06 ohms 09 ohms 11 ohms 12 ohms 13 ohms 14 ohms No ohms 1. ohms 1. ohms 1. ohms 2. ohms 2. ohms 3. ohms 3. ohms 3.	Not Loade 0 to 100 0 to 51 r 0 to 1 V 0 to 5 V 1 to 5 V 1 to 5 V 1 to 5 V 1 to 50 r 0 to 10 V 4 to 20 r 10 to 50 r 1 to 5 V 10 to 50 r 1 to 5 V 10 to 44 tes: These are drive capp ) Some com specific ) Other in can be e and mult .) This lis	ed mvdc 32 mvdc 17 ic 2 ic 8 ic 8 vdc 10 mAdc 10 mAdc 10 mAdc 59 mAdc 10 mAdc 6 in add 10 in add 10 mAdc 6 in add 10 in add 10 mAdc 6 in add 10 mAdc 6 in add 10 mAdc 6 in add 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc 10 mAdc	.9 ohms .3 ohms 25 ohms 25 ohms 25 ohms 50 ohms 50 ohms 50 ohms 50 ohms 60 ohms 60 ohms 60 ohms 60 ohms 49 ohms 60 ohms 11 imped of the may red nsult M utput ra . Alten ut model lete as	00 Not 1 08 85-1 08 85-1 08 85-1 08 85-1 08 85-1 00 00 00 00 00 00 00 00 00 00 00 00 00	the outpu by the outpu trut modu rnate ordering. be availab inal arran o availabl	dc t les. Dle or gements e.

#### ENVIRONMENTAL:

,

Amblent Temp.:	35 to 122°F (2 to 50°C) (Normal Operation - all specifications apply) 35 to 135°F (2 to 57°C) (No damage-Abnormal Operation for 200 hours, may operate outside performance specifications)
	-40 to 185°F (-40 to 85°C) (Storage)
Relative Humidity:	0 to 95% non-condensing (Operating) 0 to 99% non-condensing (Storage)
Pressure:	Armosphenc ±10 psig
Radiation Limits:	10" Rad TID gamma over forty years
Isolation:	3000 Vdc and 1000 Vac (RMS) from input to output, (Each input is isolated from every other to these values) 1000 Vdc and 1000 Vac (RMS) from input to case

DA-EE-2001-009 Rev. 2

Attachment	٥
------------	---

Page / of 2

Fault Withstand:	480 Vac or 140 Vdc at 20 amps on any port, all ports provide isolation from any other on FIA versions. Same specification except output ports isolated from power port to 132 Vac only on all other versions.
Surge Withstand:	No damage when the waveform of IEEE-472-1974 is applied in common or transverse mode to any port.

Electrical Class: Plant protection, qualified to IEEE 323-1974/1983 and IEEE 344-1975/1987.

#### POWER SUPPLY:

•••

	Power: 1 Ch → 4 Ch 8 Ch	Series 1 Series 3 Series 6	00, 500 00, 350, 500, 8 00	NOF 00	RMAL OPERATION 3 W, 7 VA 8 W, 18 VA 15 W, 36 VA	. PEAK / 5 W, 18 12 W, 50 24 W, 75	AND INRUSH VA (maximum) VA (maximum) VA (maximum)	
	Supply Voltage:		B5 to 132 Vac comprising u	c, 47 to 63 Hz p to 6% of the	or 110 to 170 Vdc. H total voltage, present	armonics of powe on the power sup	r line frequency, to the ply port, have no effect	21st harmonic, It on the module output.
	TOLERAN	CES:						
	Temperatur	e Effects:	Less than 0.0	25% of output	t fuil scale change for	a 1°C change in t	emperature.	
	Time Respo	onse:	Less than 5 n 63% of the fir	nsec from app al value. (Fil	blication of a step chai ters bypassed or not i	nge at the input to In the circuit.)	a change in the outpu	l (resistive load) of
	Accuracy:		±0.10 of outp	ut full scale, re	epeatable to 0.05%.			
	Linearity:		0.05% of outp	out full scale				
	Freq. Resp	onse:	DC to 20 Hz (	(120 Hz for ac	inputs) or as specifie	d (5 kHz maximur	m)	
	PHYSICAL							
	Senes 100	Version:	(Encapsulated, Size: 7 Weight: A	surface mour .5°w x 6.0°h x pproximately	nt, single channel moo :2.6°d 6.8 lbs	lei)		
$\rightarrow$	Series 300	Version:	(Encapsulated, Size: 7 Weight: A	surface mour .5"w x 8.0"h x pproximately	nt, multi-channel mod : 2.6°d 9.4 lbs	9)		
	Series 350	Version:	(Encapsulated, Size: 8 Weight: A	surface mour .5°w x 9.0°h x pproximately	nt, multi-channel indej : 2.6°d 11.5 lbs	pendent output ma	odel)	
	Series 500 '	Version:	(Shelf or rack n Size: 2 Weight: A	nount, single ( .78°w x 7.00°l pproximately	or multi-channel mode h x 13.75°d + 0.75° fro 4.8 lbs	il) ont clearance		
	Series 600	Version:	(19' rack moun Size: 1 Weight: A	t, multi-chann 7,0°w x 1,72°l pproximately	el model) h x 13.25°d 9 libs			
	Series 800	Version:	(Shelf or rack n Size: 3 Weight: A 800: Yellow p 801: Red pow	nount, single ( .37°w x 9.50°l pproximately ower LED and ver LED and b	pr multi-channel mode h x 15.25°d + 1.25° fro 5.3 lbs d 0.080° pin style test panana style test jacks	el) ont clearance jacks		
	FOR ADDITIONAL INFORMATIC				ITACT:			
	NUS IN 440 WE IDAHO PHONE	STRUM ST BRC FALLS,	ENTS, INC. ADWAY ID 83402 529-1000					

ALL SPECIFICATIONS ARE SUBJECT TO CHANGE WITHOUT PRIOR NOTICE.

DA-EE 2001-009 Rev. 2

.

Page 2 of 2



# [:] TRAIN B (Twinco C)

2

IBPDPCBC/11 (C3505) This circuit also feeds CREPB instrumentation.

Safety Related	<u>1:</u>		
R-30	40 VA		
R-46	40VA	80 VA	0.67 amps
Non Safety (F	URMS5):		
RK-79	50 VA		
RY-B	18VA	68 VA	0.57 amps
IBPDPCBD/(	)5 (C2665) (Twinco D)		
R-15	40VA		
R-16	40VA		
R-17	40VA	-	
R-18	40VA		
R-19	40VA		
R-20A	40VA	339 VA	2.83 amps
R-20B	40VA		
K850-R15	17VA		
K850-R16	17VA		
K850-R17	17VA		
K850-R18	17VA		
K850-R19	17VA		
K850-R120B	17VA		

# <u>**TRAIN A</u>** (Twinco E) <u>**IBPDPCBE/01 (C2621)**</u> This circuit also feeds CREPA instrumentation.</u>

Safety Relate	<u>d:</u>			
R-29	40 VA	80 VA	0.67 amps	
R-45	40 VA			
Safety Relate	<u>d: (FURMS4):</u>	Non	Safety (FURMS3):	·
R-10A	40VA	R-10	B 40VA	
R-11	40VA	R-13	40VA	DA-EE-2001-009 FW. C
R-12	40VA	R-14	40VA	
K850-R10A	17VA	K850	)-R10B 17VA	
K850-R11	17VA	K850	)-R13 17VA	P
K850-R12	17VA	K850	)-R14 17VA	Attachment O
RK-78	50VA	RY-1	0A 7.14VA	Allacinnen
		RY-1	1 7.14VA	- I of I
		RY-1	2 7.14VA	Page
		RY-1	0B 7.14VA	
		. RY-1	.3 7.14VA	
		RY-1	4 7.14VA	
		RY-A	A 18VA	
221.0 VA 1.	84 amps		231.84 VA	1.93 amps

~ ~

.

# Attachment 3

**RG&E Procurement Specification EE-171** 

、

-

D0819526

रे ह

#### Control Room Radiation Monitor Specification

**Ginna Station** 

PCR 99-004

Rochester Gas and Electric Corporation 89 East Avenue Rochester, NY 14649

••••

ReeType DieType SPEC Initial

EE-171 Revision 1

February 25, 2000

FEB 28 2000

RECORDS MANAGEMENT

2/25/00 z/cs/cc 2/25/00 a. Con Date: Prepared by: Assigned Engineer Date: Reviewed by: Independent Reviewer ss) Date: Approved by: Manager, I & C Electric

Page 1 of 7

# 01412.4772

...

- + ~ `

·.·

-- :

4-

. •

.

-----

. ....

1

;

	EE-171	Page 2 of 7 Revision 1	
1	2.8	EPRI TR-102348, Guideline on Licensing Digital Upgrades, 1993	
1	2.7	EPRI TR-192323-R1, Guidelines for Electromagnetic Interference Testing in Power Plants, 1997	
	2.6	RG&E Design Analysis DA-EE-99-063, PCR 99-001 Electrical Factors Analysis	
	2.5	RG&E drawing 33013-0721, Control Building Ventilation Duct New Outside Supply	
	2.4	Updated Final Safety Analysis Report (UFSAR) for R. E. Ginna Nuclear Power Plant	
	2.3	ANSI N42.3 (1969), "American National Standard and IEEE Standard Test Procedure for Geiger-Muller (G/M) Counters"	
	2.2	ANSI/ANS-HPSSC-6.8.1 (1981), "Location and Design Criteria for Area Radiation Monitoring Systems for Light Water Nuclear Reactors"	
	2.1	ANSI N45.2.2 (1972), "Packing, Shipping, Receiving, Storage and Handling of Items for Nuclear Power Plants." [ANSI/ASME NQA-2 (1989), "Quality Assurance Requirements for Nuclear Facility Applications:, Incorporates the technical requirements of ANSI N45.2.2]	
	2.0	Referenced Codes and Standards	
	1.4	They shall be supplied new (not used or rebuilt).	
	1.3	They are safety related and shall be supplied in accordance with the requirements of 10CFR50, Appendix B.	
	1.2	The monitors will be used to continuously monitor radiation levels in a 42 inch diameter control room air intake duct. They will be used to inform the control room when a predetermined limit is exceeded. They will provide an isolation signal to the control room dampers and a signal to initiate the control room air filtration system. The plant process computer system (PPCS) will receive an analog input from each monitor. A recorder will receive a voltage input from each monitor.	
	1.1	documentation for two duct mounted control room air intake radiation monitors.	
	1.0		
	10	Scope	

. :

#### 3.0 Design Requirements

- 3.1 The power requirements for each monitor shall have a minimum allowable voltage range of 120 Vac ±10%. The maximum allowable operating voltage range and system power requirements (Watts and Volt Amps) shall be provided with the monitors.
- 3.2 Environmental
- 3.2 1 The ratemeter will be installed in RMS2 in the Control Room. Per Table 3.11.1 of reference 2.4, the normal ambient conditions in the Control Room are less than 104°F, 0 psig, 60% humidity, radiation is negligible.
- 3.2.2 The detectors will be mounted in the Control Room intake air duct which draws outside air and is located in the Turbine Building. Per Section 2.3.2.2 of reference 2.4, the ambient conditions in the air duct are 2°F to 91°F, 0 psig 100% humidity. To provide additional margin, the detectors should operate over a range of -10°F to 122°F.
- 3.2.3 The monitor shall meet the requirements of EPRI TR-103232-R1 and TR-102348. The testing shall verify that the monitors remain functional with an 8 dB margin over the generic emission measurement surveys in the guideline. (Per reference 2.7.)
- 3.3 Monitoring Range
- 3.3.1 In accordance with Section 4.3 and Table 2 of reference 2.2, the required radiation rate range expected during routine monitoring will be 1.0E-2 to 1.0E+3 mR/hr.
- 3.4 Indications and Alarms
- 3.4.1 Each channel shall have a panel mounted ratemeter with audible and visual alarms which will activate at a predetermined exposure rate.

6342...

1

• 1

the bad and had

4

4 ......

ŝ

请见:4:1 字 , 4:1×	
3.4.2	All contact output logic shall be fail-safe and shall actuate on a loss of power.
	Per Section 7.4 of reference 2.6, the high alarm contact outputs of each monitor will interface with Westinghouse BF relays which have 120 Vac coils and have a power requirements of 12 Volt Amps.
	Each monitor shall have one double pole double throw (DPDT) high alarm output, two DPDT warning outputs, two DPDT fail outputs. The fail outputs will be activated upon the following conditions: no counts, loss of power, a hardware failure, or detector anti-jam occurs.
	The DPDT relay output contacts shall be rated for 5' amps (a) 120 Vac or 5 amps (a) 29 Vdc.
	In addition, each monitor shall have one 0-10 Vdc output and one 4-20 mA output that will drive a 250 ohm resistor.
3.5	Detector
3.5.1	Shall be a self quenched halogen G/M counter.
3.5.2	A plot of each detector plateau (count rate versus voltage) shall be supplied. The detector operating temperature limits shall be supplied. The affect of the entire temperature operating range on the detector accuracy shall be provided.
3.5.3	The range of the detector energy dependence of reading shall be 80 keV to 1.5 MeV. The documentation shall include the detector accuracy over this range.
3.5.4	Repeated count-rate measurements of a source at a fixed voltage should be made to determine if the counter has become stabilized. To test for hysteresis, the plateau voltage shall be traversed in an ascending and then a descending direction with a total clapsed time of less than one hour.
3.5.5	The photosensitivity shall be tested by measuring the background counting rate first with the counter operating in the dark and then with the counter exposed to a stated illumination. The results shall be included in the test report.

Revision 1

# 01418.4775

, ⁻

3.6	Power Supply Voltages		
3.6.1	The high voltage power supply must be capable of delivering the maximum current demand and must do so without overloading or loss of regulation. The regulation against line and load variations should be one percent or better. The ripple should be less than 100 millivolts. (Per reference 2.3.)		
3.7	Primary Calibration		
3.7.1	This calibration shall be performed with a procedure that uses sources or instruments or both that are traccable to the National Institute of Standards and Technology (NIST).		
3.7.2	The calibration shall include the response to Xe-133, Cs-137 and the ratio of Xe-133 to Cs-137. Cobalt 60 shall be used as the gamma-ray sources in tests of count rate versus exposure rate and current versus exposure rate. Strontium 90 can be used for radial sensitivity measurements. The response shall be within $\pm 20\%$ of the actual exposure rate present at the detector location.		
3.8	Functional Test		
3.8.1	The monitor verification of operability shall utilize a check source mechanism that contains a Cs-137 radiological source of sufficient strength for a detector response that is greater than 5 mR/hr.		
4.0	Materials		
4.1	The detector housings shall be aluminum, weather proof.		
4.2	Each detector shall be provided with 1700 feet of shielded cable and connectors. The cable and connectors shall provide the maximum resistance to electromagnetic interference (EMI).		
5.0	Fabrication		
5.1	The detectors shall be supplied with hardware suitable for mounting in a 42 inch steel pipe (API 5L, GR. B, 0.375" wall). Reference 2.5		
5.2	The ratemeters shall be supplied with hardware that will allow them to be slid into and out of a 19 inch rack.		

Revision 1

# 03412.4776

Ĵ,

1. 11 s.

-----

6.0	Optional Equipment		
6.1	A G/M adapter for use in our Inovision (Victoreen) Model 848-8 field calibrator shall be supplied. This will be used during secondary calibrations.		
6.2	Two non-safety related ratemeters shall be supplied with a 0-10 volt input for use in a simulator.		
7.0	Quality Verification Requirements		
7.1	RG&E will review the test procedures and the documentation. RG&E will provide a source surveillance of the primary calibration and the functional testing of the monitors.		
8.0	Documentation		
8.1	The documentation shall provide the accuracy and drift of the ratemeters (including high alarm setpoint) and the detectors. It shall include what effect changes in pressure, temperature and power supply aging over a 30 month period has on the ratemeters, high alarm setpoint and detectors. It shall include any random effects that may bias the monitor's output.		
8.2 [°]	The ratemeter firmware documentation shall include revisions, functional descriptions and any supporting test data.		
8.3	The documentation shall include system interconnection drawings with details for installing connectors and terminating, inspecting and testing cables. If applicable, include recommended cable separation and/or routing restrictions.		
8.4	A report shall document the requirements of this specification and include the results of the primary calibration and the functional tests.		
8.5	The ascending and descending detector plateau curves shall be supplied.		
8.6	The high voltage power supply specifications shall be supplied.		
8.7	The recommended periodic maintenance including but not limited to calibration practices and frequencies shall be supplied.		
8.8	A Certificate of Compliance to this specification shall be supplied.		
8.9	For each item, four copies of vendor manuals and drawings shall be supplied.		

1

1

Revision 1

である

۲» ۱۰

:-

.

# 11443,22447777

ļ

- ¹7,

8.10	Four copies of vendor recommended spare parts list shall be supplied.				
9.0	Markings and Identification				
9.1	Each ratemeter, detector, calibration source and standard geometry shall include the manufacturer's name, a serial number.				

Ĵ

(1) ***
,

,

ς.

## Attachment 4

**Certificate of Conformance (C of C) Purchase Orders for Inovision Equipment** 

.



## **Radiation Measurements**

6045 Cochran Road Cleveland OH 44139 Phone: 440 248-9300 FAX: 440-349-2307 www.inovision.com www.surveymeters.com

Date: May 3, 2001

## Customer P.O.:4500008671 Inovision S.O.:157033

Rochester Gas and Electric Ginna Station Ontario, NY 14519

ITEM NUMBER	PART NUMBER	DESCRIPTION		QTY
00010	S157033A	Assy, Air Intake Radiation Monitor		Lot
		Consisting of:	S/N	
1a	897A-210	GM Detector	131, 132	2
1b	S157033A1	Mounting Hardware	N/A	2
1c	956A-201-M1	Ratemeter	104643, 104644	2
1d	948B-1	UDR Mounting HW	N/A	2 (1 rack assy)
00040	897A-210	GM Detector	100762	1
00050	956A-201-M1	Ratemeter	104645	1

## **CERTIFICATE OF CONFORMANCE**

It is hereby certified that all articles herewith in the quantities as referenced by your purchase order were manufactured in accordance with the requirements of the purchase order and utilizing previously approved Quality Assurance Manual Version 003, dated 10/9/00, and specifications and drawings applicable to that order. These items are qualified for Class 1E Safty Related applications I.A.W. IEEE 344-1975 per Inovision Test Report 950.366 and appendices 950.353, 353, 338, and 360.

Sincerely, Inovision RMD

mon duts is Giatis

QA Manager