



Entergy Nuclear Northeast
Entergy Nuclear Operations, Inc
Indian Point Energy Center
P.O. Box 308
Buchanan, NY 10511
Tel 914 736 8001
Fax 914 736 8012

Robert J. Barrett
Vice President, Operations
Indian Point 3

October 11, 2002
IPN-02-084

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Mail Stop O-P1-17
Washington, D.C. 20555-0001

Subject: Indian Point 3 Nuclear Power Plant
Docket No. 50-286
License No. DPR-64
Monthly Operating Report for September 2002

Dear Sir:

The attached monthly operating report, for the month of September 2002, is hereby submitted in accordance with Indian Point 3 Nuclear Power Plant Technical Specification 5.6.4.

Indian Point 3 is making no commitments in this letter.

Very truly yours,

A handwritten signature in cursive script, appearing to read "Robert J. Barrett".

Robert J. Barrett
Vice President, Operations
Indian Point 3 Nuclear Power Plant

cc: See next page

IB 24

Attachment

cc: Mr. Hubert J. Miller
Regional Administrator
Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, Pennsylvania 19406-1415

Resident Inspector's Office
U.S. Nuclear Regulatory Commission
Indian Point 3 Nuclear Power Plant
P.O. Box 337
Buchanan, NY 10511-0337

U.S. Nuclear Regulatory Commission
ATTN: Director, Office of Information Resource Management
Washington, D.C. 20555

INPO Records Center
700 Galleria Parkway
Atlanta, Georgia 30339-5957

DOCKET NO. 50-286
 UNIT: Indian Point 3
 DATE: 10-08-02
 COMPLETED BY: T. Orlando
 TELEPHONE NO: (914) 736-8340
 LETTER NO: IPN-02-084
 ATTACHMENT
 PAGE 1 of 4

OPERATING DATA REPORT

OPERATING STATUS

1. Unit Name: Indian Point No. 3 Nuclear Power Plant
2. Reporting Period: September 2002
3. Licensed Thermal Power (MWt): 3025
4. Nameplate Rating (Gross MWe): 1013
5. Design Electrical Rating (Net MWe): 965
6. Maximum Dependable Capacity (Gross MWe): 1000
7. Maximum Dependable Capacity (Net MWe): 965
8. If Changes Occur in Capacity Ratings (Items Number 3 through 7) Since Last Report Give Reasons:

9. Power Level to Which Restricted, If Any (Net MWe): _____
10. Reasons for Restrictions, If Any: _____

	This Month	Yr-to-Date	Cumulative
11. Hours In Reporting Period	<u>720</u>	<u>6,651</u>	<u>229,072</u>
12. Number Of Hours Reactor Was Critical	<u>720</u>	<u>6,651</u>	<u>144,158.73</u>
13. Reactor Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>0</u>
14. Hours Generator On-Line	<u>720</u>	<u>6,651</u>	<u>141,348</u>
15. Unit Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>0</u>
16. Gross Thermal Energy Generated (MWH)	<u>2,176,339</u>	<u>19,785,384</u>	<u>406,616,324</u>
17. Gross Electrical Energy Generated (MWH)	<u>730,678</u>	<u>6,656,493</u>	<u>130,539,956</u>
18. Net Electrical Energy Generated (MWH)	<u>705,178</u>	<u>6,439,971</u>	<u>126,044,196</u>
19. Unit Service Factor	<u>100</u>	<u>100</u>	<u>61.7</u>
20. Unit Availability Factor	<u>100</u>	<u>100</u>	<u>61.7</u>
21. Unit Capacity factor (Using MDC Net)	<u>101.5</u>	<u>101.9</u>	<u>57.8*</u>
22. Unit Capacity Factor (Using DER Net)	<u>101.5</u>	<u>101.9</u>	<u>57.0</u>
23. Unit Forced Outage Rate	<u>0</u>	<u>0</u>	<u>23.2</u>

24. Shutdowns Scheduled Over Next 6 Months (Type, Date and Duration of Each): _____

25. If Shut Down At End Of Report Period. Estimated Date of Startup: _____

26. Units In Test Status (Prior to Commercial Operation):

	Forecast	Achieved
INITIAL CRITICALITY	_____	_____
INITIAL ELECTRICITY	_____	_____
COMMERCIAL OPERATION	_____	_____

* Weighted Average

DOCKET NO. 50-286
 UNIT: Indian Point 3
 DATE: 10-08-02
 COMPLETED BY: T. Orlando
 TELEPHONE NO: (914) 736-8340
 LETTER NO: IPN-02-084
 ATTACHMENT
 PAGE 2 of 4

AVERAGE DAILY UNIT POWER LEVEL

MONTH September 2001

DAY	AVERAGE DAILY POWER	DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	973	17	979
2	978	18	980
3	979	19	980
4	979	20	978
5	980	21	979
6	981	22	978
7	980	23	980
8	980	24	980
9	978	25	979
10	979	26	980
11	978	27	980
12	980	28	979
13	980	29	982
14	980	30	983
15	980	31	---
16	980		

INSTRUCTIONS: On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

DOCKET NO. 50-286
 UNIT: Indian Point 3
 DATE: 10-08-02
 COMPLETED BY: T. Orlando
 TELEPHONE NO. (914) 736-8340
 LETTER NO: IPN-02-084
 ATTACHMENT
 PAGE 3 of 4

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH September 2002

NO.	DATE	TYPE 1	DURATION (HOURS)	REASON 2	METHOD OF SHUTTING DOWN REACTOR 3	LICENSEE EVENT REPORT #	SYSTEM CODE 4	COMPONENT CODE 5	CAUSE & CORRECTIVE ACTION TO PREVENT RECURRENCE
	NONE								

1
 F: Forced
 S: Scheduled

2
 Reason:
 A- Equipment
 B- Maintenance or Test
 C- Refueling
 D- Regulatory Restriction
 E- Operator Training & Licensee Examination
 F- Administrative
 G- Operational Error
 H- Other (Explain)

3
 Method:
 1-Manual
 2-Manual Scram
 3-Automatic Scram
 4-Other (Explain)

4
 Exhibit G - Instructions
 for Preparation of Data
 Entry Sheets for Licensee
 Event Report (LER) File
 (NUREG - 0161)

5
 Exhibit 1 -
 Same Source

DOCKET NO. 50-286
UNIT: Indian Point 3
DATE: 10-08-02
COMPLETED BY: T. Orlando
TELEPHONE NO.: (914) 736-8340
LETTER NO. IPN-02-084
ATTACHMENT
PAGE 4 of 4

SUMMARY OF OPERATING EXPERIENCE

September 2002

The Indian Point Unit No. 3 Nuclear Power Plant was synchronized to the bus for a total of 720 hours, producing a gross electrical energy generation of 730,678 MWH.