



**TXU Energy**  
Comanche Peak Steam  
Electric Station  
P.O. Box 1002 (E01)  
Glen Rose, TX 76043  
Tel 254 897 8920  
Fax 254 897 6652  
lance.terry@txu.com

**C. Lance Terry**  
Senior Vice President &  
Principal Nuclear Officer

Ref: 10CFR50.36

CPSES-200203517  
Log # TXX-02183  
File # 10010, 916(COLR), RN-48

October 10, 2002

U. S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, DC 20555

**SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION (CPSES)  
DOCKET NO. 50-445  
THE UNIT 1, CYCLE 10 CORE OPERATING LIMITS REPORT**

Gentlemen:


Enclosed is the Core Operating Limits Report for Unit 1, Cycle 10 prepared and submitted pursuant to Technical Specification 5.6.5.

This communication contains no new licensing basis commitments regarding CPSES Units 1 and 2.

Sincerely,

TXU Generation Company LP  
By: TXU Generation Management Company LLC,  
Its General Partner

C. L. Terry  
Senior Vice President and Principal Nuclear Officer

By:   
Fred W. Madden  
Nuclear Licensing Manager

JDS/js  
Enclosure

D030

A member of the **STARS** (Strategic Teaming and Resource Sharing) Alliance

Callaway • Comanche Peak • Diablo Canyon • Palo Verde • South Texas Project • Wolf Creek

TXX-02183  
Page 2 of 2


c - E. W. Merschoff, Region IV  
W. D. Johnson, Region IV  
D. H. Jaffe, NRR  
Resident Inspectors, CPSES


ERX-02-004, Revision 0


CPSSES UNIT 1 CYCLE 10


CORE OPERATING LIMITS REPORT


October 2002

Prepared:  Date: 10-2-02  
Jonathan M. Ralston  
Reactor Physics

Reviewed:  Date: 10-2-02  
John T. Bosma  
Reactor Physics

Reviewed:  Date: 10/2/02  
Parvez Salim  
Safety Analysis

Approved:  Date: 10/2/02  
Stephen M. Maier  
Reactor Physics Supervisor

Approved:  Date: 10/2/02  
Whee G. Choe  
Safety Analysis Manager

## DISCLAIMER

The information contained in this report was prepared for the specific requirement of TXU Energy and may not be appropriate for use in situations other than those for which it was specifically prepared. TXU Energy PROVIDES NO WARRANTY HEREUNDER, EXPRESS OR IMPLIED, OR STATUTORY, OF ANY KIND OR NATURE WHATSOEVER, REGARDING THIS REPORT OR ITS USE, INCLUDING BUT NOT LIMITED TO ANY WARRANTIES ON MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE.

By making this report available, TXU Energy does not authorize its use by others, and any such use is forbidden except with the prior written approval of TXU Energy. Any such written approval shall itself be deemed to incorporate the disclaimers of liability and disclaimers of warranties provided herein. In no event shall TXU Energy have any liability for any incidental or consequential damages of any type in connection with the use, authorized or unauthorized, of this report or of the information in it.

TABLE OF CONTENTS

DISCLAIMER ..... ii  
 TABLE OF CONTENTS ..... iii  
 LIST OF TABLES ..... iv  
 LIST OF FIGURES ..... v

<u>SECTION</u>	<u>PAGE</u>
1.0 CORE OPERATING LIMITS REPORT .....	1
2.0 OPERATING LIMITS .....	2
2.1 SAFETY LIMITS .....	2
2.2 SHUTDOWN MARGIN .....	2
2.3 MODERATOR TEMPERATURE COEFFICIENT .....	2
2.4 ROD GROUP ALIGNMENT LIMITS .....	3
2.5 SHUTDOWN BANK INSERTION LIMITS .....	3
2.6 CONTROL BANK INSERTION LIMITS .....	4
2.7 PHYSICS TESTS EXCEPTIONS - MODE 2 .....	4
2.8 HEAT FLUX HOT CHANNEL FACTOR .....	4
2.9 NUCLEAR ENTHALPY RISE HOT CHANNEL FACTOR .....	5
2.10 AXIAL FLUX DIFFERENCE .....	6
2.11 REACTOR TRIP SYSTEM INSTRUMENTATION .....	6
2.12 RCS PRESSURE, TEMPERATURE, AND FLOW DEPARTURE FROM NUCLEATE BOILING LIMITS .....	7
2.13 BORON CONCENTRATION .....	8
3.0 REFERENCES .....	8

COLR for CPSES Unit 1 Cycle 10

LIST OF TABLES

<u>TABLE</u>		<u>PAGE</u>
1	$F_0(Z)$ MARGIN DECREASES IN EXCESS OF 2 % PER 31 EFPD .....	.9

COLR for CPSES Unit 1 Cycle 10

LIST OF FIGURES

<u>FIGURE</u>		<u>PAGE</u>
1	REACTOR CORE SAFETY LIMITS .....	10
2	ROD BANK INSERTION LIMITS VERSUS THERMAL POWER .....	11
3	K(Z) - NORMALIZED $F_0(Z)$ AS A FUNCTION OF CORE HEIGHT .....	12
4	W(Z) AS A FUNCTION OF CORE HEIGHT - (MAXIMUM) .....	13
5	W(Z) AS A FUNCTION OF CORE HEIGHT - (150 MWD/MTU) .....	14
6	W(Z) AS A FUNCTION OF CORE HEIGHT - (10,000 MWD/MTU) .....	15
7	W(Z) AS A FUNCTION OF CORE HEIGHT - (20,000 MWD/MTU) .....	16
8	AXIAL FLUX DIFFERENCE LIMITS AS A FUNCTION OF RATED THERMAL POWER .....	17

## COLR for CPSES Unit 1 Cycle 10

### 1.0 CORE OPERATING LIMITS REPORT

This Core Operating Limits Report (COLR) for CPSES UNIT 1 CYCLE 10 has been prepared in accordance with the requirements of Technical Specification 5.6.5.

The Technical Specifications affected by this report are listed below:

SL 2.1	SAFETY LIMITS
LCO 3.1.1	SHUTDOWN MARGIN
LCO 3.1.3	MODERATOR TEMPERATURE COEFFICIENT
LCO 3.1.4	ROD GROUP ALIGNMENT LIMITS
LCO 3.1.5	SHUTDOWN BANK INSERTION LIMITS
LCO 3.1.6	CONTROL BANK INSERTION LIMITS
LCO 3.1.8	PHYSICS TESTS EXCEPTIONS - MODE 2
LCO 3.2.1	HEAT FLUX HOT CHANNEL FACTOR
LCO 3.2.2	NUCLEAR ENTHALPY RISE HOT CHANNEL FACTOR
LCO 3.2.3	AXIAL FLUX DIFFERENCE
LCO 3.3.1	REACTOR TRIP SYSTEM INSTRUMENTATION
LCO 3.4.1	RCS PRESSURE, TEMPERATURE, AND FLOW DEPARTURE FROM NUCLEATE BOILING LIMITS
LCO 3.9.1	BORON CONCENTRATION



## 2.0 OPERATING LIMITS

The cycle-specific parameter limits for the specifications listed in Section 1.0 are presented in the following subsections. These limits have been developed using the NRC-approved methodologies specified in Technical Specification 5.6.5b, Items 5, 9 through 19, and 21, as supplemented by Item 20. These limits have been determined such that all applicable limits of the safety analysis are met.

### 2.1 SAFETY LIMITS (SL 2.1)

2.1.1 In MODES 1 and 2, the combination of thermal power, reactor coolant system highest loop average temperature, and pressurizer pressure shall not exceed the safety limits specified in Figure 1.

### 2.2 SHUTDOWN MARGIN (SDM) (LCO 3.1.1)

2.2.1 The SDM shall be greater than or equal to 1.3%  $\Delta k/k$  in MODE 2 with  $K_{eff} < 1.0$ , and in MODES 3, 4, and 5.

### 2.3 MODERATOR TEMPERATURE COEFFICIENT (MTC) (LCO 3.1.3)

2.3.1 The MTC upper and lower limits, respectively, are:

The BOL/ARO/HZP-MTC shall be less positive than +5 pcm/°F.

The EOL/ARO/RTP-MTC shall be less negative than -40 pcm/°F.

COLR for CPSES Unit 1 Cycle 10

2.3.2 SR 3.1.3.2

The MTC surveillance limit is:

The 300 ppm/ARO/RTP-MTC shall be less negative than or equal to  $-31 \text{ pcm}/^{\circ}\text{F}$ .

The 60 ppm/ARO/RTP-MTC shall be less negative than or equal to  $-38 \text{ pcm}/^{\circ}\text{F}$ .

where: BOL stands for Beginning of Cycle Life

ARO stands for All Rods Out

HZP stands for Hot Zero THERMAL POWER

EOL stands for End of Cycle Life

RTP stands for RATED THERMAL POWER

2.4 ROD GROUP ALIGNMENT LIMITS (LCO 3.1.4)

2.4.1 The SDM shall be greater than or equal to  $1.3\% \Delta k/k$  in MODES 1 and 2.

2.5 SHUTDOWN BANK INSERTION LIMITS (LCO 3.1.5)

2.5.1 The shutdown rods shall be fully withdrawn. Fully withdrawn shall be the condition where shutdown rods are at a position within the interval of 218 and 231 steps withdrawn, inclusive.

COLR for CPSES Unit 1 Cycle 10

2.6 CONTROL BANK INSERTION LIMITS (LCO 3.1.6)

2.6.1 The control banks shall be limited in physical insertion as shown in Figure 2.

2.6.2 The control banks shall always be withdrawn and inserted in the prescribed sequence. For withdrawal, the sequence is control bank A, control bank B, control bank C, and control bank D. The insertion sequence is the reverse of the withdrawal sequence.

2.6.3 A 115 step Tip-to-Tip relationship between each sequential control bank shall be maintained.

2.7 PHYSICS TESTS EXCEPTIONS - MODE 2 (LCO 3.1.8)

2.7.1 The SDM shall be greater than or equal to 1.3%  $\Delta k/k$  in MODE 2 during PHYSICS TESTS.

2.8 HEAT FLUX HOT CHANNEL FACTOR ( $F_q(Z)$ ) (LCO 3.2.1)

$$2.8.1 \quad F_q(Z) \leq \frac{F_q^{RTP}}{P} [K(Z)] \text{ for } P > 0.5$$

$$F_q(Z) \leq \frac{F_q^{RTP}}{0.5} [K(Z)] \text{ for } P \leq 0.5$$

where:  $P = \frac{\text{THERMAL POWER}}{\text{RATED THERMAL POWER}}$

COLR for CPSES Unit 1 Cycle 10

2.8.2  $F_q^{RTP} = 2.42$

2.8.3  $K(Z)$  is provided in Figure 3.

2.8.4 Maximum elevation dependent  $W(Z)$  values are given in Figure 4.

Figures 5, 6, and 7 give burnup dependent values for  $W(Z)$ . Figures 5, 6, and 7 can be used in place of Figure 4 to interpolate or extrapolate (via a three point fit) the  $W(Z)$  at a particular burnup.

2.8.5 SR 3.2.1.2

If the two most recent  $F_q(Z)$  evaluations show an increase in the expression

$$\text{maximum over } Z \quad [ F_q^c(Z) / K(Z) ]$$

The burnup dependent values in Table 1 shall be used instead of a constant 2% to increase  $F_q^N(Z)$  per Surveillance Requirement 3.2.1.2.a. A constant factor of 2% shall be used at all cycle burnups that are outside the range of Table 1.

2.9 NUCLEAR ENTHALPY RISE HOT CHANNEL FACTOR ( $F_{\Delta H}^N$ ) (LCO 3.2.2)

2.9.1  $F_{\Delta H}^N \leq F_{\Delta H}^{RTP} [1 + PF_{\Delta H} (1-P)]$

where:  $P = \frac{\text{THERMAL POWER}}{\text{RATED THERMAL POWER}}$

2.9.2  $F_{\Delta H}^{RTP} = 1.55$

COLR for CPSES Unit 1 Cycle 10

2.9.3  $PF_{\Delta H} = 0.3$

2.10 AXIAL FLUX DIFFERENCE (AFD) (LCO 3.2.3)

2.10.1 The AFD target band is +5%, -12% at 100% RTP linearly expanding to +20%, -17% at 50% RTP. Below 50% RTP, the AFD target band remains constant at +20%, -17%.

2.10.2 The AFD Acceptable Operation Limits are provided in Figure 8.

2.11 REACTOR TRIP SYSTEM (RTS) INSTRUMENTATION (LCO 3.3.1)

2.11.1 The numerical values pertaining to the Overtemperature N-16 reactor trip setpoint are listed below:

$$K_1 = 1.138$$

$$K_2 = 0.0139 \text{ /}^\circ\text{F}$$

$$K_3 = 0.00071 \text{ /psig}$$

$$T_c^\circ = 559.7 \text{ }^\circ\text{F}$$

$$P^1 \geq 2235 \text{ psig}$$

$$T_1 \geq 10 \text{ sec}$$

$$T_2 \leq 3 \text{ sec}$$

$$\begin{aligned} f_1(\Delta q) &= 0.00 \cdot \{(q_t - q_b) + 65\% \} && \text{when } (q_t - q_b) \leq -65\% \text{ RTP} \\ &= 0\% && \text{when } -65\% \text{ RTP} < (q_t - q_b) < +7.4\% \text{ RTP} \\ &= 2.335 \cdot \{(q_t - q_b) - 7.4\% \} && \text{when } (q_t - q_b) \geq +7.4\% \text{ RTP} \end{aligned}$$

COLR for CPSES Unit 1 Cycle 10

2.12 RCS PRESSURE, TEMPERATURE, AND FLOW DEPARTURE FROM  
NUCLEATE BOILING (DNB) LIMITS (LCO 3.4.1)

2.12.1 RCS DNB parameters for pressurizer pressure, RCS average temperature, and RCS total flow rate shall be within the surveillance limits specified below:

2.12.2 SR 3.4.1.1

Pressurizer pressure       $\geq$  2220 psig    (4 channels)  
    $\geq$  2222 psig    (3 channels)

The pressurizer pressure limits correspond to the analytical limit of 2205 psig used in the safety analysis with allowance for measurement uncertainty. These uncertainties are based on the use of control board indications and the number of available channels.

2.12.3 SR 3.4.1.2

RCS average temperature    $\leq$  592 °F        (4 channels)  
    $\leq$  592 °F        (3 channels)

The RCS average temperature limits correspond to the analytical limit of 595.7 °F used in the safety analysis with allowance for measurement uncertainty. These uncertainties are based on the use of control board indications and the number of available channels.

COLR for CPSES Unit 1 Cycle 10

2.12.4 SR 3.4.1.3

The RCS total flow rate based on precision heat balance shall be  $\geq 397,200$  gpm

2.12.5 SR 3.4.1.4

The RCS total flow rate based on precision heat balance shall be  $\geq 397,200$  gpm

The required RCS flow, based on an elbow tap differential pressure instrument measurement prior to MODE 1 after the refueling outage, shall be greater than 317,000 gpm.

2.13 BORON CONCENTRATION (LCO 3.9.1)

2.13.1 The required refueling boron concentration is 2055 ppm.

3.0 REFERENCES

Technical Specification 5.6.5.

COLR for CPSES Unit 1 Cycle 10

Table 1

$F_0(Z)$  MARGIN DECREASES IN EXCESS OF 2 % PER 31 EFPD

Cycle Burnup (MWD/MTU)	Maximum Decrease In $F_0(Z)$ Margin (Percent)
8460	2.00
8670	2.06
8870	2.17
9080	2.26
9290	2.30
9500	2.29
9700	2.24
9910	2.24
10120	2.28
10330	2.24
10540	2.10
10740	2.00

Note: All Cycle burnups outside the range of the table shall use a constant 2% decrease in  $F_0(Z)$  margin for compliance with the 3.2.1.2.a Surveillance Requirements. Linear interpolation is acceptable to determine the  $F_0(Z)$  margin decrease for cycle burnups which fall between the specified burnups.



COLR for CPSES Unit 1 Cycle 10

FIGURE 1

REACTOR CORE SAFETY LIMITS





FIGURE 2

ROD BANK INSERTION LIMITS VERSUS THERMAL POWER




- NOTES:
1. Fully withdrawn shall be the condition where control rods are at a position within the interval of 218 and 231 steps withdrawn, inclusive.
  2. Control Bank A shall be fully withdrawn.

COLR for CPSES Unit 1 Cycle 10

FIGURE 3

K(Z) - NORMALIZED F<sub>0</sub>(Z) AS A FUNCTION OF CORE HEIGHT




Axial Node	K(Z)	Axial Node	K(Z)	Axial Node	K(Z)	Axial Node	K(Z)
61	0.9250	53	0.9450	45	0.9650	37	0.9850
60	0.9275	52	0.9475	44	0.9675	36	0.9875
59	0.9300	51	0.9500	43	0.9700	35	0.9900
58	0.9325	50	0.9525	42	0.9725	34	0.9925
57	0.9350	49	0.9550	41	0.9750	33	0.9950
56	0.9375	48	0.9575	40	0.9775	32	0.9975
55	0.9400	47	0.9600	39	0.9800	1 - 31	1.0000
54	0.9425	46	0.9625	38	0.9825		

Core Height (ft) = (Node - 1) \* 0.2

COLR for CPSES Unit 1 Cycle 10

FIGURE 4

W(Z) AS A FUNCTION OF CORE HEIGHT  
(MAXIMUM)




Axial Node	W(Z)	Axial Node	W(Z)	Axial Node	W(Z)	Axial Node	W(Z)
52 - 61	---	41	1.134	30	1.108	19	1.150
51	1.152	40	1.134	29	1.114	18	1.154
50	1.158	39	1.133	28	1.121	17	1.158
49	1.155	38	1.131	27	1.129	16	1.163
48	1.145	37	1.128	26	1.134	15	1.168
47	1.135	36	1.126	25	1.137	14	1.176
46	1.130	35	1.122	24	1.140	13	1.186
45	1.133	34	1.117	23	1.142	12	1.194
44	1.134	33	1.111	22	1.144	11	1.202
43	1.134	32	1.107	21	1.146	1 - 10	---
42	1.134	31	1.106	20	1.147		

Core Height (ft) = (Node - 1) \* 0.2

COLR for CPSES Unit 1 Cycle 10

FIGURE 5

W(Z) AS A FUNCTION OF CORE HEIGHT  
(150 MWD/MTU)




Axial Node	W(Z)	Axial Node	W(Z)	Axial Node	W(Z)	Axial Node	W(Z)
52 - 61	---	41	1.117	30	1.103	19	1.150
51	1.152	40	1.115	29	1.107	18	1.154
50	1.152	39	1.111	28	1.113	17	1.158
49	1.146	38	1.107	27	1.118	16	1.163
48	1.138	37	1.103	26	1.124	15	1.168
47	1.131	36	1.099	25	1.130	14	1.172
46	1.128	35	1.096	24	1.134	13	1.177
45	1.126	34	1.095	23	1.138	12	1.181
44	1.124	33	1.096	22	1.142	11	1.185
43	1.121	32	1.097	21	1.145	1 - 10	---
42	1.118	31	1.100	20	1.147		

Core Height (ft) = (Node - 1) \* 0.2

COLR for CPSES Unit 1 Cycle 10

FIGURE 6

W(Z) AS A FUNCTION OF CORE HEIGHT  
(10,000 MWD/MTU)




Axial Node	W(Z)	Axial Node	W(Z)	Axial Node	W(Z)	Axial Node	W(Z)
52 - 61	---	41	1.121	30	1.099	19	1.141
51	1.151	40	1.119	29	1.104	18	1.146
50	1.158	39	1.116	28	1.110	17	1.152
49	1.155	38	1.113	27	1.115	16	1.158
48	1.145	37	1.110	26	1.121	15	1.165
47	1.135	36	1.106	25	1.125	14	1.172
46	1.130	35	1.102	24	1.129	13	1.178
45	1.128	34	1.098	23	1.131	12	1.183
44	1.127	33	1.094	22	1.133	11	1.188
43	1.125	32	1.093	21	1.135	1 - 10	---
42	1.123	31	1.095	20	1.137		

Core Height (ft) = (Node - 1) \* 0.2

COLR for CPSES Unit 1 Cycle 10

FIGURE 7

W(Z) AS A FUNCTION OF CORE HEIGHT  
(20,000 MWD/MTU)



Axial Node	W(Z)	Axial Node	W(Z)	Axial Node	W(Z)	Axial Node	W(Z)
52 - 61	---	41	1.134	30	1.108	19	1.145
51	1.143	40	1.134	29	1.114	18	1.145
50	1.141	39	1.133	28	1.121	17	1.148
49	1.137	38	1.131	27	1.129	16	1.156
48	1.132	37	1.128	26	1.134	15	1.166
47	1.130	36	1.126	25	1.137	14	1.176
46	1.130	35	1.122	24	1.140	13	1.186
45	1.133	34	1.117	23	1.142	12	1.194
44	1.134	33	1.111	22	1.144	11	1.202
43	1.134	32	1.107	21	1.146	1 - 10	---
42	1.134	31	1.106	20	1.146		

Core Height (ft) = (Node - 1) \* 0.2

FIGURE 8

AXIAL FLUX DIFFERENCE LIMITS AS A FUNCTION OF RATED THERMAL POWER

