

October 22, 2002

Mark A. Peifer  
Site Vice President  
Duane Arnold Energy Center  
Nuclear Management Company, LLC  
3277 DAEC Road  
Palo, IA 52324-0351

SUBJECT: DUANE ARNOLD ENERGY CENTER - CORRECTION TO ISSUANCE OF  
AMENDMENT (TAC NO. MB3810)

Dear Mr. Peifer:

On October 1, 2002, the U. S. Nuclear Regulatory Commission issued Amendment No. 247 to Facility Operating License No. DPR-49 for the Duane Arnold Energy Center. The amendment consisted of changes to the Technical Specifications in response to your application dated December 19, 2001, as supplemented April 19, 2002.

We are reissuing Page 2 of the amendment page. It contained the words "and Environmental Protection Plan" which are no longer part of the amendment.

Sincerely,

*/RA/*

Darl S. Hood, Senior Project Manager, Section 1  
Project Directorate III  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket No. 50-331

Enclosure: As stated

cc w/encl: See next page

October 22, 2002

Mark A. Peifer  
Site Vice President  
Duane Arnold Energy Center  
Nuclear Management Company, LLC  
3277 DAEC Road  
Palo, IA 52324-0351

SUBJECT: DUANE ARNOLD ENERGY CENTER - CORRECTION TO ISSUANCE OF  
AMENDMENT (TAC NO. MB3810)

Dear Mr. Peifer:

On October 1, 2002, the U. S. Nuclear Regulatory Commission issued Amendment No. 247 to Facility Operating License No. DPR-49 for the Duane Arnold Energy Center. The amendment consisted of changes to the Technical Specifications in response to your application dated December 19, 2001, as supplemented April 19, 2002.

We are reissuing Page 2 of the amendment page. It contained the words "and Environmental Protection Plan" which are no longer part of the amendment.

Sincerely,

*/RA/*

Darl S. Hood, Senior Project Manager, Section 1  
Project Directorate III  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket No. 50-331

Enclosure: As stated

cc w/encl: See next page

**DISTRIBUTION:**

PUBLIC	PD3-1 r/f	LRaghavan	DHood
GHill(2)	OGC	ACRS	WBeckner
GGrant, RIII	GWilson, SRI	THarris	SSaba
MWohl	MRubin	CHolden	

**ADAMS ACCESSION NUMBER: ML022910083**

<b>OFFICE</b>	<b>PM:PD3-1</b>	<b>LA:PD3-1</b>	<b>SC:PD3-1</b>
<b>NAME</b>	<b>DHood</b>	<b>THarris</b>	<b>LRaghavan</b>
<b>DATE</b>	<b>10/22/02</b>	<b>10/22/02</b>	<b>10/22/02</b>

OFFICIAL RECORD COPY

Duane Arnold Energy Center

cc:

Mr. Al Gutterman  
Morgan, Lewis & Bockius LLP  
111 Pennsylvania Avenue NW  
Washington, DC 20004

Chairman, Linn County  
Board of Supervisors  
Cedar Rapids, IA 52406

Plant Manager, Nuclear  
Duane Arnold Energy Center  
Nuclear Management Company, LLC  
3277 DAEC Road  
Palo, IA 52324

U.S. Nuclear Regulatory Commission  
Resident Inspector's Office  
Rural Route #1  
Palo, IA 52324

Regional Administrator  
U.S. NRC, Region III  
801 Warrenville Road  
Lisle, IL 60532-4351

Daniel McGhee  
Utilities Division  
Iowa Department of Commerce  
Lucas Office Building, 5th floor  
Des Moines, IA 50319

Mr. Roy A. Anderson  
Executive Vice President and  
Chief Nuclear Officer  
Nuclear Management Company, LLC  
700 First Street  
Hudson, WI 54016

Nuclear Asset Manager  
Alliant Energy/IES Utilities, Inc.  
3277 DAEC Road  
Palo, IA 52324

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of Facility Operating License No. DPR-49 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 247 , are hereby incorporated in the license. NMC shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance and shall be implemented within 60 days of the date of issuance. Prior to implementation, the licensee shall: (1) incorporate the committed actions and conditions as described in the December 19, 2001, application and the April 19, 2002, supplement, to be taken during the on-line replacement of 125 VDC batteries 1D1 and 1D2, into a procedure; and (2) change the Updated Final Safety Analysis Report to include a description of this and other relevant procedures. Implementation under this license amendment will be on a one-time basis, with the replacement times for each of the two battery divisions separately extended from 8 hours to 10 days.

FOR THE NUCLEAR REGULATORY COMMISSION

*/RA/*

L. Raghavan, Chief, Section 1  
Project Directorate III  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical Specifications

Date of Issuance: October 1, 2002

Corrected by NRC letter dated October 22, 2002