

Entergy Nuclear Operations, Inc. Pilgrim Nuclear Power Station 600 Rocky Hill Road Plymouth, MA 02360

FIDD

Mike Bellamy Site Vice President

October 10, 2002

U.S. Nuclear Regulatory Commission Attention: Document Control Desk Washington, D.C. 20555

SUBJECT: Entergy Nuclear Operations, Inc. Pilgrim Nuclear Power Station Docket No. 50-293 License No. DPR-35

> Request for Technical Specification Change Concerning Change of Trip Level Settings, Calibration Frequencies, and Editorial Changes, Revision 1

REFERENCE: Entergy Letter No. 2.01.086, Request for Technical Specification Change Concerning Change of Trip Level Settings, Calibration Frequencies, and Editorial Changes, dated December 12, 2001.

LETTER NUMBER: 2.02.084

Dear Sir or Madam:

By the above reference, Pilgrim Nuclear Power Station (Pilgrim) requested NRC review and approval of changes to Pilgrim's Technical Specification Tables 3.2.A, 3.2.B, 4.2.A, and 4.2.B in accordance with 10 CFR 50.90. Subsequent discussions with the NRC staff have identified changes needed in the submittal to support the NRC's review. This letter provides the information discussed with the NRC Staff and replaces the original submittal.

If you have any questions or require additional information, please contact Mr. Bryan Ford, Licensing Manager, at (508) 830-8403.

I declare under penalty of perjury that the foregoing is true and correct.

Executed on the <u>10th</u> day of <u>October</u>, 2002.

Sincerely,

Mele Belan

Robert M. Bellamy

- Attachment 1: Narrative on Proposed Changes and "No Significant Hazards Consideration" (9 pages)
- Attachment 2: Marked-up Technical Specification Pages (9 pages)

Attachment 3: Calculation Methodology Information (4 - pages)

Attachment 4: Portions of Two of the Associated Calculations (36 - pages and 26 - pages)

Attachment 5: Summary of Regulatory Commitments (1 - page)

Entergy Nuclear Operations, Inc. Pilgrim Nuclear Power Station Letter Number: 2.02.084 Page 2

cc: Mr. Travis Tate, Project Manager Project Directorate I-3 Office of Nuclear Reactor Regulation Mail Stop: 0-8B-1 U. S. Nuclear Regulatory Commission 1 White Flint North 11555 Rockville Pike Rockville, MD 20555-0001

U.S. Nuclear Regulatory Commission Region I 475 Allendale Road King of Prussia, PA 19406

Senior Resident Inspector Pilgrim Nuclear Power Station Mr. Robert Hallisey Radiation Control Program Commonwealth of Massachusetts Exec Offices of Health & Human Services 174 Portland Street Boston, MA 02114

Mr. Steve McGrail, Director Mass. Emergency Management Agency 400 Worcester Road P.O. Box 1496 Framingham, MA 01701-0313

ATTACHMENT 1

NARRATIVE ON PROPOSED CHANGES AND "NO SIGNIFICANT HAZARDS CONSIDERATION"

ATTACHMENT 1

Description of Proposed Changes

- 1) Pilgrim Nuclear Power Station (Pilgrim) proposes the following changes to Technical Specification Table 3.2.A, "Instrumentation That Initiates Primary Containment Isolation" (page 3/4.2-7).
 - a) The current trip level setting for the "Main Steam Line Tunnel Exhaust Duct High Temperature" is $\leq 170^{\circ}$ F. Pilgrim proposes to change the trip level setting to $\leq 175^{\circ}$ F.
 - b) The trip level setting of the "Turbine Basement Exhaust Duct High Temperature" is currently $\leq 150^{\circ}$ F. Pilgrim proposes to change the trip level setting to $\leq 155^{\circ}$ F.
 - c) The name of the instrument "Reactor Cleanup System High Flow" is changed to "Reactor Water Cleanup System (RWCU) High Flow."
 - d) The trip level setting of the "Reactor Water Cleanup System High Temperature" is currently ≤ 150° F. Pilgrim proposes to change the trip level setting to ≤ 148° F. The number of required channels is corrected to identify the sensors and their locations consistent with plant design and to show that there is one required channel in each of the two trip systems for each location. The sensors and their locations are as follows:

"RWCU Back Wash Receiver Tank Room High Temperature" "RWCU Heat Exchanger and Pump Rooms High Temperature" "RWCU Line in RHR Valve Room "A" High Temperature" "RWCU Line Near East CRD Modules High Temperature"

- e) The column identifying the number of available channels is removed from the table.
- 2) Pilgrim proposes the following changes to Technical Specification Table 3.2.B, "Instrumentation That Initiates or Controls the Core and Containment Cooling Systems" (pages 3/4.2-12, 3/4.2-16, and 3/4.2-17).
 - a) Not used.
 - b) Not used.
 - c) The trip level settings of the "RCIC Turbine Compartment Wall" is currently $\leq 170^{\circ}$ F. Pilgrim proposes to change the trip level setting to $\leq 168^{\circ}$ F.
 - d) The "Torus Cavity Exhaust Duct" is renamed "RCIC Exhaust Duct Torus Cavity." The trip level setting of the "RCIC Exhaust Duct Torus Cavity" is currently \leq 150° F. Pilgrim proposes to change the trip level setting to \leq 148° F.
 - e) The trip level setting of the "RCIC Valve Station Area Wall" is currently $\leq 200^{\circ}$ F. Pilgrim proposes to change the trip level setting to $\leq 198^{\circ}$ F.

- f) The "RCIC" Steam Line Lo-Press" is renamed "RCIC Steam Line Low Pressure". The current trip level setting for the "RCIC Steam Line Low Pressure" trip level setting is 100 > P > 50 psig. The new trip level setting is proposed to be 77 > P > 63 psig.
- g) The current trip level setting of the "HPCI Turbine Steam Line High Flow" is \leq 300% of rated flow. Pilgrim proposes to change the trip level setting to \leq 296% of rated flow.
- h) The "HPCI Turbine Compartment Exhaust Ducts" is renamed "HPCI Turbine Compartment Exhaust Duct." The trip level settings of the "HPCI Turbine Compartment Exhaust Duct" is currently $\leq 170^{\circ}$ F. Pilgrim proposes to change the trip level setting to $\leq 168^{\circ}$ F.
- i) The "Torus Cavity Exhaust Duct" for HPCI is renamed "HPCI Exhaust Duct Torus Cavity." The current trip level setting for the "HPCI Exhaust Duct Torus Cavity" high temperature is 190° F - 200° F. Pilgrim proposes to change the trip level setting of this trip function to \leq 198° F.
- j) The current trip level setting for the "HPCI/RHR Valve Station Area Exhaust Duct" high temperature is currently $\leq 170^{\circ}$ F. Pilgrim proposes to change the trip level settings of these trip functions to $\leq 168^{\circ}$ F.
- k) Table 3.2.B footnote 6 (page 3/4.2-17) is added regarding the trip level setting for the RCIC steam line low-pressure trip function. The footnote clarifies that the pressure indicated for the trip level setting, 70 ± 7 psig, does not include the static head pressure which is 17.5 psi.
- I) Pilgrim proposes to move the note numbers on page 3/4.2-16 to the "Remarks" column to correct the numbers' misplacement.
- 3) Pilgrim proposes the following change to Technical Specification Table 4.2.A, *"Minimum Test and Calibration Frequency for PCIS"* (page 3/4.2-31 and 3/4.2-41).
 - a) The current calibration frequency of the "Main Steam High Temp" is "Once/3 months". Pilgrim proposes to change the calibration frequency to "Once/24 months".
 - b) The "Reactor Water Cleanup High Flow" on Table 4.2.A is renamed "Reactor Water Cleanup System (RWCU) High Flow ". The "Reactor Water Cleanup High Temp" on Table 4.2.A is changed to the following to reflect the change made to Table 3.2.A (see 1d):

"RWCU Back Wash Receiver Tank Room High Temperature" "RWCU Heat Exchanger and Pump Rooms High Temperature" "RWCU Line in RHR Valve Room "A" High Temperature" "RWCU Line Near East CRD Modules High Temperature"

The current calibration frequency for the "Reactor Water Cleanup High Temperature" is "Once/3 months." Pilgrim proposes to change the calibration frequency to "Once/24 months".

c) Reference to Figure 4.1.1 in Note 1 on "Notes for Tables 4.2.A through 4.2.G (page 3/4.2-41)" is changed to reference the correct figure (Figure 4.2.1).

- 4) Pilgrim proposes the following changes to Technical Specifications Table 4.2.B, "Minimum Test and Calibration Frequency for CSCS" (pages 3/4.-32 and 3/4.2-33).
 - a) Not used.
 - b) The current calibration frequency of the "Steam Line High Temp. (HPCI & RCIC)" is "Once/3 months". Pilgrim proposes to change the calibration frequency to "Once/24 months".
 - c) The current calibration frequency of the "Safeguards Area High Temperature" is "Once/3 months". Pilgrim proposes to change the calibration frequency to "Once/24 months".
 - d) The current calibration frequency for the "RCIC Steam Line Low Pressure" is "Once/3 months". Pilgrim Station proposes to change the calibration frequencies for these instrument channels to "Once/12 months".
- 5) Following approval of the proposed Technical Specification changes Pilgrim will make the following changes to Technical Specifications Bases in accordance with Technical Specification 5.6.6 (Technical Specifications Bases Control Program).
 - a) Pilgrim proposes the following changes to Technical Specification Bases 3.2 "Protective Instrumentation" (page B3/4.2-2):

The current setting of 170° F for the main steam line tunnel detector is low enough to detect leaks on the order of 5 - 10 gpm. Pilgrim proposes to change the trip value to 175° F for the "main steam line tunnel detector," which is low enough to detect leaks of ≥ 20 gpm.

- b) Pilgrim proposes the following changes to Technical Specification Bases 3.2 "Protective Instrumentation" (page B3/4.2-3).
 - i) The current setting of \leq 300% of design flow for HPCI high flow and 200° F or 170° F, depending on sensor location, for HPCI high temperature require revision. Pilgrim proposes to change the HPCI high flow trip value to \leq 296% and HPCI high temperature sensors to \leq 198° F or \leq 168° F, depending on sensor location.
 - ii) The current setting for RCIC area high temperature is 200° F, 170° F, or 150° F, depending on sensor location. Pilgrim proposes to change the RCIC high temperature sensor trip setting to \leq 198° F, \leq 168° F, or \leq 148° F, depending on sensor location.
 - iii) The current Bases description of the RWCU system temperature and high flow instrumentation is changed by substituting the phrase"... is arranged with one instrument in each trip system for each area" for the current "... are arranged similar as that for the HPCI."

The revision of the submittal adds additional information that was identified as needed during discussions with the NRC staff and removes the changes previously requested as items 2.a, 2.b, and 4.a.

Reason for Proposed Change

Pilgrim station proposes setpoint changes to incorporate the results of setpoint calculations and decreased calibration frequencies associated with existing instruments, without adversely affecting instrument reliability. The changes also enhance the usability of the Technical Specifications by providing a clearer description of the "RWCU High Temperature" trip configuration. Changing the names of certain trips gives clearer definition of the system and is editorial. Moving the note numbers is editorial and is done for consistency. Correcting the mis-referenced figure is administrative.

These changes will have the affect of improving the usability of the Technical Specifications, decreasing plant staff burden, and reduces radiological dose.

Safety Evaluation

The functions affected by the proposed changes provide isolation signals to isolate non-limiting leaks from piping outside of containment. These instruments do not have a design basis safety function. Other functions provide the required isolation during design basis accidents.

To support the requested Technical Specification changes Pilgrim analyzed the associated setpoint and calibration frequency changes using the following methodology:

- 1. Proposed instrument setpoint changes (changes 1a, 1b, 1d, 2c, 2d, 2e, 2f, 2g, 2h, 2i, 2j) were determined following the guidance of Regulatory Guide 1.105, Revision 2. This is a more recent and rigorous methodology than the original license and design bases for these instruments. As a result, the setpoints for the associated instruments are more conservative than the original setpoints. The trip level settings were determined while analyzing the instruments in accordance with procedures that are subject to a quality assurance program that complies with 10 CFR 50 Appendix B and were found to be acceptable for the reasons described below. The analyses supporting the setpoint changes are based on a 95% probability limit that the trips would occur before the design basis analytical limit is exceeded. Each instrument has a documented "analytical limit" and an "allowable limit." The setpoint calculations fully document the basis for changes to limits, trip level settings, and calibration frequencies.
- 2. Proposed instrument calibration frequencies (changes 3a, 3b, 4b, 4c, and 4d) were determined following the guidance of Generic Letter 91-04.
- 3. The new calculated instrument setpoints were evaluated against the original associated analysis assumptions. The original associated analysis assumptions correspond to the nominal setpoints originally identified in the Technical Specifications for these instruments. When possible, the original associated analysis assumptions are maintained and the proposed instrumentation setpoints support these analysis assumptions (changes 1d, 2c, 2d, 2e, 2f, 2g, 2h, 2i, 2j).
- 4. Applying the more rigorous setpoint methodology to the original analysis assumptions resulted in inadequate margins to support plant operational needs (e.g., potential for spurious actuations). The associated analysis was revised to provide necessary margin (changes 1a and 1b). The values chosen for the new analysis assumptions were chosen to be high enough to support plant operational needs while being low enough to limit the potential impact of the associated leaks.

Additional information concerning the calculation methodology and selected portions of two of the calculations can be found in Attachments 3 and 4.

The following provides a discussion of the specific changes requested.

The trip level setting for the "Main Steam Line Tunnel Exhaust Duct High Temperature" (1a) is currently \leq 170° F. It is proposed that the trip level setting be increased to \leq 175° F to support an analytical limit of 178° F. The existing Technical Specification limit of ≤170° F was based on detection and isolation of a 10 gpm leak from the main steam lines inside the main steam tunnel while meeting 10 CFR 20 dose limits. The purpose of this isolation is to limit the release of radiation during a non-limiting leak from the main steam lines, while other systems and functions are designed to address a limiting main steam line break. This isolation is designed to limit dose effects of the analyzed leak to within 10 CFR 20 dose limits and ensure that for leaks smaller than the analyzed leak, it is not credible that dose limits are challenged prior to manually isolating the leak. The new trip setting allows detection and isolation of a main steam line leak of 20 gpm with an associated new analytical limit of 178° F. Calculations show that 20 gpm of system leakage would be detected and isolated in a timely manner (approximately 1.5 hours). The 20 gpm would need to go undetected for > 1000 days before 10 CFR 20 radiological limits could be exceeded. Such a leak going undetected for such a period is highly unlikely and thus the new setting does not result in consequences that exceed 10 CFR 20 dose limits. There is no impact on environmental qualification of electrical equipment from the potential increase in main steam tunnel temperatures. The new setting ensures adequate margin exists between the trip level setting and the new design basis analytical limit to account for all instrument and process inaccuracies and is high enough to avoid spurious isolation signals. Leaks < 20 gpm from adjacent feedwater and RWCU piping inside the main steam tunnel will still be detected by this instrumentation and result in increased area temperature indication in the control room. If the temperature increase persists, actions to identify and isolate these leaks can still be performed as described in the current licensing basis.

The trip level setting for the "Turbine Basement Exhaust Duct High Temperature" (1b) is currently \leq 150° F. It is proposed that the trip level setting be increased to \leq 155° F to support an analytical limit of 158° F. The existing Technical Specification limit of \leq 150° F was based on detection and isolation of a 150 gpm leak from the main steam lines in the turbine basement while meeting 10 CFR 20 dose limits. The purpose of this isolation is to limit the release of radiation during a non-limiting leak from the main steam lines, while other systems and functions are designed to address a limiting main steam line break. This isolation is designed to limit dose effects of the analyzed leak to within 10 CFR 20 dose limits and ensure that for leaks smaller than the analyzed leak, it is not credible that dose limits are challenged prior to manually isolating the leak. The new trip setting allows detection and isolation of a main steam line leak of 225 gpm with an associated new analytical limit of 158° F. Calculations show that the system leakage would still be detected and isolated in a timely manner (approximately 1.3 hours). The 225 gpm leak would need to continue undetected for > 7 days before 10 CFR 20 radiological limits could be exceeded. Such a leak going undetected for such a period is unlikely and thus the new setting does not result in consequences that exceed 10 CFR 20 dose limits. There is no impact on environmental qualification of electrical equipment from the potential increase in main steam tunnel temperatures. The new setting ensures adequate margin exists between the trip level setting and the new design basis analytical limit to account for all instrument and process inaccuracies and is high enough to avoid spurious isolation signals. Leaks from other piping in the turbine basement will still be detected by this instrumentation. If the temperature increase persists, actions to identify and isolate these leaks can still be performed as described in the current licensing basis. Renaming the "Reactor Cleanup System High Flow" to "Reactor Water Cleanup System (RWCU) High Flow" (1c, 3b), removing the column identifying the number of available instruments channels (1e), and relocating footnote numbers to the "Remarks" column (21) are administrative changes that do not change any technical requirements and do not impact safety.

The trip level setting of the "Reactor Water Cleanup System High Temperature" (1d) is currently $\leq 150^{\circ}$ F. It is proposed that the trip level setting be decreased to $\leq 148^{\circ}$ F to support an analytical limit of 150° F for all four sensor locations. High temperature in the vicinity of the reactor water cleanup (RWCU) equipment and piping could indicate a break in a RWCU line. When high temperature occurs near the RWCU equipment, the RWCU system is isolated. This new trip level setting ensures that the analytical limit of 150° F will not be exceeded and timely detection and isolation of the RWCU system occurs in the event of a RWCU line break. The new trip level setting of $\leq 148^{\circ}$ F is sufficiently above normal operational upper limits to avoid spurious isolation, yet low enough to provide timely detection of a line break.

The RWCU system high temperature instruments are delineated by instrument location to ensure the appropriate requirements are implemented. The minimum number of instrument channels required to be operable for each location is changed to one in each of 2 trip systems (1d). High temperature in the vicinity of the RWCU system is sensed by four sets of two bimetallic temperature switches. A set of two temperature switches is installed in each of the four areas to be monitored. Each of the switches in an area is capable of initiating isolation of its associated valve(s). This change is consistent with plant design as described in the UFSAR and the presentation of this function in NUREG-1433, "Standard Technical Specifications, BWR 3/4."

The trip level setting for the "RCIC Turbine Compartment Wall" (2c) is currently $\leq 170^{\circ}$ F. The proposed trip level setting is $\leq 168^{\circ}$ F to support an analytical limit of 170° F. The trip level setting for the "RCIC Exhaust Duct Torus Cavity" (2d) is currently $\leq 150^{\circ}$ F. The proposed trip level setting is $\leq 148^{\circ}$ F to support an analytical limit of 150° F. The trip level setting for the "RCIC Valve Station Area Wall" (2e) is currently $\leq 200^{\circ}$ F. The proposed trip level setting is \leq 198° F to support an analytical limit of 200° F. The new trip level settings for the "RCIC" Turbine Compartment Wall" (2c), "RCIC Exhaust Duct Torus Cavity" (2d), and "RCIC Valve Station Area Wall" (2e) are lower. The analytical limits for these setpoints are based on detecting RCIC steam line leaks of approximately 10 gpm and initiating isolation of the RCIC steam line. Calculations conclude that satisfactory margin exists between the trip level settings and the design basis analytical limit to account for all instrument and process inaccuracies. The probability of an inadvertent actuation caused by the decrease in operating margin was evaluated and found to be acceptable; the proposed changes do not increase the probability of an inadvertent actuation based on normal historical operating conditions. The new trip level settings are sufficiently below those for the HPCI system so that preferential isolation of the RCIC steam line occurs in the event of a small line break, and permits the HPCI system to remain operable.

Changing the RCIC "Torus Cavity Exhaust Duct" to "RCIC Exhaust Duct Torus Cavity" (2d) clarifies the instruments' location. This is an administrative change and has no impact on safety. The trip level setting for the "RCIC Steam Line Low Pressure" (2f), is currently 100 > P > 50 psig. The proposed trip level setting is 77 > P > 63 psig. The analytical limits (100 > P > 50 psig) for the "RCIC Steam Line Low Pressure" (2f) were selected to ensure the RCIC steam line is isolated at a value that ensures steam and radioactive gases will not escape from the RCIC turbine shaft seals into the reactor building after steam pressure has decreased to such a low value that the turbine can not be operated. The proposed trip level setting of 77 > P > 63 psig, by taking into account total instrument loop uncertainty, ensures steam line isolation occurs before the analytical limit is exceeded.

The "HPCI Turbine Steam Line High Flow" (2g) trip level setting is currently \leq 300% of rated flow. The proposed trip level setting for the "HPCI Turbine Steam Line High Flow" instruments of \leq 296% is more conservative than the current setting because it isolates HPCI at a slightly lower flow, thereby increasing the margin between the trip level setting and the analytical limit of

300%. The new trip level setting is closer to the normal operating band but it has been determined that adequate operating margin exists. This change does not adversely impact HPCI performance.

The trip level setting for the "HPCI Turbine Compartment Exhaust Duct" (2h) is currently \leq 170° F. The proposed trip level setting is \leq 168° F to support an analytical limit of 170° F. The trip level setting for the "HPCI Exhaust Duct Torus Cavity" (2i) is currently 190° F – 200° F. The proposed setting is \leq 198° F to support an analytical limit of 200° F with the removal of the bottom of the band for the isolation. The lower end of the current band is to preserve system availability by establishing a setting high enough to preclude spurious isolations. However, this lower setting point is not assumed in the accident analysis and therefore, is removed from the Technical Specifications.

The trip level setting for the "HPCI/RHR Valve Station Area Exhaust Duct" (2j) is currently $\leq 170^{\circ}$ F. The proposed trip level setting is $\leq 168^{\circ}$ F to support an analytical limit of 170° F. The new trip level settings for the "HPCI Turbine Compartment Exhaust Duct" (2h), "HPCI Exhaust Duct Torus Cavity" (2i), and "HPCI/RHR Valve Station Area Exhaust Duct" (2j) are lower. The analytical limits for these setpoints are based on detecting HPCI steam line leaks of approximately 10 gpm and initiating isolation of the HPCI steam line. Decreasing the trip level settings will slightly improve the ability of the instrumentation to detect and isolate steam leaks. Calculations conclude that satisfactory margin exists between the trip level settings and the design basis analytical limit to account for all instrument and process inaccuracies. The probability of an inadvertent actuation caused by the decrease in operating margin was evaluated and found to be acceptable; thus the proposed changes do not increase the probability of an inadvertent actuation based on normal historical operating conditions.

Renaming the "HPCI Turbine Compartment Exhaust Ducts" to "HPCI Turbine Exhaust Duct" (2h) is editorial and does not impact safety.

Renaming the "Torus Cavity Exhaust Duct" to "HPCI Exhaust Duct Cavity"(2i), clarifies the instrument's location. This is an administrative change and has no impact on safety.

The addition of Note 6 (2k) provides information concerning the presence of 17.5 psi static head due to the difference in elevation between the location of the sensing lines attached to the RCIC steam line and the location of the pressure sensing instrument. The note is intended to clarify that the trip level setting is based on the pressure in the steam line (process pressure) rather than instrument sensed pressure. Adding Note 6 is an administrative change and has no impact on safety.

Calibration frequencies are decreased for the "Main Steam High Temp" (3a), and the renamed "Reactor Water Cleanup High Temp" (3b) systems, the "Steamline High Temp (HPCI & RCIC)" (4b), the "Safeguards Area High Temperature" (4c), and the "RCIC Steam Line Low Pressure" (4d). The effect on total instrument loop uncertainty due to decreasing the calibration frequencies were included in the calculations that established the new Technical Specification trip settings in accordance with methodologies endorsed by R.G. 1.105. The calculations conclude that sufficient margin exists between the trip level settings and the design basis analytical limit to account for all instrument and process inaccuracies, including decreased calibration frequencies. Therefore, the decreased calibration frequencies will have no effect on the ability of the affected instrumentation to perform their safety functions. Note 1 of "Notes for Tables 4.2.A through 4.2.G" is changed to reference Figure 4.2-1 instead of the currently referenced Figure 4.1.1 (3c). This change corrects an oversight that occurred when the reformatting of Technical Specifications granted by Revision 177 renamed the Figure as Figure 4.2-1, but Note 1 was not changed. The content of Figure 4.2-1 is identical to the previous Figure 4.1.1; therefore, this is an administrative change.

Environmental Consideration

The proposed amendment changes instrument surveillance intervals and trip level settings. The proposed change is consistent with accepted engineering practice and methodologies.

The proposed change does not impact plant configuration or design. Each proposed change is to be used within the restricted area as defined in 10 CFR Part 20. Pilgrim has determined the amendment involves no significant increase in the amounts and no significant change in the types of any effluents that may be released offsite, and there is no significant increase in individual or cumulative occupational radiation exposure resulting from the implementation of this proposed change. Pilgrim has performed a no significant hazards consideration analysis (see below) and found the proposed amendment involves no significant hazards. Accordingly, Pilgrim concludes the proposed amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR Part 51.22(c)(9). Therefore, pursuant to 10 CFR Part 51.22(b), Pilgrim concludes no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendment.

No Significant Hazards Considerations

10 CFR 50.91 requires that at the time a licensee requests an amendment, it must provide to the Commission its analysis using the standards in 10 CFR 50.92, to determine no significant hazards considerations. In accordance with 10 CFR 50.91, Pilgrim has performed an analysis for the proposed changes to Technical Specification Tables 3.2.A and 3.2.B and 4.2.A and 4.2.B. Operation of Pilgrim in accordance with the proposed amendment:

• Will not involve a significant increase in the probability or consequences of an accident previously evaluated.

The methodology used to determine the proposed trip level settings and surveillance intervals ensure adequate performance of the affected instrumentation. In addition, the affected instruments are not initiators of any accident previously evaluated. Therefore, the proposed trip level settings and surveillance intervals will not involve a significant increase in the probability of an accident previously evaluated.

The proposed changes to trip level settings and surveillance intervals were established using methodologies subject to a 10 CFR Appendix B Quality Assurance program and ensure existing radiological limits are met. Therefore, the proposed trip level settings and surveillance intervals will not involve a significant increase in the consequences of an accident previously evaluated.

Other changes are editorial or administrative in nature and can not significantly increase the probability or consequences of an accident previously evaluated.

 Will not create the possibility of a new or different kind of accident from any accident previously evaluated.

No new or different types of accidents or malfunctions than those previously analyzed in Pilgrim's UFSAR are introduced by this proposed change because there are no new failure modes introduced. Therefore, the proposed changes will not create the possibility of a new or different kind of accident from any accident previously evaluated.

• Will not involve a significant reduction in the margin of safety.

The proposed changes to trip level settings and surveillance intervals were established using approved methodologies subject to a 10 CFR, Appendix B, Quality Assurance program and existing radiological limits are met. These changes do not impact Pilgrim's configuration or operation.

Editorial and administrative type changes do not impact the operation or configuration of Pilgrim. For the above reasons the proposed change does not result in a significant reduction in the margin of safety.

Schedule of Change

This change will be implemented within 90 days following Pilgrim's receipt of NRC approval.

ATTACHMENT 2

MARKED UP TECHNICAL SPECIFICATION PAGES

البرات ا PNPS TABLE 3.2.A 4

..-

.

}

.

INSTRUMENTATION THAT INITIATES PRIMARY CONTAINMENT ISOLATION

MINIMUM # OF						
Operable Instrument				•		
. <u>Channels Per Trip System (1)</u> <u>Minimum</u> Available	Instrument	Trip Level Setting	Action (2)	α		
2(7)	Reactor Low Water Level	\geq 11.6" indicated level (3)	A and D	Ð		
1.	Reactor High Pressure	<76 psig	D	R		
2 2 .	Reactor Low-Low Water Level	at or above - 46.4 in. indicated level (4)	Α	· (f)		
2 2	Reactor High Water Level	≤ 55.4 " indicated level (5)	В	Ð		
. 2(7)	lligh Drywell Pressure	≤2.22 psig	, A	•		
$2 \cdot \left(\begin{array}{c} 2 \\ 2 \end{array} \right)$	Low Pressure Main Steam Line	≥810 psig (8)	в.			
2(6)	High Flow Main Steam Line	≤136% of rated steam flow	В			
• 2	Main Steam Line Tunnel	≤170°F	· B · ·			
2	Turbine Basement Exhaust Duct High Temperature	≤1.50 ⁰ F.	в .	•		
	Reactor Gleanup System (RWCU). High Flow	<300% of rated flow	c ·			
E Z	Reactor-Cleanup-System- -Iligh-Temperature	$\underbrace{=}_{150^{\circ}F}$	C C ····			
Revision 184 G Amendment No. 34;-42;-86;-147;-150;-151;-154;-162, 464 / RWCU BACK WASH RECEIVER TANK ROOM HIGH TEMPERATURE						
	· / Rwc . (/ Rwc	LINE IN RHR VALVEROOM	"A" HIGH TEMPERATURE DULES HIGH TEMPERAT	THEE		
مرومه المروم الم		And marchined and the of the				

INSTRUMENTA	TION THAT INITIATES OR CONTROL.	S THE CORE AND CONTAINMENT	COOLING SYSTEMS
Hinimum # of Operable Instrument Channels Per Trip System (1)			
<u> </u>	Trip Function	<u>Trip_Level_Setting</u>	Remarks
2	Condensate Storage Tank Low Level	≥18" above tank zero	Provides interlock to HPCI pump suction values.
2	Suppression Chamber Nigh Level	≤l'll" below torus zero	
1	RCIC Turbine Steam Line High Flow	≤ 300 % of rated steam flo	w.
2 EPara Court	RCIC Turbine Compartment Wall	$\leq 1 \neq 0^{n} F $ (2)	
2 (DUET TORUS) CIAVITY	Torus-Gavity-Exhaust-Duct	$\leq \pm 50^{\circ} \mathrm{F} $ (2)	
2 RCIC STEAM	RCIC Valve Station Area	$\leq 200^{\circ} \mathrm{F}$ (2)	· (
4 (5)	RCIC SLEAM Line-Lo-Press	(77) (43) ±00>P>50 psig (2)	ac((6))
1	HPCI Turbine Steam Line High Flow	≤3003 of rated flow (3) Z96	
2 (HPC) SYLMANT	HPCI Turbine Compartment Exhaust Duct	≤176 ⁰ F (3)	
2 DUCT TORUS - CAUTY	Forns Cavity Enhange-Buct	(3)	
.2	HPCI/RHR Valve Station Area Exhaust Duct	≤170°F. (3)	
Kevision-177-0			

PNPS TABLE 3.2.B (Cont)

٠

Amendment No. 0;-148

•••

۴,

ø

.

3/4.2-16

•

NOTES FOR TABLE 3.2.B

`}

- 1. Whenever any CSCS subsystem is required by Section 3.5 to be operable, there shall be two (Note 5) operable trip systems. If the first column cannot be met for one of the trip systems, that system shall be repaired or the reactor shall be placed in the Cold Shutdown Condition within 24 hours after this trip system is made or found to be inoperable.
 - 2. Close isolation valves in RCIC subsystem.
 - 3. Close isolation valves in HPCI subsystem.
 - 4. Instrument set point corresponds to 79.96 inches above top of active fuel.
 - 5. RCIC has only one trip system for these sensors.
 - 6. DOES NOT INCLUDE STATIC HEAD OF 17.5 psi

::

Amendment No. 198,-142,-151

PNPS TABLE 4.2.A

MINIMUM TEST AND CALIBRATION FREQUENCY FOR PCIS

1) 2) 3) 4)	Instrument Channel (5) Reactor High Pressure Reactor Low-Low Water Level Reactor High Water Level Main Steam High Temp, Surry	<u>Instrum</u> (1) Once/3 Once/3	ment Functional months months	<u>. Test</u> (7) (7)	Calibration Frequency Once/3 months (7) (7)	<u>Instrument C</u> None Once/day Once/day None	<u>heck</u>	
5) 6) 7) 8) <u>2</u> Logi	Main Steam High Flow Hain Steam Low Pressure Reactor Water Cleanup High Flow Reactor Water Gleanup High Temp <u>c System Functional Test</u> (4) (6)	Once/3 Once/3 (1) (1) (1) (1)	months months (CRICE/2) (CRICE/2)	(7) (7) / NONT/3	(7) (7) Once/3 months Once/3 months 24 Frequency	Once/day . Once/day Once/day None None None None		
1)	Hain Steam Line Isolation Vvs. Main Steam Line Drain Vvs. Reactor Water Sample Vvs.	(ii)	DWCE/24	MONTHS	(/Once/Operating Cycle	LNONE		
2)	RUR - Isolation Vv. Control Shutdown Cooling Vvs. () Head Spray Discharge to Radvaste				Once/Operating Cycle .			
3)	Reactor Nater Cleanup Isolation				Once/Operating Cycle			
4)	Drywell Isolation Vvs. TIP Withdrawal Atmospheric Control Vvs. Sump Drain Valves				Once/Operating Cycle			•.
5) *	Standby Gas Treatment System Reactor Building Isolation	À			Once/Operating Cycle	· · ·		
Re√f Amen	rion 177° dment: No. 99;-107;-130;-151	(8) (9) (0) (11)	"RWCU Back Wa "AWCU Heat Exe "RWCU Line In F "RWCU Line Nea	ash Rece changer a II-IR Valve ar East Cf	iver Tank Room High Tempel and Pump Rooms High Temp Room "A" High Temperature 1D Modules High Temperatur	rature" erature" e" e"		3/4.2-31

•

PNPS . TABLE 4.2.B

MINIMUM TEST AND CALIBRATION FREQUENCY FOR CSCS

	Instrument Channel	Instrument	Functional Test	<u>Calibration Frequency</u>	Instrument Check
1)	Reactor Water Level		(1) (7)	(7)	Once/day
2)	Drywell Pressure		(1) (7)	(7)	Once/day
3)	Reactor Pressure		(1) (7)	(7)	Once/day
4)	Auto Sequencing Timers		NA	Once/Operating Cycle	None
5)	ADS - LPCI or CS Pump Disch. Pressure Interlock		(1)	Once/3 months	None
6)	Start-up Transf. (4160V) a. Loss of Voltage Relays		Monthly	Once/Operating Cycle	None
	b. Degraded Voltage Relays		Monthly	Once/Operating Cycle	None
7)	Trip System Bus Power Monitors		Once/Operating Cyc	cle NA :	Once/day
8)	Recirculation System d/p		(1)	Once/3 months	Once/day
9)	Core Spray Sparger d/p		NA	Once/18 months	Once/day
10)	Steam Line High Flow (HPCI & H	RCIC)	(1)	Once/3 months	None
11)	Steam Line High Temp. (HPCI &	RCIC)	(1)	Once 13 months 24	None
12)	Safeguards Area High Temp.		(1)	Once (3) months	None

Revision-177 Amendment No. 42;-61;-99;-148;-151

۰. *–*

PNPS TABLE 4.2.B (Cont)

MINIMUM TEST AND CALIBRATION FREQUENCY FOR CSCS

-	<u>Instrument Channel</u>	Instrument Functional Test	Calibration Frequency	Instrument Check	
13)	RGIC Steam Line Low Pressure	(1)	Once Athonths (12)	None	• . •
14)	HPCI Suction Tank Levels	(1)	Once/3 months	None	
15)	Emergency 4160V Buses A5 & A6 Loss of Voltage Relays	Monthly .	Once/Operating Cycle	None	

÷; ;

Revision-177-C. Amendment No. 42,-61,-99,-148,-151

·~~

٠. •

• •

1

NOTES FOR TABLES 4.2.A THROUGH 4.2.G



- 1. Initially once per month until exposure hours (M as defined on Figure (4,1,1)) is 2.0 x 10⁵; thereafter, according to Figure (4,1,1) with an interval not less than one month nor more than three months.
- 2. Functional tests, calibrations and instrument checks are not required when these instruments are not required to be operable or are tripped. Functional tests shall be performed before each startup with a required frequency not to exceed once per week. Calibrations of IRMs and SRMs shall be performed during each startup or during controlled shutdowns with a required frequency not to exceed once per week. Instrument checks shall be performed at least once per day during those periods when the instruments are required to be operable.
- 3. This instrumentation is excepted from the functional test definition. The functional test will consist of injecting a simulated electrical signal into the measurement channel.
- 4. Simulated automatic actuation shall be performed once each operating cycle. Where possible, all logic system functional tests will be performed using the test jacks.
- 5. Reactor low water level and high drywell pressure are not included on Table 4.2.A since they are tested on Tables 4.1.1 and 4.1.2.
- 6. The logic system functional tests shall include a calibration of time delay relays and timers necessary for proper functioning of the trip systems.
- 7. Calibration of analog trip units will be performed concurrent with functional testing. The functional test will consist of injecting a simulated electrical signal into the measurement channel. Calibration of associated analog transmitters will be performed each refueling outage.

BASES:

3.2 <u>PROTECTIVE INSTRUMENTATION</u> (Cont)

up to the complete circumferential break of a 28-inch recirculation line and with the trip setting given above, CSCS initiation and primary system isolation are initiated in time to meet the above criteria.

The high drywell pressure instrumentation is a diverse signal to the water level instrumentation and in addition to initiating CSCS, it causes isolation of Group 2 isolation valves. For the breaks discussed above, this instrumentation will initiate CSCS operation at about the same time as the low low water level instrumentation; thus the results given above are applicable here also. The low low water level instrumentation initiates protection for the full spectrum of loss-of-coolant accidents and causes isolation of Group 1 isolation valves.

Venturis are provided in the main steam lines as a means of measuring steam flow and also limiting the loss of mass inventory from the vessel during a steam line break accident. The primary function of the instrumentation is to detect a break in the main steam line. For the worst case accident, main steam line break outside the drywell, steam flow trip setting in conjunction with the flow limiters and main steam line valve closure, limits the mass inventory loss such that fuel is not uncovered, fuel temperatures remain . approximately 1000°F and release of radioactivity to the environs is well below 10CFR100 guidelines.

Temperature monitoring instrumentation is provided in the main steam line tunnel and the turbine basement to detect leaks in these areas. Trips are provided on this instrumentation and when exceeded, cause closure of isolation valves. The setting of F for the main steam line tunnel detector is low enough to detect leaks on the order of 5 ± 10 gpm; thus, it is capable of covering the entire spectrum of breaks. For large breaks, the high steam flow instrumentation is a backup to the temperature instrumentation.

Pressure instrumentation is provided to close the main steam isolation valves in the RUN mode before the reactor pressure drops below 785 psig. This function is primarily intended to prevent excessive vessel depressuirzation in the event of a malfunction of the nuclear system pressure regulator. This function also provides automatic protection of the low-pressure core-thermalpower safety limit (25% of rated core thermal power for reactor pressure < 785 psig). In the Refuel or Startup Mode, the inventory loss associated with such a malfunction would be limited by closure of the Main Steam Isolation Valves due to either high or low reactor water level; no fuel would be uncovered. This function is not required to satisfy any safety design bases.

....

Revision 177 C Amendment No. 34,-113,-151,-154

з.

BASES:

149

WITH OWS

SYSTEM FOR

EACH AREA

INSTRUMENT

IN EACHTRIP

3.2 <u>PROTECTIVE INSTRUMENTATION</u> (Cont)

The HPCI high flow and temperature instrumentation are provided to detect a break in the HPCI steam piping. Tripping of this instrumentation results in actuation of HPCI isolation valves. Tripping logic for the high flow is a lout of 2 logic, and all sensors are required to be operable.

Temperature is monitored at three (3) locations with four (4) temperature sensors at each location. Two (2) sensors at each location are powered by "A" direct current control bus and two (2) by "B" direct current control bus. Each pair of sensors, e.g., "A" or "B", at each location are physically separated and the tripping of either "A" or "B" bus sensor will actuate HFCI isolation valves.

The trip settings of $\leq 60\%$ of design flow for high flow and 6% F or 6% F, depending on sensor location, for high temperature are such that core uncovery is prevented and fission product release is within limits.

The RGIG high flow and temperature instrumentation arranged the same as that for the HPCI. The trip setting of ≤ 300% for high flow and the same are based on the same criteria as the HPCI.

The Reactor Water Cleanup System high flow and temperature instrumentation arranged similar as that for the HPC. The trip settings are such that core uncovery is prevented and fission product release is within limits.

The instrumentation which initiates GSCS action is arranged in a dual bus system. As for other vital instrumentation arranged in this fashion, the Specification preserves the effectiveness of the system even during periods when maintenance or testing is being performed. An exception to this is when logic functional testing is being performed.

The control rod block functions are provided to prevent excessive control rod withdrawal. The trip logic for this function is 1 out of n: e.g., any trip on one of six AFRM's, two RMB's, eight IRM's, or four SRM's will result in a rod block.

The minimum instrument channel requirements assure sufficient instrumentation to assure the single failure criteria is met. The minimum instrument channel requirements for the RBM may be reduced by one for not longer than 24 hours without significantly increasing the risk of an inadvertent control rod withdrawal.

Reactor power may be varied by moving control rods or by varying the recirculation flow rate. The APRM system provides a control rod block to prevent rod withdrawal beyond a given point; thereby possibly avoiding an APRM Scram. The rod block setpoint is automatically reduced with recirculation flow to form the upper boundary of the PNPS power/flow map. The flow biased APRM rod block is not necessary to prohibit fuel damage and is not included in the analysis of anticipated transients.

Amendment No. 140,-150,-154

83/4.2-3

ATTACHMENT 3

CALCULATION METHODOLOGY INFORMATION

ATTACHMENT 3

A. Application of the Guidance of Generic Letter 91-04

Generic Letter 91-04 provided a methodology for determining and evaluating instrument surveillance intervals. As discussed in the Generic Letter a proposed surveillance interval was acceptable if it met certain requirements.

A setpoint calculation using the same methodology that was used for the proposed changes was submitted to the NRC by letter, dated June 7, 1993. The submittal was made to facilitate NRC review and approval of a 24-month fuel cycle for Pilgrim in accordance with Generic Letter 91-04. The NRC found Pilgrim's method and results acceptable in the NRC's safety evaluation report granting License Amendment 151, dated April 6, 1994, (TAC Nos. M83787, M87191, and M88390). In addition, as requested by the NRC staff, selected portions on two of the calculations associated with this change are included in Attachment 4.

The following is a discussion of the application of the requirements of Generic Letter 91-04 for the proposed calibration frequencies.

1. Confirm that instrument drift as determined by as-found and as-left calibration data from surveillance and maintenance records has not, except on rare occasions, exceeded acceptable limits for a calibration interval.

Discussion

As-found and as-left data for the instruments being evaluated were obtained and the instrument drift for the proposed duration confirmed that the drift supported the requested interval.

As-found and as-left calibration data was collected from calibration records and statistically analyzed to determine drift. Pilgrim looked at the proposed calibration intervals plus a 25% margin (e.g.15 months for yearly calibration intervals and 30 months for 2 year calibration intervals). Pilgrim then evaluated the intervals associated with the device for which no adjustments were required during the entire interval, i.e., the device had not drifted for the entire interval and required no action on the part of the technician.

From the raw data, the shift between calibrations and the interval between calibrations was determined. Mean, standard deviation, and outliers were determined for each set of data. Then, based on the sample size, the appropriate multiplier was determined and utilized to convert the standard deviation value corresponding to 95% probability at a 95% confidence level. Statistical analysis was performed on the data to determine if the data set is normal or bounded by the normal curve. WAPD-TM-1292 (DOE Research and Development Report) "Statistics for Nuclear Engineers and Scientist, Part 1: Basic Statistical Inference" was used to obtain the multiplier to obtain a 95% probability at a 95% confidence level.

2. Confirm that the values of drift for each instrument type (make, model, and range) and application have been determined with a high probability and a high degree of confidence. Provide a summary of the methodology and assumptions used to determine the rate of instrument drift with time based upon historical plant calibration data.

Discussion

The as-found and as-left data were analyzed to ensure that the drift values corresponded to a 95% probability at a 95% confidence level. A detailed discussion of the methodology used is supplied in a Pilgrim letter to the NRC dated June 7,1993. In addition, as requested by the NRC staff, selected portions on two of the calculations associated with this change are included in Attachment 4.

3. Confirm that the magnitude of instrument drift has been determined with a high probability and a high degree of confidence for a bounding calibration interval of 30 months for each instrument type (make, model number, and range) and application that performs a safety function. Provide a list of the channels by TS section that identifies these instrument applications.

Discussion

Attachment 1 in the Description of Proposed Changes section provides a list of the instrument applications affected.

The calculations used existing analytical limits as bounding values for the setpoint analyses. As-found/as-left historical instrument calibration data were statistically analyzed to calculate 95/95% probability and confidence level values. These values were then used in the setpoint calculations. The value determined in this process was considered to include the effects of measurement and test equipment (M&TE), reference or basic component accuracy and other parameters as well as component drift. The rack and sensor setting tolerances were retained. This approach is consistent with the proposed Instrument Society of America (ISA) Recommended Practice (ISA-S67.04-1982, "Setpoints for Nuclear Safety-Related Instrumentation Used in Nuclear Power Plants", including consideration of the 6 items in Section 4.2.1 of the Standard).

The 95% probability at a 95% confidence level values were statistically analyzed to determine if the data sets were normal or bounded by a normal curve.

All uncertainties identified in the calculations were individually evaluated to determine whether they were random or biased. In the context of instrument uncertainty, it is accepted within the industry that random uncertainties are those uncertainties that a manufacturer specifies as having a + or - magnitude. Random uncertainties were combined using the root sum of the squares (RSS) technique. Biases were expressed with either a + or a - sign and were added together separately according to sign. Individual component error terms which contained both a bias and a random value were split up so that the random part was combined with other component error terms, and the biases were added to other component bias terms of the same sign. Both random and bias terms were added together to determine Total Loop Uncertainty (TLU). A random or bias term can also be further classified as being dependent or independent. Two error terms are classified as dependent if they possess a significant correlation, for whatever cause, known or unknown. Instrument proximity or physical connections alone do not cause dependency because the sign of the error term is determined solely by that instrument's measured response to the stimulus (temperature, pressure, etc.). Dependent errors were summed algebraically to form independent errors.

The interval used for the calculations was the proposed calibration interval plus 25% (i.e., 15 months or 30 months).

4. Confirm that a comparison of the projected instrument drift errors has been made with the values of drift used in the setpoint analysis. If this results in revised setpoints to accommodate larger drift errors, provide proposed TS changes to update trip setpoints. If the drift errors result in a revised safety analysis to support existing setpoints, provide a summary of the updated analysis conclusions to confirm that safety limits and safety analysis assumptions are not exceeded.

Discussion

A comparison of projected drift errors was made with the drift values used in the setpoint analysis. The calculations determined setpoints with sufficient margin to ensure at least a 95% probability of achieving the design basis setpoint analytical limit. The cases where the safety analysis assumptions needed to be revised are discussed in Attachment 1 in the Safety Evaluation section.

5. Confirm that the projected instrument errors caused by drift are acceptable for control of plant parameters to effect a safe shutdown with the associated instrumentation.

Discussion

Instrument errors caused by drift were evaluated as part of the process and found to be acceptable as part of the calculation process.

6. Confirm that all conditions and assumptions of the setpoint and safety analyses have been checked and are appropriately reflected in the acceptance criteria of plant surveillance procedures for channel checks, channel functional tests, and channel calibrations.

Discussion

The assumptions of the calculations were validated as required by the applicable setpoint calculation procedures.

7. Provide a summary description of the program for monitoring and assessing the effects of increased calibration surveillance intervals on instrument drift and its effect on safety.

Discussion

Pilgrim commits to a program that consists of monitoring, feedback, and assessment to verify instrument performance, including drift, is consistent with the parameters specified in the calculations for those instruments whose surveillance interval is being increased. Data collected from surveillance procedures will be evaluated to confirm the validity of assumptions supporting the setpoint calculations and the calculations' conclusions. The proposed (revised) setpoints will be evaluated during the first calibration interval(s) to ensure the new setpoints have no adverse impact on plant operations. The extended surveillance intervals will be monitored for three calibration interval(s) to ensure the assumptions in the calculations continue to be valid. If surveillance test results indicate that instrument performance does not meet surveillance procedure requirements, corrective actions will be taken in accordance with existing station procedures. Changes made as a result of the corrective action will be reflected in the setpoint calculations. Subsequent monitoring will rely on existing plant procedures and controls to ensure continued safe operation of Pilgrim.

B. Calculation Methodology

The methodologies used are in accordance with Regulatory Guide 1.105, Revision 2, ISA-S67.04-1982, and Generic Letter 91-04. A sample setpoint calculation using the same methodology that was used for the proposed changes was submitted to the NRC by letter dated June 7, 1993. The submittal was made to facilitate NRC approval of a 24-month fuel cycle for Pilgrim in accordance with Generic Letter 91-04. The NRC found Pilgrim's method and results acceptable in the NRC's safety evaluation report granting License Amendment 151, dated April 6, 1994, (TAC Nos. M83787, M87191, and M88390). In addition, as requested by the NRC staff, selected portions on two of the calculations associated with this change are included in Attachment 4.

In the calculations, as-found and as-left calibration data was collected from calibration records and statistically analyzed to determine drift. From the raw data, the shift between calibrations and the interval between calibrations was determined. Mean, standard deviation, and outliers were determined for each set of data. Then, based on the sample size, the appropriate multiplier was determined and utilized to convert the standard deviation value corresponding to 95% probability at a 95% confidence level. Statistical analysis was performed on the data to determine if the data set is normal or bounded by the normal curve. WAPD-TM-1292 (DOE Research and Development Report) "Statistics for Nuclear Engineers and Scientist, Part 1: Basic Statistical Inference" was used to obtain the multiplier to obtain a 95/95 confidence level.

All calculations were prepared using this same methodology.

ATTACHMENT 4

PORTIONS OF TWO OF THE ASSOCIATED CALCULATIONS

Pilgrim Calculation No. 1-N1-115

- -

Pages 2 thru 21 and 24 thru 38

Rev 0 Date <u>11/21/95</u>



Sheet <u>2</u> of <u>47</u>

FORM 4. CALCULATION SHEET

CALCULATION NUMBER ____ I-N1- 115

CALCULATION WORK OR REMARKS:

Statement of Problem

1

đ

.

1

1

ł

This calculation will provide the uncertainity analysis for the development of the RWCU system space high temperature group 6 isolation setpoint based on a twenty-four month calibration frequency. It will determine a plant setpoint and allowable value which will ensure at least 95% probability of achieving the isolation on or before reaching the setpoint analytical limit. Parameters determined by this calculation are:

- Trip Setpoint
- Technical Specification Allowable Value
- Setpoint Analytical Limit
- Field Reset Value
- Calibration No Adjust Limits
- Instrument Surveillance Interval
- Measurement and Test Equipment Equipment Accuracy

Method of Solution

This calculation is performed based on the methodology described in BECO NEDWI No. 394 and uses ABB Impell Project Instruction No. 25-226-PI-001 for the analysis of the as-found as-left instrument calibration data. The calculation is in accordance with the U.S. NRC Regulatory Guide No. 1.105, Rev. 2 and Instrument Society of America Standard ISA-S67.04-1982.

Input Data and Assumptions

The RWCU system space high area temperature instruments consists of four sets of two bimetallic temperature switches. Each set is a one out of two trip system capable of initiating isolation. The temperature switch sets are located in the following areas:

Rev 0 Date <u>11/21/95</u>



Sheet 3 of 47

FORM 4.	CALCULATION SHEET
	······

CALCULATION NUMBER _____ I -N1- 115__

- HV duct from the Backwash Receiver Tank Room
- HV duct from the RWCU Heat Exchanger Room
- RHR Piping Room
- HV duct from the RHR "A" Valve Room

Input data and references are listed on Form 1 of this calculation. Any assumptions are identified under the notes section.

Summary of Results and Recommendations

This calculation determined a new instrument setpoint, technical specification allowable value and setpoint calibration frequency. These values were determined based on industry and plant specific calibration data and NEDWI No. 394 methodology. The new setpoint is more conservative than the present. The new values determined by this calculation require a plant design change for implementation at PNPS.

Note, the new setpoint allowable value and calibration frequency require a Technical Specification change.

The results of this calculation are listed below:

Trip Setpoint: 138 deg F Technical Specification Allowable Value: ≤148 deg F Setpoint Analytical Limit: ≤150 deg F Setpoint Reset Value: 133 deg F (Typically) No Adjust Limits: ± 3 deg F Surveillance Interval: Once per 24 months plus 25% M&TE Accuracy: ± 5 deg F

Rev D Date $\frac{4}{196}$ **Boston Edison** Sheet 3^{α} of $\frac{47}{7}$

ſ

1

FORM 4. CALCULATION SHEET				
CALCULATION NUMBER I-NI-115				
CALCULATION WORK OR REMARKS:				
RWCU SYSTEM SPACE TEMP. ISOLATION				
TS 1291- 140 1 1 1 1 1 1 1 1 1 1 1 1 1				
Notes: TS 1291-14E, F, G, H J and K are similar Dwg. MIN 39-13, Sh.1				

Rev 0 Date <u>11/17/95</u>

😼 Boston Edison

Sheet <u>4</u> of <u>47</u>

FORM 4. CALCULATION SHEET

CALCULATION NUMBER _____I-N1-115

CALCULATION WORK OR REMARKS:

Notes:

1. The RWCU system space high temperature switches are part of the Primary Containment and Reactor Vessel Isolation Control System (PCIS). The objective of the PCIS is to provide timely protection against the onset and consequences of accidents (leaks and breaks) involving the gross release of radioactive materials from the fuel and nuclear system process barrier by initiating automatic isolation of appropriate lines which penetrate the primary containment whenever monitored variables exceed preselected operational limits (FSAR Section 7.3.1). This protects the fuel by limiting losses of reactor coolant and stopping the release of radioactive materials. See FSAR Section 7.3.3 for the PCIS Safety Design Bases.

The safety function of the RWCU system space high temperature instrumentation is to detect high temperature in the vicinity of the RWCU system equipment in excess of its preselected setpoint. High temperature could indicate a leak or a break in a RWCU system pipe line. The high temperature isolation setting is selected far enough above anticipated normal RWCU system operational levels to avoid spurious isolations, but low enough to provide timely detection of a RWCU line break (FSAR section 7.3.4.7).

2. The Circuit Leakage Allowance is applicable to low energy analog signals only. The RWCU system space high temperature switches are mechanical on/off 120 vac devices. The performance of 120 vac on/off signals are not affected by circuit leakage. Therefore, this error is not applicable.

3. Process Measurement Accuracy for a temperature switch is typically the response time of the sensor. The actual sensor temperature always lags a change in the process temperature which translates to an error in the process setpoint if time is essential in the operation of the switch. Because dynamic effects such as time response are addressed in the plant accident analysis the error associated with sensor response time will not be included in the setpoint calculation.

Also, it is assumed the temperature switches are located at the highest temperature of the room. Therefore, there will not be an error due to sensor location.

Rev 0 Date <u>11/17/95</u>

👙 Boston Edison

Sheet <u>5</u> of <u>47</u>

FORM 4. CALCULATION SHEET	
CALCULATION NUMBER	I-N1-115

4. The sensor drift was statistically analyzed for a three month interval in attachment no. 2 in accordance with ABB Impell Project Instruction 25-226-PI-001. The analysis used empirical data from 5/18/93 through 5/21/95 obtained from the PNPS as-found as-left instrument calibration records. Reference PNPS Procedure 8.M.2-1.2.2. The drift value determined is .62 \pm 6.27. Also, industry data for the EGS Patel temperature switch was statistically analyzed in attachment no. 3 for a 30 month interval. The drift value determined is 2.22 \pm 7.05. The value obtained from the statistical analysis has a probability and confidence of 95/95%.

The Pilgrim specific drift data for a 3 month interval when compared to industry drift data for a 30 month interval is not significantly different. It is therefore concluded the drift of these switches are not a function of time. Based on this data the calibration interval for these switches is to be extended to 24 months. This calculation will assume drift of TS 1291-14C,D,E,F,G,H,J&K for a 24 month calibration frequency is the value determined from the industry data above.

The as-found as-left calibration data used to determine the drift also includes the error associated with sensor accuracy and measurement and test equipment (M&TE) accuracy. Therefore, the value for the sensor normal accuracy and calibration accuracy is considered to be included in the drift error and will be identified as N/A in this calculation. It is assumed that the accuracy of the M&TE used for calibration is less than or equal to the accuracy of the instrument being calibrated. Reference PNPS Procedure 1.3.36.

5. The Environmental Allowance includes errors due to temperature, radiation, humidity, pressure, and seismic effects. This error is identified in Patel Report PEI-TR-831200-1 in section X-2.3.2.1. The accuracy of the switches tested remained within the ±6 deg F acceptance criteria throughout the entire test program without any adjustments. The environmental conditions for TS-1291-14C, TS-1291-14D, TS-1291-14E, TS-1291-14F, TS-1291-14G, TS-1291-14H, TS-1291-14J and TS-1291-14K applications are identified in Boston Edison Co. Environmental Qualification Evaluation Sheets. The conditions of the Patel test program envelope both the normal and accident environment at PNPS. Therefore, the Environmental Allowance of TS-1291-14C, TS-1291-14F, TS-1291-14G, TS-1291-14H, TS-1291-14K is considered to include all the above effects.

Rev 0 Date <u>11/17/95</u>

👙 Boston Edison

Sheet 6 of 47

FORM 4. CALCULATION SHEET

CALCULATION NUMBER _____ I-N1-115_

6. From the as-found as-left calibration data (reference PNPS Procedure 8.M.2-1.2.2) the reset differential for the EGS Patel temperature switch, model no. 01-170020-090 is typically less than 5 deg F. Therefore the reset value is typically greater than 133 deg F.



REV_0___ DATE_11/21/95____

Calculation Number_I-N1-115____

SHEET_7_OF_47

Instrument Number_TS-1291-14C thru k

FORM 1 INSTRUMENT DATA

Page 1 of 9

TITLE		DESCRIPTION/VALUE	REFERENCE	REMARKS
GENERAL INFORMATION	INSTRUMENT NUMBER	TS-1291-14C,D,E,F,G,H,J & K	DWG. M 247	
	SERVICE DESCRIPTION	Reactor Water Cleanup System Space High Temperature Isolation	FSAR Section 7.3.4.7	
	QUALITY CATEGORY	Q	PNPS Q-List Page 3-45-9	
	ENVIRONMENTAL QUALIFICATION	YES EQ Area 1.11C, 1.11, 1.9A, & 1.9	EQ Master List System 45	
	SAFETY FUNCTION (IF APPLICABLE)	See Note 1	FSAR Section 7.3.3 and 7.3.4.7	
	TECHNICAL SPECIFICATION (IF APPLICABLE)	≤150 deg F	Technical Specification Table 3.2.A	
	MANUFACTURER	EGS Patel	Equipment Qualification Data Files TS-1291-14C,D ,E,F,G,H,J & K	
	MODEL NUMBER	01-170020-090	Equipment Qualification Data Files TS-1291-14C,D ,E,F,G,H,J & K	


Calculation Number_I-N1-115____

sheet<u>8</u> of <u>47</u>

Instrument Number_TS-1291-14C thru k

FORM 1 INSTRUMENT DATA

Page 2 of 9

TITLE			DESCRIPTION/VALUE	REFERENCE	REMARKS
	ANALYTICAL LIMIT		≤150 deg F	S&SA Memo 95-47	
	Allowae (A	SLE VALUE V)	≤148 deg F	Sheet 3, Form 3 this calc	
	SETPOINT	TRIP	138 deg F	Sheet 3, Form 3 this calc	
		RESET	133 deg F	Sheet 4, Form 3 this calc.	Switch has a fixed reset
	NORMAL OPERATION UPPER LIMIT (NUL)		105 deg F	Specification E536	
INSTRUMENT SETPOINT DATA	NORMAL C LOWER LI	OPERATION MIT (NLL)	N/A	N/A .	Not a decreasing setpoint
	PROCESS CALIBRATED RANGE		N/A		The switch is calibrated at the setpoint only
	OPERATING MARGIN (OM)*		33 deg F	Sheet 4, Form 3 this calc.	
	*NOTE: ADE OPERATION PROCESS NO	EQUATE OPER UPPER OR LO OISE, TRANSIE	ATING MARGIN IS REQUIRED WER LIMIT, AS APPLICABLE, 1 NTS AND MEASUREMENT UN	BETWEEN THE SETPOINT AND O AVOID INADVERTENT TRIPS CERTAINTIES.	THE NORMAL DUE TO



Calculation Number__I-N1-115____

FORM 1 INSTRUMENT DATA

Instrument Number_TS-1291-14C thru k

SHEET 9_OF 47

Page 3 of 9

TITLE		DESCRIPTION/VALUE	REFERENCE	REMARKS
	ADJUSTABLE RANGE	-100 deg F to 600 deg F	Patel/EGS Product Data Sheet (Attachment 1)	
	INPUT SIGNAL FROM	Ambient Air	FSAR Section 7.3.4.7	
	INPUT SIGNAL CALIBRATED RANGE	N/A	N/A	The switch is calibrated at the setpoint only
INSTRUMENT SETPOINT DATA (CONT)	OUTPUT SIGNAL TO	Group 6 Isolation	FSAR Table 5.2-4	
•	OUTPUT SIGNAL CALIBRATED RANGE	N/A	N/A	The switch is calibrated at the setpoint only
1	SETPOINT CALIBRATION FREQUENCY	Once per 24 months plus 25%	This Calculation	See Note 4



SHEET 10 OF 47

Instrument Number_TS-1291-14C thru k

FORM 1	INSTRUMENT DAT	Pag	Page 4 of 9		
	TITLE	DESCRIPTION/VALUE	REFERENCE	REMARKS	
	TEMPERATURE EFFECT (Te)		Patel Report PEI-TR-831200-1 (EQDF REF 340)	See Note 5	
ENVIRONMENT ALLOWANCE (EA)	RADIATION EFFECT (Re)		Patel Report PEI-TR-831200-1 (EQDF REF 340)	See Note 5	
FORM 3 STEP 1	STEAM/CHEMICAL SPRAY EFFECT (S/Ce)	< ±6°F	Patel Report PEI-TR-831200-1 (EQDF REF 340)	See Note 5	
	PRESSURIZATION (EXTERNAL) EFFECT (Pe)		Patel Report PEI-TR-831200-1 (EQDF REF 340)	See Note 5	
	SEISMIC EFFECT (Se)		Patel Report PEI-TR-831200-1 (EQDF REF 340)	See Note 5	
	CABLE LEAKAGE (CI)	N/A	N/A	See Note 2	
CIRCUIT LEAKAGE ALLOWANCE (LA) FORM 3 STEP 2	TERMINAL BLOCK LEAKAGE (TI)	N/A	N/A	See Note 2	
i.	PENETRATION LEAKAGE (PI)	N/A	N/A	See Note 2	

Calculation Number_I-N1-115____



SHEET 11 OF 47

Calculation Number__I-N1-115____

Instrument Number_TS-1291-14C thru k

FORM 1 INSTRUMENT DATA

Page 5 of 9

TITLE		DESCRIPTION/VALUE	REFERENCE	REMARKS
CIRCUIT LEAKAGE ALLOWANCE (LA)	SPLICE LEAKAGE (SI)	N/A	N/A	See Note 2
(CONTINUED)	SEALING DEVICE LEAKAGE (DI)	N/A	N/A	See Note 2
PROCESS ALLOWANCE (PA)	PROCESS MEASUREMENT ACCURACY (Pma)	N/A	N/A	See Note 3
FORM 3 STEP 3	PRIMARY ELEMENT ACCURACY (Pea)	N/A	N/A .	No Primary Element
CALIBRATION ALLOWANCE	SENSOR CALIBRATION ACCURACY (Sca)	N/A	N/A	See Note 4
(CA) FORM 3 STEP 4	RACK EQUIPMENT CALIBRATION ACCURACY (Rca)	N/A	N/A	No Rack Equipment



Calculation Number_I-N1-115____

FORM 1 INSTRUMENT DATA

Instrument Number_TS-1291-14C thru k

Page 6 of 9

	TITLE	DESCRIPTION/VALUE	REFERENCE	REMARKS
	RACK EQUIPMENT ACCURACY (Rea)	N/A : '	N/A	No rack equipment
RACK EQUIPMENT ALLOWANCE (RA) FORM 3 STEP 5	RACK TEMPERATURE EFFECTS (Rłe)	N/A	N/A	No rack equipment
	RACK POWER SUPPLY EFFECTS (Rps)	N/A	N/A _	No rack equipment
	RACK EQUIPMENT MISCELLANEOUS EFFECTS (Rme)	N/A	N/A	No rack equipment



Calculation Number_1-N1-115____

FORM 1 INSTRUMENT DATA

SHEET 13 OF 47

i

Instrument Number_TS-1291-14C thru k

Page 7 of 9

TITLE		DESCRIPTION/VALUE	REFERENCE	REMARKS
	SENSOR BASIC ACCURACY (Sa)	N/A	N/A	See Note 4
	SENSOR STATIC PRESSURE SPAN SHIFT (Ssps)	N/A	N/A	Temperature elements are not pressure sensitive
SENSOR ALLOWANCE (SA)	SENSOR STATIC PRESSURE ZERO SHIFT (Sspz)	N/A	N/A	Temperature elements are not pressure sensitive
FORM 3 STEP 6	SENSOR TEMPERATURE EFFECTS (Ste)	N/A	N/A .	Not applicable to temperature sensors
	SENSOR POWER SUPPLY EFFECTS (Spse)	N/A	N/A	Mechanical temperature sensors do not use power supplies for operation
i	SENSOR MISCELLANEOUS EFFECTS (Sme)	N/A	N/A	



Calculation Number_I-N1-115____

FORM 1 INSTRUMENT DATA

Instrument Number_TS-1291-14C thru k

Page 8 of 9

TITLE		DESCRIPTION/VALUE	REFERENCE	REMARKS
DRIFT ALLOWANCE	SENSOR DRIFT (Sd)	+ 2.22 \pm 7.05 deg F	See Note 4 and Attachment 2 and 3	
(DA) FORM 3 STEP 7	RACK EQUIPMENT DRIFT (Red)	N/A	N/A	No rack equipment
TOLERANCE	SENSOR TOLERANCE (Sł)	±3 deg F	PNPS Procedure 8.M.2-1.2.2	This application is to use the same no adjust limits as utilized by the HPCI, RCIC & Main Steam line leak detection setpoints
ALLOWANCE (TA) FORM 3 STEP 8	RACK EQUIPMENT TOLERANCE (Rei)	N/A	N/A	No rack equipment

SHEET 14 OF 47



SHEET 15 OF 47

٩

Calculation Number____I -N1- 115____

Instrument Number TS-1291-14C, 14D, 14E, 14F, 14G, 14H, 14J &14K

FORM 2A CALCULATION INPUT SHEET (INCREASING SETPOINT)

	PARAMETER	DESCRIPTION	ABBRE	VIATION/VALUE *	COMMENTS
+	ANALYTICAL LIMIT	A	AL	≤ 150 deg F	S&SA Memo 95-47
	ENVIRONMENTAL ALLOWANCE (<u>EA</u>)	TEMPERATURE EFFECT RADIATION EFFECT STEAM/CHEM SPRAY EFFECT PRESSURIZATION (EXT.) EFFECT SEISMIC EFFECT	Te Re S/Ce Pe Se	. = = = = = = = = = = = = =	See note 5 See note 5 See note 5 See note 5 See note 5
T O T A L	CIRCUIT LEAKAGE ALLOWANCE (<u>LA</u>)	CABLE LEAKAGE TERMINAL BLOCK LEAKAGE PENETRATION LEAKAGE SPLICE LEAKAGE SEALING DEVICE LEAKAGE	CI TI PI SI DI	= N/A = N/A = N/A = N/A = N/A	See note 2 See note 2 See note 2 See note 2 See note 2 See note 2
L O P	PROCESS ALLOWANCE (<u>PA</u>)	PROCESS MEASUREMENT ACCURACY PRIMARY ELEMENT ACCURACY	Pma Pea	= N/A = N/A	See note 3
U N C	CALIBRATION ALLOWANCE (<u>CA</u>)	SENSOR CALIBRATION ACCURACY RACK EQUIPMENT CALIBRATION ACCURACY	Sca Rca	= N/A = N/A	See note 4
E R T A I N	RACK EQUIPMENT ALLOWANCE (<u>RA</u>)	RACK EQUIPMENT ACCURACY RACK TEMPERATURE EFFECT RACK POWER SUPPLY EFFECT RACK EQUIPMENT MISCELLANEOUS EFFECT	Rea Rte Rps Rme	= N/A = N/A = N/A = N/A	
Y	SENSOR ALLOWANCE (<u>SA</u>) ALLOWABLE	SENSOR BASIC ACCURACY SENSOR STATIC PRESSURE SPAN SHIFT SENSOR STATIC PRESSURE ZERO SHIFT SENSOR TEMPERATURE EFFECTS SENSOR POWER SUPPLY EFFECTS SENSOR MISCELLANEOUS EFFECTS	Sa Ssps Sspz Ste Spse Sme	= ±5 deg F = N/A = N/A = N/A = N/A = N/A	See note 4
	VALUE DRIFT ALLOWANCE (<u>DA</u>) TOLERANCE ALLOWANCE (<u>IA</u>) TRIP SETPOINT	SENSOR DRIFT RACK EQUIPMENT DRIFT SENSOR TOLERANCE RACK EQUIPMENT TOLERANCE	Sd= Red St Ret TSp**	s 148 deg F + 2.22 ± 7.05 deg F = N/A = ± 3 deg F = N/A = 138 deg F	See note 4
	RESET VALUE NORMAL OPERATION UPPER LIMIT	OPERATING MARGIN	RV OM NUL	= 133 deg F = 33 deg F = 105 deg F	See note 6
	NORMAL OPERATION	NORMAL OPERATING BAND		= N/A	

*NOTE: VALUES ARE IDENTIFIED FOR MAGNITUDE ONLY AND ARE COMBINED IN ACCORDANCE WITH THE EQUATIONS ON FORM 3 **NOTE: CALCULATED VALUES FROM FORM 3





•

REV_0____DATE__11/17/95____

FORM 3. CALCULATION SHEET

SHEET 18 OF 4-7

SHEET NO. 3 of 4

Calculation Number_____I-N1-115___

Instrument Number __TS-1291-14C, 14D, 14E, 14F, 14G, 14H, 14J & 14K___

10. TRIP SETPOINT (TSp) IN PROCESS UNITS

10A. FOR INCREASING SETPOINT - FORM 2A: (ENTER N/A IF DECREASING SETPOINT)

TSp = AL - TLU

TSp = 150 - 11.95 = 138.05, say 138 deg F

10B. FOR DECREASING SETPOINT - FROM 2B: (ENTER N/A IF INCREASING SETPOINT)

TSp = AL + TLU

TSp = N/A + N/A = N/A

11. ALLOWABLE VALUE (AV)

11A. FOR INCREASING SETPOINT - FORM 2A: (ENTER N/A IF DECREASING SETPOINT)

$$AV = TSp + \sqrt{DA^2 + TA^2}$$

 $AV = 138 + \sqrt{(7.05)^2 + (3)^2}$

+ 2.22

AV = 147.88 , say 148 deg F

11B. FOR DECREASING SETPOINT - FORM 2B: (ENTER N/A IF INCREASING SETPOINT)

$$AV = TSp - \sqrt{DA^2 + TA^2}$$
$$AV = N/A - \sqrt{(N/A)^2 + (N/A)^2}$$

AV = N/A

-

REV_0____DATE _11/17/95____

FORM 3. CALCULATION SHEET

SHEET 19 OF 47

SHEET NO. 4 of 4

Calculation Number 1-N1-115____

Instrument Number _____TS-1291-14C, 14D, 14E, 14F, 14G, 14H, 14J & 14K____

12. OPERATING MARGIN (OM)

12A. FOR INCREASING SETPOINT - FORM 2A: (ENTER N/A IF DECREASING SETPOINT)

OM = TSp - NUL

 $OM = 138 - 105 = 33 \deg F$

12B. FOR DECREASING SETPOINT - FORM 2B: (ENTER N/A IF INCREASING SETPOINT) OM = NLL - TSp

OM = N/A - N/A = N/A

13. RESET VALUE (RV)

13A. FOR INCREASING SETPOINT - FORM 2A: (ENTER N/A IF DECREASING SETPOINT) RV > NUL RV = 133 deg F See note 6 NUL = 105 deg F
13B. FOR DECREASING SETPOINT - FORM 2B: (ENTER N/A IF INCREASING SETPOINT)

RV < NLLRV = N/ANLL = N/A

14. TRIP SETPOINT (TSp) IN PROCESS UNITS

TSs = TSp MODIFIED BY THE FACTORS ACCOUNTING FOR CONVERSION FROM PROCESS UNIT TO SIGNAL UNITS (VOLTS, AMPS, COUNTS, etc.).

TSs = N/A

Rev 0 Date 11/21/95

😼 Boston Edison

Sheet 20 of 47

FORM 4. CALCULATION SHEET

CALCULATION NUMBER ____I-N1-115

CALCULATION WORK OR REMARKS:

References:

- 1. Drawings:
- M-247, Rev. E36 P&ID; RWCU System
- M-312, Rev. E6 HV∾ Reactor Bldg. Aux. Bay
- M-313, Rev. E5 HV∾ Reactor Bldg. Plan El. 51
- M-319, Rev. E4 HV∾ Reactor Bldg. Aux. Bay
- M1N39-13, Rev. E17 Elementary Diagram; Primary Containment Isolation System

2. Pilgrim Unit 1 Specification E-536, Rev. 4; Environmental Parameters for use in the Environmental Qualification of Electrical Equipment (Per 10CFR50.49)

3. PNPS EQ List, Rev. E43

- 4. PNPS Q-List, Rev. E63
- 5. PNPS FSAR, Rev. 16
- 6. PNPS Technical Specification, Rev. 184

7. Boston Edison Co. Equipment Qualification Data Files; TS-1291-14C, TS-1291-14D, TS-1291-14E, TS-1291-14F, TS-1291-14G, TS-1291-14H, TS-1291-14J & TS-1291-14K; Rev. E2

8. PNPS Procedure No.1.3.36, Rev. 13; Measurement and Test Equipment

9. PNPS Procedure No. 8.M.2-1.2.2, Rev. 22; RWCU Area High Temperature Sensors

10. Office Memorandum No. S&SA 95-47, Dated 9/7/95; HPCI, RCIC and RWCU Steam Leak Detection Setpoint Information

Rev 0 Date <u>11/21/95</u>

Boston Edison

Sheet 21 of 47

FORM 4. CALCULATION SHEET

CALCULATION NUMBER _____ I-N1-115_

11. Patel Engineers Technical Report No. PEI-TR-831200-1, Rev. a; Final Report on the Qualification of a Patel Engineers Modified Fenwal Temperature Switch Manufactured by Fenwal Inc. (EQDF Ref. # 340)

12. Patel / EGS Temperature Switch Product Data Sheet, Rev. 11/89 (Attachment 1)

13. ABB Impell Project Instruction No. 25-226-PI-001, Rev. E2; Data Collection and Analysis

14. NEDWI 394, Rev. 3; Methodology for Calculation of Instrument Setpoints

15. U.S. NRC Regulatory Guide 1.105, Rev. 2; Instrument Setpoints for Safety Related Systems

16. Instrument Society of America Standard ISA-67.04-1982; Setpoints for Nuclear Safety Related Instrumentation Used in Nuclear Power Plants

ATTACHMENT 2 TS1291-14C,D,E,F,G,H,J,K DRIFT DATA CALC. NO. I-N1-115 R.O

5h24 of 47

<u></u>	DATA	CAL. DA	TA			RAW DAT	A SUM.	1ST OU	T. SUM.	2ND OU	T. SUM
DATE	STATUS	" "	"D"	INT	REMARKS		"D"	" "	"D"		"D"
5/18/93	AS FOUND	149.2			TS1291-14C						
	AS LEFT	146 1									
7/16/93	AS FOUND	149.2		59		3.10		3.10		3 10	·
	AS LEFT	146.9								0.10	
10/19/93	AS FOUND	145		95		-1.90		-1.90		-1.90	
	AS LEFT	143,3									
1/19/94	AS FOUND	143.3		92		0.00		0.00		0.00	
	AS LEFT	141.7									
4/28/94	AS FOUND	142.1		99		0,40		0.40		0 40	
	AS LEFT	141.2									
7/28/94	AS FOUND	141.7		91		0.50		0.50		0.50	• • • • • • • • • • • • • • • • • • • •
	AS LEFT	141.7			······································						
11/14/94	AS FOUND	142.2		109	······································	0.50		0.50		0.50	i
	AS LEFT	140.3									
2/15/95	AS FOUND	142.1		93		1.80		1.80		1.80	
	AS LEFT	142.3									
5/21/95	AS FOUND	145.2		95		2.90		2.90		2,90	·
	AS LEFT	140.6			· · · · · · · · · · · · · · · · · · ·						
5/18/93	AS FOUND	148.3			TS1291-14D						
	AS LEFT	146.5			and the second						
7/16/93	AS FOUND	152.6		59	······································	6.10		6.10		6.10	
	AS LEFT	144.3									
10/19/93	AS FOUND	141.8		95		-2.50		-2.50		-2.50	
	AS LEFT	140.9									
1/19/94	AS FOUND	146.1		92		5.20		5,20		5 20	
	AS LEFT	144.1									
4/28/94	AS FOUND	142 6		99		-1.50		-1.50	•	-1.50	
	AS LEFT	140.1									
7/28/94	AS FOUND	145 8]	91		5.70		5.70		5.70	
	AS LEFT	140.7									
11/14/94	AS FOUND	145.3		109		4.60		4.60		4,60	
	AS LEFT	145.4									
2/15/95	AS FOUND	145		93		-0.40		-0.40		-0 40	
	AS LEFT	142.9									
5/21/95	AS FOUND	143.9		95		1.00		1.00		1.00	
	AS LEFT	143.5									
5/18/93	AS FOUND	139.3]	TS1291-14E						
	AS LEFT	144.9		[

١

•

Sh 25 of 47

ŧ

7/16/93	AS FOUND	149.3	59		4.40	4.40	4 40
	AS LEFT	144.3		、 、			
10/19/93	AS FOUND	140.9	95		-3 40	-3.40	-3.40
	AS LEFT	144.2					
1/19/94	AS FOUND	145	92		0.80	0.80	0.80
	AS LEFT	142.4					
4/28/94	AS FOUND	139.1	99		-3.30	-3.30	-3.30
	AS LEFT	142.6					
7/28/94	AS FOUND	141.7	91		-0.90	-0.90	-0.90
	AS LEFT	142.4					
11/14/94	AS FOUND	142.8	109		0.40	0.40	0.40
	AS LEFT	143.4					
2/15/95	AS FOUND	143.9	93		0.50	0.50	0.50
	AS LEFT	140.9				,	
5/21/95	AS FOUND	144.9	95		4.00	4.00	4.00
	AS LEFT	145.1					
5/18/93	AS FOUND	146.1		TS1291-14F			
	AS LEFT	146.4					
7/16/93	AS FOUND	147.5	59		1.10	1.10	1.10
	AS LEFT	143.5					
10/19/93	AS FOUND	138.1	95		-5.40	-5.40	-5.40
	AS LEFT	142.5					
1/19/94	AS FOUND	142.9	92		0.40	0.40	0.40
	AS LEFT	143.8					
4/28/94	AS FOUND	140.9	99		-2.90	-2.90	-2.90
•	AS LEFT	144.8					
7/28/94	AS FOUND	146.2	91		1.40	1.40	1.40
	AS LEFT	142.4					
11/14/94	AS FOUND	145.7	109		3.30	3.30	3.30
	AS LEFT	146.7				•	
2/15/95	AS FOUND	145.8	93		-0.90	-0.90	-0.90
	AS LEFT	141.6					
5/21/95	AS FOUND	143.7	95		2.10	2.10	2.10
	AS LEFT	145.7					
5/18/93	AS FOUND	148 8		TS1291-14G			
	AS LEFT	144.6					
7/16/93	AS FOUND	146.8	59		2.20	2.20	2.20
	AS LEFT	143.8					
10/19/93	AS FOUND	147.4	95		3.60	3.60	3.60
	AS LEFT	146.6					
1/19/94	AS FOUND	147.7	92	······································	1.10	1.10	1.10

.

sh 26 of 47

ATTACHMENT 2 TS1291-14C,D,E,F,G,H,J,K DRIFT DATA CALC. NO. I-N1-115 P.O

	AS LEFT	141.5						
4/28/94	AS FOUND	141.2	99		-0.30	-0.30	-0.30	
	AS LEFT	142.5						
7/28/94	AS FOUND	145.4	91		2.90	2.90	2.90	
	AS LEFT	142.1						<u> </u>
11/14/94	AS FOUND	145.1	109		3.00	3.00	3.00	
	AS LEFT	145.9						
2/15/95	AS FOUND	145	93		-0.90	-0.90	-0.90	
	AS LEFT	141.8		·····				
5/21/95	AS FOUND	144.7	95		2.90	2,90	2.90	
	AS LEFT	145.3						r
5/18/93	AS FOUND	153.5		TS1291-14H				
	AS LEFT	143.1						
7/16/93	AS FOUND	144.9	59		1.80	1.80	. 1.80	
	AS LEFT	143.1						
10/19/93	AS FOUND	142.5	95		-0.60	-0.60	-0 60	
	AS LEFT	143.2						
1/19/94	AS FOUND	142.9	92		-0.30	-0.30	-0.30	
	AS LEFT	145.3						
4/28/94	AS FOUND	145.8	99		0.50	0.50	0 50	1
	AS LEFT	140.5						
7/28/94	AS FOUND	142.4	91		1.90	1.90	1.90	
	AS LEFT	145.4			······································			
11/14/94	AS FOUND	143.2	109		-2,20	-2.20	-2.20	
1	AS LEFT	142,3						
2/15/95	AS FOUND	143.2	93		0.90	0.90	0.90	
	AS LEFT	145.5						
5/21/95	AS FOUND	145 6	95		0.10	0.10	0.10	1
	AS LEFT	143.2						
5/18/93	AS FOUND	145.1		TS1291-14J			· · · · · · · · · · · · · · · · · · ·	1
	AS LEFT	147						
7/16/93	AS FOUND	148.2	59		1.20	1.20	1.20	
	AS LEFT	144.7						1
10/19/93	AS FOUND	147.5	95		2.80	2.80	2.80	
	AS LEFT	142.3						
1/19/94	AS FOUND	149.8	92		7.50	7.50	7.50	
	AS LEFT	142.8						
4/28/94	AS FOUND	141.3	99		-1.50	-1.50	-1.50	
	AS LEFT	144.7		······				
7/28/94	AS FOUND	143.6	91		-1.10	-1.10	-1.10	
	AS LEFT	141.4						

.

ATTACHMENT 2 TS1291-14C,D,E,F,G,H,J,K DRIFT DATA CALC. NO. I-N1-115 R.O

Sh	27	٥F	47

11/14/94	AS FOUND	143.8	109		2.40	2.40	2.40	
	AS LEFT	145.3						
2/15/95	AS FOUND	145.1	93	,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,	-0.20	-0.20	-0.20	
	AS LEFT	142						
5/21/95	AS FOUND	143.1	95		1.10	1.10	1 10	
	AS LEFT	144.5						
5/18/93	AS FOUND	144		TS1291-14K				
	AS LEFT	146.5						
7/16/93	AS FOUND	144.3	59		-2.20	-2.20	-2.20	
	AS LEFT	144						
10/19/93	AS FOUND	137.9	95	······	-6.10	-6.10	-6.10	
	AS LEFT	145.1						
1/19/94	AS FOUND	143.4	92		-1.70	-1.70	-1.70	
	AS LEFT	144.2	•				· · · · · · · · · · · · · · · · · · ·	
4/28/94	AS FOUND	144.3	99		0.10	0.10	0.10	
	AS LEFT	141.5						
7/28/94	AS FOUND	142.6	91		1.10	1.10	1.10	
	AS LEFT	143.4						
11/14/94	AS FOUND	143	109		-0.40	-0 40	-0.40	
	AS LEFT	143.4						
2/15/95	AS FOUND	138.5	93		-4,90	-4.90	-4.90	
	AS LEFT	142.7						·····
5/21/95	AS FOUND	140.6	95		-2.10	-2.10	-2.10	
	AS LEFT	146.6						
				· · ·				
							· · · · · · · · · · · · · · · · · · ·	
				AVERAGE	0.62	0 62	0.62	
				STANDARD DEVIATION	2.69	2.69	2.69	
				COUNT	64	64	64	
				% OF ORIGINAL DATA POINT	S	100%	100%	
				95%/95% TOL. INT.DEG F		6.27	6.27	

١

.

ATTACHMENT 3 PATEL/EGS TEMP. SWITCH DRIFT DATA CALC. NO. I-N1-115, Rev. 0 {



	DATA	CAL. DA	<u>AIA</u>			RAW DA	TA SUM.	1ST OU	T. SUM.	2ND OU	T. SUM.
DATE	STATUS		"D"	INT	SERIAL NUMBER		"D"	- nla	"D"		"D"
					•			1			
8/13/86	AS FOUND							1		11	
	AS LEFT	189.5								1	
3/9/89	AS FOUND	194		939	1733	4.50		4.50		4 50	
	AS LEFT										
8/13/86	AS FOUND									<u> </u>	
	AS LEFT	190								1	
3/9/89	AS FOUND	197.2		939	1731	7.20		7.20	****	7.20	
	AS LEFT										
8/13/86	AS FOUND									-	
	AS LEFT	188.5								<u>├</u> ├	
3/9/89	AS FOUND	207		939	1752	18.50		OUTLIER			
	AS LEFT										
8/13/86	AS FOUND									<u> </u>	
	AS LEFT	189.5									
3/9/89	AS FOUND	190		939	1783	0.50	····	0.50		0.50	
	AS LEFT									0,00	
8/13/86	AS FOUND									·	
	AS LEFT	189.5			·						
3/9/89	AS FOUND	187		939	1755	-2.50		-2 50		-2.50	
•	AS LEFT							2.00		-2.00	
8/13/86	AS FOUND									[· · · · · · · · · · · · · · · · · · ·	
	AS LEFT	189					**			<u>├</u>	
3/9/89	AS FOUND	189.9		939	1712	0.90		0.90	· · · · · · · · · · · · · · · · · · ·	0.90	
	AS LEFT									0.00	
8/13/86	AS FOUND									-	
	AS LEFT	189							•	<u> </u>	
3/9/89	AS FOUND	187		939	1718	-2 00		-2 00		-2.00	
	AS LEFT							2.00			
8/13/86	AS FOUND						••			<u> </u> -	
	AS LEFT	189			·····					<u> </u>	
3/9/89	AS FOUND	190		939	1760	1 00		1.00		1.00	
	AS LEFT				1100	1.50		1.00		1.00	
8/13/86	AS FOUND				······					├	
	AS LEFT	190									
3/9/89	AS FOUND	190.5		939	1711	0.50		0.50		0.50	
	AS LEFT							0,00		0.00	·····
8/13/86	AS FOUND										
··	AS LEFT	191		·							

١

.

5h 29 of 47

ATTACHMENT 3 PATEL/EGS TEMP. SWITCH DRIFT DATA CALC. NO. I-N1-115, Rev. 0

3/9/89	AS FOUND	190.9	939	1708	-0.10	-0.10	-0.10	
	AS LEFT				1			
8/13/86	AS FOUND			· · · · · · · · · · · · · · · · · · ·				
	AS LEFT	189.2						
3/9/89	AS FOUND	191.9	939	1769	2.70	2.70	2.70	
	AS LEFT							
8/13/86	AS FOUND							
	ASLEFT	190.5						
3/9/89	AS FOUND	193.3	939	1706	2.80	2.80	2.80	
	AS LEFT							
8/13/86	AS FOUND							
	AS LEFT	191						
3/9/89	AS FOUND	192.1	939	1743	1.10	1.10	1.10	
	AS LEFT			······				
8/13/86	AS FOUND							
	AS LEFT	189.6						
3/9/89	AS FOUND	192.5	939	1728	2.90	2.90	2.90	
	AS LEFT							
8/13/86	AS FOUND							
	AS LEFT	189.8						
3/9/89	AS FOUND	194	939	1726	4.20	4.20	4.20	1
	AS LEFT							=
8/13/86	AS FOUND							
	AS LEFT	189.8						
3/9/89	AS FOUND	191	939	1749	1.20	1.20	1.20	
	AS LEFT							
8/13/86	AS FOUND							
	AS LEFT	190.2						
3/9/89	AS FOUND	190.5	939	1737	0.30	0.30	0.30)
	AS LEFT						<u></u>	
8/14/86	AS FOUND							
	AS LEFT	189						
3/9/89	AS FOUND	191	938	1704	2.00	2.00	2.00)
	AS LEFT							
8/14/86	AS FOUND							
	AS LEFT	191.6						
3/9/89	AS FOUND	194.9	938	1723	3,30	3.30	3.30	?
	AS LEFT					<u> </u>		
8/14/86	AS FOUND							
	AS LEFT	190						. <u> </u>
3/9/89	AS FOUND	192.6	938	1719	2.60	2.60	2.60	<u>'</u>

•

Sh 30 of 47

ATTACHMENT 3 PATEL/EGS TEMP. SWITCH DRIFT DATA CALC. NO. I-N1-115, Rev. 0

	AS LEFT				ſ	T	1	Т
8/14/86	AS FOUND						·	•
•	AS LEFT	190	· · · · · · · · · ·			1	1	
3/9/89	AS FOUND	194	938	1758	4.00	4.00	4.00	;
	AS LEFT							
8/14/86	AS FOUND					<u> </u>	1	
	AS LEFT	191.8				<u> </u>		1
3/9/89	AS FOUND	198.2	938	1714	6 40	6.40	6.40	; †
	AS LEFT							1
8/14/86	AS FOUND							1
	AS LEFT	189.4				<u> </u>		
3/9/89	AS FOUND	189,9	938	1735	0.50	0.50	0.50	1
	AS LEFT						1	
8/14/86	AS FOUND		•				· · ·	1
	AS LEFT	189.2						1
3/9/89	AS FOUND	194	938	1740	4.80	4.80	4.80	1
	AS LEFT							1
8/14/86	AS FOUND							1
	AS LEFT	190.1						1
3/9/89	AS FOUND	199.7	938	1710	9 60	9,60	9.60	1
	AS LEFT							
8/14/86	AS FOUND							-
	AS LEFT	190						1
3/9/89	AS FOUND	199.8	938	1764	9,80	9.80	9.80	,[
	AS LEFT							1
8/14/86	AS FOUND							1
	AS LEFT	188.3				1		
3/9/89	AS FOUND	188	938	1753	-0.30	-0.30	-0.30	,†
	AS LEFT					1		1
8/14/86	AS FOUND							1
_	AS LEFT	191						1
3/9/89	AS FOUND	192.2	938	1722	1.20	1.20	1.20	1
	AS LEFT						1	
8/14/86	AS FOUND							1
	AS LEFT	190.6						†
3/9/89	AS FOUND	189.5	938	1738	-1.10	-1.10	-1.10	1
	AS LEFT							
8/14/86	AS FOUND							<u> </u>
	AS LEFT	190.2						<u> </u>
3/9/89	AS FOUND	195	938	1739	4.80	4.80	4.80	
	AS LEFT			·····				<u> </u>

ì

.

5h 31 0F 47

ATTACHMENT 3 PATEL/EGS TEMP. SWITCH DRIFT DATA CALC. NO. I-N1-115, Rev. 0

					•			
8/14/86	AS FOUND	l						
	AS LEFT	189,9						
3/9/89	AS FOUND	191.9	938	1757	2.00	2.00	2.00	j i i
	AS LEFT							
8/14/86	AS FOUND							
	AS LEFT	189.3						<u> </u>
3/9/89	AS FOUND	188.5	938	1716	-0.80	-0.80	-0.80	,
	AS LEFT				<u></u>			1
8/14/86	AS FOUND							
	AS LEFT	189						1
3/9/89	AS FOUND	192.5	938	1759	3.50	3.50	3.50	1
	AS LEFT							
8/14/86	AS FOUND							
	AS LEFT	190.5	·				· · ·	
3/9/89	AS FOUND	196	938	1763	5.50	5,50	5.50	1
	AS LEFT							1
8/14/86	AS FOUND							1
	AS LEFT	190.9						1
3/9/89	AS FOUND	191.1	938	1727	0.20	0.20	0.20	j
	AS LEFT							1
8/14/86	AS FOUND							1
	AS LEFT	188.3					•	-
3/9/89	AS FOUND	192.5	938	1767	4.20	4.20	4.20	5
·	AS LEFT							
8/14/86	AS FOUND							
	AS LEFT	188					,	1
3/9/89	AS FOUND	192.5	938	1746	4.50	4.50	4.50	1
	AS LEFT							
8/14/86	AS FOUND						•	1
	AS LEFT	189.1						
3/9/89	AS FOUND	193	938	1734	3 90	3.90	3.90	J
	AS LEFT							
8/14/86	AS FOUND							
	AS LEFT	189.5						
3/9/89	AS FOUND	189.6	938	1736	0.10	0.10	0.10	1
	AS LEFT							
8/14/86	AS FOUND							
	AS LEFT	189						
3/9/89	AS FOUND	191.5	938	1777	2.50	2.50	2,50	/
	AS LEFT							
8/14/86	AS FOUND			· · · · · · · · · · · · · · · · · · ·				

i

•

ATTACHMENT 3 PATEL/EGS TEMP. SWITCH DRIFT DATA CALC. NO. I-N1-115, Rev. 0

Sh 32 of 47

•

ì

	ASLEFT	190						1
3/9/89	AS FOUND	189,3	938	1707	-0.70	-0.70	-0.70	1
	AS LEFT	1		l				
8/14/86	AS FOUND	1				†····-	<u> </u>	
	AS LEFT	190.5				<u> </u>		<u> </u>
3/9/89	AS FOUND	187.9	938	1744	-2.60	-2.60	-2.60	<u> </u>
	AS LEFT							
8/14/86	AS FOUND					<u> </u>		
	AS LEFT	189.3		·		<u> </u>		
3/9/89	AS FOUND	190.1	938	1697	0.80	0.80	0.80	
	AS LEFT			·				
8/14/86	AS FOUND					[
	AS LEFT	189.7						
3/9/89	AS FOUND	188.9	938	1725	-0.80	-0.80	-0.80	
	AS LEFT							
8/14/86	AS FOUND					<u>├</u>		
	AS LEFT	189.5				<u> </u>		
3/9/89	AS FOUND	182.9	938	1703	-6.60	-6.60	-6 60	
	AS LEFT							
8/14/86	AS FOUND							
	AS LEFT	189.1			•			
3/9/89	AS FOUND	191.4	938	1771	2.30	2.30	2 30	
	AS LEFT				<u></u>			
8/14/86	AS FOUND							
	AS LEFT	188.1		······		<u> </u>		
3/9/89	AS FOUND	186.5	938	1768	-1.60	-1.60	-1.60	
	AS LEFT			· · · · · · · · · · · · · · · · · · ·				
8/14/86	AS FOUND			······································				
	AS LEFT	191		······································				
3/9/89	AS FOUND	195	938	1778	4.00	4.00	4.00	
	AS LEFT			······································				
8/18/86	AS FOUND			· · · · · · · · · · · · · · · · · · ·				
	AS LEFT	189.6		1				·
3/9/89	AS FOUND	195.9	934	1779	6.30	6.30	6.30	l
	AS LEFT							· · · · · · · · · · · · · · · · · · ·
8/18/86	AS FOUND							
	AS LEFT	189.8						
3/9/89	AS FOUND	190.6	934	1761	0.80	0.80	0.80	
	AS LEFT							·····
8/18/86	AS FOUND							
	AS LEFT	189.3						

5h 33 of 47

ATTACHMENT 3 PATEL/EGS TEMP. SWITCH DRIFT DATA CALC. NO. I-N1-115, Rev. 0

3/9/89	AS FOUND	188.3	934	1705	-1.00	-1.00	-1.00	
·	AS LEFT				·			1
8/18/86	AS FOUND				·	†		
	AS LEFT	190			i			1
3/9/89	AS FOUND	190	934	1721	0.00	0.00	0.00	<u> </u>
	AS LEFT							
8/18/86	AS FOUND					t	[
	AS LEFT	190					{	l
3/9/89	AS FOUND	190	934	1732	0.00	0.00	0.00	<u> </u>
	AS LEFT							
8/18/86	AS FOUND							
	AS LEFT	188.8		·····				
3/9/89	AS FOUND	195.9	934	1774	7.10	7.10	7.10	i
	AS LEFT	í – – – – – – – – – – – – – – – – – – –						
8/18/86	AS FOUND	í					<u> </u>	
	AS LEFT	190					<u> </u>	
3/9/89	AS FOUND	194.2	934	1730	4.20	4.20	4 20	
	AS LEFT	· · · · · ·						
8/18/86	AS FOUND	(·	
	AS LEFT	191.5					·	
3/9/89	AS FOUND	194.5	934	1773	3.00	3.00	3.00	
	AS LEFT	1						ł
8/18/86	AS FOUND	í						
	AS LEFT	191					<u> </u>	
3/9/89	AS FOUND	195.1	934	1700	4.10	4.10	4.10	
	AS LEFT	· · · · · · · · · · · · · · · · · · ·						
8/18/86	AS FOUND	(t						
	AS LEFT	189					<u>├</u> //	
3/9/89	AS FOUND	192.3	934	1766	3.30	3 30	• 3.30	
	AS LEFT							
8/18/86	AS FOUND	·						
<u> </u>	AS LEFT	188						
3/9/89	AS FOUND	193	934	1724	5.00	5.00	5.00	
	AS LEFT			······································			0.00	¦
8/18/86	AS FOUND				ł		i	
	ASLEFT	188.4					¦━	
3/9/89	AS FOUND	193.2	934	1782	4 80	4 80	4 80	
	ASIEFT						7.00	
8/18/86	AS FOUND						·	
0110/00	ASIFET	190.9					/────┤	
3/0/80		107 4			6 50	C 50		
0/0/00		101.4	934		0.00	0,50	0.501	

١

sh 34 of 47

ATTACHMENT 3 PATEL/EGS TEMP. SWITCH DRIFT DATA CALC. NO. I-N1-115, Rev. 0

	AS LEFT								
8/18/86	AS FOUND			<u>enne netter namen en netterne netternetterne</u>					
	AS LEFT	188.6							
3/9/89	AS FOUND	195	934	1780	6.40	6.4	0	6.40	
	AS LEFT								··
8/18/86	AS FOUND			.					
	AS LEFT	189.8							
3/9/89	AS FOUND	191	934	1696	1.20	1.2	20	1.20	
·	AS LEFT								
8/18/86	AS FOUND								
	AS LEFT	190.9		·····					
3/9/89	AS FOUND	195	934	1729	4.10	4.1	0	4.10	
	AS LEFT								
12/17/86	AS FOUND						•		
······································	AS LEFT	190							
3/3/89	AS FOUND	193.9	807	1789	3,90	3.9	0	3.90	
	AS LEFT								
12/17/86	AS FOUND								
	AS LEFT	192							
3/3/89	AS FOUND	188.8	807	1834	-3.20	-3,	20	-3.20	
	AS LEFT	•						1	
12/17/86	AS FOUND								
	AS LEFT	191		· · · · · · · · · · · · · · · · · · ·					
3/3/89	AS FOUND	192.5	807	1825	1.50	1.	50	1.50	
	AS LEFT							1	
12/17/86	AS FOUND								
	AS LEFT	188						1	
3/3/89	AS FOUND	187.1	807	1843	-0.90	-0.	90	-0.90	
	AS LEFT								
12/17/86	AS FOUND								
	AS LEFT	192							
3/3/89	AS FOUND	190 4	807	1899	-1.60	-1.	50	-1.60	
	AS LEFT								
12/17/86	AS FOUND								
	AS LEFT	193		· · · · · · · · · · · · · · · · · · ·					
3/3/89	AS FOUND	191.8	807	1713	-1.20	-1.:	20	-1.20	
	AS LEFT								
12/17/86	AS FOUND								
	AS LEFT	193							
3/3/89	AS FOUND	193.4	807	1841	0.40	0,4	10	0.40	
	AS LEFT								

.

Sh 35 of 47

ATTACHMENT 3 PATEL/EGS TEMP. SWITCH DRIFT DATA CALC. NO. I-N1-115, Rev. 0

v

.

•

12/17/86	AS FOUND							
	AS LEFT	189						
3/3/89	AS FOUND	190.2	807	1829	1.20	1.20	1.20	
	AS LEFT							
12/17/86	AS FOUND							
	AS LEFT	193						-
3/3/89	AS FOUND	191.3	807	1833	-1.70	-1.70	-1.70	
	AS LEFT							
12/17/86	AS FOUND							
	AS LEFT	191						
3/3/89	AS FOUND	192.5	807	1842	1.50	1.50	1.50	
	AS LEFT							
12/17/86	AS FOUND							
	AS LEFT	190						
3/3/89	AS FOUND	198.5	807	1835	8.50	8.50	8.50	
	AS LEFT							
12/17/86	AS FOUND							1
	AS LEFT	191						
3/3/89	AS FOUND	191	807	1827	0 00	0.00	0.00	
	AS LEFT							1
12/17/86	AS FOUND							1
	AS LEFT	190						
3/3/89	AS FOUND	188	807	1826	-2.00	-2.00	-2.00	
	AS LEFT							
12/17/86	AS FOUND							
	AS LEFT	188						
3/3/89	AS FOUND	199.6	807	1822	11.60	11.60	11.60	
1	AS LEFT							
12/17/86	AS FOUND							
	AS LEFT	188					•	
3/3/89	AS FOUND	196	807	; 1933	8.00	8.00	8.00)
	AS LEFT							
12/17/86	AS FOUND							
	AS LEFT	190.2						
3/3/89	AS FOUND	191.6	807	1874	1,40	1.40	1.40)
	AS LEFT							
12/17/86	AS FOUND							
	AS LEFT	192						
3/3/89	AS FOUND	194	807	1875	2.00	2.00	2.00	
	AS LEFT							
12/17/86	AS FOUND							

ATTACHMENT 3 PATEL/EGS TEMP. SWITCH DRIFT DATA CALC. NO. I-N1-115, Rev. 0

٠

.

. 1 -----

3h 36 of 47

	AS LEFT	190						
3/3/89	AS FOUND	190.9	807	1838	0.90	0.90	0.90	
·	AS LEFT							
12/17/86	AS FOUND							1
	AS LEFT	190,8						1
3/3/89	AS FOUND	192	807	1925	1.20	1.20	1.20	
	AS LEFT							
12/17/86	AS FOUND							-
	AS LEFT	192						
3/3/89	AS FOUND	190	807	1839	-2.00	-2.00	-2.00	H
	AS LEFT							1
12/17/86	AS FOUND							1
	AS LEFT	190.5		······································				1
3/3/89	AS FOUND	191.2	807	1830	0.70	0.70	• 0.70	
	AS LEFT							
12/17/86	AS FOUND							
	AS LEFT	189		· · · · · · · · · · · · · · · · · · ·	·			
3/3/89	AS FOUND	190.9	807	1836	1,90	1.90	1.90	
	AS LEFT			······································				
12/17/86	AS FOUND							
	AS LEFT	188 5						
3/3/89	AS FOUND	211	807	1919	22.50	OUTLIER	OUTLIER	
	AS LEFT							1
12/17/86	AS FOUND							
	AS LEFT	189.5						<u> </u>
3/3/89	AS FOUND	189.8	807	1930	0.30	0.30	0.30)
	AS LEFT							1
12/17/86	AS FOUND							
	AS LEFT	190						
3/3/89	AS FOUND	191.4	807	1916	1.40	1.40	1.40	
	AS LEFT							
12/17/86	AS FOUND							
	AS LEFT	189.8						
3/3/89	AS FOUND	192.3	807	1790	2.50	2.50	2.50	
	AS LEFT							
12/17/86	AS FOUND							1
	AS LEFT	188.1						
3/3/89	AS FOUND	189.1	807	1846	1.00	1.00	1.00	<u> </u>
	AS LEFT							<u> </u>
12/17/86	AS FOUND							<u> </u>
	AS LEFT	190						

Sh 37 07 47

ATTACHMENT 3 PATEL/EGS TEMP. SWITCH DRIFT DATA CALC. NO. I-N1-115, Rev. 0

3/3/89	AS FOUND	191.4	807	1854	1.40	1.40	1.40	
	AS LEFT							<u> </u>
12/17/86	AS FOUND		i		!		+	
	AS LEFT	190.8	·					
3/3/89	AS FOUND	199	807	1880	8.20	8.20	8.20	
	AS LEFT	· · · · · · · · · · · · · · · · · · ·						
12/17/86	AS FOUND						<u> </u>	
	AS LEFT	186 8					∤ ∤∤	
3/3/89	AS FOUND	189.6	807	1754	2.80	2.80	2.80	
	AS LEFT							
12/17/86	AS FOUND					····		l
	AS LEFT	189.2					<u> </u>	
3/3/89	AS FOUND	191.6	807	1844	2.40	2.40	2.40	
	AS LEFT		· · ·					
12/17/86	AS FOUND							
	AS LEFT	187.8						í
3/3/89	AS FOUND	194.6	807	1795	6.80	6.80	6.80	i
	AS LEFT							
12/17/86	AS FOUND							
	AS LEFT	192.8						
3/3/89	AS FOUND	191.6	807	1845	-1.20	-1 20	-1 20	
	AS LEFT							
12/17/86	AS FOUND							
	AS LEFT	189	,					l
3/3/89	AS FOUND	193	807	1882	4.00	4.00	4.00	
	AS LEFT					·		
12/17/86	AS FOUND							
	AS LEFT	191						
3/3/89	AS FOUND	194.1	807	1741	3.10	3.10	3.10	
L	AS LEFT						•	·
12/17/86	AS FOUND							
	AS LEFT	186						
3/3/89	AS FOUND	193.1	807	1698	7.10	7.10	7.10	
	AS LEFT							
12/17/86	AS FOUND							
	AS LEFT	188.1						
3/3/89	AS FOUND	190	807	1896	1.90	1.90	1 90	*****
	AS LEFT							
12/17/86	AS FOUND							
	AS LEFT	186.2						
3/3/89	AS FOUND	190.5	807	1848	4.30	4.30	4.30	

•

ATTACHMENT 3 PATEL/EGS TEMP. SWITCH DRIFT DATA CALC. NO. I-N1-115, Rev. 0

.

.

.

٠

	AS LEFT							
12/17/86	AS FOUND							1
	AS LEFT	191						
3/3/89	AS FOUND	188	807	1891	-3.00	-3.00	-3,00	1
	AS LEFT							
				AVERAGE	2.57	2.22	2.22	
				STANDARD DEVIATION	4.04	3.17	3.17	
				COUNT	103	101	101	
				% OF ORIGINAL DATA POINTS		98.1%	98.1%	
				95%/95% TOL. INT.DEG F		7.06	7.06	

-

.

Pilgrim Calculation No. 1-N1-195

Pages 3 thru 26 and 31 and 32

Rev 1____ Date 2/28/97 Soston Edison

Sheet 3 of 34

FORM 4. CALCULATION SHEET

CALCULATION NUMBER I-N1-195

CALCULATION WORK OR REMARKS:

Statement of Problem

This calculation will provide the uncertainty analysis for the development of the RCIC steam line low pressure isolation setpoint. It will determine a plant setpoint and allowable value which will ensure initiation on or before reaching the design basis analytical limits. Other parameters determined by this calculation are:

- Instrument Surveillance Interval
- Measurement and Test Equipment Accuracy
- Calibration No Adjust Limits
- Field Reset Value

Method of solution

This calculation is performed based on the methodology described in Beco NEDWI No. 394 and uses ABB Impell Project Instructions No. 25-226-PI-001 for analysis of the as-found and as-left instrument calibration data. The calculation has been prepared in accordance with the U.S. Nuclear Regulatory Commission Regulatory Guide No. 1.105, Rev. 2 and Instrument Society of America Standard ISA-S67.04-1982.

Input Data and Assumptions

In accordance with PNPS FSAR Sections 7.3.4.7 and 7.3.4.8 the RCIC turbine steam line low pressure switches are utilized to isolate the RCIC turbine steam line so that steam and radioactive gases will not escape from the RCIC turbine shaft seals into the Reactor building after steam pressure has decreased to such a low value that the turbine cannot be operated. This trip is not considered a PCIS function. The mission time of these switches is based upon an accident which RCIC is required to function.

Rev 1 Date 2/28/97 **Boston Edison** Sheet 4 of 34

FORM 4. CALCULATION SHEET

CALCULATION NUMBER I-N1-195

Summary of Results and Recommendations

This calculation determined a new setpoint and Technical Specification allowable value. These values were determined based on plant specific calibration data and NEDWI No. 394 methodology. The sensed instrument setpoint includes margin to account for an instrument line static head of 17.5 psig. The sensed instrument setpoint is equal to the process setpoint plus the instrument line static head.

The results of the calculation are listed below (see note 8):

Trip Setpoint: 70 psig (process pressure) 87.5 psig (instrument sensed pressure)

Technical Specification Allowable Value: 70 ± 7 psig (process pressure) 87.5 ± 7 psig (instrument sensed pressure)

Setpoint Analytical limit: >50 psig, but < 100 psig (process pressure) >67.5 psig, but < 117.5 psig (instrument sensed pressure)

Setpoint Reset Value: ≤79 psig (process pressure) ≤96.5 psig (instrument sensed pressure)

No Adjust Limits: ±5 psig

Surveillance Interval: Once per 24 months

M&TE Accuracy: \pm 1% of full scale

Rev 1 Date 2/28/97 Soston Edison

Sheet 5 of 34

FORM 4. CALCULATION SHEET

CALCULATION NUMBER I-N1-195

This calculation is based on the accuracy specifications of the Static-O-Ring pressure switch model number 6TA-B3-U8-C1A-JJTTNQ and PNPS specific drift data for the Static -O-Ring pressure switch model number 6TA-B3-NX-C1A-JJTTX6 and 6TA-B3-NX-C1A-JJTTX12. These switches are similar in design. The performance data used in the calculation is considered representative of these model numbers

Pressure switch PS1360-9B is a Static-O-Ring model no. 6TA-B3-NX-C1A-JJTTX12 and PS1360-9A, C and D are Barksdale model no. P1H-M85SSV. Replacement of switches PS1360-9A. C and D with Static-O-Ring model no. 6TA-B3-U8-C1A-JJTTNQ or 6TA-B3-NX-C1A-JJTTX12 is required for this calculation to be in effect. The Barksdale switches are being replaced because their setpoint cannot be adjusted to the new value determined by this calculation.

Rev 1 Date 2/28/97

😼 Boston Edison

Sheet <u>6</u> of <u>34</u>

FORM 4. CALCULATION SHEET

CALCULATION NUMBER _____ I-N1-195

Calculation Work Or Remarks:

Notes:

1. RCIC turbine steam line low pressure is used to automatically close the two isolation valves in the RCIC turbine steam line, so that steam and radioactive gases will not escape from the RCIC turbine shaft seals into the reactor building after steam pressure has decreased to such a low value that the turbine cannot be operated. See FSAR Section 7.3.4.7.9. In accordance with FSAR Table 4.7-1 the RCIC Turbine Steam Inlet pressure range is 150 to 1,120 psia. Therefore, to ensure that RCIC is available for the above pressure range the Turbine should not be trip off or restarted greater than 135 psig. The isolation setpoint and reset are chosen at a pressure below that at which the RCIC turbine can operate effectively. This isolation is expected to be operational anytime RCIC is operated including after an accident.

2. The calculation is based on the Static-O-Ring switch model numbers 6TA-B3-U8-C1A-JJTTNQ and 6TA-B3-NX-C1A-JJTTX12. The switches are similar in design and the accuracy data used in this calculation is considered representative of these switches. See SOR Forms # 216 and 651. Presently, switches PS1360-9A,C and D are Barksdale model no. P1H-M85SSV and switch PS1360-9B is a Static-O-Ring model no. 6TA-B3-NX-C1A-JJTTX12. A design change is to be performed which will replace the Barksdale switches with static-o-ring model no. 6TA-B3-U8-C1A-JJTTNQ. Therefore, the results of this calculation are not in effect until the design change has been completed.

3. The Static-O-Ring pressure switch will not experience a pressure effect due to a pipe break outside containment. The maximum ambient pressure due to a steam line break is 15.22 psia. Reference Pilgrim Unit 1 Specification E-536, Figure C.4.1-7 for the pressure profile. This transient will not cause the pressure switch to experience an error because the switch housing is sealed and the sensing element is referenced to the pressure inside the switch housing. Reference Attachment 1. See note 4 for internal housing pressure changes due to ambient temperature variations.

Rev 1 Date 2/28/97

🐉 Boston Edison

Sheet 7 of 34

FORM 4. CALCULATION SHEET			
CALCULATION NUMBER	I-N1-195	<u> </u>	

4. The temperature effect of the Static-O-Ring pressure switch is identified in Attachment 1. The switch setpoint changes as a result of a sealed housing effect and natural temperature influence. This relationship is applicable to the Static-O-Ring pressure switch model numbers 6TA-B3-U8-C1A-JJTTNQ and 6TA-B3-NX-C1A-JJTTX12. The change in setpoint due to a temperature increase from a normal operating temperature of 60 deg. F to the peak accident temperature of 242 deg. F (reference FSAR Table 10.9-1 and Specification E-536, Fig.C.4.1-7) is:

Change in Setpoint = (.04psi/deg F - .0003 x SP psi/deg F)∆ deg F

(.04psig/deg. F)(242-60)deg. F - (.0003/deg. F)(87.5)psig(242-60)deg. F= 2.5 psig

Because the change in setpoint is positive, the error will make the switch trip sooner on a decreasing signal and therefore will be subtracted from the upper Analytical Limit when determining the setpoint.

5. The radiation effect or error is defined as the change in setpoint due to radiation testing. The radiation effect of the Static-O-Ring pressure switch is determined in attachment 2. Six switches were tested. Though the models 6TA-B3-U8-C1A-JJTTNQ and 6TA-B3-NX-C1A-JJTTX12 switches were not included in the switches tested, the test results are representative of these models and can be used in this analysis. The greatest change (error) for a decreasing setpoint in these tests is 2.8% of span. Assuming this error is random and independent of the other errors in this analysis, a value of (+/- .028 * 88 psig = +/- 2.5 psig) is to be used for the radiation effect of the Static-O-Ring switch.

6. The seismic effect or error is defined as the change in setpoint due to seismic testing. The seismic effect of the static-o-ring pressure switch is determined from attachment 2. Six switches were tested. Though the model 6TA-B3-U8-C1A-JJTTNQ and 6TA-B3-U8-C1A-JJTTX12 switches were not included in the test, the results are representative of these models and can be used in this analysis. The greatest change for a decreasing setpoint in these tests is 4% of span. Assuming the error is random and independent of the errors in this analysis, a value of (+/- .04 * 88 psig = +/- 3.5 psig) is to be used for the seismic effect.

Rev 1 Date 2/28/97

😼 Boston Edison

Sheet <u>8</u> of <u>34</u>

FORM 4. CALCULATION SHEET		 	
CALCULATION NUMBER	I-N1-195		

7. The circuit leakage allowance is applicable to low energy analog signals only. The RCIC low pressure switches are mechanical on/off switches. Therefore, this error is not applicable.

8. The RCIC steam line low pressure switches connect to the process at approximately 44'- 6 " elevation in the drywell. Reference drawings M1001 sh 55 and 56 and M100BC21-3. the pressure switches are located in the reactor building and are shown on drawings M15 and M1P355-5. The instrument line drywell penetrations are shown on drawings M1002 sh. 68 and 69. These drawings delineate the instrument line routing and are used to determine equipment elevations in the below static head calculation.

The instrument lines are maintained filled with condensate which creates a static head that is sensed by PS1360-9A, B, C & D. Due to dimensional differences, these four installations have different instrument line static heads. This analysis will use the installation which has the greatest head to determine "Sensed Instrument Setpoint". The sensed instrument setpoint is equal to the process setpoint plus instrument line greatest static head.

The instrument line head is a function of reactor pressure, and drywell and reactor building temperature. The operating conditions which causes the greatest static head will be assumed. The conditions are reactor pressure equal to 50 psig, drywell ambient temperature equal to 120 deg. F and reactor bldg. ambient temperature equal to 60 deg. F (reference Pilgrim Unit 1 Specification E-536, Figure C.4.1-18 and FSAR Table 10.9-1).

Instrument Line Greatest Static Head

Static Head Inside Drywell	= [Process Conn. ElD.W. Pent. El] Density
,	= [45.25′-17.19′] x (61.73 lbs./ cu. ft.) / 144 sq. in. / sq. ft. =12.03 psig
Rev 1 Date 2/28/97

Boston Edison Sheet 9 of 34

.

FORM 4.	CALCUL	ATION	SHEET
	••		••••••

CALCULATION NUMBER _____ I-N1-195

	· ·						
Static Head	= [D.W. Pent. ElInstrument El.] Density						
Outside Drywell	=[17.19′ - 4.583′] x (62.38 lbs./ cu. ft.)/144 sq. in./ sq. ft. = 5.46 psig						
Total Static Head	= 17.5 psig						
The effects on the instrument setpoint of this static head being less than maximum will introduce a nonconservative error between the setpoint and the upper analytical limit. The instrument line installation and operating condition (LOCA) which provides the least static head is calculated below. This value is to be used when determining the instrument line static head error. See Form 3, sheet 3, item 10b.							
The operating condition is reactor pressure equal to 50 psig, drywell ambient temperature equal to 330 deg.F and reactor bldg. ambient temperature equal to 112 deg. F (reference Pilgrim Unit 1 Specification E-536, Figure C.4.1-18 and Table 7.0-1).							
Instrument Line Leas	st Static Head						
Static Head	= [Process Conn. El Drywell Pent. El.] Density						
Inside Drywell	= [44.3' - 17.11'][.14306 lbs./cu. ft.] /144 sq. in. / sq. ft. = .03 psig (Flashing)						
Static Head	= [Drywell Pent. El Inst. El.] Density						
	= [17.11′ - 6.58′][61.84 lbs./ cu. ft.]/144 sq. in. / sq. ft. = 4.52 psig						
Total Static Head	= 4.55psig						

-

Rev 1 Date 228 97

😼 Boston Edison

Sheet 10 of 34

FORM 4.	CALCULATION SHEET
---------	-------------------

CALCULATION NUMBER _____ I-N1-195___

Instrument Line Static Head Error

Error = Maximum Static Head - Minimum Static Head = 17.5 psig - 4.55psig = 13 psig

This error will make the switch trip sooner on a decreasing signal and therefore will be subtracted from the upper Analytical Limit when determining the setpoint.

9. The sensor drift was statistically analyzed in Attachment no. 3 in accordance with ABB Impell Project Instruction 25-226-PI-001. The analysis used empirical data from 6/20/88 through 6/27/96 obtained from the PNPS as-found as-left instrument calibration records (reference PNPS Procedure 8.M.2- 2.6.4). The calibration frequency of the switches for the above data is once per 3 months. The drift interval for the above analysis is 30 months. This interval is determined by combining consecutive surveillance's that do not require interim calibration. The value obtained from the statistical analysis has a probability and confidence of 95/95 %.

The sensor drift determined is considered to include the effects of measurement and test equipment (M&TE) and sensor basic accuracy. Therefore, values will not be entered in this calculation for SCA (calibration accuracy) or SA (sensor accuracy). It is assumed the accuracy of the M&TE used for calibration is less than or equal to the instrument being calibrated (reference PNPS Procedure 1.3.36).

10. The errors identified in this calculation are to be used to determine the setpoint and allowable value. See Form 3, sheets 2 and 3. Because of the instrument line static head, the process setpoint and allowable value are different than the "sensed" instrument setpoint and notify watch engineer value. The relationship between these values are:

Instrument Setpoint = Process Setpoint + Maximum Instrument Line Static Head

Notify Watch Engineer Value = Allowable Value + Maximum Instrument Line Static Head

Rev 1 Date 2/28/97

👙 Boston Edison

Sheet 11 of 34

FORM 4. CALCULATION SHEET

CALCULATION NUMBER _____ I-N1-195

The process setpoint and allowable value are:

Process Setpoint = 70 psig Allowable Value = 70 ± 7 psig

The instrument setpoint and notify watch engineer value are:

Instrument Setpoint = 87.5Notify Watch Engineer Value = 87.5 ± 7 psig



REV_1_ DATE__2/28/97

L.

Calculation Number____I-N1-195____

FORM 1 INSTRUMENT DATA

SHEET 12 OF 34

Instrument Number_PS1360-9A,B,C&D_

Page 1 of 9

	TITLE	DESCRIPTION/VALUE	REFERENCE	REMARKS
	INSTRUMENT NUMBER	PS1360-9A, B, C & D	Dwg. M245 [.]	
	SERVICE DESCRIPTION	RCIC Turb. Steam Line Low Press. Isolation	FSAR Section 7.3.4.8	
	QUALITY CATEGORY	Q	PNPS Q-List	
	ENVIRONMENTAL QUALIFICATION	Yes, EQ Area 1.7	Environmental Qualification Master List	
GENERAL INFORMATION	SAFETY FUNCTION (IF APPLICABLE)	See Note 1	FSAR Section 7.3.4.7.9	
	TECHNICAL SPECIFICATION (IF APPLICABLE)	100 psig >p > 50 psig	Technical Specification Table 3.2.B	
	MANUFACTURER	Static-O-Ring	Data sheet M221ADS7	See Note 2
ì	MODEL NUMBER	6TA-B3-NX-C1A-JJTTX12 & 6TA-B3-U8-C1A-JJTTNQ	Data sheet M221ADS7	See Note 2



REV_1_ DATE_ 2/28/97

Calculation Number I-N1-195

Ł

DAA 1 INICTOURADARNIT

SHEET 13 OF 34

Instrument Number_P\$1360-9A,B,C&D_

FORM I INSTRUMENT DATA				Page 2 of 9			
	TITLE		DESCRIPTION/VALUE	REFERENCE	REMARKS		
	ANALYTIC (A	CAL LIMIT L)	> 50 psig, <100 psig	FSAR Table 7.3-2 S&SA Memo 95-10	See Note1		
	ALLOWAB	SLE VALUE V)	70 ± 7 psig (process pressure)	Form 3, Sheet 3 this calc.	See Note 10		
•	SETPOINT TRIP		70 psig (process press.)	Form 3, Sh. 3 this calc.	See Note 10		
		RESET	< 79 psig (process press.)	Form 3, Sh.4 this calc.			
	NORMAL C UPPER LIN	OPERATION AIT (NUL)	N/A		Decreasing setpoint		
INSTRUMENT SETPOINT DATA	NORMAL C LOWER LI	PERATION MIT (NLL)	940 psig	PNPS Procedure 2.1.1			
	PROCESS CALIBRATED RANGE		Adjustable, 12 TO 100 psig	SOR Inc. Form 216 and 651			
	OPERATING MARGIN (OM)*		870 psig	Form 3 Sheet 4, this calc.			
	*NOTE: ADE OPERATION PROCESS NO	QUATE OPEI UPPER OR LO DISE, TRANSI	RATING MARGIN IS REQUIRED B OWER LIMIT, AS APPLICABLE, TO ENTS AND MEASUREMENT UNC	ETWEEN THE SETPOINT AND T O AVOID INADVERTENT TRIPS ERTAINTIES.	HE NORMAL DUE TO		



REV_1_ DATE 2/28/97

Calculation Number I-N1-195____

FORM 1 INSTRUMENT DATA REMARKS REFERENCE DESCRIPTION/VALUE TITLE SOR Inc. Form 216 12 TO 100 psig and 651 ADJUSTABLE RANGE . **RCIC Steamline** Dwg. M245 INPUT SIGNAL FROM • Instrument is a pressure N/A switch INPUT SIGNAL CALIBRATED RANGE DWG. M1G12-12 **RCIC** automatic isolation **OUTPUT SIGNAL TO** INSTRUMENT SETPOINT DATA (CONT) Instrument is a pressure N/A switch OUTPUT SIGNAL CALIBRATED RANGE

Once per 3 months

plus 25%

SETPOINT

CALIBRATION

FREQUENCY

SHEET 14 OF 34

This calculation is performed

based on a 24 month

calibration frequency. The

Tech. Spec. is to be revised.

PNPS Tech. Spec.

Table 4.2.b and

Section 1.0, u

Instrument Number_P\$1360-9A,B,C&D_

Page 3 of 9



REV_1_ DATE__2/28/97

Calculation Number____I-N1-195_____

ł

FORM 1 INSTRUMENT DATA

SHEET 15 OF 34

Instrument Number_PS1360-9A,B,C&D_

Page 4 of 9

TITLE		DESCRIPTION/VALUE	REFERENCE	REMARKS
	TEMPERATURE EFFECT (Te)	-2.5 psig	Attachment 1	See Note 4
ENVIRONMENT ALLOWANCE (EA) FORM 3 STEP 1	RADIATION EFFECT (Re)	± 2.5 psig	Attachment 2	See Note 5
	STEAM/CHEMICAL SPRAY EFFECT (S/Ce)	N/A		Equipment is environmentally sealed and located in secondary cont.
	PRESSURIZATION (EXTERNAL) EFFECT (Pe)	N/A	Attachment 1	See Note 3
	SEISMIC EFFECT (Se)	±3.5 psig	Attachment 2	See Note 6
•	CABLE LEAKAGE (CI)	N/A		See Note 7
CIRCUIT LEAKAGE ALLOWANCE (LA)	TERMINAL BLOCK	N/A		See Note 7
	PENETRATION LEAKAGE (PI)	N/A		See Note 7



REV_1_ DATE__2/28/97

.

Calculation Number____I-N1-195_____

FORM 1 INSTRUMENT DATA

SHEET 16 OF 34

Instrument Number_PS1360-9A,B,C&D_

Page 5 of 9

TITLE		DESCRIPTION/VALUE REFERENCE		REMARKS		
CIRCUIT LEAKAGE	SPLICE LEAKAGE (SI)	N/A		See Note 7		
ALLOWANCE (LA) (CONTINUED)	SEALING DEVICE LEAKAGE (DI)	N/A		See Note 7		
PROCESS	PROCESS MEASUREMENT	- 13 psig	Dwgs. M1001, Sh 55 & 56; M1002, Sh 68 & 69; M100BC21-3; M1P355-5; M15 and ASME.Stm Table	See Note 8		
ALLOWANCE (PA) FORM 3 STEP 3	PRIMARY ELEMENT ACCURACY (Pea)	N/A		No primary element. Switch directly sensors process.		
	SENSOR CALIBRATION ACCURACY (Sca)	N/A		See Note 9		
(CA) FORM 3 STEP 4		N/A	X	No rack equipment		



2/28/97 REV__1__ DATE___

1

Calculation Number____I-N1-195_____

FORM 1 INSTRUMENT DATA

SHEET 17 OF 34

Instrument Number_PS1360-9A,B,C&D_

Page 6 of 9

TITIE		DESCRIPTION/VALUE	REFERENCE	REMARKS
RACK EQUIPMENT ALLOWANCE (RA) FORM 3 STEP 5	RACK EQUIPMENT ACCURACY (Rea)	N/A		No rack equipment
	RACK TEMPERATURE EFFECTS (Rte)	N/A		No rack equipment
	RACK POWER SUPPLY EFFECTS (Rps)	N/A		No rack equipment
	RACK EQUIPMENT MISCELLANEOUS EFFECTS (Rme)	N/A		No rack equipment



2/28/97 REV___1 ___ DATE____

Calculation Number____I-N1-195_____

FORM 1 INSTRUMENT DATA

SHEET 18 OF 34

Instrument Number_PS1360-9A,B,C&D_

Page 7 of 9

	TITLE	DESCRIPTION/VALUE	REFERENCE	REMARKS
	SENSOR BASIC ACCURACY (Sa)	N/A		See Note 9
	SENSOR STATIC PRESSURE SPAN SHIFT (Ssps)	N/A	•	Sensor is not a differential pressure switch
SENSOR ALLOWANCE (SA)	SENSOR STATIC PRESSURE ZERO SHIFT (Sspz)	N/A		Sensor is not a differential pressure switch
FORM 3 STEP 6	SENSOR TEMPERATURE EFFECTS (Ste)	N/A		Sensor Temperature effect Included In Temperature Effect, Te
	SENSOR POWER SUPPLY EFFECTS (Spse)	N/A		
	SENSOR MISCELLANEOUS EFFECTS (Sme)	N/A		



v

REV_1_ DATE_2/28/97

Calculation Number____I-N1-195_____

sheet<u>19</u>0f<u>34</u>

Instrument Number_P\$1360-9A,B,C&D_

FORM 1	INSTRUMENT DAT	<u>A</u>	Page 8 of 9			
	TITLE	DESCRIPTION/VALUE	REFERENCE	REMARKS		
DRIFT	SENSOR DRIFT (Sd)	±4.7 psig	Attachment 3	95/95 drift value based on 30 months. See note 9		
(DA) . FORM 3 STEP 7	RACK EQUIPMENT DRIFT (Red)	N/A		No rack equipment		
TOLERANCE	SENSOR TOLERANCE (St)	±5 psig	PNPS Procedure 8.M.2-2.6.4			
ALLOWANCE (TA) FORM 3 STEP 8	RACK EQUIPMENT TOLERANCE (Ref)	N/A		No rack equipment		



REV_1___ DATE___2/28/97___

SHEET 20 OF 34

Calculation Number____ I-N1-195____

Instrument Number_PS1360-9A, B, C & D__

FORM 2B CALCULATION INPUT SHEET (DECREASING SETPOINT)

		DESCRIPTION		BBREVI	ATION	I/VALUE*	COMMENTS
			_	NUL	=	N/A	
		NORMAL OPERATING BAND					
	NORMAL OPERATION		<u> </u>	NLL	=	940 PSIG	
		OPERATING MARGIN	-	ОМ RV	=	870 PSIG 96.5 PSIG	
1	TRIP SETPOINT	SENSOR DRIFT	·	TSp** Sd	=	70 PSIG ± 4.7 PSIG	SEE NOTE 10 SEE NOTE 9
	TOLERANCE ALLOWANCE ([A]	RACK EQUIPMENT DRIFT SENSOR TOLERANCE RACK EQUIPMENT TOLERANCE		Red St Ret	= = =	N/A ±5 PSIG N/A	
	ALLOWABLE VALUE			AV**	=	70±7 PSIG	SEE NOTE 10
	ENVIRONMENTAL	TEMPERATURE EFFECT RADIATION EFFECT STEAM/CHEM SPRAY		Te Re S/Ce	8 8 8	- 2.5 PSIG ± 2.5 PSIG N/A	SEE NOTE 4 SEE NOTE 5
	ALLOWANCE (<u>EA</u>)	EFFECT PRESSURIZATION (EXT.) EFFECT		Pe	=	N/A	
T O		SEISMIC EFFECT		Se	=	±3.5 PSIG	SEE NOTE 6
T A L	CIRCUIT LEAKAGE ALLOWANCE (<u>LA</u>)	CABLE LEAKAGE TERMINAL BLOCK LEAKAGE PENETRATION LEAKAGE SPLICE LEAKAGE		CI TI PI SI		N/A N/A N/A N/A	
L O	<u> </u>	SEALING DEVICE LEAKAGE		DI	=	N/A	
O P U	PROCESS ALLOWANCE (<u>PA</u>)	PROCESS MEASUREMENT ACCURACY PRIMARY ELEMENT		Pma Pea	=	- 13 PSIG N/A	SEE NOTE 8
N				<u></u>			
Ë R T	ALLOWANCE (CA)	RACK EQUIPMENT CALIBRATION ACCURACY		Rca	=	N/A N/A	
A 1 N T	RACK EQUIPMENT ALLOWANCE (<u>RA</u>)	RACK EQUIPMENT ACCURACY RACK TEMPERATURE EFFECT RACK POWER SUPPLY EFFECT RACK EQUIPMENT		Rea Rte Rps Rme	= = =	N/A N/A N/A N/A	
Y I	Ļ	MISCELLANEOUS EFFECT					
	SENSOR ALLOWANCE (<u>SA</u>)	SENSOR BASIC ACCURACY SENSOR STATIC PRESSURE SPAN SHIFT SENSOR STATIC PRESSURE ZERO SHIFT SENSOR TEMPERATURE EFFECTS SENSOR POWER SUPPLY EFFECTS SENSOR MISCELLANEOUS FEFECTS		Sa Ssps Sspz Ste Spse Sme		N/A N/A N/A N/A N/A	
<u> </u>			 	AL	=	>50PSIG, BUT < 100 PSIG	

*NOTE: VALUES ARE IDENTIFIED FOR MAGNITUDE ONLY AND ARE COMBINED IN ACCORDANCE WITH THE EQUATIONS ON FORM 3







10. TRIP SETPOINT (TSp) IN PROCESS UNITS 10A. FOR INCREASING SETPOINT - FORM 2A: (ENTER N/A IF DECREASING SETPOINT) TSp = AL - TLU $TSp = N/A_ - N/A_ = N/A_$ 10B. FOR DECREASING SETPOINT - FROM 2B: (ENTER N/A IF INCREASING SETPOINT) UPPER AL LOWER AL $T_{SD} = AL - TLU$ TSp = AL + TLU $T_{sp} = 100 - 23.6 = 76.4$ $TSp = _50_ + _8.1_ = _58.1_$ CHOSE A SETPOINT = 70 PSIG (PROCESS PRESSURE) SEE NOTE 10 11. ALLOWABLE VALUE (AV) 11A. FOR INCREASING SETPOINT - FORM 2A: (ENTER N/A IF DECREASING SETPOINT) $AV = TSp + \sqrt{DA^2 + TA^2}$ $AV = N/A_+ (N/A_)^2 + (N/A_)^2$ AV = N/A11B. FOR DECREASING SETPOINT - FORM 2B: (ENTER N/A IF INCREASING SETPOINT) $AV = TSp - \sqrt{DA^2 + TA^2}$ $AV = _70_- (4.7_)^2 + (5_)^2$ $AV = _70 \pm 6.9$ PSIG; SAY 70 ± 7 PSIG (PROCESS PRESSURE)

REV_1______ DATE 2/28/97

SHEET 24 OF 34

FORM 3. CALCULATION SHEET

SHEET NO. 4 of 4

Calculation Number_____I-N1-195___

Instrument Number _____ PS-1360-9A, B, C & D_____

12. OPERATING MARGIN (OM)

12A. FOR INCREASING SETPOINT - FORM 2A: (ENTER N/A IF DECREASING SETPOINT)

OM = TSp - NUL

 $OM = N/A_ - N/A_ = N/A_$

12B. FOR DECREASING SETPOINT - FORM 2B: (ENTER N/A IF INCREASING SETPOINT) OM = NLL - TSp

OM = _940_ - _70_ = _870 PSIG___ (PROCESS PRESSURE) SEE NOTE 10

13. RESET VALUE (RV)

13A. FOR INCREASING SETPOINT - FORM 2A: (ENTER N/A IF DECREASING SETPOINT) RV > NUL RV = __N/A____ NUL = __N/A

 13B. FOR DECREASING SETPOINT - FORM 2B: (ENTER N/A IF INCREASING SETPOINT)

 RV < NLL</td>

 RV = __<79 PSIG_ (PROCESS PRESSURE)________</td>

 NLL = ___940 PSIG______FROM DATA SHEET M221 ADS7 RESET DIFFERENTIAL GREATEST VALUE

 EQUAL TO 9 PSI
 i.e. RV = SP + RESET DIFF.

14. TRIP SETPOINT (TSp) IN PROCESS UNITS

TSs = TSp MODIFIED BY THE FACTORS ACCOUNTING FOR CONVERSION FROM PROCESS UNIT TO SIGNAL UNITS (VOLTS, AMPS, COUNTS, etc.).

TSs = ____N/A_____ (NOTE: DOCUMENT CONVERSION ON FORM 4)

Rev 1 Date 2/28/97 SBoston Edison

Sheet 25 of 34

FORM 4. CALCULATION SHEET

CALCULATION NUMBER I-N1-195

CALCULATION WORK OR REMARKS:

References

1. Drawings

- M245, Rev. 25 P&ID RCIC System
- M1G2-5, Rev. E9 Function Control Diagram RCIC System
- M1G12-12, Rev. E14 Elementary Digram RCIC System
- M1P355-5, Rev.E3 Arrangement Drawing Leak Detection Instrument Rack 2257
- M1001 Sh. 55, Rev. 5 RCIC System Diff. Press. 1360-1
- M1001 Sh. 56, Rev. 4 RCIC System Diff. Press. 1360-1
- M1002 Sh. 68, Rev. 7 RCIC Instrument Piping to DPIS 1360-1
- M1002 Sh. 69, Rev. 7 RCIC Instrument Piping to DPIS 1360-1
- M100BC21-3, Rev. E3 RCIC Syst. Steam Supply Line to Turbine X-202
- M15, Rev. E17 Equipment Location Reactor Building ٠
- 2. NEDWI 394, Rev. 3; Methodology for Calculation of Instrument Setpoints
- U.S. NRC Regulatory Guide 1.105, Rev. 2; Instrument Setpoints for Safety Related Systems 3.
- 4. Instrument Society of America Standard ISA-67.04-1982; Setpoints for Nuclear Safety Related Instrumentation Used in Nuclear Power Plants
- 5. PNPS FSAR, Rev. 19
- 6. PNPS Technical Specification, Rev. 187
- 7. PNPS Q-List, Rev. E64
- PNPS Equipment Qualification Master List, Rev. E45 8.
- 9. PNPS Procedure No. 1.3.36, Rev. 13; Measurement and Test Equipment

Rev 1 Date 2/28/97 Boston Edison

Sheet 26 of 34

FORM 4. CALCULATION SHEET

CALCULATION NUMBER _____ I-N1-195_

- 10. PNPS Procedure No. 2.1.1, Rev. 83; Startup from Shutdown
- 11. PNPS Procedure No. 8.M.2-2.6.4, Rev. 21; RCIC Steamline Low Pressure
- 12. ABB Impell Project Instruction No. 25-226-PI-001, Rev. E2; Data Collection and Analysis
- 13. SOR Inc. Form No. 216 Rev. 3/90; Pressure Switch by SOR Inc. for Process Applications
- 14. SOR Inc. Form No. 651 Rev. 7/93; SOR 1E Qualified Pressure, Vacuum & Temperature Switches for the Nuclear Power Industry
- 15. Pilgrim Unit 1 Specification E-536, Rev. E5; Environmental Parameters for Use in the Environmental Qualification of Electrical Equipment
- 16. Data Sheet M221ADS7, Rev. 1
- 17. Boston Edison Co. Equipment Qualification Data Files; PS1360-9B; Rev. E3
- 18. SOR Inc. Test Report No. 9058-102, Copyright 1993; Nuclear Qualification Test Report for SOR Pressure , Vacuum, and Temperature Switches (EQDF Ref. 419)

Sheet 31 at 24

ATTACHMENT 3 PS-1360-9B DRIFT DATA CALC. NO. I-N1-195, Rev. 1

	DATA	CAL.	DATA	l l		RAW DA	TA SUM.	1ST OU	T. SUM.	2ND OL	IT. SUM.
DATE	STATUS	սիս	"D"	INT	REMARKS	"D"		"D"	" "	"D"	l "l"
	AS FOUND	76			PS1360-9B						
6/20/88	AS LEFT	76			· · ·					1	
	AS FOUND	76.5			· · · · · · · · · · · · · · · · · · ·						
8/13/88	AS LEFT	76.5									· · · · · · · · · · · · · · · · · · ·
	AS FOUND	76							· · · · ·		
11/13/88	AS LEFT	76			· · · · · · · · · · · · · · · · · · ·						
	AS FOUND	76.6									
2/10/89	AS LEFT	76.6						,			
	AS FOUND	73									
5/14/89	AS LEFT	73									
	AS FOUND	73									
8/14/89	AS LEFT	73									
	AS FOUND	75.4									
11/13/89	AS LEFT	75.4			· · · · · · · · · · · · · · · · · · ·						
	AS FOUND	74									
2/15/90	AS LEFT	74									
	AS FOUND	77									
5/16/90	AS LEFT	77						•			
	AS FOUND	76									
8/22/90	AS LEFT	76									
	AS FOUND	77		889		1.00		1.00		1.00	
11/26/90	AS LEFT	77							·····		
	AS FOUND	77		926		0.50		0.50		0.50	
2/25/91	AS LEFT	77									
	AS FOUND	76.5		955		0.50		0,50		0.50	
6/26/91	AS LEFT	76.5						·····			
	AS FOUND	76		957		-0,60		-0.60		-0.60	
9/25/91	AS LEFT	76									
	AS FOUND	77		961		4.00		4.00		4.00	
12/31/91	AS LEFT	77									
	AS FOUND	75.5		964		2,50		2.50		2.50	
4/4/92	AS LEFT	75.5									
	AS FOUND	74.4		968		-1.00		-1.00		-1.00	
7/8/92	AS LEFT	74.4			· · · · · · · · · · · · · · · · · · ·						
	AS FOUND	73.5		966		-0.50		-0.50		-0.50	
10/8/92	AS LEFT	73,5									
•	AS FOUND	76		979		-1.00		-1.00		-1.00	
1/19/93	AS LEFT	76									

١

1

4

i

sheet 32 of 34

~

ATTACHMENT 3 PS-1360-9B DRIFT DATA CALC. NO. I-N1-195, Rev. 1

	AS FOUND	75.25	1003		-0.75	-0.75	· -0.75	
5/21/93	AS LEFT	75.25						
	AS FOUND	76	1018		-1.00	-1.00	-1.00	
9/9/93	AS LEFT	76						
	AS FOUND	75	1015		-2.00	-2.00	-2.00	
12/6/93	AS LEFT	75						
	AS FOUND	74	989		-2.50	-2.50	-2.50	
3/11/94	AS LEFT	74						
	AS FOUND	73.4	999		-2.60	-2.60	-2.60	
6/20/94	AS LEFT	73.4						
	AS FOUND	79	994		2.00	2.00	2.00	
9/20/94	AS LEFT	79						
	AS FOUND	75.25	991		-0.25	-0.25	-0.25	
12/21/94	AS LEFT	75.25						
	AS FOUND	75	973		0.60	0.60	0.60	
3/8/95	AS LEFT	75						
	AS FOUND	75	995		1.50	1.50	1.50	
6/30/95	AS LEFT	75						
	AS FOUND	76.2	974		0.20	0.20	0.20	
9/20/95	AS LEFT	76.2						
	AS FOUND			SWITCH REPLACED		'		
10/19/95	AS LEFT	76						
	AS FOUND	75						
12/20/95	AS LEFT	75						
	AS FOUND	74.5						
3/26/96	AS LEFT	74.5						
	AS FOUND	73.4						
6/27/96	AS LEFT	73.4				•		
	1			AVERAGE	0.03	0.03	0.03	
				STANDARD DEVIATION	1.69	1.69	1.69	
				COUNT	19	19	19	
				% OF ORIGINAL DATA POINTS		100.00%	100%	
~~~~~				95%/95% TOL, INT.DEG F		4.66	4.66	

5

i.

١

.

### **ATTACHMENT 5**

### SUMMARY OF REGULATORY COMMITMENTS

**---**.

### Summary of Regulatory Commitments

The following table identified those actions committed to by Pilgrim in this document. Any other statements in this submittal are provided for information purposes and are not considered to be regulatory commitments.

	REGULATORY COMMITMENTS	DUE DATE		
1.	Monitor and assess the effects of decreased calibration surveillance intervals on instrument drift and it's effect on safety.	For three (3) calibration intervals.		
2.	Implement changes to the Technical Specifications within 90 days of approval.	90 days following approval of the amendment.		