

November 12, 2002

MEMORANDUM TO: Biweekly Notice Coordinator

FROM: William A. Macon, Jr., Project Manager, Section 2 */RA/*
Project Directorate III
Division of Licensing Project Management

SUBJECT: REQUEST FOR PUBLICATION IN BIWEEKLY FR NOTICE -
NOTICE OF ISSUANCE OF AMENDMENTS TO FACILITY
OPERATING LICENSES (TAC NOS. MB5556 AND MB5557)

Exelon Generation Company, LLC, Docket Nos. 50-373 and 50-374, LaSalle County
Station, Units 1 and 2, LaSalle County, Illinois

Date of application for amendments: July 8, 2002

Brief description of amendments: The proposed amendments would change Appendix A, Technical Specifications (TS), of Facility Operating License Nos. NPF-11 and NPF-18. Specifically, the proposed change adds two footnotes to TS Table 3.3.8.1-1, "Loss of Power Instrumentation," Functions 1.e and 2.e, "Degraded Voltage - Time Delay, LOCA," and makes an editorial change to the heading of TS Table 3.3.8.1-1. The Degraded Voltage - Time Delay, LOCA, function is currently required to be OPERABLE during plant configurations when the ECCS instrumentation that generates the Loss of Coolant Accident (LOCA) signal is not required to be OPERABLE. The proposed changes correct this inconsistency by adding two new footnotes to TS Table 3.3.8.1-i that modify the required OPERABILITY of the Degraded Voltage - Time Delay, LOCA, function.

Date of issuance: November 12, 2002

Effective date: As of the date of issuance and shall be implemented within 30 days.

Amendment Nos.: 155 & 141

Facility Operating License Nos. NPF-11 and NPF-18: The amendments revised the Technical Specifications.

Date of initial notice in FEDERAL REGISTER: August 20, 2002 (67 FR 53986)

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated November 12, 2002.

No significant hazards consideration comments received: No.

Amendment Nos.: 155 & 141

Facility Operating License Nos. NPF-11 and NPF-18: The amendments revised the Technical Specifications.

Date of initial notice in FEDERAL REGISTER: August 20, 2002 (67 FR 53986)

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated November 12, 2002.

No significant hazards consideration comments received: No.

DISTRIBUTION:

Non-Public
PD3-2 r/f
W. Macon
C. Rosenberg

ADAMS Accession Number: ML022950088

OFFICE	PM:LPD3-2	LA:LPD3-2	OGC*	SC:LPD3-2
NAME	WMacon	CRosenberg	RWeisman	LRaghavan for AMendiola
DATE	10/23/02	10/23/02	11/01/02	11/05/02

OFFICIAL RECORD COPY