

OCT 14 2002

LR-N02-0355



U. S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555

Gentlemen:

**MONTHLY OPERATING REPORT  
HOPE CREEK GENERATING STATION  
DOCKET NO. 50-354**

In compliance with Section 6.9, Reporting Requirements for the Hope Creek Technical Specifications, the operating statistics for **September 2002** are being forwarded.

Sincerely,

A handwritten signature in black ink, appearing to read "D. F. Garchow".

D. F. Garchow  
Vice President - Operations

RAR  
Attachments

C Distribution

Handwritten initials "JEG" in black ink, slanted upwards to the right.

DOCKET NO.: 50-354  
 UNIT: Hope Creek  
 DATE: 10/09/02  
 COMPLETED BY: F. Todd  
 TELEPHONE: (856) 339-1316

Reporting Period September 2002

**OPERATING DATA REPORT**

Design Electrical Rating (MWe-Net)  
 Maximum Dependable Capacity (MWe-Net)

No. of hours reactor was critical  
 No. of hours generator was on line (service hours)  
 Unit reserve shutdown hours  
 Net Electrical Energy (MWH)

1083		
1049		
Month	Year-to-date	Cumulative
720	6484	118906
720	6345	116610
0	0	0
737734	6490345	118125953

**UNIT SHUTDOWNS**

NO.	DATE	TYPE F=FORCED S=SCHEDULED	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN THE REACTOR (2)	CORRECTIVE ACTION/ COMMENT

(1) Reason

- A - Equipment Failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory Restriction
- E - Operator Training/License Examination
- F - Administrative
- G - Operational Error (Explain)
- H - Other

(2) Method

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)

DOCKET NO.: 50-354  
UNIT: Hope Creek  
DATE: 10/09/02  
COMPLETED BY: R. Ritzman  
TELEPHONE: (856) 339-1445

### Summary Of Monthly Operating Experience

- Hope Creek began the month at 100% power.
- On September 28, power was reduced to approximately 40% for planned Motor Generator Set Brush Replacement.
- At the end of the month, Hope Creek completed 95 days of continuous on-line operation.

OCT 14 2002

LR-N02-0356



U. S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555

Gentlemen:

**MONTHLY OPERATING REPORT  
SALEM GENERATING STATION UNIT 1  
DOCKET NO. 50-272**

In compliance with Section 6.9, Reporting Requirements for the Salem Unit 1 Technical Specifications, the operating statistics for **September 2002** are being forwarded.

Sincerely,

A handwritten signature in black ink, appearing to read "D. F. Garchow".

D. F. Garchow  
Vice President - Operations

RAR  
Attachments

C Distribution

DOCKET NO.: 50-272  
 UNIT: Salem 1  
 DATE: 10/09/02  
 COMPLETED BY: F. Todd  
 TELEPHONE: (856) 339-1316

Reporting Period September 2002

**OPERATING DATA REPORT**

Design Electrical Rating (MWe-Net)  
 Maximum Dependable Capacity (MWe-Net)

No. of hours reactor was critical  
 No. of hours generator was on line (service hours)  
 Unit reserve shutdown hours  
 Net Electrical Energy (MWH)

1130		
1096		
Month	Year-to-date	Cumulative
720	6393	140620
720	6313	136008
0	0	0
805507	6979449	138262847

**UNIT SHUTDOWNS**

NO.	DATE	TYPE F=FORCED S=SCHEDULED	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN THE REACTOR (2)	CORRECTIVE ACTION/ COMMENT

(1) Reason

- A - Equipment Failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory Restriction
- E - Operator Training/License Examination
- F - Administrative
- G - Operational Error (Explain)
- H - Other

(2) Method

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)

DOCKET NO.: 50-272  
UNIT: Salem 1  
DATE: 10/09/02  
COMPLETED BY: R. Ritzman  
TELEPHONE: (856) 339-1445

**Summary Of Monthly Operating Experience**

- Salem 1 entered the month at approximately 100%.
- There were no reportable power reductions at Salem 1 during September.
- At the end of the month, Salem 1 completed 201 days of continuous on line operation.

OCT 14 2002

LR-N02-0357



U. S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555

Gentlemen:

**MONTHLY OPERATING REPORT  
SALEM GENERATING STATION UNIT 2  
DOCKET NO. 50-311**

In compliance with Section 6.9, Reporting Requirements for the Salem Unit 2 Technical Specifications, the operating statistics for **September 2002** are being forwarded.

Sincerely,

A handwritten signature in black ink, appearing to read "D. F. Garchow".

D. F. Garchow  
Vice President - Operations

RAR  
Attachments

C Distribution

DOCKET NO.: 50-311  
 UNIT: Salem 2  
 DATE: 10/09/02  
 COMPLETED BY: F. Todd  
 TELEPHONE: (856) 339-1316

Reporting Period September 2002

**OPERATING DATA REPORT**

Design Electrical Rating (MWe-Net)  
 Maximum Dependable Capacity (MWe-Net)

No. of hours reactor was critical  
 No. of hours generator was on line (service hours)  
 Unit reserve shutdown hours  
 Net Electrical Energy (MWH)

1131		
1092		
Month	Year-to-date	Cumulative
720	5494	118207
720	5411	114749
0	0	0
774858	5898115	116719656

**UNIT SHUTDOWNS**

NO.	DATE	TYPE F=FORCED S=SCHEDULED	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN THE REACTOR (2)	CORRECTIVE ACTION/ COMMENT

(1) Reason

- A - Equipment Failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory Restriction
- E - Operator Training/License Examination
- F - Administrative
- G - Operational Error (Explain)
- H - Other

(2) Method

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)



DOCKET NO.: 50-311  
UNIT: Salem 2  
DATE: 10/09/02  
COMPLETED BY: R. Ritzman  
TELEPHONE: (856) 339-1445

### Summary Of Monthly Operating Experience

- Salem 2 began the month at 100% reactor power.
- On September 21, power was reduced to approximately 45% to perform planned Turbine Valve Testing. Power was returned to 100% on September 23.
- At the end of the month, Salem 2 completed 136 days of continuous on line operation.