

**Mano K. Nazar**  
**Site Vice President**  
Prairie Island Nuclear Generating Plant  
Nuclear Management Company, LLC  
1717 Wakonade Dr. East • Welch MN 55089

October 14, 2002

US Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, DC 20555

**PRAIRIE ISLAND NUCLEAR GENERATING PLANT**  
Docket Nos. 50-282 License Nos. DPR-42  
Docket Nos. 50-306 License Nos. DPR-60

**Prairie Island Emergency Plan**  
**Implementing Procedures - F3**

**Emergency Response Plan Implementing Procedures**

Furnished with this letter is the Prairie Island Nuclear Generating Plant Emergency Plan Implementing Procedures Temporary Change Addition. This addition includes the following procedures:

**INDEXES:**

**REVISIONS:**


**DELETIONS:**

**TEMPORARY CHANGE ADDITIONS:**

2002 1580 F3-2 Classification of Emergencies

**INSTRUCTIONS:**

Please post changes in your copy of the Prairie Island Nuclear Generating Plant Emergency Plan Implementing Procedures. Procedures, which have been superseded or deleted, should be destroyed. Please sign and return the acknowledgment of this update to Bruce Loesch, Prairie Island Nuclear Generating Plant, 1717 Wakonade Drive East, Welch, MN 55089. If you have any questions, please contact Mel Agen at 651-388-1121 Extension 4240.

  
Mano K. Nazar  
Site Vice President  
Prairie Island Nuclear Generating Plant

AD45

c: USNRC – Steve Orth, Region III (2 copies)  
NRC Resident Inspector (w/o attachment)  
M Agen (w/o attachment)  
Records Management (Doc Control Copy) (w/o attachment)  
NL File (w/o attachment)

Mfst Num: 2002 - 0792  
FROM : Bruce Loesch/Mary Gadiant  
TO : UNDERWOOD, BETTY J

Date : 10/08/02  
Loc : Prairie Island  
Holder : US NRC DOC CONTROL DESK

Copy Num: 515  
SUBJECT : Revisions to CONTROLLED DOCUMENTS

\*\*\*\*\*

Procedure #	Rev	Title
-------------	-----	-------

Temporary Change Additions:  
=====

2002 1580 F3-2

CLASSIFICATIONS OF EMERGENCIES

UPDATING INSTRUCTIONS  
-----

Place this material in your Prairie Island Controlled Manual or File. Remove revised or cancelled material and recycle it. Sign and date this letter in the space provided below within ten working days and return to Bruce Loesch or Mary Gadiant, Prairie Island Nuclear Plant, 1717 Wakonade Drive E., Welch, MN 55089.

Contact Bruce Loesch (ext 4664) or Mary Gadiant (ext 4478) if you have any questions.

Received the material stated above and complied with the updating instructions

\_\_\_\_\_ Date \_\_\_\_\_

**TEMPORARY CHANGE NOTICE**  
(SAWI 1.5.10)

**I. CHANGE REQUEST**

Procedure #: F3-2 Rev: 30 Project ID #: \_\_\_\_\_

WO #: \_\_\_\_\_

Title: Classifications of Emergencies

Description of Change: Condition II: Fires, EAL 11 A on page 36  
(e.g. page #, step #, summary/reason) was changed to include the fire must be confirmed before the fire alarm is considered valid.

Is this an OC reviewed procedure/critical WO? Yes  No

Is a permanent procedure change needed? Yes  No  If Yes, submit PINGP 436

Originator: Mel Rojas Employee #: AGNM01 Date: 10/8/02

**II. INITIAL REVIEWS**

A. Is this a change in intent? Yes  No  If No, go to II B

1. OC Review Initial/Date (if procedure is OC reviewed/critical WO): \_\_\_\_\_

2. Procedure Approver (Work Supv for WO): \_\_\_\_\_

B. 10 CFR 50.59 Review

1. Is this change or procedure exempt from 10CFR 50.59 screening per SAWI 3.3.5, App. A or B? Yes  No  If Yes, go to II.C

2. Complete 50 59 screening per SAWI 3.3.5/PINGP 1229. Screening/Evaluation # \_\_\_\_\_

C. Does this change affect Special Reviews? Yes  No  If Yes, document Special Review(s) in CHAMPS

D. Does this change affect plant operation or Tech Specs? Yes  No  If Yes and work is in progress, SS notified by \_\_\_\_\_ (initial)

E. Do controlled copies need to be updated? Yes  No  If Yes, attach marked-up procedure pages to white copy

F. All master/working copies updated? Yes  NA

G. Is training on temporary change needed? Yes  No  If Yes, PINGP 1268 or PINGP 1224 (Ops Only) issued

**III. REVIEW AND APPROVAL**

Reviewer: D Smith Date: 10-8-02  
(Unit Management Staff)

Approver: W [Signature] Date: 10-8-02  
(Unit Management Staff; SRO for OC reviewed procedures/critical WO)

Forward white copy to Procedure Control

**IV. POST REVIEWS** (required for OC reviewed procedures/critical WO, leave blank if reviewed/approved in II.A)

OC Review Initial/Date: \_\_\_\_\_ Procedure Approver: \_\_\_\_\_ Date: \_\_\_\_\_

**V. TEMPORARY CHANGE DELETION** (leave blank if controlled copies not updated, refer to II.E)

A. Reviewer: \_\_\_\_\_ Date: \_\_\_\_\_  
(Unit Management Staff)

B. Approver: \_\_\_\_\_ Date: \_\_\_\_\_  
(Unit Management Staff; SRO for OC reviewed procedures/critical WO)

White Copy - Procedure Control      Yellow Copy - Attach to procedure

[Signature]  
10/14/02

Condition 11 : Fires

Fire within the plant or ISFSI lasting more than 10 minutes.

(EAL Ref Manual 11A)

Note

FIRE: is combustion characterized by heat and light (flame). Sources of smoke such as slipping drive belts or overheated electrical equipment do not constitute fires. Observation of flame is preferred but is NOT required if large quantities of smoke and heat are observed.

Notification of fire or fire detection alarm in the Control Room

Fire confirmed within the Reactor Bldg., Auxiliary Bldg., Turbine Bldg., Service Bldg., Rad Waste Bldg., Plant Screen House, D5/D6 Bldg., Cooling Tower Equip. House, Transformers, or on the surface of a loaded spent fuel cask in the ISFSI Area

Fire not extinguished within 10-minutes of alarm or notification > 10 minutes

Notification of Unusual Event

