INITIAL SUBMITTAL OF THE WRITTEN EXAMINATION

FOR THE BRAIDWOOD INITIAL EXAMINATION - JULY 2002

Exelon
Nuclear

May 14, 2002
BW020042

James E. Dyer
Regional Administrator
U.S. NRC Region III Administrator
801 Warrenville Road
Lisle, IL 60532-4351

Braidwood Station, Units 1 and 2
Facility Operating License Nos. NPF-72 and NPF-77
NRC Docket Nos. 50-456 and 50-457

Subject: Submittal of Integrated Initial License Training Examination Materials

Enclosed are the examination materials, which Braidwood Station is submitting in support of the Initial License Examination scheduled for the weeks of July 8, 2002 through July 19, 2002, at the Braidwood Station.

This submittal includes the Senior Reactor Operator and Reactor Operator Written Examinations, Job Performance Measures, and Integrated Plant Operation Scenario Guides.

These examination materials have been developed in accordance with NUREG-1021, "Operator Licensing Examination Standards," Revision 8, Supplement 1. Please note that reference materials are attached to each individual examination question or item.

Some minor modifications have been made to the Integrated Examination Outline with regards to the operational scenarios in order to improve balance and content. These changes improve examination quality and are in compliance with NUREG-1021, Revision 8, Supplement 1.

Some modifications or adjustments to the examination material may be required due to procedural changes.

In accordance with NUREG 1021, Revision 8, Supplement 1, Section ES-201, "Initial Operator Licensing Examination Process," please ensure that these materials are withheld from public disclosure until after the examinations are complete.

Should you have any questions concerning this letter, please contact Amy Ferko, Regulatory Assurance Manager, at 815-417-2699. For questions concerning examination materials, please contact Mark Olson at 815-458-7856 or 815-458-7829.

Respectfully,

James D. von Suskil
Site Vice President
Braidwood Station

Enclosures: (Hand delivered to Mike Bielby, Chief Examiner, NRC Region III)

RO/SRO Composite Examination with references attached
Control Room Systems and Facility Walk-Through Job Performance Measures with references attached
Administrative Topic Job Performance Measures with references attached
Integrated Plant Operation Scenario Guides
Completed Checklists:

- Operating Test Quality Checklist (Form ES-301-3)
- Simulator Scenario Quality Checklist (Form ES-301-4)
- Competencies Checklist (Form ES-301-6)
- Written Exam Quality Checklist (Form ES-401-7)
- Examination Security Agreements (Form ES-201-3)
- Record of Rejected KAs (Form ES 401-10)

RO SkyScraper | SRO Skyscraper | RO System/Evolution List | SRO System/Evolution List | Outline Changes

Question Topic Continuous Rod Withdrawal

During power operations, a continuous rod withdrawal accident has resulted in an ATWS situation on Unit 1

Which of the following is REQUIRED to align the PREFERRED method of emergency boration for this event?

a. Open 1CV8104, start the BA transfer pump, check emergency boration flow >30 gpm, verify charging flow >30 gpm

b. Open 1CV112D or 1CV112E, close 1CV112B or 1CV112C, maximize charging flow, isolate letdown

c. Open 1CV110A and 1CV110B, start the BA transfer pump, verify charging flow >30 gpm

d. Open 1SI8801A or 1SI8801B, locally throttle running CV pump discharge valve to match 1FI-917 and letdown flow

Answer a | **Exam Level** B | **Cognitive Level** Memory | **Facility:** Braidwood | **ExamDate:** 7/19/02

KA: 000001A104 AA1.04 **RO Value:** 3.8 **SRO Value:** 3.6 **Section:** EPE **RO Group:** 2 **SRO Group:** 1

System/Evolution Title Continuous Rod Withdrawal

KA Statement: Ability to operate and / or monitor the following as they apply to Continuous Rod Withdrawal
Operating switch for emergency boration motor-operated valve operating switch

Explanation of Answers: (A) is the preferred method (listed first) per 1BwFR-S 1 (B and C) are backup methods listed in FR-S 1 if (A) is unsuccessful. (D) is only an option listed in OA PRI-2

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Functional Restoration - ATWS Procedure	1BwFR-S 1	Step 4	4	1AWOG	

Material Required for Examination

Question Source: New | **Question Modification Method:** | **Used During Training Program**

Question Source Comments

Comment Type	Comment

Reviews Complete
Peer
Supervisory
Facility
NRC

Question Topic Dropped Control Rod

The following plant conditions exist on Unit 1

- Reactor power is 75 %
- Tave is 565 F
- Pressurizer pressure is 2235 psig
- Rod H-8 drops to the bottom of the core
- ROD AT BOTTOM annunciator is LIT

The INITIAL primary plant response to this event is RCS pressure (1) and RCS Tave (2)

	(1)	(2)
a.	Increases	Increases
b.	Decreases	Increases
c.	Increases	Decreases
d.	Decreases	Decreases

Answer d **Exam Level** B **Cognitive Level** Comprehension **Facility:** Braidwood **ExamDate:** 7/19/02

KA: 000003A106 AA1 06 **RO Value:** 4 0 **SRO Value:** 4 1 **Section:** EPE **RO Group:** 2 **SRO Group:** 1

System/Evolution Title Dropped Control Rod

KA Statement: Ability to operate and / or monitor the following as they apply to Dropped Control Rod
RCS pressure and temperature

Explanation of Answers: RCS temperature and pressure will decrease with power immediately following a dropped control rod (D) is Correct

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Dropped or Misaligned Rod	1BwOA ROD-3	Symptoms	1	101	
BwOA ROD-3 Lesson Plan	11-OA-XL-34	II	4	8	2.5

Material Required for Examination

Question Source: New **Question Modification Method:** **Used During Training Program**

Question Source Comments

Comment Type	Comment	Reviews Complete
		Peer
		Supervisory
		Facility
		NRC

2

Question Topic Inoperable/Stuck Control Rod

The following plant conditions exist on Unit 1

- PDMS is inoperable
- Control Bank D Rod D-12 has become misaligned from the rest of the group by 10 steps
- Thermal power is 100% and stable
- QPTR is calculated with N41 has just been determined to be 1.15

If QPTR cannot be reduced to less than 1.10 over the next 48 hours, thermal power will be limited to

a.

b.

c.

d. 77

Answer	b	**Exam Level**	B	**Cognitive Level**	Application	**Facility:**	Braidwood	**ExamDate:**	7/19/02
KA:	000005K101	AK1.01	**RO Value:**	3.1	**SRO Value:**	3.8	**Section:**	EPE	**RO Group:** 1 **SRO Group:** 1

System/Evolution Title Inoperable/Stuck Control Rod 005

KA Statement: Knowledge of the operational implications of the following concepts as they apply to Inoperable/Stuck Control Rod: Axial power imbalance

Explanation of Answers: Per 3.2.4 - reduce power greater than or equal to 3% for each 1% over 1.00. QPTR will be measured Once per 12 hours and thermal power reduced within 2 hours of each determination. (A) is incorrect - the TS is not applicable below 50% power. (C&D) are incorrect, power levels listed are too high. 77% is only a 3% reduction. 70% is only the initial reduction.

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Dropped or Misaligned Rod	1BwOA Rod-3		8.9	101	
Tech Specs	3.2.4		3.2.4-1	110	

Material Required for Examination

Question Source: Facility Exam Bank **Question Modification Method:** Editorially Modified **Used During Training Program**

Question Source Comments

Comment Type	Comment

Reviews Complete

Peer

Supervisory

Facility

NRC

Question Topic Reactor Trip

An east [illegible] has [illegible] required to parallel entry into 1BwEP-0 "Reactor Trip or Safety Injection". During performance of the first step the operator [illegible] the Reactor Trip and Bypass Breakers are open. All Rod Bottom lights are lit. [illegible] nuclear instrumentation indicates [illegible] at the [illegible] DPM start up rate.

What is the NEXT [illegible] of the operator?

a. Manually trip the reactor

b. Verify the [illegible] panel

c. Send an operator to locally verify reactor trip breakers are open

d. Transition to 1BwEP-[illegible] "Response to Nuclear Power Generation/ATWS"

Answer a **Exam Level** B **Cognitive Level** Memory **Facility:** Braidwood **ExamDate:** 7/19/02

KA: 000007K203 EK2.03 **RO Value:** 3.5 **SRO Value:** 3.6 **Section:** EPE **RO Group:** 2 **SRO Group:** 2

System/Evolution Title Reactor Trip 007

KA Statement: Knowledge of the interrelations between Reactor Trip and the following
Reactor trip status panel

Explanation of Answers: Per 1BwEP-0 Step 1, actions are closed bulletted therefore reactor trip breakers must be verified open or the RNO applied to manually trip the reactor. After the manual trip attempt the operators may proceed to step 2 (B incorrect). Transition to FR-S.1 is not required with SUR more negative than -.02 DPM (D incorrect). No provisions are allowed to dispatch an operator to locally verify the status of Reactor Trip Breakers while performing the RNO of step 1 (C incorrect)

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Reactor Trip or Safety Injection	1BwEP-0	Step 1	3	100WO	

Material Required for Examination

Question Source: Facility Exam Bank **Question Modification Method:** Editorially Modified **Used During Training Program**

Question Source Comments 1997 Bwd NRC Exam

Comment Type **Comment**

Reviews Complete
Peer
Supervisory
Facility
NRC

4

RO SkyScraper | SRO Skyscraper | RO System/Evolution List | SRO System/Evolution List | Outline Changes

Question Topic Pressurizer (PZR) Vapor Space Accident: Relief Valve Stuck Open

A large vapor space LOCA has occurred on Unit 1
The operating crew has implemented the appropriate emergency procedure and is currently in 1BwEP-1, Loss of Reactor or Secondary Coolant
The CSFA is monitoring status trees
The following conditions are observed in the Main Control Room:

- Train 'A' CFTCs indicate 720 F
- Train 'B' CFTCs are de-energized
- Thermocouple Map Display on CRT #2 indicates Average CFTCs at 750 F
- RCS indicates 15 psig in the plenum
- RCS pressure is 350 psig

Core cooling is (1) and will be evaluated by performing (2)

	(1)	(2)
a.	ADEQUATE	1BwEP-1, Loss of Reactor or Secondary Coolant
b.	SATURATED	1BwFR-C.3, Response to Saturated Core Cooling
c.	DEGRADED	1BwFR-C.2, Response to Degraded Core Cooling
d.	INADEQUATE	1BwFR-C.1, Response to Inadequate Core Cooling

Answer c **Exam Level** S **Cognitive Level** Comprehension **Facility:** Braidwood **ExamDate:** 7/19/02

KA: 000008A216 AA2.16 **RO Value:** 3.8 **SRO Value:** 4.1 **Section:** EPE **RO Group:** 2 **SRO Group:** 2

System/Evolution Title Pressurizer Vapor Space Accident 008

KA Statement: Ability to determine and interpret the following as they apply to Pressurizer Vapor Space Accident
RCS in-core thermocouple indicators, use of plant computer for interpretation

Explanation of Answers: (C) Correct - given conditions present an ORANGE path on status trees. At >700 F the correct procedure is BwFR-C.2. (A&B) are incorrect as the ORANGE path overrides the normal EOP and a Yellow terminus. (D) Incorrect - >1200 F required for this endpoint.

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Status Trees	1BwST-2		1	WOG 1	

Material Required for Examination 1BwST-2 status tree & Steam Tables

Question Source: Facility Exam Bank **Question Modification Method:** Editorially Modified **Used During Training Program**

Question Source Comments 2001 Bwd NRC

Comment Type **Comment**

Reviews Complete
Peer
Supervisory
Facility
NRC

5

Question Topic [illegible] Pressurizer Vapor Space Accident, Relief Valve Stuck Open

[illegible]

a. Reportable — The PORVs were safety valves challenged

b. Reportable — [illegible] Safety Valves challenged

c. Not Reportable — [illegible] the safety limit

d. Not Reportable — The PORVs are Safety Valves after opening

Answer a **Exam Level** S **Cognitive Level** Application **Facility:** Braidwood **ExamDate:** 7/19/[illegible]

KA: 0000086430 2.4.30 **RO Value:** 2.2 **SRO Value:** 3.6 **Section:** EPE **RO Group:** 2 **SRO Group:** 2

System/Evolution Title Pressurizer Vapor Space Accident 008

KA Statement: Knowledge of which events related to system operations/status should be reported to outside agencies.

Explanation of Answers: Per TS 5.6.4 - Monthly Operating Reports. Document all challenges to the Pzr PORVs or Safety Valves. (A) is correct. (B) Incorrect as the PORVs were challenged and is also reportable. (C&D) Incorrect - it is reportable.

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Tech Specs - Monthly Operating Report	5.6.4		5.6-2	A98	

Material Required for Examination

Question Source: New **Question Modification Method:** **Used During Training Program**

Question Source Comments

Comment Type Comment

Reviews Complete

Peer

Supervisory

Facility

NRC

6

Question Topic [illegible]

[illegible]

Reference [illegible]

a. [illegible]

b. [illegible]

c. [illegible] heated by the [illegible] along the top of the partially filled hot leg pipe

d. [illegible] heated by the [illegible] steam generator tubes and [illegible] along the bottom of each filled hot leg pipe

Answer a **Exam Level** B **Cognitive Level** Memory **Facility:** Brunswick **ExamDate:** 7/19/02

KA: 000009K101 EK1.01 **RO Value:** 4.2 **SRO Value:** 4.7 **Section:** EPE **RO Group:** 2 **SRO Group:** 2

System/Evolution Title Small Break LOCA 009

KA Statement: Knowledge of the operational implications of the following concepts as they apply to Small Break LOCA
Natural circulation and cooling, including reflux boiling

Explanation of Answers: (A) Correct - reflux cooling involves the condensation of steam in the steam generators and draining the resultant liquid back into the Rx core via the hot leg. Occurs after core cooling disrupts natural circulation flow

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Background Documents	E-1	LOCAs	16	1	
Mitigating Core Damage	MTG	LOCA Core Cooling	1-1-89-90		

Material Required for Examination

Question Source: Facility Exam Bank **Question Modification Method:** Editorially Modified **Used During Training Program**

Question Source Comments

Comment Type **Comment**

Reviews Complete

Peer

Supervisory

Facility

NRC

RO SkyScraper | SRO Skyscraper | RO System/Evolution List | SRO System/Evolution List | Outline Changes

Question Topic [illegible]

Rest [illegible]

a. [illegible]

b. [illegible]

c. [illegible]

d. Rapidly depressurizing all Steam Generators to atmospheric pressure

Answer b **Exam Level** R **Cognitive Level** Comprehension **Facility:** Braidwood **ExamDate:** 7/19/02

KA: 000011A210 EA2.10 **RO Value:** 4.5 **SRO Value:** 4.7 **Section:** EPE **RO Group:** 2 **SRO Group:** 1

System/Evolution Title Large Break LOCA 011

KA Statement: Ability to determine and interpret the following as they apply to Large Break LOCA
Verification of adequate core cooling

Explanation of Answers: "Reinitiation of High Head SI is the most effective method to recover the core and restore adequate core cooling" 1BwFR C.1 background document (B) is the correct response

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Background Documents - Inadequate cooling	BwFR C.1	2	2	1	

Material Required for Examination

Question Source: New **Question Modification Method:** **Used During Training Program**

Question Source Comments

Comment Type Comment

Reviews Complete
Peer
Supervisory
Facility
NRC

8

a. [illegible]

b. To remove R[illegible] water to prevent [illegible]

c. To [illegible] circulation [illegible]

d. [illegible] natural circul[illegible]

Answer a

KA: 000011K30[illegible] **Exam Level** B **Cognitive Level** [illegible]

System/Evolution Title EK303 Large Break LOCA **RO Value:** 4.1 **SRO Value:** 4.3 **Section:** EPE **Facility:** Braidwood **ExamDate:**

Statement: Knowledge of the reasons for the following responses as they apply to Large Break LOCA: Starting auxiliary feed pumps and flow, ED/G, and [illegible] pumps

Explanation of Per bkgrd docs - (A) Correct. Since SG's will [illegible] be depressurized, [illegible] will prevent primary to secondary leakage. (B,C,D) Incorrect. Steam generators are not required as a heat sink for [illegible] break LOCAs (temps and pressures typically [illegible]

Reference Title Secondary Coolant [illegible]nts

Facility Reference Number 1BwEP-1 EP-1

Reference Section Step 3 Step 3

Page No. 4 51

Revision [illegible]

L.O. Number [illegible]

Question Modification Method: [illegible]

Used During Training Program

Reviews Complete

Peer

Supervisory

Facility

NRC

RO SkyScraper | SRO Skyscraper | RO System/Evolution List | SRO System/Evolution List | Outline Changes

Question Topic [illegible]

[illegible]

[illegible]

a. [illegible]

b. [illegible]

c. [illegible]

d. [illegible]

Answer [illegible] **Exam Level** B **Cognitive Level** Comprehension **Facility:** Braidwood **ExamDate:** [illegible]

KA: 000017A122 AA1.22 **RO Value:** 4.0 **SRO Value:** 4.2 **Section:** EPE **RO Group:** 1 **SRO Group:** 1

System/Evolution Title Reactor Coolant Pump Malfunctions (Loss of RC Flow) 017

KA Statement: Ability to operate and/or monitor the following as they apply to Reactor Coolant Pump Malfunctions (Loss of RC Flow): RCP seal failure malfunction

Explanation of Answers: Indications are that the No. 1 seal has failed. The operator action summary of 1BwOA RCP-1 states to go to step 12 which states to trip the reactor and the RCP. Due to the high seal leakoff flow, continued monitoring is not the proper action to take. A controlled RCP is required if seal leakoff is high but not above 45 gpm or seal is not affected.

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
RCP Seal Failure	1BwOA RCP-1	OAS			
RCS LP	AP-XL-01				8
RCP Seal Failure LP	01-OA-XL-27		4	10	3

Material Required for Examination

Question Source: Facility Exam Bank **Question Modification Method:** Direct From Source **Used During Training Program**

Question Source Comments 1999 Bwd NRC

Comment Type	Comment	Reviews Complete
		Peer
		Supervisory
		Facility
		NRC

10

Question Topic [illegible]

[illegible]

a. [illegible]

b. [illegible] RCS temperature

c. [illegible] RCS temperature

d. [illegible] letdown relief valve to lift

Answer c **Exam Level** R **Cognitive Level** Comprehension **Facility:** Braidwood **ExamDate:** 7 19 02

KA: 000024A2.06 AA2.06 **RO Value:** 3.6 **SRO Value:** 3.7 **Section:** EPE **RO Group:** 1 **SRO Group:** 1

System/Evolution Title Emergency Boration 024

KA Statement: Ability to determine and interpret the following as they apply to Emergency Boration
When boron dilution is taking place

Explanation of Answers: (C) Correct - CC130 fails open on loss of air, cooling off letdown flow. At lower temperatures, mixed beds have a higher affinity for boron. Less boron in the RCS causes power/RCS temperature to rise. Control rods will step in. (A) Incorrect - letdown temperature will [illegible] and increase. (B) Incorrect - reactivity will increase power and tave. (D) Incorrect - this is a 3 way divert valve and will not [illegible] closed or cause letdown pressure to rise

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Uncontrolled Dilution	1BwOA PRI-12	Symptoms / step 3	4	100	
CVCS LP	11-CV-XL-01 (15a)		9	10	14

aterial Required for Examination

estion Source: Facility Exam Bank **Question Modification Method:** Direct From Source **Used During Training Program**

estion Source Comments 2000 Exam [illegible] 1991 Zion NRC Exam

[illegible] Type **Comment**

Reviews Complete

Peer

Supervisory

Facility

NRC

RO SkyScraper | SRO Skyscraper | RO System/Evolution List | SRO System/Evolution List | Outline Changes

Question Topic [illegible]

[illegible]

a. [illegible]

b. [illegible]

c. 1B&OA PRI 1, [illegible] Boration

d. *1B&OA ROD [illegible] Rod Motion Emergency Borate

Answer [illegible] **Exam Level** [illegible] **Cognitive Level** Application **Facility:** Braidwood **ExamDate:** [illegible] 7/19/02

KA: 0000024G404 2.4.4 **RO Value:** 4.0 **SRO Value:** 4.3 **Section:** EPE **RO Group:** 1 **SRO Group:** 1

System/Evolution Title Emergency Boration 024

KA Statement:

Ability to recognize abnormal indications for system operating parameters which are entry level conditions for emergency and abnormal operating procedures

Explanation of Answers:

(A) Correct - Per *BwEP-0 step 1 RNO, enter 1BwFR-S.1 which will at step 4 direct the crew to emergency borate. (B) Incorrect - There are no entry symptoms for Pri 2 which does not direct a reactor trip. (C) Incorrect - No indications of an uncontrolled dilution [illegible]

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Abnormal Operating Procedure	1BwOA PRI 2, PRI 12, ROD 1	B	1,2	58,100,5	
Emergency Operating Procedure	1BwEP-0	Step 1	3	100	
Functional Restoration Procedure	1BwFR-S.1	Step 4	4	1A	

Material Required for Examination

Question Source: New **Question Modification Method:** **Used During Training Program**

Question Source Comments

Comment Type	Comment
SRO	Assessment of conditions and selection of appropriate procedures

Reviews Complete

Peer

Supervisory

Facility

NRC

12

Question Topic

a.

b.

c.

d.

Answer **Exam Level** B **Cognitive Level** Memory **Facility:** Braidwood **ExamDate:** 7-19-02

KA: 000024K1.04 AK1.04 **RO Value:** **SRO Value:** **Section:** EPE **RO Group:** 1 **SRO Group:** 1

System/Evolution Title Emergency Boration 024

KA Statement: Knowledge of the operational implications of the following concepts as they apply to Emergency Boration
Low temperature limits for boron concentration

Explanation of Answers: (C) Correct - TRM requires 40° to 70° F and 65 F (A&B) Incorrect (D) Incorrect - surveillance for flowpath includes 1112D&E and 1CV8104

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Reactivity Control System	TRM	3.1.1	2	1	

Material Required for Examination

Question Source: New **Question Modification Method:** **Used During Training Program**

Question Source Comments

Comment Type **Comment**

Reviews Complete

Peer

Supervisory

Facility

NRC

13

RO SkyScraper | SRO Skyscraper | RO System/Evolution List | SRO System/Evolution List | Outline Changes

Question Topic [illegible]

[illegible]

a. [illegible]

b. [illegible]

c. [illegible]

d. [illegible]

Answer [illegible] **Exam Level** [illegible] **Cognitive Level** Application **Facility:** [illegible] **ExamDate:** 7/19/02

KA: 000025K203 AK2.03 **RO Value:** 2.7 **SRO Value:** 2.7 **Section:** EPE **RO Group:** 2 **SRO Group:** 2

System/Evolution Title Loss of Residual Heat Removal System 025

KA Statement: Knowledge of the interrelations between Loss of Residual Heat Removal System and the following: Service water or closed cooling water pumps

Explanation of Answers: (D) Correct. With 1FT619 failing low, more flow will be demanded from flow control valve 619, more flow will bypass the RH Heat Exchanger, less RCS flow through the heat exchanger will decrease the RCS cooldown rate. Less heat is transferred to CCW and CCW temps increase.

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Normal Operating Procedures - RH Cooling	B.O.P. RH-6	F	14-15	26	
Bwd Big Notes	RH-1 RHR Cooldown		1	3	

Material Required for Examination

Question Source: New **Question Modification Method:** [illegible] **Used During Training Program** [illegible]

Question Source Comments

Comment Type **Comment**

Reviews Complete

Peer

Supervisory

Facility

NRC

14

RO SkyScraper | SRO Skyscraper | RO System/Evolution List | SRO System/Evolution List | Outline Changes

Question Topic [illegible]

[illegible]

[illegible]

[illegible]

a.	[illegible]	RCP bearing temperatures have been exceeded due to a loss of cooling flow
b.	[illegible] the RCS cooldown rate	CCW heat exchanger temperatures have exceeded design limits allowed for RCS cooldown
c.	Manually actuate SI per 1BwEP-0	A loss of all Component Cooling Water has occurred on Unit 1
d.	Start additional CCW pumps	More flow is required through the CC Heat Exchanger to control CCW temperatures

Answer b **Exam Level** S **Cognitive Level** Comprehension **Facility:** Braidwood **ExamDate:** 7/19/02

KA: 000026A204 AA2.04 **RO Value:** 2.5 **SRO Value:** 2.9* **Section:** EPE **RO Group:** 1 **SRO Group:** 1

System/Evolution Title Loss of Component Cooling Water 026

KA Statement: Ability to determine and interpret the following as they apply to Loss of Component Cooling Water
The normal values and upper limits for the temperatures of the components cooled by SWS

Explanation of Answers: (A) Incorrect - RCP bearing temperatures are well within limits. Motor bearings < 195 F, lower radial bearing < 225 F, Seal outlet < 235 F. (B) Correct - per 1BwOA PRI-6, with CC suction temp and discharge temps in alarm, heat exchanger outlet will be > 120 F which is max allowed by TS (Section 3.7.7). Reduce the cooldown rate of the RCS. (C) Incorrect - No SI criteria has been met, a total loss of CC is not occurring. (D) Incorrect - increasing CC flow through one heat exchanger will only serve to increase the RCS cooldown, contrary to actions required in OA PRI-6.

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Component Cooling Malfunction	1BwOA PRI-6	Main Body	6,7	100	
Annunciator Response Procedures	1,2 C5&D5, 1,2 E3&E5	Cause/Actions	1	vari	
Tech Spec	Bases	3.7.7	7-3	0	

Material Required for Examination

Question Source: New **Question Modification Method:** **Used During Training Program**

Question Source Comments

Comment Type	Comment
SRO	[illegible]

Reviews Complete

Peer

Supervisory

Facility

NRC

15

Question Topic [illegible]

[illegible]

[illegible]

[illegible]

a.	[illegible]	[illegible]
b.	[illegible]	[illegible]
c.	[illegible]	[illegible]
d.	1BwOA [illegible] Loss of AIAC [illegible]	All ECCS and safe shutdown loads must be stopped [illegible] from starting

Answer c **Exam Level** S **Cognitive Level** Application **Facility:** Braidwood **ExamDate:** 7/19/02

KA: 0000026G404 2.4.4 **RO Value:** 4.0 **SRO Value:** 4.4 **Section:** EPE **RO Group:** 1 **SRO Group:** 1

System/Evolution Title Loss of Component Cooling Water 026

KA Statement:

Ability to recognize abnormal indications for system operating parameters which are entry level conditions for emergency and abnormal operating procedures

Explanation of Answers: (C) Correct - symptoms are of decreasing surge tank level and [illegible] of a running CC pumps. Operators are directed to enter PRI 6 for the CC malfunction and EP 6 if the surge tank decreases to [illegible] to trip the reactor and step 1 RCPs. (A) incorrect - leakage [illegible] making this a lesser priority. (B) incorrect - the loss of thermal barrier [illegible] components [illegible] is maintained. (D) incorrect - ECCS safe shutdown loads are cooled by SX.

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Component Cooling Malfunction	1BwOA PRI 6	Attachment A	50	100	
Annunciator Response	BwAR 1 2 A4 A5 E 4	Operator Actions	1		

Material Required for Examination

Question Source: New **Question Modification Method:** **Used During Training Program**

Question Source Comments

Comment Type	Comment
[illegible]	[illegible]

Reviews Complete

Peer

Supervisory

Facility

NRC

10

Question Topic [illegible]

[illegible]

a. [illegible]

b. [illegible]

c. [illegible]

d. [illegible]

Answer a **Exam Level** B **Cognitive Level** Application **Facility:** Braidwood **ExamDate:** 7/19/92

KA: 000027K1.03 AK1.03 **RO Value:** 2.5 **SRO Value:** 2.9 **Section:** EPE **RO Group:** 1 **SRO Group:** 2

System/Evolution Title Pressurizer Pressure Control Malfunctions 027

KA Statement: Knowledge of the operational implications of the following concepts as they apply to Pressurizer Pressure Control Malfunction: Latent heat of vaporization/condensation

Explanation of Answers: (A) Correct - load decrease causes an insurge into the Pzr as RCS heats up and expands. insurge compresses the Pzr bubble, raising pressure slightly above saturation. Condensation occurs which tends to limit the pressure rise. (B) incorrect - steam condenses with the pressure rise. (C) incorrect - [illegible] and expansion insurge of RCS into pzr

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Pzr Lesson Plan	11 RY XL 01	Review Qs	61	2	29

Material Required for Examination

Question Source: New **Question Modification Method:** **Used During Training Program**

Question Source Comments

Comment Type **Comment**

Reviews Complete

Peer

Supervisory

Facility

NRC

RO SkyScraper | SRO Skyscraper | RO System/Evolution List | SRO System/Evolution List | Outline Changes

Question Topic [illegible]

[illegible]

a. [illegible]

b. [illegible]

c. [illegible]

d. [illegible]

Answer c **Exam Level** S **Cognitive Level** Memory **Facility:** Braidwood **ExamDate:** 7/19/02

KA: 000036A203 AA2.03 **RO Value:** 3.[illegible] **SRO Value:** 4.[illegible] **Section:** EPE **RO Group:** 3 **SRO Group:** 3

System/Evolution Title Fuel Handling Incidents 036

KA Statement: Ability to determine and interpret the following as they apply to Fuel Handling Incidents:
Magnitude of potential radioactive release

Explanation of Answers: Per TRM 3.9.d (Old TS 3.9.7) Crane travel with loads in excess of 2000 lbs is limited to ensure in the event the load is dropped the activity release will be limited to that contained in a single fuel assembly and possible distortion of or fuel in the racks will not result in a criticality.

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Refueling Operations	TRM	3.9.d	[illegible]	[illegible]	
TS (old) Bases	TS 3.4.9.2	Bases	9.2	A25	

Material Required for Examination

Question Source: New **Question Modification Method:** **Used During Training Program**

Question Source Comments

Comment Type	Comment
SRO	TS Basis

Reviews Complete

Peer

Supervisory

Facility

NRC

Question Topic [illegible]

[illegible]

a. [illegible]

b. [illegible]

c. [illegible]

d. [illegible]

Answer b **Exam Level** R **Cognitive Level** Memory **Facility:** Brunswick **ExamDate:** 7/19/02

KA: 000036K302 AK3.02 **RO Value:** 2.9 **SRO Value:** 3.6 **Section:** EPE **RO Group:** 3 **SRO Group:** 3

System/Evolution Title Fuel Handling Incidents 036

KA Statement: Knowledge of the reasons for the following responses as they apply to Fuel Handling Incidents: Interlocks associated with fuel handling equipment

Explanation of Answers: (A) incorrect - Gripper will not open when closed unless it senses > 1200 lbs. (B) Correct - per LP. (C) Incorrect - weight restriction is >2700 lbs. (D) Incorrect - there are 2 slow zones, at +/- 10" top and bottom. None in the middle

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Fuel Handling	H-FH-XU-01	II	20-22	52	6

Material Required for Examination

Question Source: New **Question Modification Method:** **Used During Training Program**

Question Source Comments

Comment Type **Comment**

Reviews Complete

Peer

Supervisory

Facility

NRC

Question Topic [illegible]

[illegible]

a. [illegible]

b. [illegible]

c. [illegible]

d. [illegible]

Answer a **Exam Level** B **Cognitive Level** Memory **Facility:** Brunswick **ExamDate:** 7/19/02

KA: [illegible] **RO Value:** [illegible] **SRO Value:** [illegible] **Section:** EPE **RO Group:** [illegible] **SRO Group:** 2

System/Evolution Title Steam Generator Tube Leak 037

KA Statement: Knowledge of the reasons for the following responses as they apply to Steam Generator Tube Leak
Maximum load change capability of facility

Explanation of Answers: A. Correct. Steam dumps will absorb a 40% load rejection, which is essentially the situation in question. 10% more can be absorbed by the rods (10 + 40 = 50) but that is not a distractor. Anything higher will result in opening of the SG PORV's

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Horse Notes - Steam Dumps	MS-4 Main Steam Dumps	Purpose			

Material Required for Examination

Question Source: Facility Exam Bank **Question Modification Method:** Direct From Source **Used During Training Program**

Question Source Comments [illegible] Bwd NRC

Comment Type **Comment**

Reviews Complete

Peer

Supervisory

Facility

NRC

20

Question Topic [illegible]

[illegible]

[illegible]

a. [illegible]

b. [illegible]

c. [illegible]

d. [illegible]

Answer a **Exam Level** B **Cognitive Level** C (Comprehension) **Facility:** Braidwood **ExamDate:** 7/19/02

KA: 000038A124 EA1.24 **RO Value:** 3.6* **SRO Value:** 3.4 **Section:** EPE **RO Group:** 2 **SRO Group:** 2

System/Evolution Title Steam Generator Tube Rupture 038

KA Statement: Ability to operate and/or monitor the following as they apply to Steam Generator Tube Rupture
Safety injection pump ammeter and indicators

Explanation of Answers: (A) Correct - per the reference document, SI must be terminated when conditions are reached in order to prevent SG overfill. (B) Incorrect - with only 1 SI pump the repressurization would be slow, and only reach the shutoff head of the SI pump which is ~1500 [illegible] (C) Incorrect - [illegible] with all RCP's running. The amount of RCS [illegible] at the time of SI termination is set by the operators use of steam release and not dependent on Safflow. (D) Incorrect - SI pumps have recirc lines open to the RWST.

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
WOG background document	1EAE P-3				

Material Required for Examination

Question Source: Facility Exam Bank **Question Modification Method:** Significantly Modified **Used During Training Program**

Question Source Comments

Comment Type	Comment

Reviews Complete

Peer

Supervisory

Facility

NRC

21

RO SkyScraper | SRO Skyscraper | RO System/Evolution List | SRO System/Evolution List | Outline Changes

Question Topic

a.

b.

c.

d.

Answer b **Exam Level** S **Cognitive Level** Application **Facility:** [illegible] **ExamDate:** 7/19/02

KA: 000038A211 EA 11 **RO Value:** 3.7 **SRO Value:** [illegible] **Section:** EPE **RO Group:** 2 **SRO Group:** 2

System/Evolution Title Steam Generator Tube Rupture 0.38

KA Statement: Ability to determine and interpret the following as they apply to Steam Generator Tube Rupture
Local radiation reading on main steam lines

Explanation of Answers: TS Limit for SG Tube Leakage is 150 gpd through any 1 SG. (B) Correct - a 1 mr/hr increase over background will yield an estimated leak rate of 150 gpd per 1BwOS SG 1, Fig 2. (A) incorrect - yields about 75 gpd est. (C) Incorrect - than the minimum of 8 at 225 [illegible] (D) Incorrect - [illegible] of 8 at 900 gpd

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Steam Generator Leakage Estimation	1BwOS SG 1	E, Figure 2	4	4	
Tech Specs - Operational Leakage	2.4.13	LCO	3.4.13-1	A98	

Material Required for Examination 1BwOS SG 1SG Leakage Estimation - Figure 2 (page 12)

Question Source: New **Question Modification Method:** **Used During Training Program**

Question Source Comments

Comment Type **Comment**

Reviews Complete

Peer

Supervisory

Facility

NRC

Question Topic [illegible]

[illegible]

a. [illegible]

b. [illegible]

c. 1B&EP-2 [illegible]

d. 1B&C-A-2.1 [illegible]

Answer c **Exam Level** R **Cognitive Level** Application **Facility:** Braidwood **ExamDate:** 7/19/02

KA: 000340G404 2.4.4 **RO Value:** 4.0 **SRO Value:** 4.3 **Section:** EPE **RO Group:** 1 **SRO Group:** 1

System/Evolution Title Steam Line Rupture 040

KA Statement:

Ability to recognize abnormal indications for system operating parameters which are entry level conditions for emergency and abnormal operating procedures

Explanation of Answers: Per 1B&EP [illegible] Correct. [illegible] SG pressure is decreasing in an uncontrolled manner. At this point in E-0 there is no controlled RCS cooldown in progress yet. [illegible] Incorrect. [illegible] pressure are normal post trip readings. (A&D) Incorrect - [illegible]

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Reactor Trip or Safety Injection	1B&EP-0		22-23	100wog1	

Material Required for Examination

Question Source: New **Question Modification Method:** [illegible] **Used During Training Program**

Question Source Comments

Comment Type **Comment**

Reviews Complete

Peer

Supervisory

Facility

NRC

23

Question Topic [illegible]

[illegible]

a. [illegible]

b. [illegible]

c. [illegible]

d. [illegible]

Answer a **Exam Level** B **Cognitive Level** Memory **Facility:** Brunswick **ExamDate:** [illegible]

KA: 000054A104 AA1.04 **RO Value:** 4.4 **SRO Value:** 4.4 **Section:** EPE **RO Group:** 2 **SRO Group:** 2

System/Evolution Title Loss of Main Feedwater 054

KA Statement: Ability to operate and/or monitor the following as they apply to Loss of Main Feedwater: HPI, under total feedwater loss conditions.

Explanation of Answers: (A) Correct - per H.1 background documents. Early bleed and feed allows maximum RCS pressure drop, greater SI flow rates and ensures effective heat removal. The further the transient is allowed to progress before bleed and feed is initiated, the smaller the [illegible]

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Functional Restoration Procedures	1BwFR-H.1	OAS Steps	3	106	
Background Documents	1BwFR-H.1	Bleed & Feed	34,35	1	

Material Required for Examination

Question Source: Facility Exam Bank **Question Modification Method:** Editorially Modified **Used During Training Program**

Question Source Comments 1998 Submitted to NRC

Comment Type **Comment**

Reviews Complete

Peer

Supervisory

Facility

NRC

RO SkyScraper | SRO Skyscraper | RO System/Evolution List | SRO System/Evolution List | Outline Changes

Question Topic

a. [illegible] Train A

b. [illegible] Train B

c. 242 to 142 Train A

d. 242 to 142 Train B

Answer b **Exam Level** S **Cognitive Level** Application **Facility:** Brunswick **ExamDate:** 7/19/02

KA: 000055A203 EA2.03 **RO Value:** 3.9 **SRO Value:** 4.7 **Section:** EPE **RO Group:** 1 **SRO Group:** 1

System/Evolution Title Station Blackout 055

KA Statement: Ability to determine and interpret the following as they apply to Station Blackout
Actions necessary to restore power

Explanation of Answers: (B) Correct - per 2BwCA 0.3 "It is preferred to prepare 4KV ESF Bus 241 for the Unit 1 crosstie to support the motor driven AF Pump availability." (A) Incorrect - bus selections OK, but Unit 2 must align Train B loads to support Unit 1 operation. (C&D) Incorrect - 242 would be preferred because power [illegible]

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Response to Opposite Unit Loss of AC	2BwCA 0.3	Step 4 NOTE	4	1WOG1	

Material Required for Examination

Question Source: New **Question Modification Method:** **Used During Training Program**

Question Source Comments

Comment Type	Comment
SRO	Assessment of conditions [illegible]

Reviews Complete
Peer
Supervisory
Facility
NRC

Question Topic [illegible]

a. [illegible]

b. [illegible]

c. [illegible]

d. [illegible] ACB 14*4

Answer C **Exam Level** R **Cognitive Level** Apply **Facility:** Brad Wood **ExamDate:** 7-19-02

KA: 000055A2.04 E A2.04 **RO Value:** 3.7 **SRO Value:** 4.1 **Section:** EPE **RO Group:** 1 **SRO Group:** 1

System/Evolution Title Station Blackout 055

KA Statement: Ability to determine and interpret the following as they apply to Station Blackout: Instruments and controls operable with only the battery power available

Explanation of Answers: DC power supplies 125VDC for both ESF divisions including Rx trip switchgear. MCB ESF section ESF switchgear control systems. MSIVs will close (immerse) phase A will reset. ACB 14*4 will close. (A B D) Incorrect. (C) Correct - 1CC685 is a motor operated valve and [illegible]

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Loss of All AC Power	13AC A 0 C		2 5	8	
Bwd Brq Notes - 125 VDC System	DC 1			3	

Material Required for Examination

Question Source: New **Question Modification Method:** **Used During Training Program**

Question Source Comments

Comment Type **Comment**

Reviews Complete

Peer

Supervisory

Facility

NRC

RO SkyScraper | SRO Skyscraper | RO System/Evolution List | SRO System/Evolution List | Outline Changes

Question Topic

a.

b.

c.

d.

Answer **Exam Level** **Cognitive Level** Memory **Facility:** **ExamDate:** 7/19/02

KA: 000055G430 2.4.30 **RO Value:** **SRO Value:** 3.6 **Section:** EPE **RO Group:** 1 **SRO Group:** 1

System/Evolution Title Station Blackout 055

KA Statement:

Knowledge of which events related to system operations status should be reported to outside agencies

Explanation of Answers: Per EP AA-114 "Notifications" - offsite notifications must be made within 15 minutes of any classification level change. (A) is only Correct time frame

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Notifications	EP AA-114	4.1.1	1	1	

Material Required for Examination

Question Source: New **Question Modification Method:** **Used During Training Program**

Question Source Comments

Comment Type	Comment
SRO	Assessment of conditions

Reviews Complete

Peer

Supervisory

Facility

NRC

Question Topic

a.

b.

c.

d.

Answer c **Exam Level** B **Cognitive Level** Memory **Facility:** Braidwood **ExamDate:** 7/19/0[illegible]

KA: 000058K302 AK3.02 **RO Value:** 4.0 **SRO Value:** 4.2 **Section:** EPE **RO Group:** 2 **SRO Group:** 2

System/Evolution Title Loss of DC Power 058

KA Statement: Knowledge of the reasons for the following responses as they apply to Loss of DC Power: Actions contained in EOP for loss of dc power

Explanation of Answers: (C) Correct - the main generator remains connected to the UAT 4KV bus 143 and to 9 bus 157 will have lost breaker control power and cannot ABT. They will remain energized, will all attendent loads, from the main generator as long as the PMG remains closed. As the generator slows, voltage and frequency drops. (A) Incorrect - although 1A RCP remains energized, it will not reverse direction. (B) Incorrect - steam dumps fail closed and are not affected by DC 111. (D) Incorrect - feedwater isolation valves fail closed and are controlled via the ESF DC Busses 111 and 112

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Abnormal Operation Procedures	1BwOAE-EC-1	Attachment A	3	100	
Bwd Big Notes	DC-1		1	3	
BwOAE-EC-1 Lesson Plan	1BOAC-EC-1	II	2	6	3.4

Material Required for Examination

Question Source: Facility Exam Bank **Question Modification Method:** Significantly Modified **Used During Training Program**

Question Source Comments

Comment Type **Comment**

Reviews Complete

Peer

Supervisory

Facility

NRC

Question Topic

a.

b.

c.

d.

Answer a **Exam Level** B **Cognitive Level** Memory **Facility:** Braidwood **ExamDate:** 7/19/02

KA: 000060K2.02 AK2.02 **RO Value:** 2.7 **SRO Value:** 3.1 **Section:** EPE **RO Group:** 2 **SRO Group:** 2

System/Evolution Title Accidental Gaseous Radwaste Release 060

KA Statement: Knowledge of the interrelations between Accidental Gaseous Radwaste Release and the following: Auxiliary building ventilation system

Explanation of Answers: Hi rad interlock from 0RT AR055 provides for auto start of the EHB Charcoal Booster Fan, auto opening of the charcoal absorber inlet (and outlet) dampers, and auto closure of the charcoal absorber bypass damper. (a) is the only correct answer

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Normal Operating Procedures	BwOP AR PR 1 T1	Interlock functions	4	9	
Annunciator Response	BwAR 4 0AR055J	B	1	1	
AR PR LP	H AR XL 01		16	2	4

Material Required for Examination

Question Source: New **Question Modification Method:** I **Used During Training Program**

Question Source Comments

Comment Type **Comment**

Reviews Complete

Peer

Supervisory

Facility

NRC

Question Topic [illegible]

[illegible]

a. [illegible]

b. [illegible]

c. [illegible]

d. [illegible]

Answer d **Exam Level** B **Cognitive Level** Application **Facility:** [illegible] **ExamDate:** 7/19/02

KA: 1500060K502 AK2.02 **RO Value:** 3.3* **SRO Value:** 3.5* **Section:** EPE **RO Group:** 2 **SRO Group:** 2

System/Evolution Title Accidental Gaseous Radwaste Release 060

KA Statement: Knowledge of the reasons for the following responses as they apply to Accidental Gaseous Radwaste Release: Isolation of the auxiliary building ventilation

Explanation of Answers: Per TS Basis 3.7.12 (D) correct - design basis is established by the large break LOCA. Assumes a passive ECCS failure outside containment such as a SI pump seal which occurs during cold leg recirc. (A-C) incorrect - occuring inside of containment

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
TS Basis	B 3.7.12	Basis	3.7.12-3	0	

Material Required for Examination

Question Source: New **Question Modification Method:** [illegible] **Used During Training Program**

Question Source Comments

Comment Type **Comment**

Reviews Complete

Peer

Supervisory

Facility

NRC

Question Topic [illegible]

[illegible]

a. [illegible]

b. [illegible]

c. [illegible]

d. [illegible]

Answer d **Exam Level** B **Cognitive Level** Memory **Facility:** Brunswick **ExamDate:** 7/19/02

KA: [illegible] 2.1.7 **RO Value:** 2.8 **SRO Value:** 2.9 **Section:** EPE **RO Group:** 2 **SRO Group:** 2

System/Evolution Title Area Radiation Monitoring (ARM) System Alarms 061

KA Statement:

Knowledge of system purpose and/or function

Explanation of Answers: A,B: Building Charcoal Booster fans auto start upon receipt of a SI signal only. Not from Hi rad. (A,C) are correct functions of the general area radiation monitoring system. (D) is the incorrect. Correct answer

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Normal Operating Procedures	B&OP VA 5	E	2	10	
Radiation Monitor LP	LP AR X, 011390	LA	1	2	1

Material Required for Examination

Question Source: New **Question Modification Method:** **Used During Training Program**

Question Source Comments

Comment Type Comment

Reviews Complete

Peer

Supervisory

Facility

NRC

Question Topic [illegible]

[illegible]

a. [illegible]

b. [illegible]

c. [illegible]

d. [illegible]

Answer b **Exam Level** B **Cognitive Level** Application **Facility:** Braidwood **ExamDate:** 7/19/92

KA: 000062A101 AA1.01 **RO Value:** 3.1 **SRO Value:** [illegible] **Section:** EPE **RO Group:** 1 **SRO Group:** 1

System/Evolution Title Loss of Nuclear Service Water 062

KA Statement: Ability to operate and/or monitor the following as they apply to Loss of Nuclear Service Water
Nuclear service water temperature indications

Explanation of Answers: (A) Incorrect - isolation of 1 heat exchanger in each unit invokes LCO 3.0.3 (B) Correct - per 1BAOA PRI-8, attach B step 1b RNO (C) Incorrect - renders control of containment temperatures not possible (D) Incorrect - renders RCFCs incapable of controlling containment temperature [illegible]

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Abnormal Operating Procedure	1BAOA PRI-8	Attach B	[illegible]	13[illegible]	

Material Required for Examination

Question Source: Facility Exam Bank **Question Modification Method:** Significantly Modified **Used During Training Program**

Question Source Comments

Comment Type	Comment

Reviews Complete

Peer

Supervisory

Facility

NRC

Question Topic [illegible]

[illegible]

a. [illegible]

b. [illegible]

c. [illegible]

d. [illegible]

Answer [illegible] **Exam Level** S **Cognitive Level** Application **Facility:** Brownwood **ExamDate:** 7/19/02

KA: [illegible] **RO Value:** 4.0 **SRO Value:** [illegible] **Section:** [illegible] **RO Group:** 3 **SRO Group:** 2

System/Evolution Title Loss of Instrument Air 065

KA Statement:

Ability to perform without reference to procedures those actions that require immediate operation of system components and controls.

Explanation of Answers:

Loss of DC Bus 111 has occurred as evidenced by annunciator 1-21-E[illegible] and DC Bus voltage indicator. Loss of ESF DC results in loss of IA to the main feed regulating valves, which fail closed. Resulting closure of MFRVs results in or required an immediate reactor trip due to potential loss of heat sink. (D) Correct - (A) Incorrect - safe shutdown equipment on Train B is not affected by loss of DC power. Train A equip will not be operated locally w/o tripping protection if an operable train is available. (B) Incorrect - no indications exist that the battery charger has tripped off. (C) Incorrect - While it may be desireable to cross tie DC Busses at some point, must first determine status of why 111 bus tripped. Before that, the immediate concern is the failure of all FRVs on Unit 1 lowering SG level and imminent reactor trip.

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Abnormal Operating Proc - Loss of DC Bus	1BwOA ELEC-1	Attach A	3	100	

Material Required for Examination

Question Source: New **Question Modification Method:** **Used During Training Program**

Question Source Comments

Comment Type	Comment
SRO	[illegible]

Reviews Complete

Peer

Supervisory

Facility

NRC

33

Question Topic [illegible]

[illegible]

a. [illegible]

b. [illegible]

c. [illegible]

d. [illegible]

Answer a **Exam Level** B **Cognitive Level** Memory **Facility:** Braidwood **ExamDate:** 7/19/02

KA: 000009K101 AK1.01 **RO Value:** [illegible] **SRO Value:** [illegible] **Section:** EPE **RO Group:** 1 **SRO Group:** 1

System/Evolution Title Loss of Containment Integrity 069

KA Statement: Knowledge of the operational implications of the following concepts as they apply to Loss of Containment Integrity
Effect of pressure on leak rate

Explanation of Answers: Worst case LOCA generates larger mass and energy release than the worst case steam line break. Inadvertant CS actuation would cause pressure to decrease. even if all RCP seals failed a DB LOCA is a larger mass and energy release

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
FR-Z Containment	[illegible]	II	2	1	3
Technical Specifications	[illegible]	B [illegible]	B 3.6.4.1	0	

Material Required for Examination

Question Source: Facility Exam Bank **Question Modification Method:** Direct From Source **Used During Training Program**

Question Source Comments 2000 Bank NRC

Comment Type **Comment**

Reviews Complete

Peer

Supervisory

Facility

NRC

34

Question Topic [illegible]

[illegible]

a. [illegible]

b. [illegible]

c. [illegible]

d. [illegible]

Answer a **Exam Level** B **Cognitive Level** Application **Facility:** Beaver Valley **ExamDate:** 7/19/02

KA: 0[illegible] EK1.09 **RO Value:** 2.8 **SRO Value:** 3.1 **Section:** EPE **RO Group:** 1 **SRO Group:** 1

System/Evolution Title Inadequate Core Cooling 074

KA Statement: Knowledge of the operational implications of the following concepts as they apply to Inadequate Core Cooling: Definition of subcooled liquid

Explanation of Answers: calculated value with the steam tables for a pressure of 485 psig (500 psia has Tsat of 467 F. 50 F subcooled is 417 F. Psat for 417 F is 300 psia = 285 psig

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Inadequate Core Cooling LP	[illegible]	[illegible]	1	1	2
Steam Tables					

Material Required for Examination Steam Tables

Question Source: Facility Exam Bank **Question Modification Method:** Editorially Modified **Used During Training Program**

Question Source Comments using steam tables to determine saturation at 485 psig and 50 F lower to 285 psig (A)

Comment Type	Comment	Reviews Complete
		Peer
		Supervisory
		Facility
		NRC

RO SkyScraper | SRO Skyscraper | RO System/Evolution List | SRO System/Evolution List | Outline Changes

Question Topic [illegible]

[illegible]

[illegible]

a. [illegible]

b. [illegible]

c. 1RH-[illegible] Residual Heat Exchanger Bypass [illegible]

d. 1RY-[illegible] Pressurizer Spray Valve

Answer b **Exam Level** B **Cognitive Level** Application **Facility:** Braidwood **ExamDate:** 7/19/02

KA: 000074K2[illegible] EK2.09 **RO Value:** 2.6 **SRO Value:** 2.6 **Section:** EPE **RO Group:** 1 **SRO Group:** 1

System/Evolution Title Inadequate Core Cooling 074

KA Statement: Knowledge of the interrelations between Inadequate Core Cooling and the following: Controllers and Positioners

Explanation of Answers: B Correct Decreasing demand on this controller will reduce flow from the RH pump to be injected into the core because it's on the discharge of the pump and normally aligned 100% open A Incorrect decreasing demand on 1CV-182 will not decrease charging flow to the core because this path is isolated C Incorrect This valve is normally fully closed at 100% power D Incorrect closing a spray valve will not decrease flow to the core because there will be no RCPs running to affect RCS pressure

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
System big notes	dwgs CV-1, RH-1			4.3	
Op Action Summary Page	1BwEP-0	Trip RCPs When			

Material Required for Examination None

Question Source: New **Question Modification Method:** **Used During Training Program**

Question Source Comments

Comment Type Comment

Reviews Complete

Peer

Supervisory

Facility

NRC

36

Question Topic [illegible]

[illegible]

a. [illegible]

b. [illegible]

c. [illegible]

d. [illegible]

Answer [illegible] **Exam Level** B **Cognitive Level** Comprehension **Facility:** Braidwood **ExamDate:** 7/19/02

KA: 000[illegible] K3.02 K3.02 **RO Value:** [illegible] **SRO Value:** [illegible] **Section:** SYS **RO Group:** 1 **SRO Group:** 1

System/Evolution Title Control Rod Drive System 001

KA Statement: Knowledge of the effect that a loss or malfunction of the Control Rod Drive System will have on the following: RCS

Explanation of Answers: (A) incorrect - pressurizer pressure and level would decrease (B) incorrect - pressurizer pressure and level would decrease as Tave decreased (C) Correct - all symptoms of rod withdrawal and Tave increase (D) incorrect - pressurizer pressure would decrease

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Rod Control LP	01 RD [illegible] 01		1	2	1.20

Material Required for Examination

Question Source: Facility Exam Bank **Question Modification Method:** Significantly Modified **Used During Training Program**

Question Source Comments

Comment Type **Comment**

Reviews Complete

Peer

Supervisory

Facility

NRC

Question Topic

a.

b.

c.

d.

Answer d **Exam Level** B **Cognitive Level** Memory **Facility:** Braidwood **ExamDate:** 7/19/02

KA: 001000K613 Ke 1.3 **RO Value:** 3.6 **SRO Value:** 3.7 **Section:** SYS **RO Group:** 1 **SRO Group:** 1

System/Evolution Title Control Rod Drive System 001

KA Statement: Knowledge of the effect of a loss or malfunction on the following will have on the Control Rod Drive System: Location and operation of RPIS

Explanation of Answers: (A) incorrect - accuracy for data A failure (B) incorrect - rod at bottom lights for failure in both cabinets or dropped rod (C) incorrect - error is not in both cabinets (D) correct - system shifts to half accuracy with every other LED indicating rod position

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Bwd System Bkg Notes	Dwg RD-6			2	

Material Required for Examination

Question Source: New **Question Modification Method:** **Used During Training Program**

Question Source Comments

Comment Type **Comment**

Reviews Complete

Peer

Supervisory

Facility

NRC

Question Topic [illegible]

[illegible]

a. [illegible]

b. [illegible]

c. [illegible]

d. [illegible]

Answer [illegible] **Exam Level** B **Cognitive Level** Application **Facility:** Braidwood **ExamDate:** 7/19/02

KA: [illegible]2000K303 K3.03 **RO Value:** 3.2 **SRO Value:** 4.6 **Section:** SYS **RO Group:** 2 **SRO Group:** 2

System/Evolution Title Reactor Coolant System 002

KA Statement: Knowledge of the effect that a loss or malfunction of the Reactor Coolant System will have on the following: Containment

Explanation of Answers: (C) correct - only RCS leakage will cause actual radiation levels to increase. (A,B,D) incorrect - all three will change in the same direction regardless of the transient (SLB or LOCA)

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Intro to EPLP	11 EP X 01	accID chart			

Material Required for Examination

Question Source: Facility Exam Bank **Question Modification Method:** Editorially Modified **Used During Training Program**

Question Source Comments

Comment Type **Comment**

Reviews Complete

Peer

Supervisory

Facility

NRC

RO SkyScraper | SRO Skyscraper | RO System/Evolution List | SRO System/Evolution List | Outline Changes

Question Topic [illegible]

[illegible]

a. [illegible]

b. [illegible]

c. [illegible]

d. [illegible]

Answer [illegible] **Exam Level** B **Cognitive Level** Memory **Facility:** Braidwood **ExamDate:** 7/19/02

KA: 002000K603 [illegible] **RO Value:** 3.1 **SRO Value:** [illegible] **Section:** SYS **RO Group:** 2 **SRO Group:** 2

System/Evolution Title Reactor Coolant System 002

KA Statement: Knowledge of the effect that a loss or malfunction of the following will have on the Reactor Coolant System: Reactor vessel level indicator

Explanation of Answers: only 1 train of RVLIS is available of the 2 total. Each train consists of 2 reactor head level indicators and 6 reactor vessel plenum level indicators. a. only correct answer

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
ILT Big Notes	CORE 2	RVLIS		1	

Material Required for Examination

Question Source: New **Question Modification Method:** [illegible] **Used During Training Program**

Question Source Comments

Comment Type **Comment**

Reviews Complete

Peer

Supervisory

Facility

NRC

Question Topic [illegible]

[illegible]

a. [illegible]

b. [illegible]

c. [illegible]

d. [illegible]

Answer [illegible] **Exam Level** B **Cognitive Level** Application **Facility:** Braidwood **ExamDate:** [illegible] 2-19-02

KA: 003000A205 A2.05 **RO Value:** 2.9 **SRO Value:** 2.8 **Section:** SYS **RO Group:** 1 **SRO Group:** 1

System/Evolution Title Reactor Coolant Pump System 003

KA Statement: Ability to (a) predict the impacts of the following on the Reactor Coolant Pump System; and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operation:
Effects of VCT pressure on RCP seal leakoff flows

Explanation of Answers: (C) correct - increasing level causes pressure to increase; increasing backpressure on the RCP seals, decreasing #1 seal leakoff flow. Venting the pressure from the VCT is the required action to take while degassing the RCS. (A&B) incorrect - backpressure increases causing #1 seal leakoff to decrease. (D) incorrect - opening 1CV112 will increase seal injection flow but does not compensate for increased VCT pressure. Seal leakoffs will not return to normal parameters.

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Mechanical Degassing of the RCS	B.AOP.CV.11	E.8.36	5.14	16	

Material Required for Examination

Question Source: New **Question Modification Method:** **Used During Training Program**

Question Source Comments

Comment Type **Comment**

Reviews Complete

Peer

Supervisory

Facility

NRC

Question Topic [illegible]

[illegible]

a. [illegible]

b. [illegible]

c. [illegible]

d. [illegible]

Answer b **Exam Level** B **Cognitive Level** Memory **Facility:** Brunswick **ExamDate:** [illegible] 7/19/02

KA: 003000K4.04 K4.04 **RO Value:** 2.8 **SRO Value:** 3.1 **Section:** SYS **RO Group:** 1 **SRO Group:** 1

System/Evolution Title Reactor Coolant Pump System 003

KA Statement: Knowledge of Reactor Coolant Pump System design feature(s) and/or interlock(s) which provide for the following: Adequate cooling of RCP motor and seal

Explanation of Answers: (B) Correct. Air cools the motor windings and water (CV) cools the #1 seal in series.

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
RCP Lesson Plan	1 RC-XL-01		2.11.49	1	3,4

Material Required for Examination

Question Source: New **Question Modification Method:** [illegible] **Used During Training Program**

Question Source Comments

Comment Type **Comment**

Reviews Complete

Peer

Supervisory

Facility

NRC

Question Topic [illegible]

[illegible]

A. [illegible]
B. [illegible]
C. [illegible]
D. [illegible]

[illegible]

a. [illegible]

b. [illegible]

c. [illegible]

d. [illegible]

Answer a **Exam Level** B **Cognitive Level** Application **Facility:** Brunswick **ExamDate:** 7/19/02

KA: 004000A109 A1.09 **RO Value:** 3.6 **SRO Value:** 3.8 **Section:** SYS **RO Group:** 1 **SRO Group:** 1

System/Evolution Title Chemical and Volume Control System 004

KA Statement: Ability to predict and/or monitor changes in parameters associated with operating the Chemical and Volume Control System controls including:
RCS pressure and temperature

Explanation of Answers: (A) Correct - water is an incompressible fluid in a solid condition - small variations in inventory (charging/letdown flows) will result in large variations in pressure

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
CVCS LP	[illegible]				
RCS FT and Vent	B&OP RC[illegible]	F	16-19	14	

Material Required for Examination

Question Source: Facility Exam Bank **Question Modification Method:** Direct From Source **Used During Training Program**

Question Source Comments

Comment Type **Comment**

Reviews Complete
Peer
Supervisory
Facility
NRC

Question Topic [illegible]

[illegible]

a. [illegible]

b. [illegible]

c. [illegible]

d. [illegible]

Answer d **Exam Level** R **Cognitive Level** Comprehension **Facility:** Brunswick **ExamDate:** 7/19/02

KA: 004000K205 K2.05 **RO Value:** 2.7 **SRO Value:** 2.[illegible] **Section:** SYS **RO Group:** 1 **SRO Group:** 1

System/Evolution Title Chemical and Volume Control System 004

KA Statement: Knowledge of bus power supplies to the following MOVs

Explanation of Answers: (D) correct - the only non esf powered MOV in the list 1CVB109 is powered from 1B SW1 (A B C) incorrect - these are ESF powered valves and will be energized following a loss of off site by the respective EDGs

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
CV Electrical Lineup	BwOP CV-E1		[illegible]	5	

Material Required for Examination

Question Source: New **Question Modification Method:** [illegible] **Used During Training Program**

Question Source Comments

Comment Type **Comment**

Reviews Complete

Peer

Supervisory

Facility

NRC

RO SkyScraper | SRO Skyscraper | RO System/Evolution List | SRO System/Evolution List | Outline Changes

Question Topic [illegible]

[illegible]

RC[illegible]
RC[illegible]
P[illegible]
1A RH[illegible]
1B RH[illegible]

[illegible]

Which of the following [illegible]

a. [illegible]

b. [illegible] the 1A RH Pump [illegible]

c. 1RH[illegible] 1A RH Discharge [illegible] the 1A RH Pump

d. 1RH8702A RC Loop A to RH Pump Suction [illegible] inadvertently closed due to an instrument failure

Answer c **Exam Level** B **Cognitive Level** Comprehension **Facility:** Braidwood **ExamDate:** 7/19/02

KA: 005000K301 K3.01 **RO Value:** 3.9 **SRO Value:** 4.0 **Section:** SYS **RO Group:** 3 **SRO Group:** 3

System/Evolution Title Residual Heat Removal System

KA Statement: Knowledge of the effect that a loss or malfunction of the Residual Heat Removal System will have on the following: RCS

Explanation of Answers: (A) Incorrect - closure of the discharge will not increase suction pressure (B) Incorrect - RCS is not solid (C) Correct - per reference closure of the disch X-tie valve is performed to prevent overpressurization of the idle pump suction header (D) Incorrect - closure of the RH Suction valve will [illegible]

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Placing the RH system in S D Cooling	BwOP RH-6	F	12	26	

Material Required for Examination

Question Source: Facility Exam Bank **Question Modification Method:** Editorially Modified **Used During Training Program**

Question Source Comments

Comment Type **Comment**

Reviews Complete

Peer

Supervisory

Facility

NRC

45

Question Topic [illegible]

[illegible]

[illegible]

[illegible]

a. [illegible]

b. [illegible]

c. [illegible]

d. [illegible] Increase

Answer b **Exam Level** B **Cognitive Level** Comprehension **Facility:** Beaver **ExamDate:** 7/19/02

KA: 005000K505 K5.05 **RO Value:** 2.7* **SRO Value:** 3.1* **Section:** SYS **RO Group:** 3 **SRO Group:** 3

System/Evolution Title Residual Heat Removal System

KA Statement: Knowledge of the operational implications of the following concepts as they apply to the Residual Heat Removal System: Plant response during "solid plant" pressure change due to the relative incompressibility of water

Explanation of Answers: (B) Correct. Loss of RH cooling flow will allow RCS to heat up. 1CV-131 will sense pressure drop as RH pump is tripped and close to raise RCS pressure. (A) incorrect. pressure will increase. (C&D) Incorrect. RCS will heat up as RH cooling is lost.

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
General Operating Procedure	1BwGP-100-1	D.3	5	17	

Material Required for Examination

Question Source: New **Question Modification Method:** **Used During Training Program**

Question Source Comments

Comment Type **Comment**

Reviews Complete

Peer

Supervisory

Facility

NRC

46

Question Topic [illegible]

[illegible]

a. [illegible]

b. [illegible]

c. [illegible]

d. [illegible]

Answer a **Exam Level** B **Cognitive Level** Memory **Facility:** Brunswick **ExamDate:** [illegible]

KA: 006000K417 K4.17 **RO Value:** 3.8 **SRO Value:** 4.1 **Section:** SYS **RO Group:** [illegible] **SRO Group:** [illegible]

System/Evolution Title Emergency Core Cooling System 006

KA Statement: Knowledge of Emergency Core Cooling System design feature(s) and/or interlock(s) which provide for the following: Safety Injection valve interlocks

Explanation of Answers: (A) Correct - closing either (2SI8820 AND 2SI8814) or closing 2SI8813 satisfies the rest of the interlock to open the RH crosstie 2RH8804B. (B,C,D) Incorrect - none are in the interlock circuitry

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
GPs - Main Control Board Valve Interlocks	2BwGP 100-1A3		2	[illegible]	

Material Required for Examination

Question Source: New **Question Modification Method:** **Used During Training Program**

Question Source Comments

Comment Type	Comment

Reviews Complete

Peer

Supervisory

Facility

NRC

Question Topic Pressurizer Relief Tank Quench Tank System (PRTS)

The NSO has noted an increasing level in the Pressurizer Relief Tank (PRT)

Which one of the following RELIEF VALVES might be discharging to the PRT?

a. 1CV8118, Charging Pump discharge relief valve

b. 1CV8117, Letdown line orifice relief valve

c. 1CC9426A-D, RCP thermal barrier relief valves

d. 1SI8856A/B, RH Pump discharge relief valves

Answer	b	**Exam Level**	R	**Cognitive Level**	Memory	**Facility:**	Braidwood	**ExamDate:**	7/19/02

KA:	007000A301	A3.01	**RO Value:**	2.7*	**SRO Value:**	2.9	**Section:**	SYS	**RO Group:**	3	**SRO Group:** 3

System/Evolution Title Pressurizer Relief Tank/Quench Tank System 007

KA Statement: Ability to monitor automatic operations of the Pressurizer Relief Tank/Quench Tank System including: Components which discharge to the PRT

Explanation of Answers: (A) Incorrect - 1CV8118 relieves to the VCT (B) Correct - relieves to the PRT (C) Incorrect - relieves to the Cnmt Bldg Floor Drain Sump (D) Incorrect - relieves to the HUT

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
P&ID	M-64 sheet 5			BE	

Material Required for Examination

Question Source: Facility Exam Bank **Question Modification Method:** Editorially Modified **Used During Training Program**

Question Source Comments 2001 Bwd NRC

Comment Type	Comment

Reviews Complete
Peer
Supervisory
Facility
NRC

Question Topic Component Cooling Water System (CCWS)

A leak in which of the following components will result in an automatic closure of 1CC017, "Component Cooling Surge Tank Vent Valve"

a. Seal Water Heat Exchanger

b. Spent Fuel Pool Heat Exchanger

c. Letdown Heat Exchanger

d. Waste Gas Compressor Heat Exchanger

Answer	c	**Exam Level**	R	**Cognitive Level**	Application	**Facility:**	Braidwood	**ExamDate:**	7/19/02

KA:	008000K103	K1.03	**RO Value:**	2.8*	**SRO Value:**	3.0	**Section:**	SYS	**RO Group:**	3	**SRO Group:** 3

System/Evolution Title Component Cooling Water System 008

KA Statement: Knowledge of the physical connections and/or cause-effect relationships between Component Cooling Water System and the following

PRMS

Explanation of Answers: (C) correct - RCS letdown is at a higher pressure than the CCW system and will result in inleakage to CCW. (A,B,D) are all at a lower operating pressure than CCW and will result in CC outleakage. (see 1BwOA PRI-6)

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Big Notes	CC-2	Leakage Sourcres		4	
Component Cooling Malfunction	1BwOA PRI-6	Attach B	27-30	100	

Material Required for Examination

Question Source: Facility Exam Bank **Question Modification Method:** Significantly Modified **Used During Training Program**

Question Source Comments

Comment Type	Comment

Reviews Complete

Peer

Supervisory

Facility

NRC

Question Topic rediagnosis

With Unit 1 operating at 100% power the following events occurred

- A reactor trip, coincident with a loss of Instrument Bus 114
- All systems responded as expected after the trip

With NO operator actions, 5 minutes after the trip Steam Generator water levels will be

a. HIGHER than normal post trip response due to a delay in ISOLATING AFW flow and the Rediagnosis procedure 1BwEP ES-0.0 should be used

b. HIGHER than normal post trip response due to a delay in ISOLATING AFW flow and the Rediagnosis procedure 1BwEP ES-0.0 should NOT be used

c. LOWER than normal post trip response due to DECREASED AFW flow and the Rediagnosis procedure 1BwEP ES-0.0 should be used

d. LOWER than normal post trip response due to DECREASED AFW flow and the Rediagnosis procedure 1BwEP ES-0.0 should NOT be used

Answer	d	**Exam Level**	B	**Cognitive Level**	Comprehension	**Facility:**	Braidwood	**ExamDate:**	7/19/02

KA:	00WE01K202	EK2.2	**RO Value:**	3.5	**SRO Value:**	3.8	**Section:**	EPE	**RO Group:**	2	**SRO Group:** 1

System/Evolution Title Rediagnosis E01

KA Statement: Knowledge of the interrelations between Rediagnosis and the following:
Facility's heat removal systems, including primary coolant, emergency coolant, the decay heat removal systems, and relations between the proper operation of these systems to the operation of the facility.

Explanation of Answers: A loss of inst bus 114 will cause the B train of AFW flow control valves to close after flow is sensed through them. This reduces the total AFW flow to the SG's, reducing post trip level response to just one train of AFW vice 2. Use of rediagnosis is limited to those events where SI has actuated or is required. No SI actuated or is required in this case. A,B incorrect, plausable if AFW flow control valves failed open not closed. C. incorrect - rediagnosis does not apply. D. Correct

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Loss of Instrument Bus	1BwOA ELEC-2	Table D	18	7A	
Rediagnosis	1BwEP ES-0.0	Purpose	1		

Material Required for Examination

Question Source: Facility Exam Bank **Question Modification Method:** Direct From Source **Used During Training Program**

Question Source Comments 2001 Bwd NRC

Comment Type	Comment

Reviews Complete
Peer
Supervisory
Facility
NRC

50

RO SkyScraper | SRO Skyscraper | RO System/Evolution List | SRO System/Evolution List | Outline Changes

Question Topic LOCA Outside Containment

The operating crew is responding to a LOCA outside of containment. Because of elevating Aux Building Radiation levels, the acting Emergency Director has classified the event as a Site Emergency. The following actions have been initiated / completed

- Classification has been made
- TSC/OSC is being manned
- NARs and ENS notifications have been made
- ERDS has been activiated

The NEXT action for onsite personnel will be to perform a Site (1) per procedure (2)

	(1)	(2)
a.	Evacuation	EP-AA-113 Personnel Protective Actions
b.	Assembly	EP-AA-114 Notifications
c.	Assembly	EP-AA-113 Personnel Protective Actions
d.	Evacuation	EP-AA-114 Notifications

Answer	C	**Exam Level**	S	**Cognitive Level**	Application	**Facility:**	Braidwood	**ExamDate:**	7/19/02

KA:	00WE04G114	2.1.14	**RO Value:**	2.5	**SRO Value:**	3.3	**Section:**	EPE	**RO Group:**	2	**SRO Group:** 1

System/Evolution Title LOCA Outside Containment E04

KA Statement: Knowledge of system status criteria which require the notification of plant personnel.

Explanation of Answers: (C) Correct - the assembly of personnel is the next action to be performed (before the evacuation). This is accomplished under EP-AA-113 for onsite personnel (A) Incorrect - assembly must be before evacuation to give a full accounting of all onsite personnel (B) Incorrect - the assembly is performed IAW EP-AA-113. EP-AA-114 deals with offsite notifications (D) Incorrect - Assembly is held first

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Personnel Protective Actions	EP-AA-113	Attach 4 & 5	13,15	2	

Material Required for Examination

Question Source: New **Question Modification Method:** **Used During Training Program**

Question Source Comments

Comment Type	Comment

Reviews Complete
- Peer
- Supervisory
- Facility
- NRC

51

Question Topic LOCA Outside Containment

While performing 1BwCA-1.2, "LOCA Outside Containment" under what condition would 1SI8835, "SI Pumps to Cold Leg Isolation Valve", remain closed after being repositioned?

a. RCS pressure is increasing

b. SI pump discharge pressure is increasing

c. Pressurizer level is decreasing

d. CETC temperatures are decreasing

Answer	a	**Exam Level**	B	**Cognitive Level**	Application	**Facility:**	Braidwood	**ExamDate:**	7/19/02

KA:	00WE04K302	EK3.2	**RO Value:**	3.4	**SRO Value:**	4.0	**Section:**	EPE	**RO Group:**	2	**SRO Group:** 1

System/Evolution Title LOCA Outside Containment E04

KA Statement: Knowledge of the reasons for the following responses as they apply to LOCA Outside Containment:
Normal, abnormal and emergency operating procedures associated with (LOCA Outside Containment).

Explanation of Answers: (A) Correct - as stated in the procedure 1BwCA-1.2 as the leak is isolated with an RCS pressure increase. (B,C,D) are not options as given in the procedure

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
LOCA Outside Containment (CA)	1BwCA-1.2	NOTE	4	1A WOG	

Material Required for Examination

Question Source: New **Question Modification Method:** **Used During Training Program**

Question Source Comments

Comment Type	Comment

Reviews Complete
Peer
Supervisory
Facility
NRC

Question Topic Pressurized Thermal Shock

The following conditions exist on Unit 1

- Steam generator 1A tube rupture has occurred
- Crew is performing the initial RCS cooldown step of 1BwEP-3, "Steam Generator Tube Rupture"
- All RCP's are OFF
- Loop 1A Tc indicates 180 F

The STA has reported an ORANGE path on RCS Integrity

The Unit Supervisor should (1) because (2)

	(1)	(2)
a.	Remain in 1BwEP-3 until the second RCS depressurization is complete	Cold injection water is cooling Loop 1A Tcold
b.	Immediately transition to 1BwFR-P.1 "Response to Imminent PTS"	A severe challenge exists to the CSF
c.	Transition to 1BwFR-P.1 as soon as the initial cooldown is complete	Cooldown in 1BwEP-3 takes priority over 1BwFR-P.1
d.	Remain in 1BwEP-3 until the appropriate SGTR recovery procedure is selected	An RCP will be started in 1BwEP-3

Answer	a	**Exam Level**	S	**Cognitive Level**	Application	**Facility:**	Braidwood	**ExamDate:**	7/19/02		
KA:	00WE08A202	EA2.2	**RO Value:**	3.5	**SRO Value:**	4.1	**Section:**	EPE	**RO Group:**	1	**SRO Group:** 1

System/Evolution Title Pressurized Thermal Shock E08

KA Statement: Ability to determine and interpret the following as they apply to Pressurized Thermal Shock:
Adherence to appropriate procedures and operation within the limitations in the facility's license and amendments.

Explanation of Answers: (A) correct - per 1BwEP-3 Caution prior to step 6 and Note prior to step 28 (B) Incorrect - same caution states NOT to do FR-P.1 at this time. (C) Incorrect - same caution states to wait until completion of step 28 (D) Incorrect - caution say wait until step 28, not end of the procedure

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
SGTR	1BwEP-3	step 6, 28	10,36	100WO	

Material Required for Examination

Question Source: New **Question Modification Method:** **Used During Training Program**

Question Source Comments

Comment Type	Comment
SRO	Assessment of plant conditions, procedure selection

Reviews Complete
Peer
Supervisory
Facility
NRC

Question Topic Pressurized Thermal Shock

Which of the following reflects the intent of the major actions performed in 1BwFR-P.1 "Response to Imminent Pressurized Thermal Shock"?

a. Reduce RCS cooldown rate and decrease RCS pressure

b. Reduce RCS cooldown rate and increase RCS pressure

c. Increase RCS cooldown rate and decrease RCS pressure

d. Increase RCS cooddown rate and Increase RCS pressure

Answer	a	**Exam Level**	B	**Cognitive Level**	Memory	**Facility:**	Braidwood	**ExamDate:**	7/19/02

KA:	00WE08K302	EK3.2	**RO Value:**	3.6	**SRO Value:**	4.0	**Section:**	EPE	**RO Group:**	1	**SRO Group:** 1

System/Evolution Title Pressurized Thermal Shock E08

KA Statement: Knowledge of the reasons for the following responses as they apply to Pressurized Thermal Shock:
Normal, abnormal and emergency operating procedures associated with (Pressurized Thermal Shock).

Explanation of Answers: (C,D) incorrect - increasing the cooldown rate increases the thermal stresses. (B) incorrect, increasing RCS pressure increases the stresses (A) Correct - reduces thermal and pressure stresses, per 1BwFR P.1

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Response to Imminent PTS	1BwFR-P.1		3-22	1A, WO	
Response to Imminent PTS	Background Document P-1	1	1	1	

Material Required for Examination

Question Source: Facility Exam Bank **Question Modification Method:** Editorially Modified **Used During Training Program**

Question Source Comments 2001 Bwd NRC

Comment Type	Comment

Reviews Complete
Peer
Supervisory
Facility
NRC

SY

Question Topic Natural Circulation Operations

If operated within TS limits, all of the following preclude the hot fuel rod in the core from undergoing DNB during a loss of forced coolant flow accident EXCEPT

a. QPTR

b. FQz

c. FNdH

d. DNBR

Answer	c	**Exam Level**	S	**Cognitive Level**	Memory	**Facility:**	Braidwood	**ExamDate:**	7/19/02		
KA:	00WE09A202	EA2.2	**RO Value:**	3.4	**SRO Value:**	3.8	**Section:**	EPE	**RO Group:**	1	**SRO Group:** 1

System/Evolution Title Natural Circulation Operations E09

KA Statement: Ability to determine and interpret the following as they apply to Natural Circulation Operations:
Adherence to appropriate procedures and operation within the limitations in the facility's license and amendments.

Explanation of Answers: (A,B,D) incorrect - per TS basis each protects against DNB on loss of forced flow. FQz 3.2.1, QPTR 3.2.4, DNBR 3.2.5 (C) correct response - does not preclude DNB on a loss of flow accident. TS Basis 3.2.2

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Tech Specs	Basis	3.2.1,3.2.2,3.2.4,3.2.5		22,23,0	

Material Required for Examination

Question Source: New **Question Modification Method:** **Used During Training Program**

Question Source Comments

Comment Type	Comment
SRO	Tech Spec and Basis knowledge

Reviews Complete
Peer
Supervisory
Facility
NRC

55

Question Topic Natural Circulation Operations

Which of the following describes why it is important to run CRDM fans when performing a natural circulation cooldown?

a. Provides the heat removal mechanism for the vessel head area

b. Aids in natural circulation flow through the RCS vessel head region

c. Prevents erratic indication of SR instruments

d. Aids in natural circulation flow through the RCS

Answer	a	**Exam Level**	B	**Cognitive Level**	Memory	**Facility:**	Braidwood	**ExamDate:**	7/19/02

KA:	00WE09K202	EK2 2	**RO Value:**	3.6	**SRO Value:**	3.9	**Section:**	EPE	**RO Group:**	1	**SRO Group:** 1

System/Evolution Title Natural Circulation Operations E09

KA Statement: Knowledge of the interrelations between Natural Circulation Operations and the following:
Facility's heat removal systems, including primary coolant, emergency coolant, the decay heat removal systems, and relations between the proper operation of these systems to the operation of the facility.

Explanation of Answers: CRDM fans cool the upper head region that may not be cooled by natural circulation flow. Rx Cavity vent fans provide cooling to the SR NI's.

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
EP-0 Series LP	I1-EP-XL-01	VII	38	13	3
Natural Circulation Cooldown	1BwEP ES-0.2	Step 22 RNO	14	WOG1C	

Material Required for Examination

Question Source: Facility Exam Bank **Question Modification Method:** Direct From Source **Used During Training Program**

Question Source Comments 1999 Bwd NRC

Comment Type	Comment	Reviews Complete
		Peer
		Supervisory
		Facility
		NRC

Question Topic Natural Circulation with Steam Void with without RVLIS

The following conditions exist on Unit 1

- 1BwEP ES-0.4 "Natural Circulation Cooldown with Steam Void in Vessel (Without RVLIS) Unit 1" is in progress
- RCS Temperature is 450 F
- RCS Pressure is 800 psig
- RVLIS is NOT available
- Charging and letdown flows are matched

With RVLIS NOT available to monitor for void growth in the vessel, which of the following combined indications can be used to verify the presence of a void when letdown flow is increased > charging flow?

RCS pressure will (1) and Pressurizer level will (2)

	(1)	(2)
a.	Increase	Increase
b.	Increase	Decrease
c.	Decrease	Decrease
d.	Decrease	Increase

Answer	d	**Exam Level**	R	**Cognitive Level**	Application	**Facility:**	Braidwood	**ExamDate:**	7/19/02		
KA:	00WE10A102	EA1.2	**RO Value:**	3.6	**SRO Value:**	3.8	**Section:**	EPE	**RO Group:**	1	**SRO Group:** 1

System/Evolution Title Natural Circulation with Steam Void in Vessel with/without RVLIS E10

KA Statement: Ability to operate and / or monitor the following as they apply to Natural Circulation with Steam Void in Vessel with/without RVLIS
Operating behavior characteristics of the facility.

Elimination of Answers: (D) Correct - rapidly increasing pressurizer level during the RCS depressurization is a sign that voids are forming in the primary system. Pressure decreases, fluid flashes to steam displacing pzr level. (A&B) incorrect - pressure decreases as inventory is removed. (C) incorrect - level increases as voids form

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Nat Circ Cooldown w/o RVLIS	1BwEP ES-0.4	Note - step 8	7	1AWOG	
Background Documents	1BwEP ES-0.4	Step 8	33	1C	

Material Required for Examination

Question Source: New **Question Modification Method:** **Used During Training Program**

Question Source Comments

Comment Type	Comment

Reviews Complete
Peer
Supervisory
Facility
NRC

Question Topic Steam Generator Overpressure

The following conditions exist on Unit 1

- A spurious closure of all MSIVs occurred while operating at 100% power
- The reactor was manally tripped by the operators and immediate actions of 1BwEP-0 were performed
- Recovery operations are in progress utilizing 1BwEP ES-0.1, "Reactor Trip Response"
- The STA has identified a YELLOW path overpressure condition on 1C SG with pressure at 1240 psig
- Checking 1PM04J, there is no steam flow indicated on the 1C steam generator
- All other steam generators and plant safety systems functioned as designed
- During subsequent repairs the unit has been holding in Mode 3 for the past 20 hours

The condition of the 1C steam generator is reportable to the NRC because

a. The plant exceeded a safety limit

b. Challenges occurred to safety valves

c. A loss of two fission product barriers is imminent

d. The plant is in a condition prohibited by tech specs

Answer	d	**Exam Level**	S	**Cognitive Level**	Application	**Facility:**	Braidwood	**ExamDate:**	7/19/02		
KA:	00WE13G430 2.4.30	**RO Value:**	2.2	**SRO Value:**	3.6	**Section:**	EPE	**RO Group:**	3	**SRO Group:**	3

System/Evolution Title Steam Generator Overpressure E13

KA Statement: Knowledge of which events related to system operations/status should be reported to outside agencies.

Explanation of Answers: (A) Incorrect - the reportable safety limits are for primary system power level and pressure only. (B) Safety valves are only the Pzr safety valves, not the SG safety valves (C) Incorrect - loss of 2 fission product barriers would result in a Site Emergency which we are not in. Do not meet criteria for potential losses per EALs (D) Correct - with no steam flow and SG pressure at 1240 psig it is above the lift setpoint of all MS safety valve which are inoperable.

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Functional Restoration proc SG Overpress	1BwFR H.2		1	1AWOG	
FR H.2 background document	FR-H.2	FR-H.2	2-4	1	
Exelon Reportability Manual	LS-AA-1110	SAF 1.11	39		

Material Required for Examination

Question Source: New **Question Modification Method:** **Used During Training Program**

Question Source Comments

Comment Type	Comment

Reviews Complete

Peer

Supervisory

Facility

NRC

58

Question Topic Steam Generator Overpressure

The following sequence of events has occurred on Unit 1

- Reactor has been manually tripped due to a secondary system malfunction
- 1BwEP-0 has been performed and a transition made to 1BwEP ES-0.1, "Reactor Trip Response"
- The STA has identified a YELLOW path on the Heat Sink Status Tree for steam generator pressure
- The crew has entered 1BwFR-H.2, "Response to Steam Generator Overpressure"
- The crew is preparing to dump steam from the affected steam generator
- The US reads a CAUTION that does not allow releasing steam from a SG with a narrow range level of greater than 93%

Why shouldn't the crew dump steam from the affected SG if NR level is >93%?

a. May cause an uncontrolled radiation release since it is likely that the steam generator is ruptured

b. May result in two phase flow and water hammer, potentially damaging pipes and valves

c. Will be ineffective in lowering SG pressure since the SG water is likely subcooled

d. Will cause a rapid pressure drop in the RCS, potentially resulting in a safety injection

Answer	b	**Exam Level**	B	**Cognitive Level**	Memory	**Facility:**	Braidwood	**ExamDate:**	7/19/02
KA:	00WE13K202	EK2.2	**RO Value:**	3.0	**SRO Value:**	3.2	**Section:**	EPE	**RO Group:** 3 **SRO Group:** 3

System/Evolution Title Steam Generator Overpressure E13

KA Statement: Knowledge of the interrelations between Steam Generator Overpressure and the following:
Facility's heat removal systems, including primary coolant, emergency coolant, the decay heat removal systems, and relations between the proper operation of these systems to the operation of the facility.

Explanation of Answers: (B) Correct - per FR-H series background documents. (A) Incorrect - no indications are present that would suspect a SGTR had occurred. (C) incorrect - at 1235# and RCS Tave post trip, opening the PORV or Steam Dumps will release steam. (D) Incorrect - no indications to conclude a controlled release cannot be obtained.

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Response to SG Overpressure	1BwFR-H.1		5	1A	
Background Documents	FR-H.2	Caution	12	1C	

Material Required for Examination

Question Source: Other Facility **Question Modification Method:** Editorially Modified **Used During Training Program**

Question Source Comments 2001 Prairie Island NRC

Comment Type	Comment	Reviews Complete
		Peer
		Supervisory
		Facility
		NRC

Question Topic High Containment Pressure

While performing actions of 1BwFR-Z.1, "Response to High Containment Pressure", what steps are taken to limit the peak pressure rise in containment in the event one of the steam generators is faulted?

a. All four RCFCs are started in Fast Speed upon entry to 1BwFR-Z.1

b. Feed Flow is isolated to any steam generator that is depressurizing in an uncontrolled manner

c. Aux Feedwater Flow to all steam generators is throttled down to 45 gpm per steam generator

d. All steam generators are allowed to completely depressurize before exiting 1BwFR-Z.1

Answer	b	**Exam Level**	B	**Cognitive Level**	Comprehension	**Facility:**	Braidwood	**ExamDate:**	7/19/02

KA:	00WE14K202	EK2.2	**RO Value:**	3.4	**SRO Value:**	3.8	**Section:**	EPE	**RO Group:**	1	**SRO Group:** 1

System/Evolution Title High Containment Pressure E14

KA Statement: Knowledge of the interrelations between High Containment Pressure and the following:
Facility's heat removal systems, including primary coolant, emergency coolant, the decay heat removal systems, and relations between the proper operation of these systems to the operation of the facility.

Explanation of Answers: (B) Correct - per step 6 of FR-Z.1. (A) incorrect - RCFC's are never run in fast speed in adverse containment conditions to protect the fans (C) incorrect - AFW is only throttled to 45 gpm if all steam generators are faulted. (D) incorrect - all steam generators are not depressurized before exiting Z.1

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Response to High Cnmt Pressure	1BwFR-Z.1		9	1AWOG	

Material Required for Examination

Question Source: New **Question Modification Method:** **Used During Training Program**

Question Source Comments

Comment Type	Comment

Reviews Complete
Peer
Supervisory
Facility
NRC

60

Question Topic High Containment Pressure

1BwCA-1.1 "Loss of Emergency Coolant Recirculation", is in progress when a RED path is identified for containment pressure. 1BwFR-Z.1 "Response to High Containment Pressure", is entered immediately and containment isolation is verified. The operators then operate the containment spray system according to the directions found in 1BwCA-1.1 instead of 1BwFR-Z.1

Under these conditions, 1BwCA-1.1 takes precedence over 1BwFR-Z.1 because the 1BwCA-1.1 pump operating criteria

a. Ensure that the maximum heat removal system capacity is used to reduce containment pressure

b. Are more restrictive, ensuring continuous containment spray system operation to reduce containment pressure

c. Are less restrictive, permitting reduced containment spray operation to conserve RWST water

d. Provide a more rapid means of verifying automatic actuation of the containment spray system

Answer	c	**Exam Level**	B	**Cognitive Level**	Application	**Facility:**	Braidwood	**ExamDate:**	7/19/02		
KA:	00WE14K302	EK3.2	**RO Value:**	3.1	**SRO Value:**	3.7	**Section:**	EPE	**RO Group:**	1	**SRO Group:** 1

System/Evolution Title High Containment Pressure E14

KA Statement: Knowledge of the reasons for the following responses as they apply to High Containment Pressure:
Normal, abnormal and emergency operating procedures associated with (High Containment Pressure).

Explanation of Answers: (C) Correct - spray operation requirements are relaxed to allow conservation of RWST water inventory (A) incorrect - CS is not maximized but reduced (B) incorrect - 1.1 criteria is less restrictive, allowing no CS pumps if all RCFCs are available and running in accident mode. (D) incorrect - actuation is not verified until step 9, and then only to look at required flows

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Response to High Containment Pressure	1BwFR-Z.1	Caution	3	1A	
Loss of Emergency Coolant Recirculation	1BwCA-1.1	step 9 - table	8	100	

Material Required for Examination

Question Source: Facility Exam Bank **Question Modification Method:** Editorially Modified **Used During Training Program**

Question Source Comments

Comment Type	Comment

Reviews Complete
Peer
Supervisory
Facility
NRC

Question Topic Containment Flooding

A large break LOCA has occurred on Unit 1. The crew is currently performing steps in 1BwEP-1 "Loss of Reactor of Secondary Coolant". The following conditions existed when the STA made his initial scan of the Status Trees.

- Pressurizer level was 0%
- Containment spray had automatically actuated. Cnmt pressure was 12 psig and decreasing
- Containment rad monitors 1RT-AR020 and 1RT-AR021 were in ALARM
- Containment floor water level indicated 65 inches

Which of the following procedures must be entered to address the above containment conditions?

a. 1BwFR-Z.1 Response to High Containment Pressure

b. 1BwFR-Z.2 Response to Containment Flooding

c. 1BwFR-Z.3 Response to High Containment Radiation Level

d. 1BwFR-I.2 Response to Low Pressurizer Level

Answer	b	**Exam Level**	R	**Cognitive Level**	Application	**Facility:**	Braidwood	**ExamDate:**	7/19/02
KA:	00WE15A201	EA2.1	**RO Value:**	2.7	**SRO Value:**	3.2	**Section:**	EPE	**RO Group:** 3 **SRO Group:** 3

System/Evolution Title Containment Flooding E15

KA Statement: Ability to determine and interpret the following as they apply to Containment Flooding:
Facility conditions and selection of appropriate procedures during abnormal and emergency operations.

Explanation of Answers: (A) Incorrect - cnmt pressure is <20 psig and not required to be identified for entry by the STA. (B) Correct - flooding entry pt is 64 inches. This is an ORANGE endpoint and the highest in the conditions present. (C) Incorrect - Rad monitors in ALARM is a YELLOW endpoint and not higher than flooding. (D) Incorrect - Pzr Level is YELLOW endpoint and not higher than flooding.

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Containment / Inventory Status Trees	1BwST-5 and 6			1wog1C	

Material Required for Examination 1BwST-5 Containment Status Tree

Question Source: Facility Exam Bank **Question Modification Method:** Significantly Modified **Used During Training Program**

Question Source Comments 2001 Bwd NRC

Comment Type	Comment	Reviews Complete
		Peer
		Supervisory
		Facility
		NRC

62

Question Topic High Containment Radiation

The following conditions exist on Unit 1

- A small break RCS LOCA occurred 45 minutes ago
- The reactor was successfully tripped and SI actuated
- RCS pressure is 900 psig and increasing slowly
- RCS temperature is 500°F and decreasing slowly
- Pzr level is 25% and increasing slowly
- Containment pressure is 4 psig, decreasing slowly from a peak pressure of 22 psig
- Containment radiation levels are steady at 2 6E5 R/hr
- All S/Gs are intact with NR levels at 27% and increasing slowly
- The operating crew has performed all applicable steps of 1BwEP-0 and have transitioned to 1BwEP-1 "Loss of Reactor or Secondary Coolant"

Which of the following statements is true concerning the current plant conditions?

a. Total Aux Feed Flow may be throttled back to less than 500 gpm to reduce RCS cooldown effects

b. Containment Spray pumps may now be stopped at any time deemed appropriate to conserve RWST inventory

c. RCS subcooling is acceptable and would allow for SI termination if all other parameters are met

d. Pzr level would require SI be immediately reinitiated if it had been previously terminated

Answer	d	**Exam Level**	B	**Cognitive Level**	Application	**Facility:**	Braidwood	**ExamDate:**	7/19/02

KA:	00WE16A101	EA1.1	**RO Value:**	3.1	**SRO Value:**	3.2	**Section:**	EPE	**RO Group:**	2	**SRO Group:** 2

System/Evolution Title High Containment Radiation E16

KA Statement: Ability to operate and / or monitor the following as they apply to High Containment Radiation:
Components, and functions of control and safety systems, including instrumentation, signals, interlocks, failure modes, and automatic and manual features.

Explanation of Answers: Adverse containment conditions exit due to the high rad levels (>1E5 r/hr). (A) incorrect - requires SG levels between 31-50%. (B) incorrect - requires run time of >2 hours. (C) incorrect - 500°F requires 950psig adverse cnmt. (D) Correct - Pzr level is required to be >20%

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Loss Of Reactor or Secondary Coolant EP	1BwEP-1	OAS, steps 3,6,7		100WO	

Material Required for Examination Figure 1BwEP 1-1 RCS Subcooling Margin

Question Source: New **Question Modification Method:** **Used During Training Program**

Question Source Comments

Comment Type	Comment

Reviews Complete
Peer
Supervisory
Facility
NRC

Question Topic Pressurizer Level Control System (PZR LCS)

Which of the following Pressurizer level channels is NOT density compensated, making it read lower than actual level at normal operating temperature and pressure?

a. LT-459

b. LT-460

c. LT-461

d. LT-462

Answer	d	**Exam Level**	R	**Cognitive Level**	Memory	**Facility:**	Braidwood	**ExamDate:**	7/19/02

KA:	011000K403	K4.03	**RO Value:**	2.6	**SRO Value:**	2.9	**Section:**	SYS	**RO Group:**	2	**SRO Group:**	2

System/Evolution Title Pressurizer Level Control System 011

KA Statement: Knowledge of Pressurizer Level Control System design feature(s) and or interlock(s) which provide for the following: Density compensation of PZR level

Explanation of Answers: LT-462 is not density compensated or calibrated to read accurately at pressurizer temperatures of ~680°F. (D) is correct.

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Pressurizer LP	I1-RY-XL-01	II	15	2	18

Material Required for Examination

Question Source: Facility Exam Bank **Question Modification Method:** Editorially Modified **Used During Training Program**

Question Source Comments

Comment Type	Comment

Reviews Complete

Peer

Supervisory

Facility

NRC

64

Question Topic Pressurizer Level Control System (PZR LCS)

What single or combination of Pressurizer Level Channels, if failed, will require an additional Tech Spec entry for Post Accident Monitoring (PAM) Instrumentation, LCO 3.3.3?

a. LT-459 alone

b. LT-459 and LT-460

c. LT-460 and LT-462

d. LT-462 alone

Answer	b	**Exam Level**	R	**Cognitive Level**	Memory	**Facility:**	Braidwood	**ExamDate:**	7/19/02

KA:	011000K605	K6.05	**RO Value:**	3.1	**SRO Value:**	3.7	**Section:**	SYS	**RO Group:**	2	**SRO Group:** 2

System/Evolution Title Pressurizer Level Control System 011

KA Statement: Knowledge of the effect of a loss or malfunction on the following will have on the Pressurizer Level Control System:
Function of PZR level gauges as postaccident monitors

Explanation of Answers: TS 3.3.3 requires 2 channels operable. LT-459, LT-460 and LT-461 are used for PAM instrumention. 2 of these 3 channels inoperable will require entry into Conditon B for PAM 3.3.3. (B) is correct

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Tech Specs	LCO 3.3.3	Inst	3.3.3-1	Am98	
Accident Monitoring Inst Monthly	1BwOSR 3.3.3.1	Data Sheets	D-3	4	

Material Required for Examination

Question Source: New **Question Modification Method:** **Used During Training Program**

Question Source Comments

Comment Type	Comment

Reviews Complete
Peer
Supervisory
Facility
NRC

65

Question Topic Reactor Protection System

Given the following plant conditions on Unit 1

- The reactor was at full power with all systems in a normal, automatic lineup
- The reactor tripped on a LO-2 S/G narrow range level condition
- Reactor trip breaker B (RTB) did NOT open as expected

With NO operator action, the steam dumps will open on a signal from the (1) controller and will control Tave at (2)

	(1)	(2)
a.	Plant trip	557°F
b.	Load reject	557°F
c.	Load reject	560°F
d.	Plant trip	560°F

Answer	c	Exam Level	B	Cognitive Level	Application	Facility:	Braidwood	ExamDate:	7/19/02

KA:	012000K303	K3.03	RO Value:	3.1*	SRO Value:	3.3	Section:	SYS	RO Group:	2	SRO Group:	2

System/Evolution Title Reactor Protection System 012

KA Statement: Knowledge of the effect that a loss or malfunction of the Reactor Protection System will have on the following:
SDS

Explanation of Answers: RTA arms the steam dumps in the plant trip mode. (A&D) are incorrect as dumps will only be armed for the load rejection (>10%) Temperature will be controlled within a 3°F deadband - in this case from no load Tave. (C) is then correct. (B) Is incorrect

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Operator Big Notes	MS-4			6	

Material Required for Examination

Question Source: Facility Exam Bank **Question Modification Method:** Direct From Source **Used During Training Program**

Question Source Comments

Comment Type	Comment

Reviews Complete
Peer
Supervisory
Facility
NRC

66

Question Topic Reactor Protection System

Which of the following reactor protection system trips serves as a BACK-UP to the Power Range Neutron Flux - High trip and is designed to ensure that the allowable heat generation rate (kw/ft) of the fuel is NOT exceeded?

a. OTdT

b. OPdT

c. Pzr low pressure

d. RCS low flow

Answer	b	**Exam Level**	B	**Cognitive Level**	Memory	**Facility:**	Braidwood	**ExamDate:**	7/19/02		
KA:	012000K502	K5.02	**RO Value:**	3.1*	**SRO Value:**	3.3	**Section:**	SYS	**RO Group:**	2	**SRO Group:** 2
System/Evolution Title	Reactor Protection System										012
KA Statement:	Knowledge of the operational implications of the following concepts as they apply to the Reactor Protection System: Power density										
Explanation of Answers:	Per TS 3.3.1 - basis (B) is only correct response										

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Tech Specs	Basis	B 3.3.1	17	24	

Material Required for Examination

Question Source: New **Question Modification Method:** **Used During Training Program**

Question Source Comments

Comment Type	Comment

Reviews Complete
Peer
Supervisory
Facility
NRC

Question Topic Engineered Safety Features Actuation System (ESFAS)

The following conditions exist on Unit 1

- A RCS LOCA has occurred
- Safety Injection and all ESFAS equipment has actuated and is functioning as designed
- The Emergency Director has declared an ALERT condition exists
- The crew is performing the actions of 1BwEP ES-1.2, "Post LOCA Cooldown and Depressurization"
- No CSF higher than YELLOW is in effect
- Annunciator 1-6-B7, "RWST LEVEL LO-2" has just alarmed

Which of the following actions should be taken?

a. A Site Evacuation should be ordered AND the people directed to assemble at the New Training Building

b. A plant announcement should be made warning personnel to restrict entry into the Aux Building due to potential high radiation

c. The event should be reclassified as a General Emergency AND the NRC, State and local governments notified immediately

d. Protective Action Recommendations (PARs) determined AND State and local governments notified within 1 hour following evaluation

Answer	b	**Exam Level**	S	**Cognitive Level**	Comprehension	**Facility:**	Braidwood	**ExamDate:**	7/19/02		
KA:	013000G114	2.1.14	**RO Value:**	2.5	**SRO Value:**	3.3	**Section:**	SYS	**RO Group:**	1	**SRO Group:** 1

System/Evolution Title Engineered Safety Features Actuation System 013

KA Statement: Knowledge of system status criteria which require the notification of plant personnel.

Explanation of Answers: (A) Incorrect - No radiological safety hazzard warrenting evacuation is in progress. (B) Correct - Switchover to recirc may cause high rad levels in the aux building. (C) Incorrect - No General Emergency conditions have been met. (D) Incorrect - PARs are only required for a General Emergency

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Transfer to cold leg recirc	1BwEP ES-1.2	CAUTION	10	100	
Generating Stations Emergency Plan	GSEP - Braidwood Annex	Initiating Conditions	3.4	6	
Emerg Classifications & PARs	EP-AA-111		1-16		

Material Required for Examination

Question Source: Other Facility **Question Modification Method:** Editorially Modified **Used During Training Program**

Question Source Comments 2001 Prairie Island NRC

Comment Type	Comment

Reviews Complete
Peer
Supervisory
Facility
NRC

Question Topic Engineered Safety Features Actuation System (ESFAS)

Unit 2 is presently at 90% power and shutting down due to an extended loss of Instrument Bus 214. All systems are in automatic when a loss of reactor coolant occurs. When pressurizer pressure reaches 1829 psig on 2/4 channels which of the following will occur?

a. Automatic SI will occur. Train A ECCS equipment will automatically start. Train B ECCS equipment must be manually started.

b. Automatic SI will NOT occur. Train A and Train B ECCS equipment will automatically start when SI is manually actuated.

c. Automatic SI will occur. Train A and Train B ECCS equipment will automatically start when SI is automatically actuated.

d. Automatic SI will NOT occur. Train A ECCS equipment must be manually started. Train B ECCS equipment cannot be started.

Answer	a	**Exam Level**	R	**Cognitive Level**	Application	**Facility:**	Braidwood	**ExamDate:**	7/19/02

KA:	013000K201	K2.01	**RO Value:**	3.6*	**SRO Value:**	3.8	**Section:**	SYS	**RO Group:**	1	**SRO Group:**	1

System/Evolution Title Engineered Safety Features Actuation System 013

KA Statement: Knowledge of bus power supplies to the following:
ESFAS/safeguards equipment control

Explanation of Distractors: SI will automatically actuate, both trains. Train B ESF Loads however have lost the relay (energize to actuate) and will not auto start as designed. They can be manually started. (A) Correct (B) incorrect - SI will actuate, Train B will not auto start (C) Train B will not auto start (D) incorrect - Train A will auto start

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Loss of Instrument Bus	1BwOA ELEC-2	table D	18	100	

Material Required for Examination

Question Source: Facility Exam Bank **Question Modification Method:** Editorially Modified **Used During Training Program**

Question Source Comments

Comment Type	Comment

Reviews Complete
Peer
Supervisory
Facility
NRC

Question Topic engineered Safety Features Actuation System (ESFAS)

Concerning the Engineered Safety Features Actuation System (ESFAS) there are (1) channels of narrow range steam generator level instrumentation on each steam generator which input to (2) independent safety trains of ESF

	(1)	(2)
a.	2	4
b.	2	2
c.	4	2
d.	4	4

Answer	c	**Exam Level**	B	**Cognitive Level**	Memory	**Facility:**	Braidwood	**ExamDate:**	7/19/02

KA:	013000K501	K5.01	**RO Value:**	2.8	**SRO Value:**	3.2	**Section:**	SYS	**RO Group:**	1	**SRO Group:** 1

System/Evolution Title Engineered Safety Features Actuation System .013

KA Statement: Knowledge of the operational implications of the following concepts as they apply to the Engineered Safety Features Actuation System:
Definitions of safety train and ESF channel

Explanation of Answers: There are 2 independent trains of ESF (A&B). Each train will receive an input from each one of 4 level channels on each steam generator for ESF purposes. (TS 3.3.2) (C) is only correct combination

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
ESF LP	I1-EF-XL-01	II		2	5.7
Tech Specs	LCO	3.3.2	13	Am115	

Material Required for Examination

Question Source: New **Question Modification Method:** **Used During Training Program**

Question Source Comments

Comment Type	Comment

Reviews Complete
Peer
Supervisory
Facility
NRC

70

Question Topic Rod Position Indication System (RPIS)

The following conditions exist on Unit 1

- Reactor power is holding steady at 1x10e-8 amps during a normal reactor startup
- Individual and group position indicators show all control bank D rods at 120 steps withdrawn

When the NSO begins to withdraw control rods to raise reactor power, the IR NIS indication suddenly drops by 1/3 decade and continues to decrease at a negative (-) 25 DPM. There is no significant change in RCS Tave. The control bank D step counters now read 121 steps for both D1 and D2 groups. DRPI indicators for rods D-12, M-4, and H-8 indicate 0 steps. All other rod postion indicators (DRPI) are unchanged

Which of the following has occurred based on these indications?

a. The control bank step counters and associated DRPI indicators, along with the NIS indications are consistent with multiple dropped rods

b. The individual rod position indicators appear to have failed, more than a single dropped rod would have resulted in a reactor trip

c. The control bank D group 2 step counter has failed, it should also read 0 steps if the rods in this group are fully inserted

d. Either the control bank D group step counter or 3 DRPI indicators have failed, not enough information is provided to determine which

Answer	a	**Exam Level**	B	**Cognitive Level**	Application	**Facility:**	Braidwood	**ExamDate:**	7/19/02

KA:	014000K102	K1.02	**RO Value:**	3.0	**SRO Value:**	3.3	**Section:**	SYS	**RO Group:**	2	**SRO Group:** 1

System/Evolution Title Rod Position Indication System .014

KA Statement: Knowledge of the physical connections and/or cause-effect relationships between Rod Position Indication System and the following: NIS

Explanation of Answers: Indications provided are consistent with multiple dropped rods. (A) is correct. (B) incorrect - the reactor does not trip from neg rate (C) incorrect - group counters are demand indicators only. (D) incorrect - given NIS response, DRPI or group demand counters have no independent affect on NIS

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Abnormal Ops - Dropped or Misaligned Rod	1BwOA ROD-3	Symptoms	1	101	
Bwd Big Notes	RD-6	DRPI Indicatons	1	2	

Material Required for Examination

Question Source: Facility Exam Bank **Question Modification Method:** Editorially Modified **Used During Training Program**

Question Source Comments

Comment Type	Comment

Reviews Complete
Peer
Supervisory
Facility
NRC

71

Question Topic Nuclear Instrumentation System

Which of the following describes the effects of a short unintentional emergency boration on the reactor at 75% power. Assume that control rods are in MANUAL

a. Tave initially decreases causing reactor power to decrease. Tave then increases to approximately the initial value

b. Tave initially increases causing reactor power to decrease. Tave then decreases to approximately the initial value

c. Reactor power initially decreases causing Tave to decrease. Reactor power then increases to approximately the initial value.

d. Reactor power initially decreases causing Tave to increase. Reactor power then increases to approximately the initial value.

Answer	c	**Exam Level**	B	**Cognitive Level**	Application	**Facility:**	Braidwood	**ExamDate:**	7/19/02
KA:	015000A107	A1.07	**RO Value:**	3.3*	**SRO Value:**	3.4	**Section:**	SYS	**RO Group:** 1 **SRO Group:** 1

System/Evolution Title Nuclear Instrumentation System 015

KA Statement: Ability to predict and/or monitor changes in parameters associated with operating the Nuclear Instrumentation System controls including:
Changes in boron concentration

Explanation of Answers: Boration is an added poison, fewer neutrons available for absorption in the fuel, reactor power decreases. The decrease in reactor power results in a lower Tave. As Tave decreases, (+) reactivity is added causing reactor power to increase. (C) correct respoonse.

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Normal Operating Procedures	BwOP CV-6	Precautions	2	14	

Material Required for Examination

Question Source: Facility Exam Bank **Question Modification Method:** Direct From Source **Used During Training Program**

Question Source Comments

Comment Type	Comment

Reviews Complete
Peer
Supervisory
Facility
NRC

72

Question Topic Nuclear Instrumentation System

The following conditions exist on Unit 2

- A normal reactor startup is in progress
- Reactor power is steady at 1000 cps
- PR NI channel N-41 has failed low
- Operators have completed performing 2BwOA INST-1, "Nuclear Instrumentation Malfunction" for the failed PR channel

Seconds later the control power fuses on PR channel N-43 both indicate blown

Which of the following describes the next action to take

a. Verify all rod at bottom lights LIT

b. Manually reinsert all control bank rods

c. Manually reinsert all control and shutdown banks

d. Complete the startup to <P-10 using only IR instruments

Answer	a	**Exam Level**	B	**Cognitive Level**	Application	**Facility:**	Braidwood	**ExamDate:**	7/19/02		
KA:	015000K604	K6.04	**RO Value:**	3.1	**SRO Value:**	3.2	**Section:**	SYS	**RO Group:**	1	**SRO Group:** 1
System/Evolution Title	Nuclear Instrumentation System										015
KA Statement:	Knowledge of the effect of a loss or malfunction on the following will have on the Nuclear Instrumentation System: Bistables and logic circuits										
Explanation of Answers:	automatic trip on PR instruments is active, even at < indictaed PR power. SR instruments are de-energized due to P-10 pickup. (A) is correct. Candidates may confuse 2 PR channel failures with P-10 actuation and blocking of SR instruments which make distractors (B,C,D) plausible but incorrect										

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Braidwood Big Notes		NI-2	1	4	

Material Required for Examination

Question Source: New **Question Modification Method:** **Used During Training Program**

Question Source Comments

Comment Type	Comment

Reviews Complete
Peer
Supervisory
Facility
NRC

Question Topic Non-Nuclear Instrumentation System (NNIS)

Which of the following Main Control Board recorders provides the operator with the option of SELECTING specific channels for trending?

a. 1LR-930 RWST Level

b. 1PR-937 Containment Pressure

c. 1PR-0514 Steam Generator Pressure

d. 1FR-0510 Steam Generator Steam Flow/Feed Flow

Answer	d	**Exam Level**	B	**Cognitive Level**	Memory	**Facility:**	Braidwood	**ExamDate:**	7/19/02		
KA:	016000A402	A4.02	**RO Value:**	2.7	**SRO Value:**	2.6*	**Section:**	SYS	**RO Group:**	2	**SRO Group:** 2

System/Evolution Title Non-Nuclear Instrumentation System 016

KA Statement: Ability to manually operate and/or monitor in the control room:
Recorders

Explanation of Distractors (A,B,D) have no capability to select optional channels on the MCB. (C) has 2 channels available with a MCB selector switch on 1PM04J

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
MCB Layout					
SGWLC LP	I1-FW-XL-01	II	11-14	2	S.FW2-10

Material Required for Examination

Question Source: New **Question Modification Method:** **Used During Training Program**

Question Source Comments

Comment Type	Comment

Reviews Complete
Peer
Supervisory
Facility
NRC

74

Question Topic In-Core Temperature Monitor (ITM) System

The In-Core Temperature Monitoring System is utilized as part of the Power Distribution Monitoring System (PDMS). As such, the MINIMUM number of Incore Thermocouples required to be OPERABLE is (1) with greater than or equal to (2) detector(s) per core quadrant

	(1)	(2)
a.	11	1
b.	14	2
c.	17	2
d.	20	3

Answer	c	**Exam Level**	R	**Cognitive Level**	Memory	**Facility:**	Braidwood	**ExamDate:**	7/19/02

KA:	017000G222	2.2.22	**RO Value:**	3.4	**SRO Value:**	4.1	**Section:**	SYS	**RO Group:**	1	**SRO Group:** 1

System/Evolution Title In-Core Temperature Monitor System 017

KA Statement: Knowledge of limiting conditions for operations and safety limits

Explanation of Answers: TRM 3.3.h requires 17 with greater than or equal to 2 per quadrant. (C) Correct

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Tech Requirements Manual	TRM	PDMS 3.3.h	h-5	16	

Material Required for Examination

Question Source: New **Question Modification Method:** **Used During Training Program**

Question Source Comments

Comment Type	Comment

Reviews Complete
Peer
Supervisory
Facility
NRC

Question Topic In-Core Temperature Monitor (ITM) System

A Loss of Coolant Accident has occurred, core exit thermocouple (CETC) temperatures are reading 690 F and increasing

Which of the following describes the expected response of the CETCs as the Reactor Coolant System and core exit temperatures continue to increase (Assume no core cooling is present)

The CETC's will indicate

a. lower than actual temperature above 700 F, and will stop indicating altogether as temperatures exceed 1200 F

b. accurately up to 1800 F, and can be used for trending purposes up to 2300 F

c. higher than actual temperature above 700 F, and cannot be relied upon for accurate indication above 1200 F

d. accurately up to 1200°F, and will fail completely above 1800°F

Answer	b	Exam Level	R	Cognitive Level	Application	Facility:	Braidwood	ExamDate:	7/19/02

KA:	017000K102	K1.02	RO Value:	3.3	SRO Value:	3.5	Section:	SYS	RO Group:	1	SRO Group:	1

System/Evolution Title In-Core Temperature Monitor System 017

KA Statement: Knowledge of the physical connections and/or cause-effect relationships between In-Core Temperature Monitor System and the following:
RCS

Explanation of Answers: CETCs usable range is 200-1800°F. They are expected to indicate up to 2300°F with reduced accuracy. (B) is correct.

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Inadequate Core Cooling System LP	I1-IT-XL-01	II	8	1	5

Material Required for Examination

Question Source: Facility Exam Bank **Question Modification Method:** Significantly Modified **Used During Training Program**

Question Source Comments

Comment Type	Comment

Reviews Complete
Peer
Supervisory
Facility
NRC

Ke

RO SkyScraper | SRO Skyscraper | RO System/Evolution List | SRO System/Evolution List | Outline Changes

Question Topic Containment Cooling System (CCS)

The following conditions exist on Unit 2

- The reactor is at 100% power, steady state
- 2A and 2C RCFCs are running in high speed
- 2B and 2D RCFCs are in standby
- A reactor trip and Safety Injection occur due to a large break RCS LOCA

Which of the following describes the low speed start response of the RCFCs after the SI signal is received?

a. All four RCFCs start 20 seconds after the SI signal

b. 2A and 2C RCFCs start 20 seconds after the SI signal 2B and 2D RCFCs start immediately

c. All four RCFCs start immediately after the SI signal

d. 2A and 2C RCFCs start immediately after the SI signal, 2B and 2D RCFCs start 20 seconds later

Answer	a	**Exam Level**	B	**Cognitive Level**	Application	**Facility:**	Braidwood	**ExamDate:**	7/19/02		
KA:	022000A401	A4.01	**RO Value:**	3.6	**SRO Value:**	3.6	**Section:**	SYS	**RO Group:**	1	**SRO Group:** 1

System/Evolution Title Containment Cooling System 022

KA Statement: Ability to manually operate and/or monitor in the control room:
CCS fans

Explanation of Answers: Fans already running in slow speed will remain running - none are in this example. All high speed breakers trip (2A & 2C). After a 20 second time delay, slow speed breakers close on non-running fans. (A) correct response.

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Bwd Big Notes	Containment Cooling	VP-3		5	

Material Required for Examination

Question Source: Facility Exam Bank **Question Modification Method:** Significantly Modified **Used During Training Program**

Question Source Comments

Comment Type	Comment

Reviews Complete
Peer
Supervisory
Facility
NRC

Question Topic Containment Cooling System (CCS)

The following conditions exist on Unit 1

- A small RCS LOCA has occurred
- The crew is performing 1BwOA PRI-1 "Excessive Primary Plant Leakage"
- Containment pressure is 2.9 psig and increasing slowly
- RCFC 1C low speed breaker auto SI closure relay failed and was declared inoperable
- Annunciator 1-3-E5, "RCFC LOCAL CONT", is LIT
- RCFC 1C is in LOCAL control at the RSDP and running in HIGH SPEED

Which of the following describes the available operation of the 1C RCFC in the current configuration if containment pressure continues to rise to 4.0 psig?

a. The high speed breaker will automatically trip, the low speed breaker CAN ONLY be closed from the RSDP 20 seconds later

b. The high speed breaker will NOT automatically trip, the low speed breaker CAN NOT be closed at either the RSDP or 1PM06J

c. The high speed breaker will automatically trip, the low speed breaker CAN BE manually closed from 1PM06J 20 seconds later

d. The high speed breaker will NOT automatically trip, the low speed breaker MUST BE closed locally after the high speed breaker is tripped

Answer	c	**Exam Level**	R	**Cognitive Level**	Application	**Facility:**	Braidwood	**ExamDate:**	7/19/02		
KA:	022000G431	2.4.31	**RO Value:**	3.3	**SRO Value:**	3.4	**Section:**	SYS	**RO Group:**	1	**SRO Group:** 1

System/Evolution Title Containment Cooling System 022

KA Statement: Knowledge of annunciators alarms and indications, and use of the response instructions.

Explanation of Answers: RCFC LOCAL CONT indicates that the high speed breaker for the RCFC is in local control. Low speed breaker operation is unaffected by the Local/remote switch. (C) is correct (A) Incorrect - low speed operation is not available at the RSDP. (B) Incorrect - High speed breaker will trip on the SI, 1PM06J low speed operation is available. (D) Incorrect - High speed breaker will trip, 1PM06J low speed operation is available.

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Annunciator Response procedures	BwAR 1-3-E5	NOTE	1	5	

Material Required for Examination

Question Source: New **Question Modification Method:** **Used During Training Program**

Question Source Comments

Comment Type	Comment

Reviews Complete
Peer
Supervisory
Facility
NRC

RO SkyScraper | SRO Skyscraper | RO System/Evolution List | SRO System/Evolution List | Outline Changes

Question Topic Containment Spray System (CSS)

Which of the following valves is interlocked with OPENING of the 1A CS Pump Sump Suction Isolation Valve, 1CS009A?

a. 1SI8809A RHR Cold Leg Injection Isolation Valve

b. 1SI8811A 1A Containment Sump Isolation Valve

c. 1CS007A 1A CS Pump Discharge Isolation Valve

d. 1CS001A 1A CS Pump RWST Suction Isolation Valve

Answer	b	**Exam Level**	B	**Cognitive Level**	Memory	**Facility:**	Braidwood	**ExamDate:**	7/19/02		
KA:	026000K101	K1.01	**RO Value:**	4.2	**SRO Value:**	4.2	**Section:**	SYS	**RO Group:**	2	**SRO Group:** 1

System/Evolution Title Containment Spray System 026

KA Statement: Knowledge of the physical connections and/or cause-effect relationships between Containment Spray System and the following: ECCS

Explanation of Answers: Interlocks for opening 1CS009A are: 1SI8811A Open, 1RH8701A Closed, CS to Open. (B) is only correct answer. (A,C,D) valves are not in interlock circuitry and are incorrect

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
CS LP	I1-XL-CS-01	II	16	2	S.CS1-08-A
Bwd Big Notes	Containment Spray	CS-1		5	

Material Required for Examination

Question Source: Facility Exam Bank **Question Modification Method:** Editorally Modified **Used During Training Program**

Question Source Comments

Comment Type	Comment

Reviews Complete
Peer
Supervisory
Facility
NRC

Question Topic Containment Spray System (CCS)

The following conditions exist on Unit 1

- A reactor trip and safety injection have occurred due to a large break RCS LOCA
- All ECCS equipment functioned normally upon receipt of the SI signal
- Five (5) minutes after the SI was received, Containment Spray (CS) actuation setpoint was exceeded
- Train B of CS started as designed
- Train A of CS did NOT auto start and could NOT be manually started from the Control Room

Which of the following annunciators, if received JUST PRIOR to reaching the CS actuation setpoint, would result in the above status for CS?

a. 1-21-A4 BUS 133X/133Y FD BRKR TRIP

b. 1-22-A4 BUS 134X/134Y FD BRKR TRIP

c. 1-21-A10 BUS 131X FD BRKR TRIP

d. 1-22-A10 BUS 132X FD BRKR TRIP

Answer	c	**Exam Level**	B	**Cognitive Level**	Application	**Facility:**	Braidwood	**ExamDate:**	7/19/02

KA:	026000K202	K2.02	**RO Value:**	2.7*	**SRO Value:**	2.9	**Section:**	SYS	**RO Group:**	2	**SRO Group:** 1

System/Evolution Title Containment Spray System 026

KA Statement: Knowledge of bus power supplies to the following:
MOVs

Explanation of Answers: Interlocks - to auto start 1CS019 must auto open. Power supply is 131X1. For CS to be manually started, 1CS007A must be closed. Power supply is 131X5. To start in recirc, 1SI8811A must be open but we are not in recirc yet. (C) is only correct answer. (D) incorrect - train B P.O. (A&B) incorrect - non esf power supplies.

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
CS lesson Plan	I1-XL-CS-01	II	12-15	2	S.CS1-16
Bwd Big Notes	Containment Spray	CS-1		5	

Material Required for Examination

Question Source: New **Question Modification Method:** **Used During Training Program**

Question Source Comments

Comment Type	Comment

Reviews Complete
Peer
Supervisory
Facility
NRC

Question Topic Hydrogen Recombiner and Purge Control System (HRPS)

Under normal plant conditions, opening the Post LOCA Hydrogen Monitoring outside suction and discharge isloation valves, 1PS228A/B - 1PS230A/B, is accomplished in the Main Control Room from (1) , and indication of containment hydrogen concentration will normally be displayed on the (2) scale

(1) (2)

a. 1PM11J Unit 1 Containment Isolation Panel HI

b. 0PM02J Unit Common Ventillation Panel LO

c. 0PM02J Unit Common Ventillation Panel HI

d. 1PM11J Unit 1 Containment Isolation Panel LO

Answer	d	**Exam Level**	B	**Cognitive Level**	Memory	**Facility:**	Braidwood	**ExamDate:**	7/19/02

KA:	028000A403	A4.03	**RO Value:**	3.1	**SRO Value:**	3.3	**Section:**	SYS	**RO Group:**	3	**SRO Group:** 2

System/Evolution Title Hydrogen Recombiner and Purge Control System 028

KA Statement: Ability to manually operate and/or monitor in the control room:
Location and operation of hydrogen sampling and analysis of containment atmosphere, including alarms and indications

Explanation of Answers: (D) Correct - Controls and indications for 1PS228, 229, and 230A&B valves are all located on the Containment Isolation Panel, 1PM11J. PS343 and PS344 are normally selected to indicate on the LO range (B&C) Incorrect - controls are not located on 0PM02J (A) Incorrect - normally selected to LO range

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Normal Operating Procdures	BwOP PS-9	F.1	2	8E2	

Material Required for Examination

Question Source: New **Question Modification Method:** **Used During Training Program**

Question Source Comments

Comment Type	Comment

Reviews Complete
Peer
Supervisory
Facility
NRC

RO SkyScraper | SRO Skyscraper | RO System/Evolution List | SRO System/Evolution List | Outline Changes

Question Topic Containment Purge System (CPS)

The following conditions exist on Unit 1

- Reactor is at 100%, steady state power
- Containment purge is in progress and is being performed under BwRP 6110-13T1, "Containment Release Form"
- During the release, Health Physics requested 1RE-PR001 be placed in purge for a filter change

Which of the following actions must be taken prior to placing 1RE-PR001 in purge to comply with the requirements of BwRP 6110-13T1 and RETS 2.2-1a?

a. Suspend the containment release of radioactive effluents via this pathway

b. Obtain continuous samples of this pathway with auxiliary sampling equipment

c. Restore the monitor to operable status before the next 30 hour sample is required

d. Verify that Cnmt rad monitor 1RE-AR011 is operable and continue the release

Answer	a	Exam Level	B	Cognitive Level	Comprehension	Facility:	Braidwood	ExamDate:	7/19/02

KA:	029000A204	A2.04	RO Value:	2.5*	SRO Value:	3.2*	Section:	SYS	RO Group:	2	SRO Group:	2

System/Evolution Title Containment Purge System 029

KA Statement: Ability to (a) predict the impacts of the following on the Containment Purge System and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operation:
Health physics sampling of containment atmosphere

Explanation of Answers: isolating 1RE-PR001 renders the noble gas activity monitor inoperable. RETS 2.2.1a requires immediate suspension of purging via this pathway if this occurs. (A) Correct. (B) incorrect - this is an allowable option only for the iodine and particulates functions of 1RE-PR001. (C) incorrect - continuous samples are still required. (D) incorrect - substituting AR011 is not allowed.

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
ODCM RETS - Gaseous effluent monitoring	RETS 2.2-1a		18-20	5	
Containment Release Form	BwRP 6110-13T1	B	8	7	

Material Required for Examination

Question Source: New **Question Modification Method:** **Used During Training Program**

Question Source Comments similar to recent Bwd LER event

Comment Type	Comment

Reviews Complete
Peer
Supervisory
Facility
NRC

Question Topic Containment Purge System (CPS)

The following conditions exist on Unit 1

- An RCS LOCA occurred
- Operators are currently performing steps in Post LOCA Cooldown and Depressurization 1BwEP ES-1.2
- Containment Mini-Flow Purge Exhaust and Post LOCA Purge Exhaust fans are aligned and running

Which common mode failure will result in BOTH the Mini-Flow Purge Exhaust Fan AND the Post LOCA Purge Exhaust Fan tripping?

a. Closure of 1VQ005A, Mini-Flow Purge Exhaust Inside Cnmt Isolation Valve

b. Closure of 1VQ005B, Mini-Flow Purge Exhaust Outside Cnmt Isolation Valve

c. Manual actuation of deluge in the Post LOCA Purge Filter Unit

d. High alarm on the Cnmt Purge rad monitor, 1RE-PR001

Answer	a	**Exam Level**	R	**Cognitive Level**	Application	**Facility:**	Braidwood
ExamDate:	7/19/02						

KA:	029000G449	2.4.49	**RO Value:**	4.0	**SRO Value:**	4.0	**Section:**	SYS	**RO Group:**	2	**SRO Group:** 2

System/Evolution Title Containment Purge System 029

KA Statement:

Ability to perform without reference to procedures those actions that require immediate operation of system components and controls.

Explanation of Answers:

(A) Correct - VQ005A is interlocked with BOTH the mini-flow purge exhaust fan and the post LOCA purge exhaust fan. (B) Incorrect - VQ005B interlocked with ONLY the mini-flow purge exhaust fan. (C) Incorrect - this action will auto close VQ003 which isolates and trips the Post LOCA Purge exhaust fan only. (D) Incorrect - this rad monitor has NO automatic actuations

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Bwd Big Notes - Cnmt Purge	VP-2		1	5	

Material Required for Examination

Question Source: New **Question Modification Method:** **Used During Training Program**

Question Source Comments

Comment Type	Comment

Reviews Complete

Peer

Supervisory

Facility

NRC

Question Topic Spent Fuel Pool Cooling System (SFPCS)

If a leak develops on the discharge of the Spent Fuel Pool Heat Exchanger while the cooling loop is in operation, the Spent Fuel Pool will lose a MAXIMUM of (1) before the FC Pump loses suction. Using BwOP FC-11, makeup water will be added back to the Spent Fuel Pool via the (2)

(1) (2)

a. 4 feet Refueling Water Storage Tank (RWST)

b. 4 inches Volume Control Tank (VCT)

c. 4 inches Refueling Water Storage Tank (RWST)

d. 4 feet Volume Control Tank (VCT)

Answer	a	**Exam Level**	B	**Cognitive Level**	Application	**Facility:**	Braidwood	**ExamDate:**	7/19/02
KA:	033000A203	A2.03	**RO Value:**	3.1	**SRO Value:**	3.5	**Section:** SYS	**RO Group:** 2	**SRO Group:** 2

System/Evolution Title Spent Fuel Pool Cooling System 033

KA Statement: Ability to (a) predict the impacts of the following on the Spent Fuel Pool Cooling System and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operation:

Abnormal spent fuel pool water level or loss of water level

Explanation of Answers: (A) Correct - the pump suction has stops 4 feet below normal water level. The RWST is an available source of makeup water. (B) Incorrect - the 4 inches relates to the anti-siphon hole on the SFP cooling discharge to the pool. The VCT also is not an available option for makeup water. (C) Incorrect - the 4 inches relates to the anti-siphon hole on the SFP cooling discharge to the pool. (D) Incorrect - the VCT is not an available source of makeup water.

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Spent Fuel Pool Level Adjustment Proc	BwOP FC-11	F	3	20	
Spent Fuel Pool Cooling Lesson Plan	I1-FC-XL-01	fig 51-13		1	5.6

Material Required for Examination

Question Source: New **Question Modification Method:** **Used During Training Program**

Question Source Comments

Comment Type	Comment

Reviews Complete

Peer

Supervisory

Facility

NRC

34

Question Topic Fuel Handling Equipment System (SHES)

What prevents raising an irradiated fuel assembly out of the Spent Fuel Pool using the new fuel elevator?

a. Controls for the new fuel elevator will only travel in one direction - there is no upward motion available

b. Upward motion of the new fuel elevator is stopped if surface radiation levels approach 100 mr/hr

c. An upward motion interlock prevents lifting any loads greater than 1200 lbs with the new fuel elevator

d. A slack cable interlock prevents raising the much lighter spent fuel assembly via the new fuel elevator

Answer	c	**Exam Level**	B	**Cognitive Level**	Memory	**Facility:**	Braidwood	**ExamDate:**	7/19/02		
KA:	034000A302	A3.02	**RO Value:**	2.5*	**SRO Value:**	3.1	**Section:**	SYS	**RO Group:**	3	**SRO Group:** 2

System/Evolution Title Fuel Handling Equipment System 034

KA Statement: Ability to monitor automatic operations of the Fuel Handling Equipment System including: Load limits

Explanation of Alternate Choices: (C) Correct - the upward motion interlock is to prevent raising spent fuel out of the SFP, maintaining the required depth of water over the SF for shielding concerns. (A) Incorrect - the new fuel elevator does travel upward (B) Incorrect -there is no rad interlock with the new fuel elevator (D) Incorrect -this is a 02.0" downward motion stop to prevent damage/binding of a lowering assembly

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Fuel Handling LP	I1-FH-XL-01	II	17	1	6

Material Required for Examination

Question Source: Other Facility **Question Modification Method:** Significantly Modified **Used During Training Program**

Question Source Comments 2001 Prairie Island NRC

Comment Type	Comment

Reviews Complete

Peer

Supervisory

Facility

NRC

Question Topic Fuel Handling Equipment System (FHES)

Unit 1 is in Mode 6 and has commenced core off-load. The following conditions exist

- 1B EDG is OOS for overhaul
- 1A FHB Exhaust Filter Plenum is aligned and in service
- Containment mini-purge system is in service
- Fuel Handling Building Radiation Monitor, 0RE-AR055 is OOS
- Fuel Handling Building Radiation Monitor, 0RE-AR056, alarm circuitry has just failed. IMD is troubleshooting

Which of the following describes the required ACTION, if any, to be taken in order to allow core off-load to continue?

a. No ACTION is required, fuel movements may continue uninterrupted

b. Core off-load can NOT be conducted until at least one of the FHB rad monitors is repaired

c. Fuel movement may continue for up to 7 days while restoring one (1) FHB rad monitor to operable status provided 1B FHB Exhaust Filter Plenum is aligned in the Emergency Operating Mode

d. Fuel movement may be conducted indefinitely provided an appropriate portable monitor is provided and the 1A FHB Exhaust Filter Plenum is aligned in the Emergency Operating Mode

Answer	d	**Exam Level**	B	**Cognitive Level**	Application	**Facility:**	Braidwood	**ExamDate:**	7/19/02		
KA:	034000K602	K6.02	**RO Value:**	2.6	**SRO Value:**	3.3	**Section:**	SYS	**RO Group:**	3	**SRO Group:** 2

System/Evolution Title Fuel Handling Equipment System 034

KA Statement: Knowledge of the effect of a loss or malfunction on the following will have on the Fuel Handling Equipment System: Radiation monitoring systems

Explanation of Answers: (A) incorrect - per TRM 3.3.0, with 2 channels inop must place 1 FHB Vent in emergency mode and provide portable monitor or stop fuel movements. (B) Incorrect - may move fuel with vent alignment and protable monitor (C) Incorrect - need to also place portable monitor, and 1B train of FHB Vent has no operable emergency power supply as required by TRM (D) Correct - all actions taken into account.

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Fuel Handling LP	I1-FH-XL-01	II	26-32	52	7.10
Tech Requirements Manual	TRM 3.3.o		1.2	1	

Material Required for Examination

Question Source: New **Question Modification Method:** **Used During Training Program**

Question Source Comments

Comment Type	Comment

Reviews Complete
Peer
Supervisory
Facility
NRC

RO SkyScraper | SRO Skyscraper | RO System/Evolution List | SRO System/Evolution List | Outline Changes | QHom

Question Topic Main and Reheat Steam System (MRSS)

Prior to start up following completion of A2R09, the Unit 2 Main Steam Isolation Valves (MSIVs) were tested to ensure a closure time of < 5 seconds and that each MSIV actuated to it's isolation position on an actual or simulated actuation signal. The basis for performing these surveillances was to limit or mitigate all of the following EXCEPT

a. Accidents that could result in offsite exposures comparable to 10CFR100 limits

b. The potential for uncontrolled RCS cooldown and positive reactivity restart accident

c. Total mass and energy release into containment on a HELB

d. A turbine overspeed condition following a generator trip at power

Answer d | **Exam Level** S | **Cognitive Level** Comprehension | **Facility:** Braidwood | **ExamDate:** 7/19/02

KA: 039000G225 2.2.25 | **RO Value:** 2.5 | **SRO Value:** 3.7 | **Section:** SYS | **RO Group:** 2 | **SRO Group:** 2

System/Evolution Title Main and Reheat Steam System 039

KA Statement: Knowledge of bases in technical specifications for limiting conditions for operations and safety limits.

Explanation of Answers: (A,B,C) Incorrect - these are not exceptions - they are basis statements for MSIV operability. (D) Correct - Credit is not taken for MSIV operability to protect against turbine overspeed.

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Tech Spec Basis - MSIVs	B 3.7.2	Basis	1-7	0	

Material Required for Examination

Question Source: New | **Question Modification Method:** | **Used During Training Program**

Question Source Comments

Comment Type	Comment

Reviews Complete
Peer
Supervisory
Facility
NRC

Question Topic Main Turbine Generator (MTG) System

The following conditions exist on Unit 1

- Reactor power is 80%, steady state
- All systems are in automatic control
- One Main Steam Dump valve, 1MS004A fails 100% open due to a valve positioner failure

What is the expected response of the plant due to the steam dump valve failure AND what action can the operator take from the control room to stop the excess steam flow?

a. Turbine load will decrease by approx. 3% AND reactor power will remain constant. The operator can stop dumping excess steam by taking either Bypass Interlock Switch to OFF RESET

b. Turbine load will remain relatively constant AND reactor power will increase by approx. 3%. The operator can stop dumping excess steam by taking the Steam Dump Mode Selector Switch to STEAM PRESSURE.

c. Turbine load will decrease by approx. 3% AND reactor power will remain constant. The operator can stop dumping excess steam by taking the Steam Dump Mode Selector Switch to STEAM PRESSURE.

d. Turbine load will remain relatively constant AND reactor power will increase by approx. 3%. The operator can stop dumping excess steam by taking either Bypass Interlock Switch to OFF/RESET.

Answer	d	**Exam Level**	B	**Cognitive Level**	Application	**Facility:**	Braidwood	**ExamDate:**	7/19/02		
KA:	045000A208	A2.08	**RO Value:**	2.8	**SRO Value:**	3.1*	**Section:**	SYS	**RO Group:**	3	**SRO Group:** 3

System/Evolution Title Main Turbine Generator System 045

KA Statement: Ability to (a) predict the impacts of the following on the Main Turbine Generator System and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operation:
Steam dumps are not cycling properly at low load, or stick open at higher load (isolate and use atmospheric reliefs when necessary)

Explanation of Answers: (A) Incorrect - turbine load will remain relatively constant with IMP IN (normal at 100%). Reactor power will then increase due to increased steam flow. (B) Incorrect - selecting Steam Pressure Mode will not close the steam dumps if the failure is in the valve positioner. (C) Incorrect - (see A&B). (D) Correct - turbine load is expected to remain relatively constant with IMP IN, reactor power will increase due to increased steam flow, and either Steam Dump Bypass Interlock switch in OFF/RESET will close all steam dumps (train A&B)

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Bwd Big Notes	MS-4	Main Steam	1	6	

Material Required for Examination

Question Source: Other Facility **Question Modification Method:** Editorially Modified **Used During Training Program**

Question Source Comments 2001 Prairie Island

Comment Type	Comment

Reviews Complete
Peer
Supervisory
Facility
NRC

Question Topic Main Turbine Generator (MT/G) System

Once every 31 days each of the 12 extraction steam nonreturn check valves are tested by observing freedom of movement of the weight arms on each valve. This testing is performed to ensure:

a. Steam line breaks which occur outside the Auxiliary Building are positively isolated

b. Flooding does not occur in feedwater heaters, limiting the ability to restart following a reactor trip

c. Excessive overspeed of the turbine does not occur following a turbine generator trip

d. Overpressurization of the main condenser does not occur if feedwater heater levels increase too high

Answer	c	**Exam Level**	S	**Cognitive Level**	Memory	**Facility:**	Braidwood	**ExamDate:**	7/19/02		
KA:	045000G225	2.2.25	**RO Value:**	2.5	**SRO Value:**	3.7	**Section:**	SYS	**RO Group:**	3	**SRO Group:** 3

System/Evolution Title Main Turbine Generator System 045

KA Statement: Knowledge of bases in technical specifications for limiting conditions for operations and safety limits.

Explanation of Answers: Nonreturn check valves (12) are part of the turbine overspeed protection circuitry and thus protect the turbine from overspeed following a normal turbine trip, specifically from steam flashing in feedwater heaters from reentering the MT. (C) Is correct. (A,B,D) are not discussed and are not part of the basis for turbine overspeed protection.

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Tech Specs - TRM	TRM 3.3.g	TSR 3.3.g.2	g-2	1	
Old Tech Spec Basis Doc	B 3/4 3-6	Turb Overspeed	3-6		

Material Required for Examination

Question Source: New **Question Modification Method:** **Used During Training Program**

Question Source Comments

Comment Type	Comment
SRO	TS Basis

Reviews Complete
Peer
Supervisory
Facility
NRC

Question Topic Main Feedwater (MFW) System

The following conditions exist on Unit 1

- Reactor is at 100% power, steady state
- All control systems are in automatic
- Instrument Air is lost to one feedwater regulating valve FRV-510

If no action is taken in response to the FRV, which of the following describes the response of the plant AND followup action required by the MCB operator?

a. "TURBINE TRIP ABOVE P-8" trips the reactor. All Main Feedwater Pumps AUTOMATICALLY trip. Operator must simply VERIFY Feedwater Isolation AUTOMATICALLY occurs.

b. "TURBINE TRIP ABOVE P-8" trips the reactor. All Main Feedwater Pumps must be MANUALLY tripped in EP-0. Operator must MANUALLY close all Feedwater Isolation Valves.

c. "S/G 1A LEVEL LO-2" trips the reactor. All Main Feedwater Pumps AUTOMATICALLY trip. Operator must MANUALLY close all Feedwater Isolation Valves.

d. "S/G 1A LEVEL LO-2" trips the reactor. All Main Feedwater Pumps must be MANUALLY tripped in EP-0. Operator must simply VERIFY Feedwater Isolation AUTOMATICALLY occurs.

Answer	d	**Exam Level**	R	**Cognitive Level**	Application	**Facility:**	Braidwood	**ExamDate:**	7/19/02

KA:	059000A212	A2.12	**RO Value:**	3.1*	**SRO Value:**	3.4*	**Section:**	SYS	**RO Group:**	1	**SRO Group:** 1

System/Evolution Title Main Feedwater System 059

KA Statement: Ability to (a) predict the impacts of the following on the Main Feedwater System and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operation:
Failure of feedwater regulating valves

Explanation of Answers: (D) Correct - FRVs fail closed on loss of air. SG level will decrease to the lo-2 rx trip setpoint. Lo-2 level does not trip the MFPs. P-4 initiates FW isolation. (A&B) Incorrect - FRV fails closed, levels decrease. (C) Incorrect - Lo-2 level does not trip the MFPs. P-4 does initiate FW isolation.

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Annunciator response proc	BwAR 1-11-A8		1	8E1	
Bwd Big Notes	FW-1		1	4	

Material Required for Examination

Question Source: New **Question Modification Method:** **Used During Training Program**

Question Source Comments

Comment Type	Comment

Reviews Complete
Peer
Supervisory
Facility
NRC

Question Topic Main Feedwater (MFW) System

At 50% power on both units, the Steam Generator programmed level for each unit is

	Unit 1	Unit 2
a.	33.0%	36.3%
b.	50.0%	50.0%
c.	60.0%	63.7%
d.	81.0%	80.8%

Answer	c	**Exam Level**	R	**Cognitive Level**	Memory	**Facility:**	Braidwood	**ExamDate:**	7/19/02		
KA:	059000A302	A3.02	**RO Value:**	2.9	**SRO Value:**	3.1	**Section:**	SYS	**RO Group:**	1	**SRO Group:** 1

System/Evolution Title Main Feedwater System 059

KA Statement: Ability to monitor automatic operations of the Main Feedwater System including:
Programmed levels of the S/G

Explanation of Answers: Program levels are U-1 at 60.0%, U-2 at 63.3%, from the full range 0 to 100% power. (C) is only correct response

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
SGWLC Lesson Plan	I1-FW-XL-01	II	11	2	2

Material Required for Examination

Question Source: Facility Exam Bank **Question Modification Method:** Editorially Modified **Used During Training Program**

Question Source Comments

Comment Type	Comment

Reviews Complete
Peer
Supervisory
Facility
NRC

Question Topic Main Feedwater (MFW) System

The following conditions exist on Unit 1

- Preparations are underway to perform a reactor startup per 1BwGP 100-2, "Reactor Startup"
- Steam Generator levels are being maintained utilizing tempering line flow via 1FW034A-D and 1FW035A-D
- When testing the reactor trip breakers per step 13 of 1BwGP 100-2, 1FW035D did not automatically close
- 1FW035D was manually closed by the NSO and the condition reported to the Unit Supervisor
- All other feedwater valves responded as designed

Given the above failure, per Tech Specs the reactor startup will

a. Be ALLOWED to continue with BOTH 1FW035D and 1FW034D controlling tempering line flow. Since at least one valve in the line isolated to it's required position, the safety function will not be challenged.

b. Be ALLOWED to continue, however, 1FW035D must be declared inoperable and closed with power removed from its valve actuator. The Unit is then allowed to operate indefinitely in this configuration

c. NOT be allowed to continue because BOTH valves in this line must be OPERABLE to ensure positive isolation and prevent containment out leakage in the event of an accident.

d. NOT be allowed to continue. In addition to 1FW035D being inoperable, the Aux Relay function of feedwater isolation must be declared inoperable which precludes any future Mode changes until repaired.

Answer	b	**Exam Level**	S	**Cognitive Level**	Comprehension	**Facility:**	Braidwood	**ExamDate:**	7/19/02		
KA:	059000G133	2.1.33	**RO Value:**	3.4	**SRO Value:**	4.0	**Section:**	SYS	**RO Group:**	1	**SRO Group:** 1

System/Evolution Title Main Feedwater System 059

KA Statement: Ability to recognize indications for system operating parameters which are entry-level conditions for technical specifications.

Explanation/Answers: (A) Incorrect - in order to perserve the safety function, 1FW034D must be closed with power removed - single failure. (B) Correct - 3.6.3 does not require mode reduction if the required action is completed within the time allowed. (C) Incorrect - one valve may be inoperable if closed with power removed. Required action then does not restrict power operations or mode changes (D) Incorrect - the aux relay function has not been affected.

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Tech Specs	3.3.2 ESFAS	Funct 5	2-12	A115	

Material Required for Examination

Question Source: New **Question Modification Method:** **Used During Training Program**

Question Source Comments

Comment Type	Comment

Reviews Complete
Peer
Supervisory
Facility
NRC

92

Question Topic Auxiliary / Emergency Feedwater (AFW) System

The FIRST signal to automatically start both Aux Feedwater Pumps on each respective unit is received as steam generator level passes from normal operating level through (1) % on Unit 1 and (2) % on Unit 2.

(1) (2)

a. 12.0 22.8

b. 18.0 36.3

c. 23.0 41.3

d. 88.0 80.8

Answer	b	**Exam Level**	R	**Cognitive Level**	Memory	**Facility:**	Braidwood	**ExamDate:**	7/19/02		
KA:	061000K101	K1.01	**RO Value:**	4.1	**SRO Value:**	4.1	**Section:**	SYS	**RO Group:**	1	**SRO Group:** 1

System/Evolution Title Auxiliary / Emergency Feedwater System 061

KA Statement: Knowledge of the physical connections and/or cause-effect relationships between Auxiliary / Emergency Feedwater System and the following: S/G system

Explanation of Answer: LO-2 SG Levels (2/4) will automatically start both AFW pump on each respective unit. Lo-2 U-1=18.0%, U-2=36.3%

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Annunciator Response Procs	BwAR 1/2-15-D5		1	8	

Material Required for Examination

Question Source: New **Question Modification Method:** **Used During Training Program**

Question Source Comments

Comment Type	Comment

Reviews Complete

Peer

Supervisory

Facility

NRC

Question Topic Auxiliary / Emergency Feedwater (AFW) System

The following conditions exist on Unit 1

- A reactor trip / turbine trip has occurred
- The crew has transitioned out of 1BwEP-0 to 1BwEP ES-0.1 "Reactor Trip Response"
- Step 2 is being performed, "Maintain RCS Temperature Control"
- All steam generator pressures are at 1050 psig and decreasing slowly
- All steam generator narrow range levels are <10%
- RCS temperature is 553°F and decreasing slowly

Which of the following actions is required to control and minimize the cooldown of the RCS?

a. Maintain maximum AFW flow until steam generator NR levels are >25%, then decrease total AFW flow to 500 gpm

b. Decrease total AFW flow, maintaining >500 gpm until SG NR levels are >10%, then throttle as needed to control cooldown

c. Immediately decrease total AFW flow to approximately 25 gpm per SG

d. Stop the AFW pumps, if operating, and isolate them from the steam generators

Answer	b	**Exam Level**	R	**Cognitive Level**	Application	**Facility:**	Braidwood	**ExamDate:**	7/19/02		
KA:	061000K104	K1.04	**RO Value:**	3.9	**SRO Value:**	4.1	**Section:**	SYS	**RO Group:**	1	**SRO Group:** 1

System/Evolution Title Auxiliary / Emergency Feedwater System 061

KA Statement: Knowledge of the physical connections and/or cause-effect relationships between Auxiliary / Emergency Feedwater System and the following: RCS

Explanation of Answers: per 1BwEP ES-0.1, step 2 RNO. Maintain total AFW flow >500 gpm until NR levels are >10% in at least one SG. Then no further restrictions are place on AFW flow rates. (B) Correct (A) Incorrect - 25% level & 500 gpm are too high. (C) Incorrect - cannot reduce AFW flow <500 gpm until NR levels are >10% (D) Incorrect - cannot reduce AFW flow <500 gpm until NR levels are >10%

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Reactor Trip Response & Basis	1BwEP ES-0.1	step 2 RNO	3	100	

Material Required for Examination

Question Source: Facility Exam Bank **Question Modification Method:** Editorially Modified **Used During Training Program**

Question Source Comments

Comment Type	Comment

Reviews Complete

Peer

Supervisory

Facility

NRC

94

Question Topic A.C. Electrical Distribution System

A loss of all AC power has occurred on Unit 1. The crew is performing 1BwCA-0.0, "Loss of All AC Power", and is preparing to cross-tie to Unit 2 using a limited crosstie to ESF Bus 241. DG 2A is supplying the bus. You have been assigned to monitor ESF Bus amperage as loads are restored on Bus 141.

Which of the following loads will draw the largest running amperage?

a. 1A MCR Chiller

b. 1A RCFC

c. 1A SX Pump

d. 1A CV Pump

Answer	c	**Exam Level**	R	**Cognitive Level**	Memory	**Facility:**	Braidwood	**ExamDate:**	7/19/02		
KA:	062000A301	A3.01	**RO Value:**	3.0	**SRO Value:**	3.1	**Section:**	SYS	**RO Group:**	2	**SRO Group:** 2
System/Evolution Title	A.C. Electrical Distribution										062
KA Statement:	Ability to monitor automatic operations of the A.C. Electrical Distribution including: Vital ac bus amperage										
Explanation of Answers:	(A) Incorrect - chiller draws 47 amps (B) Incorrect - RCFC draws 14 amps (Lo speed start as allowd in 0.0) (C) Correct - 1A SX draws 156 amps (D) Incorrect - 1A CV draws 63 amps										

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Loss of All AC - Contingency Procedure	1BwCA-0.0	steps 21,40,18,24		100wog1	
Loss of 4KV ESF Bus	1BwOA ELEC-3	step 5 attach A	8	56	

Material Required for Examination

Question Source:	New	**Question Modification Method:**		**Used During Training Program**
Question Source Comments				

Comment Type	Comment	Reviews Complete
		Peer
		Supervisory
		Facility
		NRC

95

RO SkyScraper | SRO Skyscraper | RO System/Evolution List | SRO System/Evolution List | Outline Changes

Question Topic A C Electrical Distribution System

A reactor trip has just occurred on Unit 1
The automatic bus transfer (ABT) failed to operate for Bus 156

Which of the following loads is now unavailable?

a. 1A Motor Driven Main Feed Pump

b. 1A Startup Feedwater Pump

c. 1A Condensate Pump

d. 1A Heater Drain Pump

Answer	a	**Exam Level**	B	**Cognitive Level**	Application	**Facility:**	Braidwood	**ExamDate:**	7/19/02		
KA:	062000K201	K2.01	**RO Value:**	3.3	**SRO Value:**	3.4	**Section:**	SYS	**RO Group:**	2	**SRO Group:** 2

System/Evolution Title A.C Electrical Distribution 062

KA Statement: Knowledge of bus power supplies to the following:
Major system loads

Explanation of Answers: (A) Correct - powered from 156 (B) Incorrect - startup FWP from 159 (C) Incorrect - 1A CD/CB from 159 (D) Incorrect - 1A HDP from 157

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
AC Distribution LP	I1-AP-XL-01	II	29,30	1	12

Material Required for Examination

Question Source: Facility Exam Bank **Question Modification Method:** Direct From Source **Used During Training Program**

Question Source Comments 2001 Bwd NRC

Comment Type	Comment

Reviews Complete
Peer
Supervisory
Facility
NRC

90

RO SkyScraper | SRO Skyscraper | RO System/Evolution List | SRO System/Evolution List | Outline Changes

Question Topic D.C. Electrical Distribution System

Which of the following describes how a Reactor Trip Breaker will respond to a LOSS of 125 VDC control power? (Assume the breaker is closed when the loss of control power occurs)

a. Trips OPEN due to loss of power to the SHUNT coil

b. Trips OPEN due to loss of power to the UNDERVOLTAGE coil

c. is NOT capable of tripping on a SHUNT trip

d. is NOT capable of tripping on a UNDERVOLTAGE trip

Answer	c	**Exam Level**	B	**Cognitive Level**	Application	**Facility:**	Braidwood	**ExamDate:**	7/19/02		
KA:	063000K201	K2.01	**RO Value:**	2.9*	**SRO Value:**	3.1*	**Section:**	SYS	**RO Group:**	2	**SRO Group:** 1

System/Evolution Title D.C. Electrical Distribution 063

KA Statement: Knowledge of bus power supplies to the following:
Major dc loads

Explanation of Answers: A. Incorrect because the shunt coil is normally de-energized. B. & D. incorrect beause the undervoltage coil is supplied with 48v power from SSPS

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Electrical Prints	20E-1-4030-RD6	N/A	1	P	
Solid State Protection System	I1-RP-XL-04	II	9.17	0	4.10

Material Required for Examination

Question Source: Facility Exam Bank **Question Modification Method:** **Used During Training Program**

Question Source Comments 2000 Bwd NRC. 1998 Calloway NRC Exam

Comment Type	Comment

Reviews Complete
Peer
Supervisory
Facility
NRC

Question Topic Emergency Diesel Generator (ED G) System

When synchronizing an Emergency Diesel Generator to an energized ESF bus immediately after closing the generator output breaker, load the EDG to 500KW by going to (1) on the Diesel Generator (2)

(1) (2)

a. Raise Governor Adjust Control

b. Raise Voltage Adjust Control

c. Lower Governor Adjust Control

d. Lower Voltage Adjust Control

Answer	a	**Exam Level**	B	**Cognitive Level**	Application	**Facility:**	Braidwood	**ExamDate:**	7/19/02		
KA:	064000A108	A1.08	**RO Value:**	3.1	**SRO Value:**	3.4	**Section:**	SYS	**RO Group:**	2	**SRO Group:** 2

System/Evolution Title Emergency Diesel Generators 064

KA Statement: Ability to predict and/or monitor changes in parameters associated with operating the Emergency Diesel Generators controls including:
Maintaining minimum load on ED/G (to prevent reverse power)

Explanation of Answers: (B) is correct. (A) Incorrect - lowering DG Speed will decrease load, approaching the reverse power trip setpoint (C&D) are incorrect - adjusting the voltage control will not affect DG loading

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Diesel Generator Startup	BwOP DG-11	F	13	23	

Material Required for Examination

Question Source: New **Question Modification Method:** **Used During Training Program**

Question Source Comments

Comment Type	Comment

Reviews Complete
Peer
Supervisory
Facility
NRC

Question Topic Liquid Radwaste System (LRS)

What TWO conditions will INDEPENDENTLY cause automatic closure of Liquid Radwaste Release Tank Discharge Key Locked Valve 0WX353?

a. Low circulating water blowdown flow and high radiation sensed in the CW blowdown flow

b. Low circulating water blowdown flow and high radiation sensed in the release header

c. High release header flow and high radiation sensed in the release header

d. High release header flow and high radiation sensed in the CW blowdown flow

Answer	b	**Exam Level**	B	**Cognitive Level**	Memory	**Facility:**	Braidwood	**ExamDate:**	7/19/02		
KA:	068000A404	A4.04	**RO Value:**	3.8	**SRO Value:**	3.7	**Section:**	SYS	**RO Group:**	1	**SRO Group:** 1

System/Evolution Title Liquid Radwaste System 068

KA Statement: Ability to manually operate and/or monitor in the control room: Automatic isolation

Explanation of Answers: Per BwOP WX-526T1, (B) is only correct combination provided

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Liquid radwaste release form	BwOP WX-526T1	E.G	22.33	18	

Material Required for Examination

Question Source: Facility Exam Bank **Question Modification Method:** Editorially Modified **Used During Training Program**

Question Source Comments 1999 Bwd NRC

Comment Type	Comment

Reviews Complete
Peer
Supervisory
Facility
NRC

99

RO SkyScraper | SRO Skyscraper | RO System/Evolution List | SRO System/Evolution List | Outline Changes | QNum 308

Question Topic Liquid Radwaste System (LRS)

An operator spent 30 minutes in a field of 150 mr/hour lining up to transfer the contents of one liquid radwaste monitor tank to another. He said later that if he had 'preplanned' his work he could have been finished in 20 minutes. How much dose could have been avoided if he had preplanned the job?

a. 50 mrem

b. 25 mrem

c. 12.5 mrem

d. 10.5 mrem

Answer b **Exam Level** R **Cognitive Level** Application **Facility:** Braidwood **ExamDate:** 7/19/02

KA: 068000K503 K5.03 **RO Value:** 2.6 **SRO Value:** 2.6 **Section:** SYS **RO Group:** 1 **SRO Group:** 1

System/Evolution Title Liquid Radwaste System 068

KA Statement: Knowledge of the operational implications of the following concepts as they apply to the Liquid Radwaste System: Units of radiation, dose, and dose rate

Explanation of Answers: 150mrem / 60min x 20min = 50mrem if done in 20 minutes. Savings of 75-50=25 mrem (B) Correct

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Health Physics / NGET					
Rad Protection LP		Practice problems	1-35		8

Material Required for Examination

Question Source: Facility Exam Bank **Question Modification Method:** Editorially Modified **Used During Training Program**

Question Source Comments

Comment Type	Comment

Reviews Complete
Peer
Supervisory
Facility
NRC

100

Question Topic Waste Gas Disposal System (WGDS)

Which of the following REDUCES the possibility of an unintentional radioactive release to the atmosphere from a Waste Gas Decay Tank (WGDT) relief valve lifting?

a. OGW014, Waste Gas Discharge valve, will close automatically on detected high radiation in the discharge header, isolating the relief path

b. WGDT relief valves discharge directly to the vent header so that flow is directed from the online tank directly to the standby tank

c. The waste gas Compressor discharge pressure is automatically limited to less than the WGDT relief valve pressure setpoint

d. WGDT inlet valve closes automatically on high pressure isolating the on-line WGDT and directing flow to the standby WGDT

Answer	d	**Exam Level**	B	**Cognitive Level**	Application	**Facility:**	Braidwood	**ExamDate:**	7/19/02		
KA:	071000K305	K3.05	**RO Value:**	3.2	**SRO Value:**	3.2	**Section:**	SYS	**RO Group:**	1	**SRO Group:** 1
System/Evolution Title	Waste Gas Disposal System										
KA Statement:	Knowledge of the effect that a loss or malfunction of the Waste Gas Disposal System will have on the following: ARM and PRM systems										071
Explanation of Answers:	(D) Correct - tanks are automatically switched on high pressure. (A) incorrect - all reliefs discharge downstream of 0WX014 so the relief path is not isolated (B) Incorrect - discharge is to the plant vent (C) incorrect - discharge of the compressor has no affect on the suction (tank header)										

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Gaseous Radwaste LP	I1-GW-XL-01	II	12-14	0	6.10
Bwd Big Notes	RW-1			0	

Material Required for Examination

Question Source: Facility Exam Bank **Question Modification Method:** Editorially Modified **Used During Training Program**

Question Source Comments 1999 Bwd NRC

Comment Type	Comment

Reviews Complete

Peer

Supervisory

Facility

NRC

Question Topic Area Radiation Monitoring (ARM) System

Radiation levels in the Fuel Handling Building INCREASED causing BOTH Fuel Handling Incident radiation monitors (AR055 and AR056) to simultaneously reach their actuation setpoints

Which of the following would AUTOMATICALLY occur due to this condition?

a. B Train FHB Charcoal Booster Fan starts, then A Train FHB Charcoal Booster Fan starts

b. B Train FHB Charcoal Booster Fan will start ONLY if A Train has failed to start

c. A Train FHB Charcoal Booster Fan starts, then B Train Charcoal Booster Fan starts

d. A Train FHB Charcoal Booster Fan will start ONLY if B Train has failed to start

Answer	d	**Exam Level**	B	**Cognitive Level**	Memory	**Facility:**	Braidwood	**ExamDate:**	7/19/02		
KA:	072000A301	A3.01	**RO Value:**	2.9*	**SRO Value:**	3.1	**Section:**	SYS	**RO Group:**	1	**SRO Group:** 1

System/Evolution Title Area Radiation Monitoring System 072

KA Statement: Ability to monitor automatic operations of the ARM system including:
Changes in ventilation alignment

Explanation of Answers: A. Incorrect. Damper interlocks prevent both trains from starting. B Train gets a start signal first. When it starts, it's dampers position, an interlock preventing the start of A Train. B. Incorrect - it is the reverse of D, the correct answer. C. Incorrect - B gets the start signal first. D. Correct

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Norse Notes Aux Bldg Vent	VA-2	FHB Interlocks			
System LP CH 43A			11.34.35		

Material Required for Examination

Question Source: Facility Exam Bank **Question Modification Method:** Direct From Source **Used During Training Program**

Question Source Comments 2001 Bwd NRC

Comment Type	Comment

Reviews Complete
Peer
Supervisory
Facility
NRC

102

RO SkyScraper | SRO Skyscraper | RO System/Evolution List | SRO System/Evolution List | Outline Changes

Question Topic Area Radiation Monitoring (ARM) System

The detector for 1RT-AR011J, Containment Fuel Handling Incident Train A Rad Monitor, has failed causing the output of the monitor to go high

Which of the following automatic actions will occur as a result of this failure?

a. OVA04CA, Fuel Handling Charcoal Booster Fan is started

b. 1VQ004A, Containment Mini-Flow Purge Supply Isolation Valve is closed

c. 1VQ003, Post LOCA Charcoal Filter Isolation Valve is opened

d. 1VQ003C, Post LOCA purge exhaust fan is started

Answer b **Exam Level** B **Cognitive Level** Memory **Facility:** Braidwood **ExamDate:** 7/19/02

KA: 072000K401 K4.01 **RO Value:** 3.3* **SRO Value:** 3.6* **Section:** SYS **RO Group:** 1 **SRO Group:** 1

System/Evolution Title Area Radiation Monitoring System 072

KA Statement: Knowledge of ARM system design feature(s) and or interlock(s) which provide for the following: Containment ventilation isolation

Explanation of Answers: (A) Incorrect - this fan is started via AR055&56 skids, not AR11J or 12J (B) Correct - this is part of the cnmt isolation signal generated. (C&D) Incorrect - these receive no auto actuation signal from any rad monitor.

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
RM-11 annunciator response	BwAR 4-1AR011J	B	1	2	
Bwd Big Notes - Cnmt Purge	VP-2			5	

Material Required for Examination

Question Source: Facility Exam Bank **Question Modification Method:** Significantly Modified **Used During Training Program**

Question Source Comments

Comment Type	Comment

Reviews Complete

Peer

Supervisory

Facility

NRC

Question Topic Circulating Water System

The following conditions exist on Unit 1

- A loss of all Circulating Water Pumps has occurred due to excessive grass collection in the intake bay
- A reactor trip / turbine trip was manually initiated by the operators
- During performance of 1BwEP-0, a SGTR occurred on the 1B steam generator
- The crew transitioned to and performed actions contained in 1BwEP-3, "Steam Generator Tube Rupture"
- The RCS cooldown and depressurization steps to equalize RCS and ruptured SG pressure have been completed
- SI was terminated and the crew is now investigating the appropriate post-SGTR cooldown method to use
- While investigating cooldown options, RCS subcooling was lost
- Additional ECCS pumps have been started and aligned, but subcooling is not recovering

Which of the following procedures must be used to continue the post SGTR cooldown and recovery actions from this point?

a. 1BwEP-3 "SGTR" must be continued until conditions exist for establishing RHR shutdown cooling

b. 1BwEP ES-3.1, "Post-SGTR Cooldown Using Backfill" must be used quickly to recover Pzr level and subcooling

c. 1BwEP ES-3.3, "Post-SGTR Cooldown Using Steam Dumps" must be used as this is the preferred method of recovery

d. 1BwCA-3.1, "SGTR With Loss of Reactor Coolant, Subcooled Recovery Desired" is the only option available and must be implemented

Answer	d	**Exam Level**	S	**Cognitive Level**	Application	**Facility:**	Braidwood	**ExamDate:**	7/19/02		
KA:	075000G406	2.4.6	**RO Value:**	3.1	**SRO Value:**	4.0	**Section:**	SYS	**RO Group:**	2	**SRO Group:** 2
System/Evolution Title	Circulating Water System										075

KA Statement: Knowledge symptom based EOP mitigation strategies.

Explanation of Answers: (A) Incorrect - step 38, Go to Appropriate Post-SGTR Cooldown Method, is the LAST step in EP-3. There is no continuation from here without a transition. (B) Incorrect - OAS and step 2 of ES-3.1 require transition to CA-3.1 with the loss of subcooling. (C) Incorrect - same as B, and with loss of CW, no condenser vacuum exists to use steam dump system. (D) Correct - as required by each procedure's OAS and step 2 in each post-SGTR cooldown procedure.

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
EOPS - SGTR	1BwEP-3	step 38 & OAS	45	100	
Post-SGTR Cooldown procedures	1BwEP ES-3.1 & 3.3	step 2 & OAS	3	1A	
EP-3 Basis	Background Docs	ES-3.1 step 2	21	1C	

Material Required for Examination

Question Source: New **Question Modification Method:** **Used During Training Program**

Question Source Comments

Comment Type	Comment
SRO	Assessment of conditions - selection of appropriate recovery procedures

Reviews Complete
Peer
Supervisory
Facility
NRC

Question Topic Fire Protection System (FPS)

Which of the following Fire Protection subsystems is used to provide coverage for the 1B Auxiliary Feedwater Pump?

a. Foam

b. Water

c. Halon

d. CO2

Answer	d	**Exam Level**	B	**Cognitive Level**	Memory	**Facility:**	Braidwood	**ExamDate:**	7/19/02		
KA:	086000K103	K1.03	**RO Value:**	3.4*	**SRO Value:**	3.5*	**Section:**	SYS	**RO Group:**	2	**SRO Group:** 2

System/Evolution Title Fire Protection System 086

KA Statement: Knowledge of the physical connections and/or cause-effect relationships between Fire Protection System and the following: AFW System

Explanation of Answers: (D) Correct. It is the only FP system in the 1B AFW Room

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Bwd Big Notes	FP-2			1	
Fire Protection LP	I1-FP-XL-01	II			

Material Required for Examination

Question Source: New **Question Modification Method:** **Used During Training Program**

Question Source Comments

Comment Type	Comment

Reviews Complete

Peer

Supervisory

Facility

NRC

105

Question Topic Fire Protection System (FPS)

In which ONE of the following areas is water NOT used as the primary fire supression agent?

a. MPT/UAT/SAT transformers

b. Upper Cable Spreading Room

c. Hydrogen Seal Oil Units

d. Ventillation Charcoal Filters

Answer	b	**Exam Level**	B	**Cognitive Level**	Memory	**Facility:**	Braidwood	**ExamDate:**	7/19/02		
KA:	086000K503	K5.03	**RO Value:**	3.1	**SRO Value:**	3.4	**Section:**	SYS	**RO Group:**	2	**SRO Group:** 2

System/Evolution Title Fire Protection System 086

KA Statement: Knowledge of the operational implications of the following concepts as they apply to the Fire Protection System:
Effect of water spray on electrical components

Explanation of Answers: water is not used where damage may result from spray on equipment. (B) is correct answer.

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Bwd Big Notes - Fire Protection	FP-2			1	

Material Required for Examination

Question Source: New **Question Modification Method:** **Used During Training Program**

Question Source Comments

Comment Type	Comment

Reviews Complete
Peer
Supervisory
Facility
NRC

Question Topic Generic

In accordance with the Pre-Job Briefing Checklist which of the following is NOT one of the 4 Key Questions asked?

a. What are the Critical Steps in this task?

b. What are the Error Likely Situations?

c. What Defenses are we relying on?

d. Who is in Charge of the evolution?

Answer	d	**Exam Level**	R	**Cognitive Level**	Memory	**Facility:**	Braidwood	**ExamDate:**	7/19/02		
KA:	194001G101	2.1.1	**RO Value:**	3.7	**SRO Value:**	3.8	**Section:**	PWG	**RO Group:**	1	**SRO Group:** 1

System/Evolution Title GENERI

KA Statement: Knowledge of conduct of operations requirements.

Explanation of Answers: (A,B,C) Incorrect - all 3 are included on the pre-job brief checklist. The fourth is "What is the Worst Thing that can go wrong" (D) is Correct answer - it is NOT included.

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Pre-Job, Heightened... Briefings	HU-AA-1211	Attachment 1	1	0	

Material Required for Examination

Question Source: New **Question Modification Method:** **Used During Training Program**

Question Source Comments

Comment Type	Comment

Reviews Complete

Peer

Supervisory

Facility

NRC

Question Topic Generic

In accordance with BwAP 320-1, "Shift Staffing", the MINIMUM shift staffing requirement to comply with Tech Specs with BOTH units at power include

RP Tech NSO

a. 2 3

b. 2 4

c. 1 3

d. 1 4

Answer	c	**Exam Level**	S	**Cognitive Level**	Memory	**Facility:**	Braidwood	**ExamDate:**	7/19/02		
KA:	194001G104	2.1.4	**RO Value:**	2.3	**SRO Value:**	3.4	**Section:**	PWG	**RO Group:**	1	**SRO Group:** 1

System/Evolution Title GENERI

KA Statement: Knowledge of shift staffing requirements.

Explanation of Answers: (C) Correct - per TS 3.5.2, a RP Tech shall be onsite when fuel is in the reactor. 3 NSOs are required per 50.54

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Shift Staffing	BwAP 320-1	C	2	14	
Tech Specs	5.2.2	Organization	5.2-2	A98	

Material Required for Examination

Question Source: Facility Exam Bank **Question Modification Method:** Significantly Modified **Used During Training Program**

Question Source Comments 2001 Bwd NRC

Comment Type	Comment
SRO	TS Admin 5.2.2

Reviews Complete

Peer

Supervisory

Facility

NRC

Question Topic Generic

In accordance with OP-AA-101-110 "Reactivity management Controls", which of the following NON-LICENSED individuals can manipulate the controls of the reactor if under the direct supervision of the licensed Reactor Operator?

a. An individual enrolled in a approved training program

b. A System Engineer during surveillance testing

c. Any Non-Licensed Operator during surveillance testing

d. Any individual directed to operate controls by the Shift Manager

Answer	a	**Exam Level**	B	**Cognitive Level**	Memory	**Facility:**	Braidwood	**ExamDate:**	7/19/02
KA:	194001G109	2.1.9	**RO Value:**	2.5	**SRO Value:**	4.0	**Section:**	PWG	**RO Group:** 1 **SRO Group:** 1

System/Evolution Title GENERI

KA Statement: Ability to direct personnel activities inside the control room.

Explanation of Answers: (A) Correct - per the reference, must "ensure trainees manipulating reactivity controls are enrolled in an approved training program and directly supervised by a licensed individual" (B,C,D) are then Incorrect

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Reactivity Management Control	OP-AA-103-104	3.5.3	2	0	
Reactivity Management Control LP	PBIG	NA	NA	0	2

Material Required for Examination

Question Source: Facility Exam Bank **Question Modification Method:** Editorially Modified **Used During Training Program**

Question Source Comments 2000 Bwd NRC 1996 Bwd NRC

Comment Type	Comment

Reviews Complete

Peer

Supervisory

Facility

NRC

Question Topic Generic

The Unit 1 NSO is throttling 1AF013A, S/G 1A ISOL VLV, to adjust AFW flow to 75 gpm. In doing so, he has operated 1AF013A TWO (2) times in the last 10 seconds.

The NSO is now limited to operating the valve (1) times in the next 50 seconds to prevent (3)

(1) (2)

a. 3 Overfeeding the 1A SG

b. 3 Overheating the valve motor

c. 4 Overfeeding the 1A SG

d. 4 Overheating the valve motor

Answer	b	Exam Level	B	Cognitive Level	Application	Facility:	Braidwood	ExamDate:	7/19/02

KA:	194001G132	2.1.32	RO Value:	3.4	SRO Value:	3.8	Section:	PWG	RO Group:	1	SRO Group:	1

System/Evolution Title: GENERI

KA Statement: Ability to explain and apply all system limits and precautions.

Explanation of Answers: Per BwOP AF-5, starting duties for MOV-AF013(A-H) is a max of 5 times w/l a one minute period. Prevents overheating the valve motor from excessive starting currents. (B) is only correct answer.

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Normal Ops - Motor Driven AFP Startup	BwOP AF-5	E	4	16	

Material Required for Examination:

Question Source: Facility Exam Bank | Question Modification Method: Significantly Modified | Used During Training Program

Question Source Comments:

Comment Type	Comment

Reviews Complete: Peer, Supervisory, Facility, NRC

110

Question Topic Generic

The following conditions exist on Unit 1 following a refueling outage

- RCS temperature is 120°F
- RCS pressure is 50 psig
- All reactor vessel head closure bolts are fully tensioned
- Preparations are being made to enter 1BwGP 100-1, "Plant Heatup"
- The following RCS chemistry sample taken 1 hour ago has been handed to you for your review
  - Disolved Oxygen = 180 ppb
  - Chloride = 160 ppb
  - Fluoride = 130 ppb

(1) is/are outside allowable value(s) for current plant conditions and must be corrected to ensure (2)

	(1)	(2)
a.	ONLY Oxygen	Structural integrity of the RCS
b.	Chloride AND Fluoride	Specific activity is minimized
c.	Fluoride AND Oxygen	Specific activity is minimized
d.	ONLY Chloride	Structural integrity of the RCS

Answer d | **Exam Level** S | **Cognitive Level** Memory | **Facility:** Braidwood | **ExamDate:** 7/19/02

KA: 194001G134 2.1.34 | **RO Value:** 2.3 | **SRO Value:** 2.9 | **Section:** PWG | **RO Group:** 1 | **SRO Group:** 1

System/Evolution Title GENERI

KA Statement: Ability to maintain primary and secondary plant chemistry within allowable limits.

Explanation of Answers: (A) Incorrect - O2 has no limit in mode 5. (B) Incorrect - Fluoride is within allowable limits (<150 ppb) (C) Incorrect - both O2 and Fluoride are within limits (D) Correct - Chloride is out of limits - > 150 ppb. Also, TS basis is for RCS integrity, not RCS activity levels

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
TRM - RCS Chemistry	Tech Requirements Manual	3.4.b	3.4.b-4	1	
Reactor Coolant LP	I1-RC-XL-01	III.A	35	1	13
TS Basis (old)	TS	Basis	3/4 4-5	A92	

Material Required for Examination

Question Source: Facility Exam Bank | **Question Modification Method:** Significantly Modified | **Used During Training Program**

Question Source Comments 2000 Bwd NRC

Comment Type	Comment
SRO	TS and Basis knowledge question

Reviews Complete
Peer
Supervisory
Facility
NRC

111

Question Topic Generic

The following conditions exist on Unit 1

- A reactor startup is in progress following an inadvertant plant trip
- The crew is performing steps of 1BwGP 100-2, "Reactor Startup"
- All control AND shutdown banks have been fully withdrawn
- The reactor is NOT critical

Which of the following describes the required operator action?

a. Manually reinsert ALL Control and Shutdown Bank rods

b. Emergency Borate to increase RCS boron concentration by >100 ppm

c. Manually reinsert ONLY the Control Bank rods

d. Immediately open the Reactor Trip Breakers

Answer	a	**Exam Level**	R	**Cognitive Level**	Application	**Facility:**	Braidwood	**ExamDate:**	7/19/02

KA:	194001G201	2.2.1	**RO Value:**	3.7	**SRO Value:**	3.6	**Section:**	PWG	**RO Group:**	1	**SRO Group:** 1

System/Evolution Title GENERI

KA Statement: Ability to perform pre-startup procedures for the facility, including operating those controls associated with plant equipment that could affect reactivity.

Explanation of Answers: Per Attachment B, Contingency for not achieving criticality with all control rods fully withdrawn. Correct response is (A). (B) is action for criticality below Lo-2 RIL. (C) Incorrect because ALL rods must be inserted. (D) Incorrect - only applies to halted startups during severe weather conditions.

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Reactor startup procedures	1BwGP 100-2	Attach B	1	1	

Material Required for Examination

Question Source: New **Question Modification Method:** **Used During Training Program**

Question Source Comments

Comment Type	Comment

Reviews Complete
Peer
Supervisory
Facility
NRC

112

Question Topic Generic

All of the following are the SAME for Unit 1 and Unit 2 during Cycle 10 operations EXCEPT

a. Shutdown Margin Limit for Modes 1,2,3 and 4

b. DNBR - Reactor Coolant System minimum total flowrate

c. Feedwater pressure differential pressure program

d. Control bank insertion limits vs. % Rated Thermal Power

Answer	c	**Exam Level**	B	**Cognitive Level**	Memory	**Facility:**	Braidwood	**ExamDate:**	7/19/02

KA:	194001G203	2.2.3	**RO Value:**	3.1	**SRO Value:**	3.3	**Section:**	PWG	**RO Group:**	1	**SRO Group:** 1

System/Evolution Title GENERI

KA Statement: (multi-unit) Knowledge of the design, procedural, and operational differences between units.

Explanation of Answers: (A) incorrect SDM both 1.3% (B) Incorrect U-1&2 =380,900 (C) Correct U-1=85-215psid, U-2=80-220psid (D) Incorrect per COLR figure 2.5.1

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
COLR	TRM COLR U-1 & U-2	COLR	5.5.17		
Power Ascension GP	BwGP 100-3	100-3A9		3.2	

Material Required for Examination

Question Source: New **Question Modification Method:** **Used During Training Program**

Question Source Comments similar to 2001 DC Cook

Comment Type	Comment

Reviews Complete
- Peer
- Supervisory
- Facility
- NRC

Question Topic Generic

Both Braidwood units undergo plant heatup and startups from cold shutdown conditions. Concerning the operation of FW009A-D, Main Feedwater Isolation Valves they are opened earlier in the startup process on (1) and must have startup purge logics satisfied before operating by opening bypass isolation flow control valves FW043A-D and FW046A-D on (2)

(1) (2)

a. Unit 1 Unit 2

b. Unit 1 Unit 1

c. Unit 2 Unit 2

d. Unit 2 Unit 1

Answer	a	**Exam Level**	R	**Cognitive Level**	Memory	**Facility:**	Braidwood	**ExamDate:**	7/19/02		
KA:	194001G204	2 2.4	**RO Value:**	2.8	**SRO Value:**	3.0*	**Section:**	PWG	**RO Group:**	1	**SRO Group:** 1

System/Evolution Title GENERI

KA Statement: (multi-unit) Ability to explain the variations in control board layouts, systems, instrumentation and procedural actions between units at a facility.

Explanation of Answers: (A) Correct - opened on Unit 1 at ~200°F in GP 100-1. On Unit 2 opened at NOP/NOT in GP 100-3. Unit 2 still maintains bypass purge permissive ckts (A) is only correct answer.

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Plant Heatup Procedure	1BwGP 100-1	F.39	31	17	
Power Ascension	2BwGP 100-3	F.40	44	21	

Material Required for Examination

Question Source: New **Question Modification Method:** **Used During Training Program**

Question Source Comments

Comment Type	Comment

Reviews Complete
Peer
Supervisory
Facility
NRC

114

Question Topic Generic

Greater than (1) feet of water must be maintained over the top of the reactor pressure vessel flange during movement of irradiated fuel assemblies within containment in order to (2)

(1) (2)

a. 23 Have sufficient water depth available to remove 99% of the assumed 10% iodine gap activity released from the rupture of an irradiated fuel assembly

b. 20 Provide sufficient water volume to allow time for the operator to recognize the indications of a dilution accident before Keff can exceed .95 delta K/K

c. 23 Maintain sufficient water volume as a heat sink for core cooling in the event the operating RH loop fails to provide long term decay heat removal.

d. 20 Maintain sufficient water above the top of the fuel assemblies to ensure that the radiation levels at the operating elevation for fuel handling equipment remains below 4 mr/hr.

Answer a **Exam Level** S **Cognitive Level** Memory **Facility:** Braidwood **ExamDate:** 7/19/02

KA: 194001G225 2.2.25 **RO Value:** 2.5 **SRO Value:** 3.7 **Section:** PWG **RO Group:** 1 **SRO Group:** 1

System/Evolution Title GENERI

KA Statement: Knowledge of bases in technical specifications for limiting conditions for operations and safety limits.

Explanation of Answers: (A) Correct per TRM 3.9.e and TS (old) basis for minimum contained water depth during movement of fuel in containment.

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
TRM		3.9.e-1	1	1	
FH LP		Ch. 52			7
TS 3/4 9.10 (old)	TS Basis (old)	Basis	9-3	A86	

Material Required for Examination

Question Source: Facility Exam Bank **Question Modification Method:** Direct From Source **Used During Training Program**

Question Source Comments 1998 Salem NRC

Comment Type	Comment

Reviews Complete

Peer

Supervisory

Facility

NRC

115

Question Topic Generic

The following conditions exist on Unit 1

- Reactor was tripped from 2% power during a normal coastdown for refueling
- 7/22/02 0900 Entered Mode 3, HOT STANDBY
- 7/22/02 1300 Entered Mode 4, HOT SHUTDOWN
- 7/23/02 0600 Entered Mode 5, COLD SHUTDOWN
- 7/23/02 2300 Entered Mode 6, REFUELING

Tthe earliest that fuel movement in the reactor vessel is allowed will be (1) to ensure that (2)

	(1)	(2)
a.	7/25/02 1100	Short lived fission products have decayed
b.	7/25/02 1100	Decay heat removal ability is adequate
c.	7/26/02 1300	Short lived fission products have decayed
d.	7/26/02 1300	Decay heat removal ability is adequate

Answer c | **Exam Level** S | **Cognitive Level** Application | **Facility:** Braidwood | **ExamDate:** 7/19/02

KA: 194001G228 2.2.28 | **RO Value:** 2.6 | **SRO Value:** 3.5 | **Section:** PWG | **RO Group:** 1 | **SRO Group:** 1

System/Evolution Title GENERI

KA Statement: Knowledge of new and spent fuel movement procedures.

Explanation of Answers: TRM 3.9.a calls for 100 hours subcritical before fuel movements can begin. (7/22/02 @ 0900 + 100 hours (3 days, 4 hours) = 7/26/02 @ 1300. TS Basis (old) defines the basis as ensuring the short lived fission products have decayed off for radioactivity concerns

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Tech Requirements Manual	TRM 3.9.a	9	a-1	17	
Tech Specs (old)	Basis	3/4 9.3	9-1	A56	
UFSAR		15.7			

Material Required for Examination

Question Source: Other Facility | **Question Modification Method:** Significantly Modified | **Used During Training Program**

Question Source Comments 2001 Prairie Island NRC 2000 Kewaunee NRC

Comment Type	Comment

Reviews Complete: Peer, Supervisory, Facility, NRC

116

Question Topic Generic

Unit 2 is being refueled following a complete core offload in accordance with the Core Loading Pattern supplied by Nuclear Fuel Services. Any deviation from the specified order of the PWR Nuclear Component Transfer List (NCTL), while transporting fuel to or from the Spent Fuel Pool or the New Fuel Storage Vault, requires the approval of (1) AND (2) before any further action is taken

(1) (2)

a. System Engineering Supervisor — Station Nuclear Materials Custodian

b. Qualified Nuclear Engineer — Fuel Handling Supervisor

c. System Engineering Supervisor — Fuel Handling Supervisor

d. Qualified Nuclear Engineer — Station Nuclear Materials Custodian

Answer	a	**Exam Level**	S	**Cognitive Level**	Memory	**Facility:**	Braidwood	**ExamDate:**	7/19/02

KA: 194001G231 2.2.31 **RO Value:** 2.2 **SRO Value:** 2.9* **Section:** PWG **RO Group:** 1 **SRO Group:** 1

System/Evolution Title GENERI

KA Statement: Knowledge of procedures and limitations involved in initial core loading.

Explanation of Answers: Per BwAP 370-3, (A) Only correct response. (B,C,D) Incorrect - all combinations of allowable reviewers for actions that do not change the intent of the procedures.

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Administrative control during refueling	BwAP 370-3	C.1.o	6	27	

Material Required for Examination

Question Source: New **Question Modification Method:** **Used During Training Program**

Question Source Comments

Comment Type	Comment
SRO	Fuel Handling procedures

Reviews Complete

Peer

Supervisory

Facility

NRC

117

Question Topic Generic

The following conditions exist on Unit *

- Reactor power is 75%, steady state equilibrium Xenon
- All controlling systems are operating in Automatic
- Turbine Impulse pressure transmitter PT-505 fails to it's 50% value

Control rods will respond by immediately stepping (1) at (2) steps per minute

	(1)	(2)
a.	IN	72
b.	OUT	72
c.	OUT	8
d.	IN	8

Answer a **Exam Level** B **Cognitive Level** Application **Facility:** Braidwood **ExamDate:** 7/19/02

KA: 194001G233 2.2.33 **RO Value:** 2.5 **SRO Value:** 2.9 **Section:** PWG **RO Group:** 1 **SRO Group:** 1

System/Evolution Title GENERI

KA Statement: Knowledge of control rod programming.

Explanation of Answers: (A) Correct - Tave program is 557°F-586°F or a delta of 29°F. At 75% tave is (.75)(29)+557=578.75°F. Tref at 50% value is (.5)(29)+(557)=571.5°F. A 7.25°F mismatch exists. Rods will step in at 72 steps/min with anything greater than a 5°F mismatch if Thot > Tave.

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Bwd Big Notes	RD-1	Speed & Direction		3	

Material Required for Examination

Question Source: Facility Exam Bank **Question Modification Method:** Significantly Modified **Used During Training Program**

Question Source Comments

Comment Type	Comment

Reviews Complete

Peer

Supervisory

Facility

NRC

Question Topic Generic

Today's date is November 12, 2002 (4th quarter). You have been assigned to authorize a rad worker to perform a routine task in the Auxiliary Building for which an estimated dose of 450 mrem will be received. Each has an exposure history this year as follows

A Age 46
Cumulated TEDE dose of 600 mrem
Has a high lifetime exposure record

B Age 38
Cumulated TEDE dose of 48 mrem
Has 2 quarters with an absent no dose record

C Age 25
Cumulated TEDE dose of 1260 mrem
Cumulated SDE dose of 6 Rem to the left hand

D Age 17
Cumulated TEDE dose of 80 mrem
Cumulated SDE dose of 15 mrem to the upper fore arm

Which of the above operators can be assigned the task without exceeding any of Exelon's radiation exposure limits or submitting approval for exposure limit extensions?

a. Worker A

b. Worker B

c. Worker C

d. Worker D

Answer	c	**Exam Level**	S	**Cognitive Level**	Application	**Facility:**	Braidwood	**ExamDate:**	7/19/02		
KA:	194001G301	2.3.1	**RO Value:**	2.6	**SRO Value:**	3.0	**Section:**	PWG	**RO Group:**	1	**SRO Group:** 1

System/Evolution Title GENERI

KA Statement: Knowledge of 10 CFR 20 and related facility radiation control requirements.

Explanation of Answers: (A) Incorrect - High lifetime exposure record limits this worker to an annual dose of 1000 mrem. (B) Incorrect - allowed dose is decreased by 1250 mrem for EACH absent/no dose record on file. (C) total dose received would remain below the 2000 mrem admin limit. SDE limit of 30 R has not been exceeded (100% R20). (D) Incorrect - minor and limited to 500 mrem for the year.

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Exposure Control and Authorization	RP-AA-203	4	2-5	2	
NGET	Student Study Guide	Rad Protection			

Material Required for Examination

Question Source: New **Question Modification Method:** **Used During Training Program**

Question Source Comments

Comment Type **Comment**

Reviews Complete
Peer
Supervisory
Facility
NRC

Question Topic Generic

Which of the following is an SRO responsibility?

a. Placing the placard "Gas Decay Tank Release In Progress" on 0PM02J prior to commencing a release

b. Performing second verification of the lineup to transfer a blowdown tank to the condensate storage tank

c. Determining the release rate for a gas decay tank release

d. Performing independent verification of the lineup to place a release tank on recirculation

Answer	a	**Exam Level**	S	**Cognitive Level**	Memory	**Facility:**	Braidwood	**ExamDate:**	7/19/02		
KA:	194001G303	2.3.3	**RO Value:**	1.8	**SRO Value:**	2.9	**Section:**	PWG	**RO Group:**	1	**SRO Group:** 1

System/Evolution Title GENERI

KA Statement: Knowledge of SRO responsibilities for auxiliary systems that are outside the control room (e.g., waste disposal and handling systems).

Explanation of Answers: A. Correct per reference. (B) Incorrect - second verifier is not required to be an SRO (C) Incorrect - Rad Protection determines release rate (D) Incorrect - IV is not required to be done by an SRO

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Waste Gas Decay Tank Release Form	BwOP GW-500T1	E.1	16	12	

Material Required for Examination

Question Source: Facility Exam Bank **Question Modification Method:** Editorially Modified **Used During Training Program**

Question Source Comments 2001 Bwd NRC

Comment Type	Comment

Reviews Complete

Peer

Supervisory

Facility

NRC

Question Topic Generic

A Site Area Emergency has been declared at Braidwood Station due to a LOCA outside containment. The LOCA is into the Auxiliary Building, a direct pathway to the environment exists, and limited makeup to the RWST is available. An operator has volunteered to enter the Aux Building to locally isolate the leak. This action would significantly reduce offsite dose and has all required approvals from the TSC.

The operator has a lifetime exposeure of 3200 mrem TEDE and an exposure for the current year of 230 mrem.

What is the maximum exposure this operator may receive while performing actions to isolate this leak?

a. 5 Rem TEDE

b. 15 Rem TEDE

c. 25 Rem TEDE

d. 50 Rem TEDE

Answer	c	Exam Level	B	Cognitive Level	Memory	Facility:	Braidwood	ExamDate:	7/19/02

KA:	194001G304	2.3.4	RO Value:	2.5	SRO Value:	3.1	Section:	PWG	RO Group:	1	SRO Group:	1

System/Evolution Title: GENERI

KA Statement: Knowledge of radiation exposure limits and contamination control, including permissible levels in excess of those authorized.

Explanation of Answers: Per EP-AA-113, Personnel Protective Actions - 25 Rem TEDE is the emergency exposure limit. IT shall be voluntary and limited to once in a lifetime. (C) is correct

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Personnel Protective Actions	EP-AA-113	4.1.3	3	2	
Exposure Control and Authorization	RP-AA-203	4.1.7	4	2	

Material Required for Examination

Question Source:	Facility Exam Bank	Question Modification Method:	Significantly Modified	Used During Training Program

Question Source Comments 2001 Prairie Island NRC

Comment Type	Comment	Reviews Complete
		Peer
		Supervisory
		Facility
		NRC

121

Question Topic Generic

Unit 1 is in Mode 4 Containment Purge is in progress using the Mini-purge Supply and Exhaust Fans While the purge is in progress, 1RE-PR001 Containment Purge Effluent Rad monitor, exceeds the ALERT setpoint

Which of the following must be performed ?

a. MANUALLY stop the containment purge in progress

b. VERIFY containment purge AUTOMATICALLY stops

c. VERIFY Post LOCA Purge filter unit AUTOMATICALLY aligns

d. MANUALLY align Post LOCA Purge filter unit

Answer	a	Exam Level	B	Cognitive Level	Memory	Facility:	Braidwood	ExamDate:	7/19/02

KA:	194001G309	2 3.9	RO Value:	2.5	SRO Value:	3.4	Section:	PWG	RO Group:	1	SRO Group:	1

System/Evolution Title GENERI

KA Statement: Knowledge of the process for performing a containment purge.

Explanation of Answers: A. Correct. B. Incorrect. The AR011/12 auto isolates the purge path, not 1RE-PR001. C. Incorrect. There is no auto alignment of the post loca purge filter unit. D. Incorrect. Procedure reference directs stopping purge (vice manually aligning the filter unit)

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Cnmt Mini-Purge System Operation	BwOP VQ-6	E.5	2	12	
Cnmt Vent LP	I1-VP-XL-01				9

Material Required for Examination

Question Source: Facility Exam Bank | Question Modification Method: Direct From Source | Used During Training Program

Question Source Comments 2001 Bwd NRC

Comment Type	Comment

Reviews Complete
Peer
Supervisory
Facility
NRC

Question Topic Generic

Given the following plant conditions

- Unit 1 is at 100% power
- Unit 2 is at 100% power
- 0PR09J "CC HX Outlet Unit 0 Radiation Monitor" is in HIGH alarm
- A confirmed High Alarm has been determined by Chemistry
- The 0 CC HX has been subsequently isolated

The crew should now verify

a. Only 1CC017 is closed and enter the LCO for Unit 1 CCW

b. Only 2CC017 is closed and enter the LCO for Unit 2 CCW

c. Both 1CC017 and 2CC017 are closed and enter the LCO for both units for CCW

d. Both 1CC017 and 2CC017 are closed and do not need to enter a LCO for either unit

Answer	c	**Exam Level**	R	**Cognitive Level**	Comprehension	**Facility:**	Braidwood	**ExamDate:**	7/19/02

KA:	194001G311	2.3.11	**RO Value:**	2.7	**SRO Value:**	3.2	**Section:**	PWG	**RO Group:**	1	**SRO Group:** 1

System/Evolution Title GENERI

KA Statement: Ability to control radiation releases.

Explanation of Answers: Both vent valves receive a closure signal from the common CC heat exchanger rad monitor. Must enter LCO for both units

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Tech Specs	3.7.7	Condition A	3.7.7-1		
CC HX OUTLET UNIT O	1BwAR 1-0PR09J		1	1E1	
CC System LP	I1-CC-XL-01		7-8	0	7

Material Required for Examination

Question Source: Facility Exam Bank **Question Modification Method:** Direct From Source **Used During Training Program**

Question Source Comments 2000 Bwd NRC Exam

Comment Type	Comment

Reviews Complete

Peer

Supervisory

Facility

NRC

Question Topic Generic

Which of the following conditions would NOT require immediate entry into 1BwEP-0 "Reactor Trip or Safety Injection", if the condition were to occur inadvertently with the reactor operating at 100% power?

a. Safety Injection actuation on Train 'A'

b. Differential overcurrent on Bus 157

c. Containment Phase A Isolation on both Trains

d. Loss of Instrument Bus 112 with PR Instrument N-44 failed

Answer	c	**Exam Level**	R	**Cognitive Level**	Application	**Facility:**	Braidwood	**ExamDate:**	7/19/02

KA:	194001G404	2.4.4	**RO Value:**	4.0	**SRO Value:**	4.3	**Section:**	PWG	**RO Group:**	1	**SRO Group:** 1

System/Evolution Title GENERI

KA Statement:

Ability to recognize abnormal indications for system operating parameters which are entry-level conditions for emergency and abnormal operating procedures.

Explanation of Answers: (A) Incorrect - Rx would trip, entry into E-0 is required (B) Incorrect - Rx would trip (loss of 2 RCS loops), entry into E-0 is required (C) Correct - no Rx trip occurs, enter and perform 1BwOA PRI-13, "Recovery from Inadvertant Phase A Containment Isolation" (D) Incorrect - Rx trip occurs on loss of 2 PR channels

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Inadvertant Phase A Isolation	1BwOA PRI-13	B	1	55	
Reactor Trip or Safety Injection	1BwEP-0	B	1.2	100wog1	

Material Required for Examination

Question Source: Other Facility **Question Modification Method:** Editorially Modified **Used During Training Program**

Question Source Comments 2001 DC Cook NRC

Comment Type	Comment

Reviews Complete

Peer

Supervisory

Facility

NRC

Question Topic Generic

1BwEP-3, "Steam Generator Tube Rupture", instructs the operators to maintain feedwater flow to the ruptured steam generator until narrow range level is greater than 10%.

This minimum level requirement ensures which of the following?

a. Sufficient heat sink is available for Reactor Coolant System cooldown

b. The ruptured steam generator tubes are covered to promote thermal stratification

c. The ruptured steam generator does NOT become a hot-dry steam generator

d. Radioactive steam does NOT contaminate the main steamlines

Answer	b	Exam Level	R	Cognitive Level	Comprehension	Facility:	Braidwood	ExamDate:	7/19/02

KA:	194001G406	2.4.6	RO Value:	3.1	SRO Value:	4.0	Section:	PWG	RO Group:	1	SRO Group:	1

System/Evolution Title GENERI

KA Statement: Knowledge symptom based EOP mitigation strategies.

Explanation of Answers: EP-3 background documents - (B) Correct. Prevents ruptured SG depressurization during upcoming RCS cooldown steps. (A) Incorrect - the ruputed SG will not be used for cooldown unless it is the only intact SG.. (C) Incorrect - No in E-3 mitigation, with SGTR it will not become "hot and dry". (D) Incorrect - radioactive steam has already contaminated the steam lines.

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Steam Generator Tube Rupture	BwEP-3	Step 4	8	100WO	
Background Documents	EP-3		62-	1C	

Material Required for Examination

Question Source: Facility Exam Bank **Question Modification Method:** Direct From Source **Used During Training Program**

Question Source Comments

Comment Type	Comment

Reviews Complete
Peer
Supervisory
Facility
NRC

Question Topic Generic

The following conditions exist on Unit 1

- Bus 141 is DE-ENERGIZED
- Bus 142 is DE-ENERGIZED
- RCS pressure is 2220 psig and decreasing slowly
- Pzr level is 31% and decreasing slowly
- Preparations are being made to cool the RCS to 350°F in order to minimize further RCS inventory loss

Operators are performing steps in (1) and are CAUTIONED NOT to decrease RCS Hot Leg temperatures below 350 F to prevent (2)

	(1)	(2)
a.	1BwCA-0.0 Loss of All AC	Accumulator Nitrogen injection
b.	1BwEP-0 Reactor Trip or SI	Pressurized Thermal Shock Conditions
c.	1BwEP-0 Reactor Trip or SI	Accumulator Nitrogen injection
d.	1BwCA-0.0 Loss of All AC	Pressurized Thermal Shock Conditions

Answer	a	**Exam Level**	S	**Cognitive Level**	Comprehension	**Facility:**	Braidwood	**ExamDate:**	7/19/02
KA:	194001G407	2.4.7	**RO Value:**	3.1	**SRO Value:**	3.8	**Section:**	PWG	**RO Group:** 1 **SRO Group:** 1

System/Evolution Title GENERI

KA Statement: Knowledge of event based EOP mitigation strategies.

Explanation of Answers: (A) Correct - ESF Buses de-energized requires use of CA-0.0. During the cooldown to 350°F the operators are cautioned "To prevent injection of accumulator N2 into the RCS, hot leg temps should not be decreased to less than 350°F (B) Incorrect - EP-0 will not be in effect if cooldown steps are in progress. PTS is not a concern (C) Incorrect - EP-0 will not be in effect if cooldown steps are in progress (D) Incorrect - PTS is not a concern (per background documents) Cold leg temps will be monitored for pts

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Loss of All AC LP	I1-CA-XL-01	II	27	4	6
Loss of All AC Power	1BwCA-0.0	step 31	39	1C	
Emergency Response Guidelines	ERG CA-0.0	step 16	118	1C	

Material Required for Examination

Question Source: Facility Exam Bank **Question Modification Method:** Significantly Modified **Used During Training Program**

Question Source Comments 2000 Bwd NRC

Comment Type	Comment

Reviews Complete
Peer
Supervisory
Facility
NRC

126

Question Topic Generic

An emergency call has been received by the Assist NSO in the control room, reporting a large fire in the Turbine Building

Which of the following is NOT one of the Shift Managers responsibilities while completing the checklist for a Fire/Hazmat Spill Response?

a. Verify the Fire Brigade has been notified/dispatched

b. Notification of Rad Protection to dispatch personnel to the area

c. Assessment of the fire/scenario and classification for the Emergency Plan

d. Announcement of the fire over the plant PA system and sounding of the plant fire alarm

Answer	d	**Exam Level**	S	**Cognitive Level**	Memory	**Facility:**	Braidwood	**ExamDate:**	7/19/02		
KA:	194001G427 2.4.27	**RO Value:**	3.0	**SRO Value:**	3.5	**Section:**	PWG	**RO Group:**	1	**SRO Group:**	1

System/Evolution Title GENERI

KA Statement: Knowledge of fire in the plant procedure.

Explanation of Answers: (A-C) are all part of the checklist for the S Manager to perform. (D) Correct - this is the assist operators responsibility per the checklist

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Fire / Hazmat Spill Response	BwAP 1100-16	Appendix A & D	4,12	14	

Material Required for Examination

Question Source: New **Question Modification Method:** **Used During Training Program**

Question Source Comments

Comment Type	Comment

Reviews Complete
Peer
Supervisory
Facility
NRC

Question Topic Generic

A large Break LOCA concurrent with a loss of containment integrity has been INITIALLY classified as a General Emergency

The offsite state authorities will be notified of this event on the (1) phone, and the NRC will be notified on the (2) phone

(1) (2)

a. Green Red

b. White Red

c. Red Green

d. Green White

Answer	a	**Exam Level**	B	**Cognitive Level**	Memory	**Facility:**	Braidwood	**ExamDate:**	7/19/02		
KA:	194001G429	2.4 29	**RO Value:**	2.6	**SRO Value:**	4.0	**Section:**	PWG	**RO Group:**	1	**SRO Group:** 1

System/Evolution Title GENERI

KA Statement: Knowledge of the emergency plan.

Explanation of Answers: (A) Dedicated lines in the MCR for NARs is GREEN and the NRC is RED.

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Notifications	EP-AA-114				
MCR equipment					

Material Required for Examination

Question Source: New **Question Modification Method:** **Used During Training Program**

Question Source Comments

Comment Type	Comment

Reviews Complete
Peer
Supervisory
Facility
NRC

Question Topic Generic

The Unit is in Mode 1 when a power supply problem in the Annunciator Cabinets results in a loss of most of the annunciators on 1PM01J, 1PM05J, and 1PM06J. Maintenance estimates 1 hour to repair

This condition (1) an Emergency Plan EAL threshold and requires (2) monitoring of plant status

(1) (2)

a. meets Continuous

b. meets Hourly

c. does NOT meet Continuous

d. does NOT meet Hourly

Answer	a	Exam Level	S	Cognitive Level	Memory	Facility:	Braidwood	ExamDate:	7/19/02

KA:	194001G432	2.4.32	RO Value:	3.3	SRO Value:	3.5	Section:	PWG	RO Group:	1	SRO Group:	1

System/Evolution Title GENERI

KA Statement: Knowledge of operator response to loss of all annunciators.

Explanation of Answers: (A) Correct - per Bwd EALs - MU6 and 1BwOS AN-1A AAR A.3 (B,C,D) Incorrect - the event does warrant EP classification and does require continuous monitoring

Reference Title	Facility Reference Number	Reference Section	Page No.	Revision	L.O. Number
Loss of Annunciators	1BwOS AN-1A	A.3	2	1	
Braidwood EALs	MU6	Threshold Value	5-44	6	

Material Required for Examination

Question Source:	New	Question Modification Method:		Used During Training Program

Question Source Comments

Comment Type	Comment
SRO	Knowledge of EALs and Actions in the AAR (selecting correct procedure)

Reviews Complete
Peer
Supervisory
Facility
NRC