

October 25, 2002

Mr. James Scarola, Vice President
Shearon Harris Nuclear Power Plant
Carolina Power & Light Company
Post Office Box 165, Mail Code: Zone 1
New Hill, North Carolina 27562-0165

SUBJECT: SHEARON HARRIS NUCLEAR POWER PLANT - REQUEST FOR ADDITIONAL
INFORMATION (RAI) ON AMENDMENT APPLICATION REGARDING ADDITION
OF METHODOLOGY REFERENCES TO THE CORE OPERATING LIMIT
REPORT (TAC NO. MB6226)

Dear Mr. Scarola:

By letter dated August 28, 2002, you submitted an amendment application regarding the addition of methodology references to the core operating limit report for the Shearon Harris Nuclear Power Plant. The NRC staff reviewed the information that you provided in the subject amendment application and identified the need for further information as described in the enclosed RAI.

This request for information was discussed by the NRC staff, Framatome, and the licensee during a telephone conversation on October 7, 2002, and a mutually agreeable schedule for a response by November 26, 2002, was established for your comprehensive response to the RAI.

If you have any questions, please contact me on (301) 415-1478.

Sincerely,

/RA/

Ram Subbaratnam, Project Manager, Section 2
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-400

Enclosure: RAI

cc w/encl: See next page

October 25, 2002

Mr. James Scarola, Vice President
Shearon Harris Nuclear Power Plant
Carolina Power & Light Company
Post Office Box 165, Mail Code: Zone 1
New Hill, North Carolina 27562-0165

SUBJECT: SHEARON HARRIS NUCLEAR POWER PLANT - REQUEST FOR ADDITIONAL INFORMATION (RAI) ON AMENDMENT APPLICATION REGARDING ADDITION OF METHODOLOGY REFERENCES TO THE CORE OPERATING LIMIT REPORT (TAC NO. MB6226)

Dear Mr. Scarola:

By letter dated August 28, 2002, you submitted an amendment application regarding the addition of methodology references to the core operating limit report for the Shearon Harris Nuclear Power Plant. The NRC staff reviewed the information that you provided in the subject amendment application and identified the need for further information as described in the enclosed RAI.

This request for information was discussed by the NRC staff, Framatome, and the licensee during a telephone conversation on October 7, 2002, and a mutually agreeable schedule for a response by November 26, 2002, was established for your comprehensive response to the RAI.

If you have any questions, please contact me on (301) 415-1478.

Sincerely,

/RA/

Ram Subbaratnam, Project Manager, Section 2
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-400

Enclosure: RAI

cc w/encl: See next page

DISTRIBUTION:

PUBLIC AHowe RSubbaratnam EDunnington FAKstulewicz
PDII-2 Rdg SCahill, RII MMcConnell VKlein OGC
ACRS

DOCUMENT NAME: C:\ORPCheckout\FileNET\ML022980207.wpd

ADAMS Accession No.

OFFICE	PM:PDII-2	INTERN:PDII-2	LA:PDII-2	DSSA:SRXB	DSSA:SRXB	SC:PDII-2
NAME	RSubbaratnam	MMcConnell	EDunnington	VKlein	FAkstulewicz	AHowe
DATE	10\24\2002	10/24\2002	10\24\2002	10/24\2002	10/24\2002	10\25\2002

OFFICIAL RECORD COPY

SHEARON HARRIS NUCLEAR POWER PLANT
REQUEST FOR ADDITIONAL INFORMATION (RAI) ON AMENDMENT REQUEST
REGARDING ADDITION OF METHODOLOGY REFERENCES TO THE CORE OPERATING
LIMIT REPORT
TAC NO. MB6226

Carolina Power & Light Company is requested to provide the following additional information relating to the above amendment request:

1. The NRC's safety evaluation of Topical Report EMF-2328(P)(A), Revision 0, "PWR Small Break LOCA Evaluation Model, S-RELAP5 Based" states a condition on the use of the ANF-RELAP code that still applies to the use of S-RELAP5. The statement is:

That while it has been shown in Reference 53 [Loomis, G.G., "Summary of the Semiscale Program (1965-1986)," NUREG/CR-4945, July 1987] that the thermal-hydraulic phenomena observed for breaks up to 10 percent of the cold leg flow area are the same, if the code is used for break sizes larger than 10 percent of the cold leg flow area additional assessments must be performed to ensure that the code is predicting the important phenomena which may occur.

Your submittal did not state the break size range for which you intend to use the code. Please provide information that says what break size range you intend to use the code for, and if you intend to use the code for breaks larger than 10 percent of the cold leg flow area, also provide the required additional assessments.

2. The NRC's safety evaluation of Topical Report EMF-2310(P)(A), Revision 0, "SRP Chapter 15 Non-LOCA Methodology for Pressurized Water Reactors" states in Section 5.0 "Evaluation of S-RELAP5":

The staff notes, however, that a generic topical report describing a code such as S-RELAP5 cannot provide full justification for each specific individual plant application. The individual applicant must still provide justification for the specific application of the code which is expected to include as a minimum, the nodalization, defense of the chosen parameters, any needed sensitivity studies, justification of the conservative nature of the input parameters, and calculated results.

Your submittal did not include any justification of your specific application of the code. Please provide the necessary information.

The delay with submitting this formal RAI was due to clarification of the time period needed by the licensee to submit a comprehensive response.

Mr. James Scarola
Carolina Power & Light Company

Shearon Harris Nuclear Power Plant
Unit 1

cc:

Mr. William D. Johnson
Vice President and Corporate Secretary
Carolina Power & Light Company
Post Office Box 1551
Raleigh, North Carolina 27602

Mr. Robert J. Duncan II
Director - Site Operations
Carolina Power & Light Company
Shearon Harris Nuclear Power Plant
Post Office Box 165, Mail Zone 1
New Hill, North Carolina 27562-0165

Resident Inspector/Harris NPS
c/o U.S. Nuclear Regulatory Commission
5421 Shearon Harris Road
New Hill, North Carolina 27562-9998

Mr. Robert P. Gruber
Executive Director
Public Staff NCUC
4326 Mail Service Center
Raleigh, North Carolina 27699-4326

Ms. Karen E. Long
Assistant Attorney General
State of North Carolina
Post Office Box 629
Raleigh, North Carolina 27602

Chairman of the North Carolina
Utilities Commission
Post Office Box 29510
Raleigh, North Carolina 27626-0510

Public Service Commission
State of South Carolina
Post Office Drawer 11649
Columbia, South Carolina 29211

Ms. Linda Coleman, Chairperson
Board of County Commissioners
of Wake County
P. O. Box 550
Raleigh, North Carolina 27602

Ms. Beverly Hall, Acting Director
Division of Radiation Protection
N.C. Department of Environment
and Natural Resources
3825 Barrett Dr.
Raleigh, North Carolina 27609-7721

Mr. Gary Phillips, Chairman
Board of County Commissioners
of Chatham County
P. O. Box 87
Pittsboro, North Carolina 27312

Mr. Terry C. Morton
Manager
Performance Evaluation and
Regulatory Affairs CPB 7
Carolina Power & Light Company
Post Office Box 1551
Raleigh, North Carolina 27602-1551

Mr. James W. Holt, Manager
Support Services
Carolina Power & Light Company
Shearon Harris Nuclear Power Plant
P.O. Box 165, Mail Zone 1
New Hill, NC 27562-0165

Mr. Benjamin C. Waldrep
Plant General Manager - Harris Plant
Carolina Power & Light Company
Shearon Harris Nuclear Power Plant
P.O. Box 165, Mail Zone 3
New Hill, North Carolina 27562-0165

Mr. John R. Caves, Supervisor
Licensing/Regulatory Programs
Carolina Power & Light Company
Shearon Harris Nuclear Power Plant
P. O. Box 165, Mail Zone 1
New Hill, NC 27562-0165

Mr. John H. O'Neill, Jr.
Shaw, Pittman, Potts & Trowbridge
2300 N Street, NW.
Washington, DC 20037-1128