

cc: U. S. Nuclear Regulatory Commission (w/o attachments)
Region II
Atlanta Federal Center
61 Forsyth St., SW, Suite 23T85
Atlanta, Georgia 30303

Mr. M. J. Morgan (w/o attachments)
NRC Senior Resident Inspector
North Anna Power Station

David A. Heacock
Site Vice President

Dominion Generation
North Anna Power Station
P.O. Box 402, Mineral, VA 23117
Phone: 540-894-2101, Fax: 540-894-2878
David_Heacock@dom.com



January 23, 2002

Mr. Jerrold W. Gotzmer - Director
Federal Energy Regulatory Commission
Atlanta Regional Office, Parkridge 85 North Building
3125 Presidential Parkway, Suite 300
Atlanta, Georgia 30340

Serial No. F2002-001

Dear Mr. Gotzmer:

PROJECT NO. 6335-VA / NATDAM NO. VA83005
NORTH ANNA HYDROELECTRIC PROJECT
ANNUAL PLOTS OF SURVEY DATA AND
ANNUAL INSTRUMENTATION SUMMARIES FOR THE MAIN DAM

As requested by the FERC letter dated November 2, 1993, Dominion Generation hereby submits the 2001 updates to plots of survey data and instrumentation summaries for the North Anna Hydroelectric Project. The net settlement survey data and a plot of crest settlement are provided in Attachment 1. Embankment instrumentation data for piezometers, weirs, and relief wells is provided in Attachment 2.

The instrumentation data include: 1) updated readings for operable piezometers, 2) individual piezometer plots depicting readings, 3) cross section of selected sections of the dam showing plots of piezometer readings, including highs and lows, 4) weir readings, and 5) summaries of relief well water levels and sediment accumulation for 2001. Our review of the survey results and instrumentation readings indicate that the North Anna Hydroelectric Project and project works are performing as designed.

Should you have any questions please contact Mr. M. P. Whalen at (540) 894-2572.

Very truly yours,


David A. Heacock
Site Vice President

Attachments