

E-0418

10/5/01

- Dave Lockwood
- Steve Moffit
- Roy Lessey - 202-887-4850 Oct 01
- Dave Coulsen Glessen

- Steve Moffit

↳

- DB - safe w/respect issue
- substantial technical basis 2001
- beyond 2001 ⇒
- evolving → substantial cost to employees

- Dave Glessen

- 1996, 1998, 2000 ⇒ Looking for leakage from CRD flanges
- susceptibility rank ⇒ 3.1 years away from Occanee

- Framstone via owners group

- worst case same as Occanee - still have 4 years

- SIA - finite element analysis

↑ 4 Sec

↑
↑
↑

- site specific crack rate - 4 years away from crack

1/01

— premature push crack rate propagation
— MRP was meeting to discuss

NR - not reached agreement on crack rate propagation
Zimmerman Hiser