

Exelon Generation  
4300 Winfield Road  
Warrenville, IL 60555

www.exeloncorp.com

10 CFR 50.90

RS-02-189

October 30, 2002

United States Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, D.C. 20555

LaSalle County Station, Units 1 and 2  
Facility Operating License Nos. NPF-11 and NPF-18  
NRC Docket Nos. 50-373 and 50-374

Subject: Withdrawal of Requested Amendment to Technical Specifications  
Excess Flow Check Valve Testing Surveillance and Relief Request RV-12

Reference: (1) Letter from K. R. Jury (Exelon Generation Company, LLC) to the NRC,  
"Request for Amendment to Technical Specifications Excess Flow Check  
Valve Testing Surveillance Requirement 3.6.1.3.8 and Relief Request RV-  
12," dated May 31, 2002

(2) Letter from K. R. Jury (Exelon Generation Company, LLC) to the NRC,  
"Response to Request for Additional Information Excess Flow Check Valve  
Testing Surveillance and Relief Request RV-12," dated October 4, 2002

Exelon Generation Company (EGC), LLC, in Reference 1 proposed a Technical Specifications (TS) change that modified TS Surveillance Requirement (SR) 3.6.1.3.8 to reduce the number of excess flow check valves (EFCVs) required to be tested every 24 months. Additionally, the submittal in Reference 1 included Relief Request RV-12, Revision 0.


During recent discussions, the NRC identified that, while the requested changes were not risk significant, the requested changes were not directly supported by the referenced documents contained in Technical Specification Task Force Traveler (TSTF) 334. As a result of these discussions, LaSalle County Station has decided to request the withdrawal of Reference 1.

AODI

October 30, 2002  
U. S. Nuclear Regulatory Commission  
Page 2

Should you have any questions concerning this submittal, please contact Mr. T. W. Simpkin at (630) 657-2821.

Respectfully,

A handwritten signature in black ink, reading "Keith R. Jury". The signature is written in a cursive, flowing style.

Keith R. Jury  
Director - Licensing  
Mid-West Regional Operating Group

cc: Regional Administrator – NRC Region III  
NRC Senior Resident Inspector – LaSalle County Station  
Office of Nuclear Facility Safety – Illinois Department of Nuclear Safety