| Component/Commodity Group | Component Commodity Group Constituents: |
|---|---|
| Structure No 8010S01 | Bldg 200: Reactor Containment Building |
| 2. Penetration sleeves, bellows and dissimilar metal welds. | , Bellows |
| | Mechanical Penetrations. |
| Component/Commodity Group | Component Commodity Group Constituents: |
| Structure No 8010S01 | Bldg 200: Reactor Containment Building |
| 3. Penetration sleeves, penetration bellows, and dissimilar metal welds | Bellows |
| | Electrical Penetrations. |
| | Fuel transfer tube. |
| | Mechanical Penetrations. |
| Component/Commodity Group | Component Commodity Group Constituents: |
| Structure No 8010S01 | Bldg 200: Reactor Containment Building |
| 4. Personnel airlock and equipment hatch | Equipment Hatch |
| | Personnel Airlock |
| Component/Commodity Group | Component Commodity Group Constituents: |
| Structure No 8010S01 | Bldg 200: Reactor Containment Building |
| 5. Personnel airlock and equipment hatch | Equipment Hatch |
| | Personnel Airlock |
| Component/Commodity Group | Component Commodity Group Constituents: |
| Structure No 8010S01 | Bldg 200: Reactor Containment Building |
| 6. Seals, gaskets, and moisture barriers | Moisture barrier. |
| | Seals & gaskets. |
| Component/Commodity Group | Component Commodity Group Constituents: |
| Structure No 8010S01 | Bldg 200: Reactor Containment Building |
| 7. Concrete elements:foundation, walls, dome. | Concrete Sump |
| | Reinforced Concrete (Cylinder Wall, Dome, Basemat). |
| Component/Commodity Group | Component Commodity Group Constituents: |
| Structure No 8010S01 | Bldg 200: Reactor Containment Building |
| 12. Steel elements: liner plate, containment shell | Containment liner plate (includes liner attachments and liner anchors). |

| Component/Comm | odity Group | Component Commodity Group Constituents: |
|---|-------------|--|
| Structure No | 2080S01 | Tank: Refueling Water Storage |
| 16. All Groups exce accessible interior/e concrete & steel cor | xterior | Anchor bolt chair for tank foundation |
| Structure No 3 | 3010S01 | Tank: Steam Generator Blowdown |
| 16. All Groups exce accessible interior/e concrete & steel cor | xterior | Structural steel (beams, plates, connectors, column) |
| Structure No | 3070S01 | Tank: Condensate Storage |
| 16. All Groups exce accessible interior/e concrete & steel cor | xterior | Anchor bolt chair for tank foundation |
| Structure No | 4015S02 | Bldg N/A: Intake Structure |
| 16. All Groups except Group 6: accessible interior/exterior concrete & steel components | | Electrical & Instrument Panels and Enclosures. |
| | | Manhole covers |
| | | Protective Enclosure. |
| | | Siding. |
| | | Structural steel (beams, plates, connectors, column) |
| Structure No 4 | 4060S01 | Bldg N/A: North Service Water Header Enclosure |
| 16. All Groups except Group 6: accessible interior/exterior concrete & steel components | | Electrical & Instrument Panels and Enclosures. |
| | | Structural steel (beams, plates, connectors, column) |
| Structure No | 5100S01 | Tank: Diesel Generator Fuel Oil Storage |
| 16. All Groups except Group 6: accessible interior/exterior concrete & steel components | | Anchor bolt chair for tank foundation |
| | | Structural steel (beams, plates, connectors, column) |
| Structure No | 5100S02 | Tank: DS Diesel Fuel Oil |
| 16. All Groups exce accessible interior/e concrete & steel cor | xterior | Miscellaneous steel (Stairs & Ladders, platforms & connectors, grating & checker |
| | | Structural steel (beams, plates, connectors, column) |
| Structure No | 5100S03 | Tank: Diesel Fire Pump Fuel Oil |
| 16. All Groups exce accessible interior/e concrete & steel cor | xterior | Miscellaneous steel (Stairs & Ladders, platforms & connectors, grating & checker |

| <i>Component/Commodity Group</i> 16. All Groups except Group 6: accessible interior/exterior concrete & steel components | | <i>Component Commodity Group Constituents:</i> Structural steel (beams, plates, connectors, column) | |
|---|------------|--|--|
| Structure No | 6082S01 | Bldg 310: EOF/TSC Security Emergency Diesel Generator Bldg | |
| 16. All Groups exe accessible interior concrete & steel c | r/exterior | Doors | |
| | | Electrical & Instrument Panels and Enclosures. | |
| | | Protective Enclosure. | |
| | | Structural steel (beams, plates, connectors, column) | |
| Structure No | 6110S01 | Bldg N/A: Security Lighting | |
| 16. All Groups exe accessible interior concrete & steel o | r/exterior | Manhole covers | |
| | | Siding. | |
| Structure No | 8010S01 | Bldg 200: Reactor Containment Building | |
| 16. All Groups except Group 6: accessible interior/exterior concrete & steel components | | Electrical & Instrument Panels and Enclosures. | |
| | | Fire Hose Station. | |
| | | Floor Drains. | |
| | | Miscellaneous steel (Stairs & Ladders, platforms & connectors, grating & checker | |
| | | Protective Enclosure. | |
| | | Reactor Vessel Missile Shield Frame. | |
| | | Structural steel (beams, plates, connectors, column) | |
| | | Sump screens. | |
| Structure No | 8300509 | Bldg 210: Radwaste Building | |
| 16. All Groups exe accessible interior concrete & steel c | r/exterior | Structural steel (beams, plates, connectors, column) | |
| Structure No | 8300S18 | Bldg 340: Dedicated Shutdown (DS) Diesel Generator Building | |
| 16. All Groups exe accessible interior concrete & steel c | r/exterior | Anchor bolt chair for tank foundation | |
| | | Electrical & Instrument Panels and Enclosures. | |
| | | Structural steel (beams, plates, connectors, column) | |
| Structure No | 8300S36 | Bldg 350: Turbine Building | |

| Component/Commodity Group | Component Commodity Group Constituents: |
|---|--|
| 16. All Groups except Group 6: accessible interior/exterior concrete & steel components | Doors |
| | Electrical & Instrument Panels and Enclosures. |
| | Louvers |
| | Miscellaneous steel (Stairs & Ladders, platforms & connectors, grating & checker |
| | Protective Enclosure. |
| | Siding. |
| | Spray shields |
| | Structural steel (beams, plates, connectors, column) |
| Structure No 8300S44 | Electrical Manholes and Duct Banks |
| 16. All Groups except Group 6: accessible interior/exterior concrete & steel components | Electrical & Instrument Panels and Enclosures. |
| | Manhole covers |
| Structure No 8300S46 | Bldgs 215, 220 and 225: Fuel Handling Building |
| 16. All Groups except Group 6: accessible interior/exterior concrete & steel components | Doors |
| | Electrical & Instrument Panels and Enclosures. |
| | Miscellaneous steel (Stairs & Ladders, platforms & connectors, grating & checker |
| | Siding. |
| | Structural steel (beams, plates, connectors, column) |
| Structure No 8300S48 | Pipe Restraint Tower |
| 16. All Groups except Group 6: accessible interior/exterior concrete & steel components | Electrical & Instrument Panels and Enclosures. |
| | Miscellaneous steel (Stairs & Ladders, platforms & connectors, grating & checker |
| | Structural steel (beams, plates, connectors, column) |
| Structure No 8300S49 | Concrete Trenches |
| 16. All Groups except Group 6: accessible interior/exterior concrete & steel components | Miscellaneous steel (Stairs & Ladders, platforms & connectors, grating & checker |
| Structure No 8300S55 | Bldg N/A: Miscellaneous Yard Structures |
| 16. All Groups except Group 6: accessible interior/exterior concrete & steel components | Electrical & Instrument Panels and Enclosures. |

| <i>Component/Commodity Group</i> 16. All Groups except Group 6: accessible interior/exterior concrete & steel components | <i>Component Commodity Group Constituents:</i> Protective Enclosure. | |
|---|--|--|
| Structure No 8320S01 | Bldg 205: Reactor Auxiliary Building | |
| 16. All Groups except Group 6: accessible interior/exterior concrete & steel components | Doors | |
| | Electrical & Instrument Panels and Enclosures. | |
| | Fire Hose Station. | |
| | Floor Drains. | |
| | Louvers | |
| | Miscellaneous steel (Stairs & Ladders, platforms & connectors, grating & checker | |
| | Protective Enclosure. | |
| | Siding. | |
| | Spray shields | |
| | Structural steel (beams, plates, connectors, column) | |
| Component/Commodity Group | Component Commodity Group Constituents: | |
| Structure No 2080S01 | Tank: Refueling Water Storage | |
| 17. Groups 1-3, 5, 7-9: inaccessible concrete components, such as exterior walls below grade and foundation | Concrete Tank Foundation | |
| Structure No 3010S01 | Tank: Steam Generator Blowdown | |
| 17. Groups 1-3, 5, 7-9: inaccessible concrete components, such as exterior walls below grade and foundation | Concrete Tank Foundation | |
| J. J | Reinforced Concrete (beams, walls, floors, columns, etc.) | |
| Structure No 3070S01 | Tank: Condensate Storage | |
| 17. Groups 1-3, 5, 7-9: inaccessible concrete components, such as exterior walls below grade and foundation | Concrete Tank Foundation | |
| | Reinforced Concrete (beams, walls, floors, columns, etc.) | |
| Structure No 4015S02 | Bldg N/A: Intake Structure | |
| 17. Groups 1-3, 5, 7-9: inaccessible concrete components, such as exterior walls below grade and foundation | Concrete Fill | |
| - | Reinforced Concrete (beams, walls, floors, columns, etc.) | |

| Component/Comm | nodity Group | Component Commodity Group Constituents: |
|--|--------------------|--|
| Structure No | 4060S01 | Bldg N/A: North Service Water Header Enclosure |
| 17. Groups 1-3, 5, inaccessible concre components, such walls below grade | ete as exterior | Concrete Fill |
| Structure No | 5100S01 | Tank: Diesel Generator Fuel Oil Storage |
| 17. Groups 1-3, 5, inaccessible concre components, such walls below grade a | ete as exterior | Concrete Tank Foundation |
| | | Reinforced Concrete (beams, walls, floors, columns, etc.) |
| Structure No | 5100S02 | Tank: DS Diesel Fuel Oil |
| 17. Groups 1-3, 5, inaccessible concre components, such walls below grade | ete as exterior | Reinforced Concrete (beams, walls, floors, columns, etc.) |
| Structure No | 5100S03 | Tank: Diesel Fire Pump Fuel Oil |
| 17. Groups 1-3, 5, inaccessible concre components, such walls below grade | ete as exterior | Reinforced Concrete (beams, walls, floors, columns, etc.) |
| Structure No | 5100S04 | Tanks: Unit 1 IC Fuel Oil Storage Facility |
| 17. Groups 1-3, 5, inaccessible concre components, such walls below grade | ete as exterior | Concrete Tank Foundation |
| Structure No | 5114S01 | Bldg N/A: DSS-Main-XFMR |
| 17. Groups 1-3, 5, inaccessible concre components, such walls below grade | ete as exterior | Reinforced Concrete (beams, walls, floors, columns, etc.) |
| Structure No | 6082S01 | Bldg 310: EOF/TSC Security Emergency Diesel Generator Bldg |
| 17. Groups 1-3, 5, inaccessible concre components, such walls below grade | ete as exterior | Reinforced Concrete (beams, walls, floors, columns, etc.) |
| Structure No | 6110S01 | Bldg N/A: Security Lighting |
| 17. Groups 1-3, 5, inaccessible concre components, such walls below grade | ete as exterior | Electrical Manhole |

| <i>Component/Commodity Group</i> 17. Groups 1-3, 5, 7-9: inaccessible concrete components, such as exterior walls below grade and foundation | <i>Component Commodity Group Constituents:</i> Reinforced Concrete (beams, walls, floors, columns, etc.) |
|--|---|
| | Underground Conduit Duct bank |
| Structure No 8010S01 | Bldg 200: Reactor Containment Building |
| 17. Groups 1-3, 5, 7-9: inaccessible concrete components, such as exterior walls below grade and foundatior | External Reinforced Concrete Components (Missile Shield slabs, walls, roof slabs |
| Structure No 8300S09 | Bldg 210: Radwaste Building |
| 17. Groups 1-3, 5, 7-9: inaccessible concrete components, such as exterior walls below grade and foundatior | Reinforced Concrete (beams, walls, floors, columns, etc.) |
| Structure No 8300S18 | Bldg 340: Dedicated Shutdown (DS) Diesel Generator Building |
| 17. Groups 1-3, 5, 7-9: inaccessible concrete components, such as exterior walls below grade and foundatior | Reinforced Concrete (beams, walls, floors, columns, etc.) |
| Structure No 8300S36 | Bldg 350: Turbine Building |
| 17. Groups 1-3, 5, 7-9: inaccessible concrete components, such as exterior walls below grade and foundatior | Reinforced Concrete (beams, walls, floors, columns, etc.) |
| Structure No 8300S44 | Electrical Manholes and Duct Banks |
| 17. Groups 1-3, 5, 7-9: inaccessible concrete components, such as exterior walls below grade and foundatior | Grout |
| | Reinforced Concrete (beams, walls, floors, columns, etc.) |
| Structure No 8300S46 | Bldgs 215, 220 and 225: Fuel Handling Building |
| 17. Groups 1-3, 5, 7-9: inaccessible concrete components, such as exterior walls below grade and foundatior | Reinforced Concrete (beams, walls, floors, columns, etc.) |
| Structure No 8300S48 | Pipe Restraint Tower |
| 17. Groups 1-3, 5, 7-9: inaccessible concrete components, such as exterior walls below grade and foundatior | Reinforced Concrete (beams, walls, floors, columns, etc.) |

| Component/Comm | odity Group | Component Commodity Group Constituents: |
|--|--------------------|---|
| Structure No | 8300S49 | Concrete Trenches |
| 17. Groups 1-3, 5, inaccessible concre components, such walls below grade a | ete as exterior | Reinforced Concrete (beams, walls, floors, columns, etc.) |
| Structure No | 8300S55 | Bldg N/A: Miscellaneous Yard Structures |
| 17. Groups 1-3, 5, inaccessible concre components, such walls below grade a | ete as exterior | Reinforced Concrete (beams, walls, floors, columns, etc.) |
| Structure No | 8320S01 | Bldg 205: Reactor Auxiliary Building |
| 17. Groups 1-3, 5, inaccessible concre components, such walls below grade a | ete as exterior | Concrete Sump |
| | | Reinforced Concrete (beams, walls, floors, columns, etc.) |
| Component/Comm | odity Group | Component Commodity Group Constituents: |
| Structure No | 4045S01 | Reservoir and Dam |
| 18. Group 6: all accessible/inacce-s concrete, steel, and components | | Anchorage/ Embedments - Exposed Surfaces |
| | | Lake Dam |
| | | Spillway for Dam Structure |
| | | Structural steel (beams, plates, connectors, column) |
| | | Tainter Gate (Dam) |
| | | Threaded fasteners. |
| Component/Comm | odity Group | Component Commodity Group Constituents: |
| Structure No | 8010S01 | Bldg 200: Reactor Containment Building |
| 19. Group 5:liners | | Bellows |
| | | Cavity Seal Ring Plate |
| | | Fuel transfer tube. |
| | | NIS Detector Cover. |
| | | Reactor Cavity Liner Plate |
| | | Reactor manway covers. |
| Structure No | 8300S46 | Bldgs 215, 220 and 225: Fuel Handling Building |
| 19. Group 5:liners | | Bellows |
| | | SF Pool Liner |
| Component/Comm | adity Creasure | Component Commodity Group Constituents: |

| Component/Commodity Group | Component Commodity Group Constituents: |
|---|--|
| Structure No 2080S01 | Tank: Refueling Water Storage |
| 25. All Groups: support members: anchor bolts, concrete surrounding anchor bolts, welds, grout pad, bolted connections, etc. | Anchorage/ Embedments - Exposed Surfaces |
| Structure No 3010S01 | Tank: Steam Generator Blowdown |
| 25. All Groups: support members: anchor bolts, concrete surrounding anchor bolts, welds, grout pad, bolted connections, etc. | Anchorage/ Embedments - Exposed Surfaces |
| | Pipe Supports |
| | Threaded fasteners. |
| Structure No 3070S01 | Tank: Condensate Storage |
| 25. All Groups: support members: anchor bolts, concrete surrounding anchor bolts, welds, grout pad, bolted connections, etc. | Anchorage/ Embedments - Exposed Surfaces |
| | Electrical component supports. |
| | Pipe Supports |
| Structure No 4015S02 | Bldg N/A: Intake Structure |
| 25. All Groups: support members: anchor bolts, concrete surrounding anchor bolts, welds, grout pad, bolted connections, etc. | Anchorage/ Embedments - Exposed Surfaces |
| | Battery Rack |
| | Electrical component supports. |
| | Expansion Anchors |
| | Instrument Racks and Frames. |
| | Pipe Supports |
| | Dida N/A, North Compion Water Hander Enclosure |
| | Bldg N/A: North Service Water Header Enclosure |
| Structure No4060S0125. All Groups: support members: anchor bolts, concrete surrounding anchor bolts, welds, grout pad, bolted connections, etc. | Anchorage/ Embedments - Exposed Surfaces |
| 25. All Groups: support members: anchor bolts, concrete surrounding anchor bolts, welds, grout pad, bolted connections, | Anchorage/ Embedments - Exposed Surfaces Electrical component supports. |
| 25. All Groups: support members: anchor bolts, concrete surrounding anchor bolts, welds, grout pad, bolted connections, | Anchorage/ Embedments - Exposed Surfaces |

| <i>Component/Commodity Group</i> 25. All Groups: support members: anchor bolts, concret surrounding anchor bolts, welds grout pad, bolted connections, etc. | Pipe Supports e |
|--|--|
| | Threaded fasteners. |
| Structure No 5100S01 | Tank: Diesel Generator Fuel Oil Storage |
| 25. All Groups: support members: anchor bolts, concret surrounding anchor bolts, welds grout pad, bolted connections, etc. | |
| | Electrical component supports. |
| | Expansion Anchors |
| | Pipe Supports |
| Structure No 5100S02 | Tank: DS Diesel Fuel Oil |
| 25. All Groups: support members: anchor bolts, concret surrounding anchor bolts, welds grout pad, bolted connections, etc. | |
| | Electrical component supports. |
| | Expansion Anchors |
| | Pipe Supports |
| Structure No 5100S03 | Tank: Diesel Fire Pump Fuel Oil |
| 25. All Groups: support members: anchor bolts, concret surrounding anchor bolts, welds grout pad, bolted connections, etc. | |
| | Expansion Anchors |
| | Pipe Supports |
| Structure No 5100S04 | Tanks: Unit 1 IC Fuel Oil Storage Facility |
| 25. All Groups: support members: anchor bolts, concret surrounding anchor bolts, welds grout pad, bolted connections, | |
| etc. | |

| Component/Commodity Gro | up Component Commodity Group Constituents: |
|--|--|
| 25. All Groups: support members: anchor bolts, conc surrounding anchor bolts, wel grout pad, bolted connections etc. | Anchorage/ Embedments - Exposed Surfaces rete ds, |
| | Electrical component supports. |
| Structure No 6082S01 | Bldg 310: EOF/TSC Security Emergency Diesel Generator Bldg |
| 25. All Groups: support members: anchor bolts, conc surrounding anchor bolts, wel grout pad, bolted connections etc. | ds, |
| | Battery Rack |
| | Electrical component supports. |
| | Expansion Anchors |
| | Pipe Supports |
| | Threaded fasteners. |
| | Vibration Isolators. |
| Structure No 6110S01 | Bldg N/A: Security Lighting |
| 25. All Groups: support members: anchor bolts, conc surrounding anchor bolts, wel grout pad, bolted connections etc. | ds, |
| | Electrical component supports. |
| Structure No 8010S01 | Bldg 200: Reactor Containment Building |
| 25. All Groups: support members: anchor bolts, conc surrounding anchor bolts, wel grout pad, bolted connections etc. | ds, |
| | Electrical component supports. |
| | Equipment Supports. |
| | Expansion Anchors |
| | HVAC Duct Supports. |
| | Instrument Line Supports. |
| | Instrument Racks and Frames. |
| | Pipe Supports |
| | Pipe whip restraints |
| | Slide bearing plates |
| | Threaded fasteners. |
| | Tube Track Supports. |

| <i>Component/Commodity Group</i> 25. All Groups: support members: anchor bolts, concrete surrounding anchor bolts, welds, grout pad, bolted connections, etc. | | <i>Component Commodity Group Constituents:</i> Vibration Isolators. | |
|--|---------------------------------|--|--|
| | 3300S09 | Bldg 210: Radwaste Building | |
| 25. All Groups: supp members: anchor bo surrounding anchor grout pad, bolted co etc. | olts, concrete bolts, welds, | Anchorage/ Embedments - Exposed Surfaces | |
| | | Expansion Anchors | |
| | | Pipe Supports | |
| | | Threaded fasteners. | |
| Structure No | 3300S18 | Bldg 340: Dedicated Shutdown (DS) Diesel Generator Building | |
| 25. All Groups: supp members: anchor bo surrounding anchor grout pad, bolted co etc. | olts, concrete bolts, welds, | Anchorage/ Embedments - Exposed Surfaces | |
| | | Battery Rack | |
| | | Electrical component supports. | |
| | | Equipment Supports. | |
| | | Expansion Anchors | |
| | | Instrument Racks and Frames. | |
| | | Pipe Supports | |
| | | Threaded fasteners. | |
| Structure No 8 | 3300S36 | Bldg 350: Turbine Building | |
| 25. All Groups: supp members: anchor be surrounding anchor grout pad, bolted co etc. | olts, concrete bolts, welds, | Anchorage/ Embedments - Exposed Surfaces | |
| | | Battery Rack | |
| | | Cable tray and conduit. | |
| | | Electrical Bus Duct (Enclosure) | |
| | | Electrical component supports. | |
| | | Equipment Supports. | |
| | | Expansion Anchors | |
| | | Instrument Line Supports. | |
| | | Instrument Racks and Frames. | |
| | | Pipe Supports | |

| Component/Commodity Group | Component Commodity Group Constituents: | |
|--|---|--|
| 25. All Groups: support members: anchor bolts, concrete surrounding anchor bolts, welds, grout pad, bolted connections, etc. | Pipe whip restraints | |
| | Threaded fasteners. | |
| | Tube Track Supports. | |
| Structure No 8300S44 | Electrical Manholes and Duct Banks | |
| 25. All Groups: support members: anchor bolts, concrete surrounding anchor bolts, welds, grout pad, bolted connections, etc. | Anchorage/ Embedments - Exposed Surfaces | |
| | Expansion Anchors | |
| | Pipe Supports | |
| Structure No 8300S46 | Bldgs 215, 220 and 225: Fuel Handling Building | |
| 25. All Groups: support members: anchor bolts, concrete surrounding anchor bolts, welds, grout pad, bolted connections, etc. | Anchorage/ Embedments - Exposed Surfaces | |
| | Electrical component supports. | |
| | Expansion Anchors | |
| | HVAC Duct Supports. | |
| | Instrument Line Supports. | |
| | Instrument Racks and Frames. | |
| | Pipe Supports | |
| | Tube Track Supports. | |
| Structure No 8300S48 | Pipe Restraint Tower | |
| 25. All Groups: support members: anchor bolts, concrete surrounding anchor bolts, welds, | Anchorage/ Embedments - Exposed Surfaces | |
| grout pad, bolted connections, etc. | | |
| • | Electrical component supports. | |
| • | Electrical component supports. Instrument Line Supports. | |
| • | | |
| • | Instrument Line Supports. | |

| Component/Commodity Group | Component Commodity Group Constituents: |
|--|--|
| 25. All Groups: support members: anchor bolts, concrete surrounding anchor bolts, welds, grout pad, bolted connections, etc. | Anchorage/ Embedments - Exposed Surfaces |
| | Expansion Anchors |
| | Pipe Supports |
| | Threaded fasteners. |
| Structure No 8300S55 | Bldg N/A: Miscellaneous Yard Structures |
| 25. All Groups: support members: anchor bolts, concrete surrounding anchor bolts, welds, grout pad, bolted connections, etc. | Anchorage/ Embedments - Exposed Surfaces |
| | Electrical component supports. |
| | Expansion Anchors |
| | Pipe Supports |
| Structure No 8320S01 | Bldg 205: Reactor Auxiliary Building |
| 25. All Groups: support members: anchor bolts, concrete surrounding anchor bolts, welds, grout pad, bolted connections, etc. | Anchorage/ Embedments - Exposed Surfaces |
| | Battery Rack |
| | Cable tray and conduit. |
| | Damper mounting |
| | Electrical Bus Duct (Enclosure) |
| | Electrical component supports. |
| | Equipment Supports. |
| | Expansion Anchors |
| | HVAC Duct Supports. |
| | Instrument Line Supports. |
| | Instrument Racks and Frames. |
| | Pipe Supports |
| | Pipe whip restraints |
| | Threaded fasteners. |
| | Tube Track Supports. |
| | Vibration Isolators. |
| Component/Commodity Group | Component Commodity Group Constituents: |
| Structure No 8010S01 | Bldg 200: Reactor Containment Building |

| Component/Comm | | Component Commodity Group Constituents: |
|--|---------------------------------|--|
| 27. All Groups: sup members: anchor b | | Anchorage/ Embedments - Exposed Surfaces |
| | | Electrical component supports. |
| | | Equipment Supports. |
| | | Expansion Anchors |
| | | HVAC Duct Supports. |
| | | Instrument Line Supports. |
| | | Instrument Racks and Frames. |
| | | Pipe Supports |
| | | Pipe whip restraints |
| | | Pressurizer Support |
| | Pressurizer Surge Line Supports | |
| | | Reactor Coolant Pump Supports |
| | | Slide bearing plates |
| | | Steam Generator Supports |
| | | Threaded fasteners. |
| | | Tube Track Supports. |
| | | Vibration Isolators. |
| Structure No | 8300S46 | Bldgs 215, 220 and 225: Fuel Handling Building |
| 27. All Groups: support members: anchor bolts, welds | | Anchorage/ Embedments - Exposed Surfaces |
| | | Electrical component supports. |
| | | Expansion Anchors |
| | | HVAC Duct Supports. |
| | | Instrument Line Supports. |
| | | Pipe Supports |
| | 8320S01 | Bldg 205: Reactor Auxiliary Building |
| 27. All Groups: sup members: anchor b | | Anchorage/ Embedments - Exposed Surfaces |
| | | Electrical component supports. |
| | | Equipment Supports. |
| | | Expansion Anchors |
| | | Instrument Line Supports. |
| | | Pipe Supports |

| Component/Commodity Group | Component Commodity Group Constituents: |
|---|--|
| Structure No 8010S01 | Bldg 200: Reactor Containment Building |
| 28. Groups B1.1, B1.2, and B1.3: support members: anchor bolts, welds, spring hangers, guides, stops, and vibration isolators | Anchorage/ Embedments - Exposed Surfaces |
| | Expansion Anchors |
| | Pipe Supports |
| | Pressurizer Support |
| | Pressurizer Surge Line Supports |
| | Reactor Coolant Pump Supports |
| | Reactor Vessel Support |
| | Slide bearing plates |
| | Steam Generator Supports |
| | Threaded fasteners. |
| Structure No 8300S36 | Bldg 350: Turbine Building |
| 28. Groups B1.1, B1.2, and B1.3: support members: anchor bolts, welds, spring hangers, guides, stops, and vibration isolators | Pipe Supports |
| Structure No 8300S46 | Bldgs 215, 220 and 225: Fuel Handling Building |
| 28. Groups B1.1, B1.2, and B1.3: support members: anchor bolts, welds, spring hangers, guides, stops, and vibration isolators | Pipe Supports |
| Structure No 8320S01 | Bldg 205: Reactor Auxiliary Building |
| 28. Groups B1.1, B1.2, and B1.3: support members: anchor bolts, welds, spring hangers, guides, stops, and vibration isolators | Pipe Supports |