#### **Duke Power**

McGuire Nuclear Station 12700 Hagers Ferry Road Huntersville, NC 28078-9340 (704) 875-4000

(704) 875-5333 OFFICE (704) 875-4809 FAX

**D.M. Jamil** Vice President, McGuire

A Duke Energy Company

October 24, 2002

United States Nuclear Regulatory Commission ATTENTION: Document Control Desk Washington, DC 20555-0001

SUBJECT: Duke Energy Corporation McGuire Nuclear Station Units 1 and 2 Docket Nos. 50-369 and 50-370 Technical Specification (TS) Bases Change

Attached is revision 35 to McGuire Technical Specification Bases (TSB) Manual.

Technical Specification Bases 3.0 was revised consistent with NRC approved Technical Specification Amendment 205/186. This amendment revised Surveillance Requirement 3.0.3 to extend the delay period before entering a Limiting Condition for Operation following a missed surveillance.

Please contact Jeff Thomas at (704) 875-4535 if you have any questions.

Very truly yours,

D.M. Jamil

Attachments



U. S. Nuclear Regulatory Commission October 24, 2002 Page 2 -----

Xc w/attachments:

2 2 X 4

> L. A. Reyes U. S. Nuclear Regulatory Commission Regional Administrator, Region II Atlanta Federal Center 61 Forsyth St., SW, Suite 23T85 Atlanta, GA 30303

> R. E. Martin U. S. Nuclear Regulatory Commission Mail Stop 0-8G9 11555 Rockville Pike Rockville, MD 20852-2738

B. O. Hall, Section Chief Division of Radiation Protection 1645 Mail Service Center Raleigh, NC 27699-1645

S. M. Shaeffer Senior Resident Inspector U. S. Nuclear Regulatory Commission McGuire Nuclear Station U. S. Nuclear Regulatory Commission October 24, 2002 Page 3 -----

~ \_\_\_\_

-----

------

Bc w/attachments:

<u>ج</u> ۱ ج

.

Mike Cash (EC050) ELL (EC050) Kay Crane McGuire Master File 1.3.2.12

#### ATTACHMENT 1

· · ·

### REVISED TECHNICAL SPECIFICATION BASES LIST OF EFFECTIVE SECTIONS

## McGuire Nuclear Station Technical Specifications List of Effective Pages and Bases List of Effective Sections

•

i	184/166	9/30/98
ii	184/166	9/30/98
iii	184/166	9/30/98
iv	184/166	9/30/98
1.1-1	184/166	9/30/98
1.1-2	184/166	9/30/98
1.1-3	206/187	8/23/02
1.1-4	194/175	9/18/00
1.1-5	206/187	8/23/02
1.1-6	206/187	8/23/02
1.1-7	194/175	9/18/00
1.2-1	184/166	9/30/98
1.2-2	184/166	9/30/98
1.2-3	184/166	9/30/98
1.3-1	184/166	9/30/98
1.3-2	184/166	9/30/98
1.3-3	184/166	9/30/98
1.3-4	184/166	9/30/98
1.3-5	184/166	9/30/98
1.3-6	184/166	9/30/98
1.3-7	184/166	9/30/98
1.3-8	184/166	9/30/98
1.3-9	184/166	9/30/98
1.3-10	184/166	9/30/98
1.3-11	184/166	9/30/98
1.3-12	184/166	9/30/98
1.3-13	184/166	9/30/98
1.4-1	184/166	9/30/98
1.4-2	184/166	9/30/98
1.4-3	184/166	9/30/98
1.4-4	184/166	9/30/98

2.0-1	184/166	9/30/98
2.0-2	191/172	3/20/00
3.0-1	184/166	9/30/98
3.0-2	184/166	9/30/98
3.0-3	184/166	9/30/98
3.0-4	205/186	8/12/02
3.0-5	184/166	9/30/98
3.1.1-1	184/166	9/30/98
3.1.2-1	184/166	9/30/98
3.1.2-2	184/166	9/30/98
3.1.3-1	184/166	9/30/98
3.1.3-2	184/166	9/30/98
3.1.3-3	184/166	9/30/98
3.1.4-1	184/166	9/30/98
3.1.4-2	184/166	9/30/98
3.1.4-3	184/166	9/30/98
3.1.4-4	186/167	9/8/99
3.1.5-1	184/166	9/30/98
3.1.5-2	184/166	9/30/98
3.1.6-1	184/166	9/30/98
3.1.6-2	184/166	9/30/98
3.1.6-3	184/166	9/30/98
3.1.7-1	184/166	9/30/98
3.1.7-2	184/166	9/30/98
3.1.8-1	184/166	9/30/98
3.1.8-2	184/166	9/30/98
3.2.1-1	184/166	9/30/98
3.2.1-2	184/166	9/30/98
3.2.1-3	184/166	9/30/98
3.2.1-4	188/169	9/22/99
3.2.1-5	188/169	9/22/99
3.2.2-1	184/166	9/30/98
3.2.2-2	184/166	9/30/98
3.2.2-3	184/166	9/30/98

.

· `

.

3.2.2-4	188/169	9/22/99
3.2.3-1	184/166	9/30/98
3.2.4-1	184/166	9/30/98
3.2.4-2	184/166	9/30/98
3.2.4-3	184/166	9/30/98
3.2.4-4	184/166	9/30/98
3.3.1-1	184/166	9/30/98
3.3.1-2	184/166	9/30/98
3.3.1-3	184/166	9/30/98
3.3.1-4	184/166	9/30/98
3.3.1-5	184/166	9/30/98
3.3.1-6	184/166	9/30/98
3.3.1-7	184/166	9/30/98
3.3.1-8	184/166	9/30/98
3.3.1-9	184/166	9/30/98
3.3.1-10	184/166	9/30/98
3.3.1-11	184/166	9/30/98
3.3.1-12	184/166	9/30/98
3.3.1-13	184/166	9/30/98
3.3.1-14	194/175	9/18/00
3.3.1-15	194/175	9/18/00
3.3.1-16	194/175	9/18/00
3.3.1-17	194/175	9/18/00
3.3.1-18	194/175	9/18/00
3.3.1-19	194/175	9/18/00
3.3.1-20	184/166	9/30/98
3.3.2-1	184/166	9/30/98
3.3.2-2	184/166	9/30/98
3.3.2-3	184/166	9/30/98
3.3.2-4	184/166	9/30/98
3.3.2-5	184/166	9/30/98
3.3.2-6	198/179	4/12/01
3.3.2-7	198/179	4/12/01
3.3.2-8	184/166	9/30/98

۰,

•

3.3.2-9	184/166	9/30/98
3.3.2-10	194/175	9/18/00
3.3.2-11	194/175	9/18/00
3.3.2-12	194/175	9/18/00
3.3.2-13	198/179	4/12/01
3.3.2-14	194/175	9/18/00
3.3.2-15	184/166	9/30/98
3.3.3-1	184/166	9/30/98
3.3.3-2	184/166	9/30/98
3.3.3-3	184/166	9/30/98
3.3.3-4	184/166	9/30/98
3.3.4-1	184/166	9/30/98
3.3.4-2	184/166	9/30/98
3.3.4-3	184/166	9/30/98
3.3.5-1	184/166	9/30/98
3.3.5-2	194/175	9/18/00
3.3.6-1	184/166	9/30/98
3.3.6-2	184/166	9/30/98
3.3.6-3	194/175	9/18/00
3.4.1-1	191/172	3/20/00
3.4.1-2	191/175	3/20/00
3.4.1-3	184/166	9/30/98
3.4.1-4	191/172	3/20/00
3.4.2-1	184/166	9/30/98
3.4.3-1	184/166	9/30/98
3.4.3-2	184/166	9/30/98
3.4.3-3	184/166	9/30/98
3.4.3-4	184/166	9/30/98
3.4.3-5	184/166	9/30/98
3.4.3-6	184/166	9/30/98
3.4.4-1	184/166	9/30/98
3.4.5-1	184/166	9/30/98
3.4.5-2	184/166	9/30/98
3.4.5-3	184/166	9/30/98

\$

3.4.6-1	184/166	9/30/98
3.4.6-2	184/166	9/30/98
3.4.7-1	184/166	9/30/98
3.4.7-2	184/166	9/30/98
3.4.8-1	184/166	9/30/98
3.4.8-2	184/166	9/30/98
3.4.9-1	184/166	9/30/98
3.4.9-2	184/166	9/30/98
3.4.10-1	184/166	9/30/98
3.4.10-2	184/166	9/30/98
3.4-11-1	184/166	9/30/98
3.4.11-2	184/166	9/30/98
3.4-11-3	184/166	9/30/98
3.4.11-4	184/166	9/30/98
3.4.12-1	184/166	9/30/98
3.4.12-2	184/166	9/30/98
3.4.12-3	184/166	9/30/98
3.4.12-4	184/166	9/30/98
3.4.12-5	184/166	9/30/98
3.4.12-6	184/166	9/30/98
3.4.13-1	184/166	9/30/98
3.4.13-2	184/166	9/30/98
3.4.14-1	184/166	9/30/98
3.4.14-2	184/166	9/30/98
3.4.14-3	184/166	9/30/98
3.4.14-4	184/166	9/30/98
3.4.15-1	184/166	9/30/98
3.4.15-2	184/166	9/30/98
3.4.15-3	184/166	9/30/98
3.4.16-1	184/166	9/30/98
3.4.16-2	184/166	9/30/98
3.4.16-3	184/166	9/30/98
3.4.16-4	184/166	9/30/98
3.4.17-1	184/166	9/30/98

•

•

۰

3.5.1-1	184/166	9/30/98
3.5.1-2	184/166	9/30/98
3.5.2-1	184/166	9/30/98
3.5.2-2	184/166	9/30/98
3.5.2 <b>-</b> 3	184/166	9/30/98
3.5.3-1	184/166	9/30/98
3.5.3-2	184/166	9/30/98
3.5.4-1	184/166	9/30/98
3.5.4-2	184/166	9/30/98
3.5.5-1	184/166	9/30/98
3.5.5 <b>-</b> 2	184/166	9/30/98
3.6.1-1	207/188	9/4/02
3.6.1-2	207/188	9/4/02
3.6.2-1	184/166	9/30/98
3.6.2-2	201/182	3/13/02
3.6.2-3	201/182	3/13/02
3.6.2-4	184/166	9/30/98
3.6.2-5	207/188	9/4/02
3.6.3-1	184/166	9/30/98
3.6.3 <b>-</b> 2	184/166	9/30/98
3.6.3-3 ົ	184/166	9/30/98
3.6.3-4	184/166	9/30/98
3.6.3-5	184/166	9/30/98
3.6.3-6	207/188	9/4/02
3.6.3-7	207/188	9/4/02
3.6.4-1	184/166	9/30/98
3.6.5-1	184/166	9/30/98
3.6.5-2	184/166	9/30/98
3.6.6-1	184/166	9/30/98
3.6.6-2	184/166	9/30/98
3.6.7-1	184/166	9/30/98
3.6.7-2	184/166	9/30/98
3.6.8-1	184/166	9/30/98
3.6.8-2	184/166	9/30/98

3

•

	3.6.9-1	184/166	9/30/98
	3.6.9-2	184/166	9/30/98
	3.6.10-1	184/166	9/30/98
	3.6.10-2	184/166	9/30/98
	3.6.11-1	184/166	9/30/98
	3.6.11-2	184/166	9/30/98
	3.6.12-1	184/166	9/30/98
	3.6.12-2	201/182	3/13/02
	3.6.12-3	201/182	3/13/02
	3.6.13-1	184/166	9/30/98
	3.6.13-2	184/166	9/30/98
	3.6.13-3	184/166	9/30/98
	3.6.14-1	184/166	9/30/98
	3.6.14-2	184/166	9/30/98
	3.6.14-3	184/166	9/30/98
	3.6.15-1	184/166	9/30/98
	3.6.15-2	184/166	9/30/98
	3.6.16-1	184/166	9/30/98
	3.6.16-2	184/166	9/30/98
	3.7.1-1	184/166	9/30/98
	3.7.1-2	184/166	9/30/98
	3.7.1-3	184/166	9/30/98
	3.7.2-1	184/166	9/30/98
	3.7.2-2	184/166	9/30/98
	3.7.3-1	184/166	9/30/98
	3.7.3-2	184/166	9/30/98
	3.7.4-1	184/166	9/30/98
	3.7.4-2 ·	184/166	9/30/98
	3.7.5-1	184/166	9/30/98
	3.7.5-2	184/166	9/30/98
	3.7.5-3	184/166	9/30/98
	3.7.5-4	184/166	9/30/98
	3.7.6-1	184/166	9/30/98
	3.7.6-2	184/166	9/30/98
•			

3.7.7-1	184/166	9/30/98
3.7.7-2	184/166	9/30/98
3.7.8-1	184/166	9/30/98
3.7.8-2	184/166	9/30/98
3.7.9-1	187/168	9/22/99
3.7.9-2	187/168	9/22/99
3.7.9-3	184/166	9/30/98
3.7.10-1	184/166	9/30/98
3.7.10-2	184/166	9/30/98
3.7.11-1	184/166	9/30/98
3.7.11-2	184/166	9/30/98
3.7.12-1	184/166	9/30/98
3.7.12-2	184/166	9/30/98
3.7.13-1	184/166	9/30/98
3.7.14-1	184/166	9/30/98
3.7.15-1	197/178	11/27/00
3.7.15-2	197/178	11/27/00
3.7.15-3	197/178	11/27/00
3.7.15-4	197/178	11/27/00
3.7.15-5	197/178	11/27/00
3.7.15-6	197/178	11/27/00
3.7.15-7	197/178	11/27/00
3.7.15-8	197/178	11/27/00
3.7.15-9	197/178	11/27/00
3.7.15-10	197/178	11/27/00
3.7.15-11	197/178	11/27/00
3.7.15-12	197/178	11/27/00
3.7.15-13	197/178	11/27/00
3.7.15-14	197/178	11/27/00
3.7.15-15	197/178	11/27/00
3.7.15-16	197/178	11/27/00
3.7.15-17	197/178	11/27/00
3.7.15-18	197/178	11/27/00
3.7.15-19	197/178	11/27/00

;

•

3.7.15-20	197/178	11/27/00
3.7.15-21	197/178	11/27/00
3.7.16-1	184/166	9/30/98
3.8.1-1	184/166	9/30/98
3.8.1-2	184/166	9/30/98
3.8.1-3	184/166	9/30/98
3.8.1-4	184/166	9/30/98
3.8.1-5	184/166	9/30/98
3.8.1-6	184/166	9/30/98
3.8.1-7	184/166	9/30/98
3.8.1-8	192/173	3/15/00
3.8.1-9	184/166	9/30/98
3.8.1-10	184/166	9/30/98
3.8.1-11	192/173	3/15/00
3.8.1-12	184/166	9/30/98
3.8.1-13	184/166	9/30/98
3.8.1-14	184/166	9/30/98
3.8.1-15	184/166	9/30/98
3.8.2-1	184/166	9/30/98
3.8.2-2	184/166	9/30/98
3.8.2-3	184/166	9/30/98
3.8.3-1	184/166	9/30/98
3.8.3-2	184/166	9/30/98
3.8.3-3	184/166	9/30/98
3.8.4-1	184/166	9/30/98
3.8.4-2	184/166	9/30/98
3.8.4-3	184/166	9/30/98
3.8.5-1	184/166	9/30/98
3.8.5-2	184/166	9/30/98
3.8.6-1	184/166	9/30/98
3.8.6-2	184/166	9/30/98
3.8.6-3	184/166	9/30/98
3.8.6-4	184/166	9/30/98
3.8.7-1	184/166	9/30/98

• - • •

-- ---- --

-----

3.8.8-1	184/166	9/30/98
3.8.8-2	184/166	9/30/98
3.8.9-1	184/166	9/30/98
3.8.9-2	184/166	9/30/98
3.8.10-1	184/166	9/30/98
3.8.10-2	184/166	9/30/98
3.9.1-1	184/166	9/30/98
3.9.2-1	184/166	9/30/98
3.9.3-1	184/166	9/30/98
3.9.3-2	184/166	9/30/98
3.9.4-1	184/166	9/30/98
3.9.4-2	184/166	9/30/98
3.9.5-1	184/166	9/30/98
3.9.5-2	184/166	9/30/98
3.9.6-1	184/166	9/30/98
3.9.6-2	184/166	9/30/98
3.9.7-1	184/166	9/30/98
4.0.1	197/178	11/27/00
4.0.2	197/178	11/27/00
4.0.2 5.1-1	197/178 184/166	11/27/00 9/30/98
4.0.2 5.1-1 5.2-1	197/178 184/166 184/166	11/27/00 9/30/98 9/30/98
4.0.2 5.1-1 5.2-1 5.2-2	197/178 184/166 184/166 184/166	11/27/00 9/30/98 9/30/98 9/30/98
4.0.2 5.1-1 5.2-1 5.2-2 5.2-3	197/178 184/166 184/166 184/166 184/166	11/27/00 9/30/98 9/30/98 9/30/98 9/30/98
4.0.2 5.1-1 5.2-1 5.2-2 5.2-3 5.3-1	197/178 184/166 184/166 184/166 184/166 184/166	11/27/00 9/30/98 9/30/98 9/30/98 9/30/98 9/30/98
4.0.2 5.1-1 5.2-1 5.2-2 5.2-3 5.3-1 5.4-1	197/178 184/166 184/166 184/166 184/166 184/166 184/166	11/27/00 9/30/98 9/30/98 9/30/98 9/30/98 9/30/98
4.0.2 5.1-1 5.2-1 5.2-2 5.2-3 5.3-1 5.4-1 5.5-1	197/178 184/166 184/166 184/166 184/166 184/166 184/166 207/188	11/27/00 9/30/98 9/30/98 9/30/98 9/30/98 9/30/98 9/30/98 9/30/98
4.0.2 5.1-1 5.2-1 5.2-2 5.2-3 5.3-1 5.4-1 5.5-1 5.5-2	197/178 184/166 184/166 184/166 184/166 184/166 184/166 207/188 207/188	11/27/00 9/30/98 9/30/98 9/30/98 9/30/98 9/30/98 9/30/98 9/4/02 9/4/02
4.0.2 5.1-1 5.2-1 5.2-2 5.2-3 5.3-1 5.4-1 5.5-1 5.5-2 5.5-3	197/178 184/166 184/166 184/166 184/166 184/166 207/188 207/188 184/166	11/27/00 9/30/98 9/30/98 9/30/98 9/30/98 9/30/98 9/30/98 9/4/02 9/4/02 9/30/98
4.0.2 5.1-1 5.2-1 5.2-2 5.2-3 5.3-1 5.4-1 5.5-1 5.5-2 5.5-3 5.5-4	197/178 184/166 184/166 184/166 184/166 184/166 207/188 207/188 184/166 184/166	11/27/00 9/30/98 9/30/98 9/30/98 9/30/98 9/30/98 9/4/02 9/4/02 9/30/98 9/30/98
4.0.2 5.1-1 5.2-1 5.2-2 5.2-3 5.3-1 5.4-1 5.5-1 5.5-2 5.5-3 5.5-3 5.5-4 5.5-5	197/178 184/166 184/166 184/166 184/166 184/166 207/188 207/188 184/166 184/166 184/166 184/166	11/27/00 9/30/98 9/30/98 9/30/98 9/30/98 9/30/98 9/4/02 9/4/02 9/30/98 9/30/98 9/30/98
4.0.2 5.1-1 5.2-1 5.2-2 5.2-3 5.3-1 5.4-1 5.5-1 5.5-2 5.5-3 5.5-3 5.5-4 5.5-5 5.5-6	197/178 184/166 184/166 184/166 184/166 184/166 207/188 207/188 184/166 184/166 184/166 190/171 184/166	11/27/00 9/30/98 9/30/98 9/30/98 9/30/98 9/30/98 9/4/02 9/4/02 9/30/98 9/30/98 12/21/99 9/30/98
4.0.2 5.1-1 5.2-1 5.2-2 5.2-3 5.3-1 5.4-1 5.5-1 5.5-2 5.5-3 5.5-3 5.5-4 5.5-5 5.5-6 5.5-6	197/178 184/166 184/166 184/166 184/166 184/166 207/188 207/188 184/166 184/166 190/171 184/166 184/166	11/27/00 9/30/98 9/30/98 9/30/98 9/30/98 9/30/98 9/4/02 9/4/02 9/30/98 9/30/98 12/21/99 9/30/98 9/30/98
4.0.2 5.1-1 5.2-1 5.2-2 5.2-3 5.3-1 5.4-1 5.5-1 5.5-2 5.5-3 5.5-3 5.5-4 5.5-5 5.5-6 5.5-6 5.5-7 5.5-8	197/178 184/166 184/166 184/166 184/166 184/166 207/188 207/188 184/166 184/166 190/171 184/166 184/166 184/166	11/27/00 9/30/98 9/30/98 9/30/98 9/30/98 9/30/98 9/4/02 9/4/02 9/30/98 9/30/98 12/21/99 9/30/98 9/30/98

٠

•

5.5-10	184/166	9/30/98
5.5-11	184/166	9/30/98
5.5-12	184/166	9/30/98
5.5-13	184/166	9/30/98
5.5-14	196/177	11/2/00
5.5-15	184/166	9/30/98
5.5-16	184/166	9/30/98
5.5-17	204/185	7/17/02
5.5-18	184/166	9/30/98
5.6-1	184/166	9/30/98
5.6-2	208/189	10/1/02
5.6-3	208/189	10/1/02
5.6-4	203/184	7/10/02
5.6-5	184/166	9/30/98
5.7-1	184/166	9/30/98
5.7-2	184/166	9/30/98

. .

#### BASES

(Revised per section)			
i	Revision 0	9/30/98	
ii	Revision 0	9/30/98	
iii	Revision 0	9/30/98	
B 2.1.1	Revision 0	9/30/98	
B 2.1.2	Revision 0	9/30/98	
B 3.0	Revision 35	8/12/02	
B 3.1.1	Revision 0	9/30/98	
B 3.1.2	Revision 10	9/22/00	
B 3.1.3	Revision 10	9/22/00	
B 3.1.4	Revision 0	9/30/98	
B 3.1.5	Revision 19	1/10/02	
B 3.1.6	Revision 0	9/30/98	
B 3.1.7	Revision 15	01/04/01	
B 3.1.8	Revision 0	9/30/98	
B 3.2.1	Revision 34	10/1/02	

B 3.2.2	Revision 10	9/22/00
B 3.2.3	Revision 34	10/1/02
B 3.2.4	Revision 10	9/22/00
B 3.3.1	Revision 31	9/17/02
B 3.3.2	Revision 31	9/17/02
B 3.3.3	Revision 26	1/15/02
B 3.3.4	Revision 0	9/30/98
B 3.3.5	Revision 11	9/18/00
B 3.3.6	Revision 0	9/30/98
B 3.4.1	Revision 8	3/20/00
B 3.4.2	Revision 0	9/30/98
B 3.4.3	Revision 0	9/30/98
B 3.4.4	Revision 0	9/30/98
B 3.4.5	Revision 0	9/30/98
B 3.4.6	Revision 0	9/30/98
B 3.4.7	Revision 0	9/30/98
B 3.4.8	Revision 0	9/30/98
B 3.4.9	Revision 0	9/30/98
B 3.4.10	Revision 0	9/30/98
B 3.4.11	Revision 0	9/30/98
B 3.4.12	Revision 30	8/13/02
B 3.4.13	Revision 0	9/30/98
B 3.4.14	Revision 0	9/30/98
B 3.4.15	Revision 0	9/30/98
B 3.4.16	Revision 0	9/30/98
B 3.4.17	Revision 0	9/30/98
B 3.5.1	Revision 30	8/13/02
B 3.5.2	Revision 10	9/22/00
B 3.5.3	Revision 0	9/30/98
B 3.5.4	Revision 0	9/30/98
B 3.5.5	Revision 0	9/30/98
B 3.6.1	Revision 32	10/4/02
B 3.6.2	Revision 32	10/4/02
B 3.6.3	Revision 32	10/4/02

-

•

•

B 3.6.4	Revision 0	9/30/98
B 3.6.5	Revision 0	9/30/98
B 3.6.6	Revision 0	9/30/98
B 3.6.7	Revision 0	9/30/98
B 3.6.8	Revision 0	9/30/98
B 3.6.9	Revision 0	9/30/98
B 3.6.10	Revision 0	9/30/98
B 3.6.11	Revision 0	9/30/98
B 3.6.12	Revision 25	3/13/02
B 3.6.13	Revision 0	9/30/98
B 3.6.14	Revision 0	9/30/98
B 3.6.15	Revision 0	9/30/98
B 3.6.16	Revision 0	9/30/98
B 3.7.1	Revision 0	9/30/98
B 3.7.2	Revision 0	9/30/98
B 3.7.3	Revision 0	9/30/98
B 3.7.4	Revision 0	9/30/98
B 3.7.5	Revision 0	9/30/98
B 3.7.6	Revision 0	9/30/98
B 3.7.7	Revision 0	9/30/98
B 3.7.8	Revision 0	9/30/98
B 3.7.9	Revision 0	9/30/98
B 3.7.10	Revision 0	9/30/98
B 3.7.11	Revision 33	9/27/02
B 3.7.12	Revision 28	5/17/02
B 3.7.13	Revision 0	9/30/98
B 3.7.14	Revision 14	11/27/00
B 3.7.15	Revision 14	11/27/00
B 3.7.16	Revision 0	9/30/98
B 3.8.1	Revision 13	1/18/01
B 3.8.2	Revision 21	1/8/02
B 3.8.3	Revision 0	9/30/98
B 3.8.4	Revision 22	1/10/02
B 3.8.5	Revision 0	9/30/98

χ.

· ·

B 3.8.6	Revision 0	9/30/98
B 3.8.7	Revision 20	1/10/02
B 3.8.8	Revision 0	9/30/98
B 3.8.9	Revision 24	2/4/02
B 3.8.10	Revision 0	9/30/98
B 3.9.1	Revision 0	9/30/98
B 3.9.2	Revision 0	9/30/98
B 3.9.3	Revision 27	5/14/02
B 3.9.4	Revision 0	9/30/98
B 3.9.5	Revision 0	9/30/98
B 3.9.6	Revision 0	9/30/98
B 3.9.7	Revision 0	9/30/98

. •

#### ATTACHMENT 2

. •

# REVISED TECHNICAL SPECIFICATION BASES 3.0

# B 3.0 LIMITING CONDITION FOR OPERATION (LCO) APPLICABILITY

,

.

BASES	
LCOs	LCO 3.0.1 through LCO 3.0.8 establish the general requirements applicable to all Specifications and apply at all times, unless otherwise stated.
LCO 3.0.1	LCO 3.0.1 establishes the Applicability statement within each individual Specification as the requirement for when the LCO is required to be met (i.e., when the unit is in the MODES or other specified conditions of the Applicability statement of each Specification).
LCO 3.0.2	LCO 3.0.2 establishes that upon discovery of a failure to meet an LCO, the associated ACTIONS shall be met. The Completion Time of each Required Action for an ACTIONS Condition is applicable from the point in time that an ACTIONS Condition is entered. The Required Actions establish those remedial measures that must be taken within specified Completion Times when the requirements of an LCO are not met. This Specification establishes that:
	a. Completion of the Required Actions within the specified Completion Times constitutes compliance with a Specification; and
	<ul> <li>Completion of the Required Actions is not required when an LCO is met within the specified Completion Time, unless otherwise specified.</li> </ul>
	There are two basic types of Required Actions. The first type of Required Action specifies a time limit in which the LCO must be met. This time limit is the Completion Time to restore an inoperable system or component to OPERABLE status or to restore variables to within specified limits. If this type of Required Action is not completed within the specified Completion Time, a shutdown may be required to place the unit in a MODE or condition in which the Specification is not applicable. (Whether stated as a Required Action or not, correction of the entered Condition is an action that may always be considered upon entering ACTIONS.) The second type of Required Action specifies the remedial measures that permit continued operation of the unit that is not further restricted by the Completion Time. In this case, compliance with the Required Actions provides an acceptable level of safety for continued operation.

#### LCO 3.0.2 (continued)

Completing the Required Actions is not required when an LCO is met or is no longer applicable, unless otherwise stated in the individual Specifications.

The nature of some Required Actions of some Conditions necessitates that, once the Condition is entered, the Required Actions must be completed even though the associated Conditions no longer exist. The individual LCO's ACTIONS specify the Required Actions where this is the case. An example of this is in LCO 3.4.3, "RCS Pressure and Temperature (P/T) Limits."

The Completion Times of the Required Actions are also applicable when a system or component is removed from service intentionally. The reasons for intentionally relying on the ACTIONS include, but are not limited to, performance of Surveillances, preventive maintenance, corrective maintenance, modifications, or investigation of operational problems. Entering ACTIONS for these reasons must be done in a manner that does not compromise safety. Intentional entry into ACTIONS should not be made for operational convenience. Alternatives that would not result in redundant equipment being inoperable should be used instead. Doing so limits the time both subsystems/trains of a safety function are inoperable and limits the time other conditions exist which result in LCO 3.0.3 being entered. Individual Specifications may specify a time limit for performing an SR when equipment is removed from service or bypassed for testing. In this case, the Completion Times of the Required Actions are applicable when this time limit expires, if the equipment remains removed from service or bypassed.

When a change in MODE or other specified condition is required to comply with Required Actions, the unit may enter a MODE or other specified condition in which another Specification becomes applicable. In this case, the Completion Times of the associated Required Actions would apply from the point in time that the new Specification becomes applicable, and the ACTIONS Condition(s) are entered.

- LCO 3.0.3 LCO 3.0.3 establishes the actions that must be implemented when an LCO is not met and:
  - a. An associated Required Action and Completion Time is not met and no other Condition applies; or

LCO 3.0.3 (continued)

b. The condition of the unit is not specifically addressed by the associated ACTIONS. This means that no combination of Conditions stated in the ACTIONS can be made that exactly corresponds to the actual condition of the unit. Sometimes, possible combinations of Conditions are such that entering LCO 3.0.3 is warranted; in such cases, the ACTIONS specifically state a Condition corresponding to such combinations and also that LCO 3.0.3 be entered immediately.

This Specification delineates the time limits for placing the unit in a safe MODE or other specified condition when operation cannot be maintained within the limits for safe operation as defined by the LCO and its ACTIONS. It is not intended to be used as an operational convenience that permits routine voluntary removal of redundant systems or components from service in lieu of other alternatives that would not result in redundant systems or components being inoperable.

Upon entering LCO 3.0.3, 1 hour is allowed to prepare for an orderly shutdown before initiating a change in unit operation. This includes time to permit the operator to coordinate the reduction in electrical generation with the load dispatcher to ensure the stability and availability of the electrical grid. The time limits specified to reach lower MODES of operation permit the shutdown to proceed in a controlled and orderly manner that is well within the specified maximum cooldown rate and within the capabilities of the unit, assuming that only the minimum required equipment is OPERABLE. This reduces thermal stresses on components of the Reactor Coolant System and the potential for a plant upset that could challenge safety systems under conditions to which this Specification applies. The use and interpretation of specified times to complete the actions of LCO 3.0.3 are consistent with the discussion of Section 1.3, Completion Times.

A unit shutdown required in accordance with LCO 3.0.3 may be terminated and LCO 3.0.3 exited if any of the following occurs:

- a. The LCO is now met.
- b. A Condition exists for which the Required Actions have now been performed.
- c. ACTIONS exist that do not have expired Completion Times. These Completion Times are applicable from the point in time that the Condition is initially entered and not from the time LCO 3.0.3 is exited.

#### LCO 3.0.3 (continued)

The time limits of Specification 3.0.3 allow 37 hours for the unit to be in MODE 5 when a shutdown is required during MODE 1 operation. If the unit is in a lower MODE of operation when a shutdown is required, the time limit for reaching the next lower MODE applies. If a lower MODE is reached in less time than allowed, however, the total allowable time to reach MODE 5, or other applicable MODE, is not reduced. For example, if MODE 3 is reached in 2 hours, then the time allowed for reaching MODE 4 is the next 11 hours, because the total time for reaching MODE 4 is not reduced from the allowable limit of 13 hours. Therefore, if remedial measures are completed that would permit a return to MODE 1, a penalty is not incurred by having to reach a lower MODE of operation in less than the total time allowed.

In MODES 1, 2, 3, and 4, LCO 3.0.3 provides actions for Conditions not covered in other Specifications. The requirements of LCO 3.0.3 do not apply in MODES 5 and 6 because the unit is already in the most restrictive Condition required by LCO 3.0.3. The requirements of LCO 3.0.3 do not apply in other specified conditions of the Applicability (unless in MODE 1, 2, 3, or 4) because the ACTIONS of individual Specifications sufficiently define the remedial measures to be taken.

Exceptions to LCO 3.0.3 are provided in instances where requiring a unit shutdown, in accordance with LCO 3.0.3, would not provide appropriate remedial measures for the associated condition of the unit. An example of this is in LCO 3.7.13, "Spent Fuel Pool (SFP) Water Level." LCO 3.7.13 has an Applicability of "During movement of irradiated fuel assemblies in the spent fuel pool." Therefore, this LCO can be applicable in any or all MODES. If the LCO and the Required Actions of LCO 3.7.13 are not met while in MODE 1, 2, or 3, there is no safety benefit to be gained by placing the unit in a shutdown condition. The Required Action of LCO 3.7.13 of "Suspend movement of irradiated fuel assemblies in the appropriate Required Action to complete in lieu of the actions of LCO 3.0.3. These exceptions are addressed in the individual Specifications.

LCO 3.0.4 LCO 3.0.4 establishes limitations on changes in MODES or other specified conditions in the Applicability when an LCO is not met. It precludes placing the unit in a MODE or other specified condition stated in that Applicability (e.g., Applicability desired to be entered) when the following exist:

LCO 3.0.4 (continued)

- a. Unit conditions are such that the requirements of the LCO would not be met in the Applicability desired to be entered; and
- b. Continued noncompliance with the LCO requirements, if the Applicability were entered, would result in the unit being required to exit the Applicability desired to be entered to comply with the Required Actions.

Compliance with Required Actions that permit continued operation of the unit for an unlimited period of time in a MODE or other specified condition provides an acceptable level of safety for continued operation. This is without regard to the status of the unit before or after the MODE change. Therefore, in such cases, entry into a MODE or other specified condition in the Applicability may be made in accordance with the provisions of the Required Actions. The provisions of this Specification should not be interpreted as endorsing the failure to exercise the good practice of restoring systems or components to OPERABLE status before entering an associated MODE or other specified condition in the Applicability.

The provisions of LCO 3.0.4 shall not prevent changes in MODES or other specified conditions in the Applicability that are required to comply with ACTIONS.

Exceptions to LCO 3.0.4 are stated in the individual Specifications. The exceptions allow entry into MODES or other specified conditions in the Applicability when the associated ACTIONS to be entered do not provide for continued operation for an unlimited period of time. Exceptions may apply to all the ACTIONS or to a specific Required Action of a Specification.

Surveillances do not have to be performed on the associated inoperable equipment (or on variables outside the specified limits), as permitted by SR 3.0.1. Therefore, changing MODES or other specified conditions while in an ACTIONS Condition, in compliance with LCO 3.0.4 or where an exception to LCO 3.0.4 is stated, is not a violation of SR 3.0.1 or SR 3.0.4 for those Surveillances that do not have to be performed due to the associated inoperable equipment. However, SRs must be met to ensure OPERABILITY prior to declaring the associated equipment OPERABLE (or variable within limits) and restoring compliance with the affected LCO.

BASES	
LCO 3.0.5	LCO 3.0.5 establishes the allowance for restoring equipment to service under administrative controls when it has been removed from service or declared inoperable to comply with ACTIONS. The sole purpose of this Specification is to provide an exception to LCO 3.0.2 (e.g., to not comply with the applicable Required Action(s)) to allow the performance of SRs to demonstrate:
	a. The OPERABILITY of the equipment being returned to service; or
	b. The OPERABILITY of other equipment.
	The administrative controls ensure the time the equipment is returned to service in conflict with the requirements of the ACTIONS is limited to the time absolutely necessary to perform the allowed SRs. This Specification does not provide time to perform any other preventive or corrective maintenance.
	An example of demonstrating the OPERABILITY of the equipment being returned to service is reopening a containment isolation valve that has been closed to comply with Required Actions and must be reopened to perform the SRs.
	An example of demonstrating the OPERABILITY of other equipment is taking an inoperable channel or trip system out of the tripped condition to prevent the trip function from occurring during the performance of an SR on another channel in the other trip system. A similar example of demonstrating the OPERABILITY of other equipment is taking an inoperable channel or trip system out of the tripped condition to permit the logic to function and indicate the appropriate response during the performance of an SR on another channel in the same trip system.
LCO 3.0.6	LCO 3.0.6 establishes an exception to LCO 3.0.2 for support systems that have an LCO specified in the Technical Specifications (TS). This exception is provided because LCO 3.0.2 would require that the Conditions and Required Actions of the associated inoperable supported system LCO be entered solely due to the inoperability of the support system. This exception is justified because the actions that are required to ensure the unit is maintained in a safe condition are specified in the support system LCO's Required Actions. These Required Actions may include entering the supported system's Conditions and Required Actions or may specify other Required Actions
	When a support system is inoperable and there is an LCO specified for it in the TS, the supported system(s) are required to be declared inoperable if determined to be inoperable as a result of the support system

ĩ

.

.

#### LCO 3.0.6 (continued)

inoperability. However, it is not necessary to enter into the supported systems' Conditions and Required Actions unless directed to do so by the support system's Required Actions. The potential confusion and inconsistency of requirements related to the entry into multiple support and supported systems' LCOs' Conditions and Required Actions are eliminated by providing all the actions that are necessary to ensure the unit is maintained in a safe condition in the support system's Required Actions.

However, there are instances where a support system's Required Action may either direct a supported system to be declared inoperable or direct entry into Conditions and Required Actions for the supported system. This may occur immediately or after some specified delay to perform some other Required Action. Regardless of whether it is immediate or after some delay, when a support system's Required Action directs a supported system to be declared inoperable or directs entry into Conditions and Required Actions for a supported system, the applicable Conditions and Required Actions shall be entered in accordance with LCO 3.0.2.

Specification 5.5.15, "Safety Function Determination Program (SFDP)," ensures loss of safety function is detected and appropriate actions are taken. Upon entry into LCO 3.0.6, an evaluation shall be made to determine if loss of safety function exists. Additionally, other limitations, remedial actions, or compensatory actions may be identified as a result of the support system inoperability and corresponding exception to entering supported system Conditions and Required Actions. The SFDP implements the requirements of LCO 3.0.6.

Cross train checks to identify a loss of safety function for those support systems that support multiple and redundant safety systems are required. The cross train check verifies that the supported systems of the redundant OPERABLE support system are OPERABLE, thereby ensuring safety function is retained. If this evaluation determines that a loss of safety function exists, the appropriate Conditions and Required Actions of the LCO in which the loss of safety function exists are required to be entered.

LCO 3.0.7 There are certain special tests and operations required to be performed at various times over the life of the unit. These special tests and operations are necessary to demonstrate select unit performance characteristics, to perform special maintenance activities, and to perform special evolutions. Test Exception LCOs 3.1.8 and 3.4.17 allow specified

#### LCO 3.07 (continued)

Technical Specification (TS) requirements to be changed to permit performances of these special tests and operations, which otherwise could not be performed if required to comply with the requirements of these TS. Unless otherwise specified, all the other TS requirements remain unchanged. This will ensure all appropriate requirements of the MODE or other specified condition not directly associated with or required to be changed to perform the special test or operation will remain in effect.

The Applicability of a Test Exception LCO represents a condition not necessarily in compliance with the normal requirements of the TS. Compliance with Test Exception LCOs is optional. A special operation may be performed either under the provisions of the appropriate Test Exception LCO or under the other applicable TS requirements. If it is desired to perform the special operation under the provisions of the Test Exception LCO, the requirements of the Test Exception LCO shall be followed.

LCO 3.0.8 LCO 3.0.8 delineates the applicability of each specification to Unit 1 and Unit 2 operations.

# B 3.0 SURVEILLANCE REQUIREMENT (SR) APPLICABILITY

r <sup>1</sup> 5

BASES	
SRs	SR 3.0.1 through SR 3.0.5 establish the general requirements applicable to all Specifications and apply at all times, unless otherwise stated.
SR 3.0.1	SR 3.0.1 establishes the requirement that SRs must be met during the MODES or other specified conditions in the Applicability for which the requirements of the LCO apply, unless otherwise specified in the individual SRs. This Specification is to ensure that Surveillances are performed to verify the OPERABILITY of systems and components, and that variables are within specified limits. Failure to meet a Surveillance within the specified Frequency, in accordance with SR 3.0.2, constitutes a failure to meet an LCO.
	Systems and components are assumed to be OPERABLE when the associated SRs have been met. Nothing in this Specification, however, is to be construed as implying that systems or components are OPERABLE when:
	a. The systems or components are known to be inoperable, although still meeting the SRs; or
	<ul> <li>b. The requirements of the Surveillance(s) are known not to be met between required Surveillance performances.</li> </ul>
	Surveillances do not have to be performed when the unit is in a MODE or other specified condition for which the requirements of the associated LCO are not applicable, unless otherwise specified. The SRs associated with a test exception are only applicable when the test exception is used as an allowable exception to the requirements of a Specification.
	Unplanned events may satisfy the requirements (including applicable acceptance criteria) for a given SR. In this case, the unplanned event may be credited as fulfilling the performance of the SR. This allowance includes those SRs whose performance is normally precluded in a given MODE or other specified condition.
	Surveillances, including Surveillances invoked by Required Actions, do not have to be performed on inoperable equipment because the ACTIONS define the remedial measures that apply. Surveillances have to be met and performed in accordance with SR 3.0.2, prior to returning equipment to OPERABLE status.

.

#### SR 3.0.1 (continued)

Upon completion of maintenance, appropriate post maintenance testing is required to declare equipment OPERABLE. This includes ensuring applicable Surveillances are not failed and their most recent performance is in accordance with SR 3.0.2. Post maintenance testing may not be possible in the current MODE or other specified conditions in the Applicability due to the necessary unit parameters not having been established. In these situations, the equipment may be considered OPERABLE provided testing has been satisfactorily completed to the extent possible and the equipment is not otherwise believed to be incapable of performing its function. This will allow operation to proceed to a MODE or other specified condition where other necessary post maintenance tests can be completed.

#### SR 3.0.2 SR 3.0.2 establishes the requirements for meeting the specified Frequency for Surveillances and any Required Action with a Completion Time that requires the periodic performance of the Required Action on a "once per . . ." interval.

SR 3.0.2 permits a 25% extension of the interval specified in the Frequency. This extension facilitates Surveillance scheduling and considers plant operating conditions that may not be suitable for conducting the Surveillance (e.g., transient conditions or other ongoing Surveillance or maintenance activities).

The 25% extension does not significantly degrade the reliability that results from performing the Surveillance at its specified Frequency. This is based on the recognition that the most probable result of any particular Surveillance being performed is the verification of conformance with the SRs. The exceptions to SR 3.0.2 are those Surveillances for which the 25% extension of the interval specified in the Frequency does not apply. These exceptions are stated in the individual Specifications. The requirements of regulations take precedence over the TS.

An example of where SR 3.0.2 does not apply is in the Containment Leakage Rate Testing Program. This program establishes testing requirements and frequencies in accordance with requirements of regulations. The TS cannot in and of themselves extend a test interval specified in regulations.

As stated in SR 3.0.2, the 25% extension also does not apply to the initial portion of a periodic Completion Time that requires performance on a

SR 3.0.2 (continued)

"once per ..." basis. The 25% extension applies to each performance after the initial performance. The initial performance of the Required Action, whether it is a particular Surveillance or some other remedial action, is considered a single action with a single Completion Time. One reason for not allowing the 25% extension to this Completion Time is that such an action usually verifies that no loss of function has occurred by checking the status of redundant or diverse components or the action accomplishes the function of the inoperable equipment in an alternative manner.

The provisions of SR 3.0.2 are not intended to be used repeatedly merely as an operational convenience to extend Surveillance intervals (other than those consistent with refueling intervals) or periodic Completion Time intervals beyond those specified.

SR 3.0.3 SR 3.0.3 establishes the flexibility to defer declaring affected equipment inoperable or an affected variable outside the specified limits when a Surveillance has not been completed within the specified Frequency. A delay period of up to 24 hours or up to the limit of the specified Frequency, whichever is greater, applies from the point in time that it is discovered that the Surveillance has not been performed in accordance with SR 3.0.2, and not at the time that the specified Frequency was not met.

This delay period provides adequate time to complete Surveillances that have been missed. This delay period permits the completion of a Surveillance before complying with Required Actions or other remedial measures that might preclude completion of the Surveillance.

The basis for this delay period includes consideration of unit conditions, adequate planning, availability of personnel, the time required to perform the Surveillance, the safety significance of the delay in completing the required Surveillance, and the recognition that the most probable result of any particular Surveillance being performed is the verification of conformance with the requirements.

When a Surveillance with a Frequency based not on time intervals, but upon specified unit conditions, operating situations, or requirements of regulations (e.g., prior to entering MODE 1 after each fuel loading, or in accordance with 10 CFR 50, Appendix J, as modified by approved exemptions, etc.) is discovered to not have been performed when specified, SR 3.0.3 allows for the full delay period of up to the specified Frequency to

. . .

perform the Surveillance. However, since there is not a time interval specified, the missed Surveillance should be performed at the first reasonable opportunity.

SR 3.0.3 provides a time limit for, and allowances for the performance of, Surveillances that become applicable as a consequence of MODE changes imposed by Required Actions.

Failure to comply with specified Frequencies for SRs is expected to be an infrequent occurrence. Use of the delay period established by SR 3.0.3 is a flexibility which is not intended to be used as an operational convenience to extend Surveillance intervals. While up to 24 hours or the limit of the specified Frequency is provided to perform the missed Surveillance, it is expected that the missed Surveillance will be performed at the first reasonable opportunity. The determination of the first reasonable opportunity should include consideration of the impact on plant risk (from delaying the Surveillance as well as any plant configuration changes required or shutting the plant down to perform the Surveillance) and impact on any analysis assumptions, in addition to unit conditions, planning, availability of personnel, and the time required to perform the Surveillance. This risk impact should be managed through the program in place to implement 10 CFR 50.65(a)(4) and its implementation guidance, NRC Regulatory Guide 1.182, 'Assessing and Managing Risk Before Maintenance Activities at Nuclear Power Plants.' This Regulatory Guide addresses consideration of temporary and aggregate risk impacts, determination of risk management action thresholds, and risk management action up to and including plant shutdown. The missed Surveillance should be treated as an emergent condition as discussed in the Regulatory Guide. The risk evaluation may use quantitative, qualitative, or blended methods. The degree of depth and rigor of the evaluation should be commensurate with the importance of the component. Missed Surveillances for important components should be analyzed quantitatively. If the results of the risk evaluation determine the risk increase is significant, this evaluation should be used to determine the safest course of action. All missed Surveillances will be placed in the licensee's Corrective Action Program.

If a Surveillance is not completed within the allowed delay period, then the equipment is considered inoperable or the variable is considered outside the specified limits and the Completion Times of the Required Actions for the applicable LCO Conditions begin immediately upon expiration of the delay period. If a Surveillance is failed within the delay period, then the equipment is inoperable, or the variable is outside the specified limits and the Completion Times of the Required Actions for the applicable LCO Conditions begin immediately upon the failure of the Surveillance.

BASES	
	Completion of the Surveillance within the delay period allowed by this Specification, or within the Completion Time of the ACTIONS, restores compliance with SR 3.0.1.
SR 3.0.4	SR 3.0.4 establishes the requirement that all applicable SRs must be met before entry into a MODE or other specified condition in the Applicability.
	This Specification ensures that system and component OPERABILITY requirements and variable limits are met before entry into MODES or other specified conditions in the Applicability for which these systems and components ensure safe operation of the unit.
	The provisions of this Specification should not be interpreted as endorsing the failure to exercise the good practice of restoring systems or component to OPERABLE status before entering an associated MODE or other specified condition in the Applicability.
	However, in certain circumstances, failing to meet an SR will not result in SR 3.0.4 restricting a MODE change or other specified condition change. When a system, subsystem, division, component, device, or variable is inoperable or outside its specified limits, the associated SR(s) are not required to be performed, per SR 3.0.1, which states that surveillances do not have to be performed on inoperable equipment. When equipment is inoperable, SR 3.0.4 does not apply to the associated SR(s) since the requirement for the SR(s) to be performed is removed. Therefore, failing to perform the Surveillance(s) within the specified Frequency does not result in an SR 3.0.4 restriction to changing MODES or other specified conditions of the Applicability. However, since the LCO is not met in this instance, LCO 3.0.4 will govern any restrictions that may (or may not) apply to MODE or other specified condition changes.
	The provisions of SR 3.0.4 shall not prevent changes in MODES or other specified conditions in the Applicability that are required to comply with ACTIONS.
	The precise requirements for performance of SRs are specified such that exceptions to SR 3.0.4 are not necessary. The specific time frames and conditions necessary for meeting the SRs are specified in the Frequency, in the Surveillance, or both. This allows performance of Surveillances when the prerequisite condition(s) specified in a Surveillance procedure require entry into the MODE or other specified condition in the Applicability of the associated LCO prior to the performance or completion of a Surveillance. A Surveillance that could not be performed until

,

2 \* 1 \*

# BASES after entering the LCO Applicability, would have its Frequency specified such that it is not "due" until the specific conditions needed are met. Alternately, the Surveillance may be stated in the form of a Note as not required (to be met or performed) until a particular event, condition, or time has been reached. Further discussion of the specific formats of SRs' annotation is found in Section 1.4, Frequency. SR 3.0.5 SR 3.0.5 delineates the applicability of the surveillance activities to

Unit 1 and Unit 2 operations.

- 3