

From: <chrisheinz@aol.com>
To: <rulemaking@nrc.gov>
Date: Thu, Nov 14, 2002 12:00 PM
Subject: Response from "Contact Us About Rulemaking-Ruleforum"

RECEIVED

NOV 15 PM 12:04

Rules and Directives
Branch
USNRC

The following information was submitted by
(chrisheinz@aol.com) on Thursday, November 14, 2002 at 12:00:08

comments: Regulatory position 1.2 of the Draft Regulatory Guide (DG-1099) supports section B.3.3 of appendix B that requires post-installed anchors to be tested in cracked concrete under seismic loads. It goes on to mention that ACI Code Committee 355 has developed a test method for testing in cracked concrete. There is no mention of the anchor bolt testing performed by the NRC that resulted in 2 NUREG reports (CR-5563, and CR-5434), and that testing program would also meet the requirements of B.3.3.

name: Christopher Heinz

organization: Drillco Devices Ltd.

address1: 24-32 44th St.

city: Ronkonkoma

state: NY

zip: 11779

country: USA

phone: 718-726-9801

SUBMIT2: Send Questions or Comments

Handwritten notes:
1/22/02
67FR 47870
④

Handwritten note: Template = ADM-013

Handwritten notes:
E-RIDS = ADM-03
Call = W. Clark (TRCZ)
H.L. GRAVES (HLG1)