



Kewaunee Nuclear Power Plant  
N490 Highway 42  
Kewaunee, WI 54216-9511  
920 388 2560

Point Beach Nuclear Plant  
6610 Nuclear Road  
Two Rivers, WI 54241  
920.755 2321

Kewaunee / Point Beach Nuclear  
Operated by Nuclear Management Company, LLC

NRC-02-100

November 11, 2002

10 CFR 50.36

U. S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, D.C. 20555

Ladies/Gentlemen:

Docket 50-305  
Operating License DPR-43  
Kewaunee Nuclear Power Plant  
Monthly Operating Report

The monthly operating report for the Kewaunee Nuclear Power Plant for October 2002 is enclosed in accordance with Technical Specification 6.9.a.3.

Sincerely,

Thomas Coutu  
Site Vice President

MLA

Enclosure

cc - US NRC - Region III  
NRC Senior Resident Inspector  
INPO Records Center  
PSCW - Sharon Henning

IE24

# OPERATING DATA REPORT

DOCKET NO. 50-305  
UNIT NAME KEWAUNEE  
DATE NOVEMBER 6, 2002  
COMPLETED BY MARY ANDERSON  
TELEPHONE (920) 388-8453

Notes: Unit continues to operate at 100% power.

REPORTING PERIOD OCTOBER, 2002

1. DESIGN ELECTRICAL RATING (MWE-NET) 535
2. MAXIMUM DEPENDABLE CAPACITY ( MWE-NET) 511

	<u>MONTH</u>	<u>YEAR-TO-DATE</u>	<u>CUMULATIVE</u>
3. NUMBER OF HOURS REACTOR WAS CRITICAL	745.0	7064.8	212030.7
4. NUMBER OF HOURS GENERATOR WAS ON LINE	745.0	7050.7	209829.3
5. UNIT RESERVE SHUTDOWN HOURS	0.0	0.0	10.0
6. NET ELECTRICAL ENERGY (MWH)	393001	3697001	104870498

# UNIT SHUTDOWNS

**DOCKET NO.** 50-305  
**UNIT NAME** KEWAUNEE  
**DATE** NOVEMBER 1, 2002  
**COMPLETED BY** MARY ANDERSON  
**TELEPHONE** (920) 388-8453

**REPORTING PERIOD** OCTOBER, 2002

NO.	DATE	Type <sup>1</sup>	DURATION (Hours)	REASON <sup>2</sup>	METHOD OF SHUTTING DOWN REACTOR <sup>3</sup>	CAUSE/CORRECTIVE ACTIONS
						No shutdowns or power reductions in October

- (1)
- F: Forced**
  - S: Scheduled**

- (2)
- Reason:**
- A - Equipment Failure (Explain)**
  - B - Maintenance or Test**
  - C - Refueling**
  - D - Regulatory Restriction**
  - E - Operator Training & License Examination**
  - F - Administrative**
  - G - Operational Error (Explain)**
  - H - Other (Explain)**

- (3)
- Method:**
- 1 - Manual**
  - 2 - Manual Trip/Scram**
  - 3 - Automatic Trip/Scram**
  - 4 - Other (Explain)**
- Continuation**

**SUMMARY:**

The unit continues to operate at 100% steady state power