



FPL

NOV 11 2002

L-2002-223
10 CFR 50.36

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

Re: Turkey Point Units 3 and 4
Docket Nos. 50-250 and 50-251
Monthly Operating Report – October 2002

In accordance with the requirements of Turkey Point Units 3 and 4 Technical Specification 6.9.1.5, and the guidance of Generic Letter 97-02, attached are the October 2002 Operating Data Reports and Summaries of Operating Experience for Turkey Point Units 3 and 4.

Very truly yours,

John P. McElwain
Vice President
Turkey Point Plant

DRL

Attachments

NRC Regulatory Issue Summary 2001-05 waived the requirements that multiple copies of documents be submitted to the NRC.

IE24

DOCKET NO.: 50-251
 UNIT: Turkey Point Unit 4
 DATE: 11/4/2002
 COMPLETED BY: David Lafleur
 TELEPHONE: (305) 246-7150

Reporting Period October, 2002

| | | | |
|--|--------|--------------|------------|
| Design Electrical Rating (MWe-Net) | 720 | | |
| Maximum Dependable Capacity (MWe-Net) | 693 | | |
| | Month | Year-to-date | Cumulative |
| No. of hours reactor was critical | 745 | 6929.2 | 189898.7 |
| No. of hours generator was on line (service hours) | 730.6 | 6906.1 | 185481.2 |
| Unit reserve shutdown hours | 0 | 0 | 577.2 |
| Net Electrical Energy (MWH) | 508543 | 4801844 | 121906855 |

UNIT SHUTDOWNS

| No. | Date | Type F=Forced S=Scheduled | Duration (hours) | Reason (1) | Method of Shutting Down (2) | Corrective Action/ Comments |
|----------|----------|---------------------------------|---------------------|---------------|-----------------------------------|--|
| 20020011 | 10/04/02 | F | 21:57 | A | 1 | Shutdown due to Main Turbine steam repair. |

(1) Reason

- A - Equipment Failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory Restriction
- E - Operator Training/License Examination
- F - Administrative
- G - Operational Error (Explain)
- H - Other

(2) Method

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)

Summary Of Monthly Operating Experience

Unit 4 operated at essentially 100% power until a shutdown was commenced on 10/4/02 at 2200 hours for a main turbine steam leak repair. Upon completion of repairs, Unit 4 entered Mode 1 on 10/5/02 at 1410 hours and reached 100% power on 10/6/02 at 0001 hours. Unit 4 remained essentially at 100% power for the rest of the month.

DOCKET NO.: 50-250
 UNIT: Turkey Point Unit 3
 DATE: 11/4/2002
 COMPLETED BY: David Lafleur
 TELEPHONE: (305) 246-7150

Reporting Period October, 2002

OPERATING DATA REPORT

| | | | |
|--|--------|--------------|------------|
| Design Electrical Rating (MWe-Net) | 720 | | |
| Maximum Dependable Capacity (MWe-Net) | 693 | | |
| | Month | Year-to-date | Cumulative |
| No. of hours reactor was critical | 745 | 7296 | 193075.8 |
| No. of hours generator was on line (service hours) | 745 | 7296 | 190744.5 |
| Unit reserve shutdown hours | 0 | 0 | 121.8 |
| Net Electrical Energy (MWH) | 525241 | 5159506 | 124303153 |

UNIT SHUTDOWNS

| No. | Date | Type F=Forced S=Scheduled | Duration (hours) | Reason (1) | Method of Shutting Down (2) | Corrective Action/ Comments |
|-----|------|---------------------------------|---------------------|---------------|-----------------------------------|-----------------------------|
| N/A | N/A | N/A | N/A | N/A | N/A | N/A |

(1) Reason

- A - Equipment Failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory Restriction
- E - Operator Training/License Examination
- F - Administrative
- G - Operational Error (Explain)
- H - Other

(2) Method

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)

Summary Of Monthly Operating Experience

Unit 3 operated at essentially 100% power for the month of October 2002.