

November 19, 2002

LICENSEE: Nuclear Management Company
FACILITY: Point Beach Nuclear Plant, Units 1 and 2
SUBJECT: SUMMARY OF TELECONFERENCE BETWEEN THE NRC AND NUCLEAR
MANAGEMENT COMPANY TO DISCUSS REACTOR PRESSURE VESSEL
MASTER CURVE EVALUATION METHODOLOGIES

The NRC staff and representatives of Nuclear Management Company (NMC) held a telephone conference on November 13, 2002, to discuss reactor pressure vessel Master Curve evaluation methodologies. This teleconference provided answers to questions raised by NMC during a September 17, 2002, meeting regarding the Point Beach Nuclear Plant (Point Beach), Units 1 and 2.

NMC inquired on the logistics for utilizing the BAW-2308 endorsed Master Curve methodology or the Kewaunee-approved Master Curve methodology to evaluate the Point Beach reactor pressure vessels. The NRC communicated that either methodology can be submitted for a potential 10 CFR Part 50 license amendment review or a potential 10 CFR Part 54 application. With either methodology, the submission would need to request various exemptions similar to the Kewaunee application. The schedule for the potential submission was discussed. NMC noted that the Master Curve evaluation results included a potential core power increase.

A list of teleconference participants is provided in the enclosure. This summary has been shared with and reviewed by NMC.

/RA/

Alvin Henry, Project Manager
License Renewal Section
License Renewal and Environmental Impacts Program
Division of Regulatory Improvement Programs
Office of Nuclear Reactor Regulation

Docket Nos: 50-266 and 50-301

Enclosure: As stated

cc w/encl: See next page

LICENSEE: Nuclear Management Company
FACILITY: Point Beach Nuclear Plant, Units 1 and 2
SUBJECT: SUMMARY OF TELECONFERENCE BETWEEN THE NRC AND NUCLEAR
MANAGEMENT COMPANY TO DISCUSS REACTOR PRESSURE VESSEL
MASTER CURVE EVALUATION METHODOLOGIES

The NRC staff and representatives of Nuclear Management Company (NMC) held a telephone conference on November 13, 2002, to discuss reactor pressure vessel Master Curve evaluation methodologies. This teleconference provided answers to questions raised by NMC during a September 17, 2002, meeting regarding the Point Beach Nuclear Plant (Point Beach), Units 1 and 2.

NMC inquired on the logistics for utilizing the BAW-2308 endorsed Master Curve methodology or the Kewaunee-approved Master Curve methodology to evaluate the Point Beach reactor pressure vessels. The NRC communicated that either methodology can be submitted for a potential 10 CFR Part 50 license amendment review or a potential 10 CFR Part 54 application. With either methodology, the submission would need to request various exemptions similar to the Kewaunee application. The schedule for the potential submission was discussed. NMC noted that the Master Curve evaluation results included a potential core power increase.

A list of teleconference participants is provided in the enclosure. This summary has been shared with and reviewed by NMC.

/RA/

Alvin Henry, Project Manager
License Renewal Section
License Renewal and Environmental Impacts Program
Division of Regulatory Improvement Programs
Office of Nuclear Reactor Regulation

Docket Nos: 50-266 and 50-301

Enclosure: As stated

cc w/encl: See next page

DISTRIBUTION:
See next page

Document Name: C:\ORPCheckout\FileNET\ML023250351.wpd

| | | | | |
|--------|----------|----------|-----------|-----------|
| OFFICE | LA:RLEP | PM:RLEP | DE | SC:RLEP |
| NAME | HBerilla | AHenry | MMitchell | SLee |
| DATE | 11/19/02 | 11/19/02 | 11/25/02 | 11/19 /02 |

OFFICIAL RECORD COPY

DISTRIBUTION: Telephone Conference with Nuclear Management Company.
Dated: November 19, 2002

HARD COPY

RLEP RF

A. Henry

E-MAIL:

PUBLIC

J. Johnson

W. Borchardt

D. Matthews

F. Gillespie

RidsNrrDe

R. Barrett

E. Imbro

G. Bagchi

K. Manoly

W. Bateman

J. Calvo

C. Holden

P. Shemanski

H. Nieh

G. Holahan

H. Walker

S. Black

B. Boger

D. Thatcher

G. Galletti

C. Li

J. Moore

R. Weisman

M. Mayfield

A. Murphy

W. McDowell

S. Smith (srs3)

T. Kobetz

R. Assa

C. Munson

RLEP Staff

M. Mitchell

List of Telephone Conference Participants

NRC

Alvin Henry
Matthew Mitchell

NMC

Roger Newton
Brian Kemp
Jim Knorr

Framatone

Ken Yoon

Enclosure

Point Beach Nuclear Plant, Units 1 and 2

cc:

Mr. John H. O'Neill, Jr.
Shaw, Pittman, Potts & Trowbridge
2300 N Street, NW
Washington, DC 20037-1128

Mr. Richard R. Grigg
President and Chief Operating Officer
Wisconsin Electric Power Company
231 West Michigan Street
Milwaukee, WI 53201

Site Licensing Manager
Point Beach Nuclear Plant
Nuclear Management Company, LLC
6610 Nuclear Road
Two Rivers, WI 54241

Mr. Ken Duveneck
Town Chairman
Town of Two Creeks
13017 State Highway 42
Mishicot, WI 54228

Chairman
Public Service Commission
of Wisconsin
P.O. Box 7854
Madison, WI 53707-7854

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
801 Warrenville Road
Lisle, IL 60532-4351

Resident Inspector's Office
U.S. Nuclear Regulatory Commission
6612 Nuclear Road
Two Rivers, WI 54241

Ms. Sarah Jenkins
Electric Division
Public Service Commission of Wisconsin
P.O. Box 7854
Madison, WI 53707-7854

Mr. Roy A. Anderson
Executive Vice President and
Chief Nuclear Officer
Nuclear Management Company, LLC
700 First Street
Hudson, WI 54016

Nuclear Asset Manager
Wisconsin Electric Power Company
231 West Michigan Street
Milwaukee, WI 53201

Mr. Alan P. Nelson
Nuclear Energy Institute
1776 I Street, N.W., Suite 400
Washington, DC 20006-3708

Mr. Fred J. Cayia
Acting Site Vice President
Point Beach Nuclear Plant
Nuclear Management Company, LLC
6610 Nuclear Road
Two Rivers, WI 54241

Manager, License Renewal
Point Beach Nuclear Plant
Nuclear Management Company, LLC
6610 Nuclear Road
Two Rivers, WI 54241