

NOV 13 2002

LR-N02-0397



U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Gentlemen:

**MONTHLY OPERATING REPORT
SALEM GENERATING STATION UNIT 1
DOCKET NO. 50-272**

In compliance with Section 6.9, Reporting Requirements for the Salem Unit 1 Technical Specifications, the operating statistics for **October 2002** are being forwarded.

Sincerely,

A handwritten signature in black ink, appearing to read "D.F. Garchow".

D. F. Garchow
Vice President - Operations

RAR
Attachments

C Distribution

JB24

DOCKET NO.: 50-272
 UNIT: Salem 1
 DATE: 11/12/02
 COMPLETED BY: F. Todd
 TELEPHONE: (856) 339-1316

Reporting Period October 2002

OPERATING DATA REPORT

Design Electrical Rating (MWe-Net)
 Maximum Dependable Capacity (MWe-Net)

No. of hours reactor was critical
 No. of hours generator was on line (service hours)
 Unit reserve shutdown hours
 Net Electrical Energy (MWH)

1130		
1096		
Month	Year-to-date	Cumulative
236	6629	140856
236	6549	136244
0	0	0
225322	7204771	138488169

UNIT SHUTDOWNS

NO.	DATE	TYPE F=FORCED S=SCHEDULED	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN THE REACTOR (2)	CORRECTIVE ACTION/ COMMENT
2	10/10/02 - 10/31/02	S	509	C	2	1R15 Refueling Outage

(1) Reason

- A - Equipment Failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory Restriction
- E - Operator Training/License Examination
- F - Administrative
- G - Operational Error (Explain)
- H - Other

(2) Method

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)

DOCKET NO.: 50-272
UNIT: Salem 1
DATE: 11/12/02
COMPLETED BY: R. Ritzman
TELEPHONE: (856) 339-1445

Summary Of Monthly Operating Experience

- Salem 1 entered the month at approximately 100% reactor power.
- On October 6, power was reduced to approximately 68% due to a 500 KV Line Outage.
- On October 10, the unit was shutdown for a scheduled refueling outage.
- At the end of the month, Salem 1 remained in the refueling outage.