



Entergy Nuclear Northeast  
Entergy Nuclear Operations, Inc.  
James A. Fitzpatrick NPP  
PO Box 110  
Lycoming, NY 13093  
Tel 315 349 6024 Fax 315 349 6480

T.A. Sullivan  
Vice President, Operations-JAF

November 12, 2002  
JAFP-02-0210

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Mail Stop O-P1-17  
Washington, DC 20555-0001

SUBJECT: James A. FitzPatrick Nuclear Power Plant  
Docket No. 50-333  
**10 CFR 50.46 Reporting of Changes In Emergency  
Core Cooling System (ECCS) Evaluation Model**

Dear Sir:

In accordance with 10 CFR 50.46 (a) (3) (ii), this submittal is provided to report a change in the Emergency Core Cooling System (ECCS) evaluation as a result of a change in fuel design use at FitzPatrick.

The plant recently completed Refueling Outage 15, and began Cycle 16 operations utilizing both General Electric 14 type fuel (GE14) and General Electric 12 type fuel (GE12). GE12 has been used during the previous three operating cycles.


The Licensing Basis peak clad temperature (PCT) calculated for GE14 is 1700° Fahrenheit (F), increasing the previous calculated PCT value by 160°F. PCT calculations for GE12/GE14 are based on the same NRC approved GE methods. The PCT increase is a result: (1) higher Linear Heat Generation Rate (LHGR) for GE14; (2) lower assumed Core Spray System flow rate; and (3) a wider band of operating conditions including Maximum Extended Loadline Limit Analysis and Final Feedwater Temperature reduction.

Since the PCT for GE14 is well below the 2200°F requirements of 10 CFR 50.46(b)(1), there is no need for re-analysis or other action per 10 CFR 50.46(a)(3)(ii). Other 10 CFR 50.46(b) criteria are met for the GE14.

Pool

No new commitments are contained in this letter. Should you have any questions, please direct them to Mr. William Drews at (315) 349-6562.

Very truly yours,

A handwritten signature in black ink that reads "for T. Sullivan". The signature is written in a cursive, somewhat stylized script.

T. A. Sullivan  
Vice President, Operations

TAS:GB

cc: Regional Administrator  
U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406

Mr. Guy Vissing, Project Manager  
Project Directorate I  
Division of Licensing Project Management  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

Office of the Resident Inspector  
James A. FitzPatrick Nuclear Power Plant  
U.S. Nuclear Regulatory Commission  
P.O. Box 136  
Lycoming, NY 133093