November 26, 2002

LICENSEE: FPL Energy Seabrook, LLC

FACILITY: Seabrook Station, Unit No. 1

SUBJECT: SUMMARY OF NOVEMBER 14, 2002, MEETING WITH FPL ENERGY SEABROOK, LLC (FPLE SEABROOK) TO DISCUSS THE ROOT CAUSE EVALUATION FOR AXIAL OUTSIDE DIAMETER INDICATIONS ON STEAM GENERATOR TUBES AT SEABROOK STATION, UNIT NO. 1

This summary refers to the meeting with FPLE Seabrook which was conducted on November 14, 2002, at the U.S. Nuclear Regulatory Commission (NRC) offices in Rockville, Maryland. The meeting was held at the request of the NRC staff. The purpose of the meeting was to discuss the root cause evaluation for axial outside diameter indications identified on steam generator tubes at Seabrook Station during the May 2002 refueling outage. Find enclosed a list of the meeting attendees (Enclosure 1) and a copy of the meeting handout presented by FPLE Seabrook (Enclosed 2).

The FPLE Seabrook presentation closely followed the material provided in the meeting handout and was consistent with the discussion topics listed in the Meeting Notice (ADAMS Accession No. ML023090002).

/RA/

Robert D. Starkey, Project Manager, Section 2
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-443

Enclosures: 1. List of Meeting Attendees

2. Meeting Handout

cc w/encls: See next page

November 26, 2002

LICENSEE: FPL Energy Seabrook, LLC

FACILITY: Seabrook Station, Unit No. 1

SUBJECT: SUMMARY OF NOVEMBER 14, 2002, MEETING WITH FPL ENERGY SEABROOK, LLC (FPLE SEABROOK) TO DISCUSS THE ROOT CAUSE EVALUATION FOR AXIAL OUTSIDE DIAMETER INDICATIONS ON STEAM GENERATOR TUBES AT SEABROOK STATION, UNIT NO. 1

This summary refers to the meeting with FPLE Seabrook which was conducted on November 14, 2002, at the U.S. Nuclear Regulatory Commission (NRC) offices in Rockville, Maryland. The meeting was held at the request of the NRC staff. The purpose of the meeting was to discuss the root cause evaluation for axial outside diameter indications identified on steam generator tubes at Seabrook Station during the May 2002 refueling outage. Find enclosed a list of the meeting attendees (Enclosure 1) and a copy of the meeting handout presented by FPLE Seabrook (Enclosed 2).

The FPLE Seabrook presentation closely followed the material provided in the meeting handout and was consistent with the discussion topics listed in the Meeting Notice (ADAMS Accession No. ML023090002).

/RA/

Robert D. Starkey, Project Manager, Section 2
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-443

Enclosures: 1. List of Meeting Attendees

2. Meeting Handout

cc w/encls: See next page

DISTRIBUTION:

PUBLIC	OGC	BMcDermott, RGNI	KKarwoski
PDI-2 R/F	ACRS	SRichards	MModes
JZwolinski/TMarsh	JAndersen	HNieh, EDO	CKhan
DStarkey	MKotzalas	LCox	JDavis
OPA	WBateman	LLund	MSwitzer
MMurphy	JTsao	ZFu	

Accession Nos.: Letter:ML023300435,Enclosure 2:ML023260159,Package: ML023300457

OFFICE	PDI-2/PM	PDI-2/LA	PDI-2/SC(A)
NAME	DStarkey	LCox	JAndersen
DATE	11-25-02	11/25/02	11/26/02

OFFICIAL RECORD COPY

LIST OF MEETING ATTENDANCE

Licensee: FPL Energy Seabrook (FPLE Seabrook)

Plant: Seabrook Station, Unit No. 1

Subject: Steam Generator Tube Indications - Evaluation and Root Cause Determination

Date: November 14, 2002 Time: 9:00 a.m. - 11:00 a.m.

Location: NRC Offices, OWFN, Room 04-B6

Name	**Title**	**Organization**
NRC STAFF		
J. Andersen	Section Chief (Acting)	NRR/DLPM/PDI-2
D. Starkey	Project Manager	NRR/DLPM/PDI-2
W. Bateman	Chief, EMCB	NRR/DE/EMCB
M. Murphy	Materials Engineer	NRR/DE/EMCB
J. Tsao	Materials Engineer	NRR/DE/EMCB
L. Lund	Section Chief	NRR/DE/EMCB
Z. Fu	Materials Engineer	NRR/DE/EMCB
K. Karwoski	Sr. Lvl Advisor for Steam Gen.	NRR/DE/EMCB
M. Modes	Sr. Reactor Engineer	NRC/Region I
C. Khan	Sr. Materials Engineer	NRR/DE/EMCB
J. Davis	Sr. Materials Engineer	RES/DET/MEB
M. Switzer	Materials Engineer	RES/DET/MEB
FPLE SEABROOK		
M. Warner	Site Vice President	FPLE Seabrook
J. Peschel	Regulatory Programs Manager	FPLE Seabrook
J. Varga	Director - Engineering	FPLE Seabrook
R. White	Mechanical Eng. Manager	FPLE Seabrook

Name	Title	Organization
FLORIDA POWER & LIGHT (FPL)		
G. Boyers	FPL Steam Gen. Prog. Coord.	FPL
WESTINGHOUSE		
L. Lagally	Fellow Engineer	Westinghouse
G. Perini	Sr. Engineer	Westinghouse
DUKE POWER		
D. Mayer	no title given	Duke Power
EXELON		
S. Leshnoff	Steam Gen. Prog. Manager	Exelon
PUBLIC		
R. Ballinger	Professor	MIT/Altran Corporation
T. Esselman	President	Altran Corporation
G. Henry	Mgr. Steam Gen. NDE	EPRI
J. Harris	Engineer	Dominion Engineering
J. Fowler	Consultant	Northeast Utilities
D. Raleigh	LIS Client Manager	LIS, Scientech

Seabrook Station, Unit No. 1
cc:

Mr. J. A. Stall
Senior Vice President, Nuclear and
Chief Nuclear Officer
Florida Power & Light Company
P.O. Box 14000
Juno Beach, FL 33408-0420

Mr. Peter Brann
Assistant Attorney General
State House, Station #6
Augusta, ME 04333

Resident Inspector
U.S. Nuclear Regulatory Commission
Seabrook Nuclear Power Station
P.O. Box 1149
Seabrook, NH 03874

Town of Exeter
10 Front Street
Exeter, NH 03823

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Office of the Attorney General
One Ashburton Place
20th Floor
Boston, MA 02108

Board of Selectmen
Town of Amesbury
Town Hall
Amesbury, MA 01913

Mr. Dan McElhinney
Federal Emergency Management Agency
Region I
J.W. McCormack P.O. &
Courthouse Building, Room 401
Boston, MA 02109

Mr. Stephen McGrail, Director
ATTN: James Muckerheide
Massachusetts Emergency Management Agency
400 Worcester Road
Framingham, MA 01702-5399

Philip T. McLaughlin, Attorney General
Steven M. Houran, Deputy Attorney
General
33 Capitol Street
Concord, NH 03301

Mr. Donald Bliss, Director
New Hampshire Office of Emergency
Management
State Office Park South
107 Pleasant Street
Concord, NH 03301

Mr. Daniel G. Roy
Nuclear Training Manager
Seabrook Station
FPL Energy Seabrook, LLC
P.O. Box 300
Seabrook, NH 03874

Mr. James M. Peschel
Regulatory Programs Manager
Seabrook Station
FPL Energy Seabrook, LLC
P.O. Box 300
Seabrook, NH 03874

Mr. Gene F. St. Pierre
Station Director
Seabrook Station
FPL Energy Seabrook, LLC
P.O. Box 300
Seabrook, NH 03874

Mr. M. S. Ross, Attorney
Florida Power & Light Company
P.O. Box 14000
Juno Beach, FL 33408-0420

Seabrook Station, Unit No. 1
cc:

Mr. Rajiv S. Kundalkar
Vice President - Nuclear Engineering
Florida Power & Light Company
P.O. Box 14000
Juno Beach, FL 33408-0420