



November 15, 2002

Technical Specification  
6.7.A.3

US Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, DC 20555

**MONTICELLO NUCLEAR GENERATING PLANT**  
Docket No. 50-263 License No. DPR-22

Submittal of Monticello Monthly Operating Report for October 2002

In accordance with Monticello Technical Specification 6.7.A.3, the report of operating statistics for the Monticello Nuclear Generating Plant for the month of October is enclosed.

Please contact Paul Hartmann at (763) 271-5172 if you require further information.

Jeffrey S. Forbes  
Site Vice President  
Monticello Nuclear Generating Plant

Enc.

- c: Regional Administrator – III, NRC  
NRR Project Manager, NRC  
Sr. Resident Inspector, NRC  
Minnesota Dept. of Commerce

FE24



DOCKET NO. 50-263  
UNIT NAME Monticello  
DATE November 4, 2002  
COMPLETED BY H. H. Paustian  
TELEPHONE 763-295-1317

## OPERATING DATA REPORT

REPORTING PERIOD: October 2002

	MONTH	YEAR TO DATE	CUMULATIVE
1. Design Electrical Rating (Mwe-Net)	600.0	600.0	600.0
2. Maximum Dependable Capacity (Mwe-Net)	578.1	578.1	578.1
3. Number of Hours the Reactor Was Critical	745.0	7,208.0	227,377.6
4. Number of Hours the Generator Was On Line	745.0	7,156.1	223,954.8
5. Unit Reserve Hours	0.0	0.0	0.0
6. Net Electrical Energy (MWH)	434,383.6	4,152,455.9	115,302,440.9

## UNIT SHUTDOWNS

DOCKET NO. 50-263UNIT NAME MonticelloDATE 11-01-02COMPLETED BY H. H. PaustianTELEPHONE 763-295-1317REPORTING PERIOD: October 2002

No.	Date	Type F: Forced S: Scheduled	Duration (hours)	Reason (1)	Method of Shutting Down (2)	Cause/Corrective Actions  Comments
	None					

1

## Reason:

- A Equipment Failure (Explain)
- B Maintenance or Test
- C Refueling
- D Regulator Restriction
- E Operator Training & Licensing Examination
- F Administrative
- G Operational Error (Explain)
- H Other (Explain)

2

## Method:

- 1 Manual
- 2 Manual Scram
- 3 Automatic Trip/Scram
- 4 Continuation
- 5 Other (Explain)

SUMMARY: The plant operated at essentially 100% power the entire month, except for a short drop in electrical output of 3 MWe on October 12-13 for minor repairs to "A" Moisture Separator drain tank dump valve and a drop to approximately 52% power on October 24-25 to make repairs to a leak in the Generator rectifier cooling system.