November 27, 2002

Mr. William T. O'Connor, Jr.
Vice President - Nuclear Generation
Detroit Edison Company
6400 North Dixie Highway
Newport, MI 48166

SUBJECT: FERMI 2 - CORRECTION TO AMENDMENT NO. 151 TO CHANGE RESPONSE TIME TESTING REQUIREMENTS FOR THE REACTOR PROTECTION SYSTEM AND PRIMARY CONTAINMENT ISOLATION INSTRUMENTATION (TAC NO. MB5173)

Dear Mr. O'Connor:

On October 2, 2002, the Commission issued Amendment No. 151 to Facility Operating License No. NPF-43 for Fermi 2 to change the Technical Specifications (TSs) in response to your application dated May 23, 2002, as supplemented July 16, 2002. The changes to the TSs revised response time testing requirements for the reactor protection system and primary containment isolation instrumentation.

In the May 23, 2002, application, the licensee requested the removal of Surveillance Requirement (SR) 3.3.6.1.7 for response time testing of AC output relays. The NRC approved the removal of SR 3.3.6.1.7 by Amendment No. 151. However, SR 3.3.6.1.7 is applicable to DC output relays as well as AC output relays. Therefore, SR 3.3.6.1.7 should have been retained in the TSs to be applicable only to DC output relays. Additionally, in TS Table 3.3.6.1-1 (page 1 of 4), SR 3.3.6.1.7 should not have been deleted from the list of SRs for Functions 1.a. and 1.c.

Enclosed is corrected TS Page 3.3-54, which reflects the reinsertion of SR 3.3.6.1.7 and its corresponding Frequency, and corrected TS Page 3.3-55, which reflects the reinsertion of SR 3.3.6.1-1 under the list of SRs for Functions 1.a. and 1.c and also reflects the removal of Amendment No. 151. The reinsertion of SR 3.3.6.1.7 on TS Page 3.3-54 necessitates the issuance of a corrected version of the preceding page, TS Page 3.3-53, to reflect the word "Continued" at the bottom of the page and the removal of Amendment No. 151.

This correction letter is consistent with the licensee's March 2, 2001, application and the NRC staff's intent. Please replace TS Pages 3.3-53, 3.3-54 and 3.3-55 that were issued with Amendment No. 151 with the enclosed corresponding pages.

Sincerely,

/RA/

John F. Stang, Senior Project Manager, Section 1
Project Directorate III
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-341

Enclosure: Corrected TS Pages 3.3-53, 3.3-54, and 3.3-55

cc w/encl: See next page

This correction letter is consistent with the licensee's March 2, 2001, application and the NRC staff's intent. Please replace TS Pages 3.3-53, 3.3-54 and 3.3-55 that were issued with Amendment No. 151 with the enclosed corresponding pages.

Sincerely,

/RA/

John F. Stang, Senior Project Manager, Section 1
Project Directorate III
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-341

Enclosure: Corrected TS Pages 3.3-53, 3.3-54, and 3.3-55

cc w/encl: See next page

DISTRIBUTION

PUBLIC	RBouling	GHill(2)
PDIII-1 Reading	OGC	PLoeser
LRaghavan	ACRS	MRing, RIII
JStang	WBeckner	

ADAMS Accession No. ML023330297

OFFICE	PDIII-1/PM	PDIII-1/LA	PDIII-1/SC
NAME	JStang	RBouling	LRaghavan
DATE	11/27/02	11/27/02	11/27/02

DOCUMENT NAME: C:\ORPCheckout\FileNET\ML023330297.wpd

OFFICIAL RECORD COPY

Fermi 2

cc:

Mr. Peter Marquardt
Legal Department
688 WCB
Detroit Edison Company
2000 2nd Avenue
Detroit, MI 48226-1279

Drinking Water and Radiological
Protection Division
Michigan Department of
Environmental Quality
3423 N. Martin Luther King Jr Blvd
P. O. Box 30630 CPH Mailroom
Lansing, MI 48909-8130

U.S. Nuclear Regulatory Commission
Resident Inspector's Office
6450 W. Dixie Highway
Newport, MI 48166

Monroe County Emergency Management
Division
963 South Raisinville
Monroe, MI 48161

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
801 Warrenville Road
Lisle, IL 60532-4351

Norman K. Peterson
Director, Nuclear Licensing
Detroit Edison Company
Fermi 2 - 280 TAC
6400 North Dixie Highway
Newport, MI 48166