

Region I NMSS Licensee Event Report

Licensee	AGILENT TECHNOLOGIES
Event Description	Notice of Gen License Device with High Removable Activity

License #	07-28762-02G	Docket #	03002988	MLER-RI	2002-080
Event Date	November 2002	Report Date	Nov. 20, 2002		

1. REPORTING REQUIREMENT

<input type="checkbox"/> 10 CFR 20.2201 Theft or Loss	<input type="checkbox"/> 10 CFR 35.33 Misadministration
<input type="checkbox"/> 10 CFR 20.2203 30 Day Report	<input type="checkbox"/> License Condition
<input type="checkbox"/> 10 CFR 30.50 Report	
<input checked="" type="checkbox"/> Other 10 CFR 31.5	

2. REGION I RESPONSE

<input type="checkbox"/> Immediate Site Inspection	Inspector/Date	
<input type="checkbox"/> Special Inspection	Inspector/Date	
<input type="checkbox"/> Telephone Inquiry	Inspector/Date	
<input type="checkbox"/> Preliminary Report	<input type="checkbox"/> Daily Report	
<input checked="" type="checkbox"/> Information Entered in RI Log	<input checked="" type="checkbox"/> Review at next inspection	
<input type="checkbox"/> Report referred to:		

3. REPORT EVALUATION

<input type="checkbox"/> Description of Event	<input type="checkbox"/> Corrective Actions
<input type="checkbox"/> Levels of RAM Involved	<input type="checkbox"/> Calculations Adequate
<input type="checkbox"/> Cause of Event	<input type="checkbox"/> Additional Information Requested from Licensee

4. SPECIAL INSTRUCTIONS OR COMMENTS

Public

Non-Public

Completed by:	Betsy Ullrich	Date	11/20/02
Reviewed by:	JDK/Kan	Date	11/20/2002

 **Agilent Technologies**
2850 Centerville Road
Wilmington, DE 19808

RECEIVED
REGION 1

2002 NOV 20 PM 3: 39

Division of Nuclear Materials Safety
U.S. Nuclear Regulatory Commission
Region I
475 Allendale Road,
King of Prussia, PA 19406

Re: Notice of General License device with high removable activity (NRC License 07-28762-02G)

November 18, 2002


Dear Sir or Madam,

Per the requirements of 10 CFR 31.5, I am notifying your office of the following devices returned to us by customers from which we have obtained removable activity wipes in excess of 0.005 μCi . The cells were evaluated by support engineering and their disposition is identified below. I have contacted the customers for further information and will notify the cell supplier of the high wipes.

Serial #	Model #	Activity (μCi)	Disposition	Comments
S9818	19312	0.009	Scrapped	Obsolete model. Cell was 18 years old
S9326	19312	0.450	Scrapped	Obsolete model. Cell was 20 years old
K1653	G1533A	0.008	Scrapped	Source looks burnt. Cell was 7 years old.
M1050	19233	0.046	Scrapped	Source dark and rusted. Cell was 12 years old.

Please contact me at 302-633-8262 if there are any questions.

Thank you,



David S. Bennett
Radiation Safety Officer