Region I
NMSS Licensee Event Report

Licensee	AGILENT TECHNOLOGIES
Event Description	Notice of Gen License Device with High Removable Activity

License #	07-28762-02G	Docket #	03002988	MLER-RI	2002- 080
Event Date	November 2002	Report Date	Nov. 20, 2002		

1. REPORTING REQUIREMENT

	10 CFR 20.2201 Theft or Loss		10 CFR 35.33 Misadministration
	10 CFR 20.2203 30 Day Report		License Condition
	10 CFR 30.50 Report		
XXX	Other 10 CFR 31.5		

2. REGION I RESPONSE

	Immediate Site Inspection	Inspector/Date	
	Special Inspection	Inspector/Date	
	Telephone Inquiry	Inspector/Date	
	Preliminary Report		Daily Report
XX	Information Entered in RI Log	X	Review at next inspection
	Report referred to:		

3. REPORT EVALUATION

	Description of Event		Corrective Actions
	Levels of RAM Involved		Calculations Adequate
	Cause of Event		Additional Information Requested from Licensee

4. SPECIAL INSTRUCTIONS OR COMMENTS

Public X Non-Public

	Initials/Date		Initials/Date
Completed by:	Beth Ullrich	Date	11/20/02
Reviewed by:	JDK	Date	11/20/2002

Location of File: G:\LAS\LER FORM REV A.wpd

Agilent Technologies
2850 Centerville Road
Wilmington, DE 19808

RECEIVED
REGION 1

2002 NOV 20 PM 3:39

Division of Nuclear Materials Safety
U.S. Nuclear Regulatory Commission
Region I
475 Allendale Road,
King of Prussia, PA 19406

Re: Notice of General License device with high removable activity (NRC License 07-28762-02G)

November 18, 2002

Dear Sir or Madam,

Per the requirements of 10 CFR 31.5, I am notifying your office of the following devices returned to us by customers from which we have obtained removable activity wipes in excess of 0.005 μCi. The cells were evaluated by support engineering and their disposition is identified below. I have contacted the customers for further information and will notify the cell supplier of the high wipes.

Serial #	Model #	Activity (μCi)	Disposition	Comments
S9818	19312	0.009	Scrapped	Obsolete model. Cell was 18 years old
S9326	19312	0.450	Scrapped	Obsolete model. Cell was 20 years old
K1653	G1533A	0.008	Scrapped	Source looks burnt. Cell was 7 years old.
M1050	19233	0.046	Scrapped	Source dark and rusted. Cell was 12 years old.

Please contact me at 302-633-8262 if there are any questions.

Thank you,

David S. Bennett
Radiation Safety Officer