Examination Cover Sheet

Exam ID: 2002 RONRC **Total Points:** 100

Exam Date: 08/05/2002

Description: 2002 NRC RO Written Examination

Student Name:	Date:	 Grade:
Graded By:	Date:	
Approved By:	Date:	
Reviewed By Examinee:		

Question 1 17898 (1 point(s))

The plant is operating at 100% power with a normal electric plant lineup when an oil leak occurs on the Normal Tranformer. The oil catches on fire. The fire brigide responds and attempt to extinguish the blaze. The oil and the fire is contained to the Normal Transformer area.

What is the potential effect of this fire?

- a. The loss of one (1) Recirculation pump **only**.
- b. A main generator trip AND Reactor scram **only**.
- c. The loss of one (1) Recirculation pump AND main generator trip AND Reactor scram **only**.
- d. The loss of BOTH Recirculation pumps AND loss of busses 1A and 1B AND a main generator trip AND Reactor scram.

Answer 1

c. The loss of one (1) Recirculation pump AND main generator trip AND Reactor scram **only**.

The NORMAL transformer will trip eventually due to the fire.

REFERENCE: C-2/A-8, NORMAL TRANSFORMER LOCKOUT, COR0010102

Foils:

- a. The main generator will trip as well.
- b. A recirc pump will also trip.
- d. Bus 1A and 1B will transfer to the Startup transformer.

New Difficulty 3 Cognitive Level 3

Enabling Objectives

INT0320134E0E0100 Given plant condition(s), determine from memory any automatic actions listed in the applicable Abnormal/Emergency Procedure(s) which will occur due to the event(s).

COR0010102001080A Predict the consequences of the following on plant operation: Loss of Normal and Startup transformers

Skills

600000.AA2.04 Ability to determine and interpret the following as they apply to PLANT FIRE ON SITE: The fire's extent of potential operational damage to plant equipment (2.8/3.1)

Question 2 17868 (1 point(s))

What is the effect of losing 125 VDC to the turbine generator?

- a. Loss of DEH pressure.
- b. Loss of main turbine remote trip capability.
- c. DEH shifts to the standby pressure regulator.
- d. The generator field breaker automatically opens.

Answer 2

b. Loss of main turbine remote trip capability.

Reference: 5.3DC125

Foils:

- a. DEH pressure is not affected. The pumps are AC powered.
- c. They are not affected by the power loss.
- d. The generator field breaker must be manually opened.

New Difficulty 2 Cognitive level: 1

Enabling Objectives

COR0020702001080C Given a specific DC Electrical Distribution system malfunction, determine the effect on any of the following: Systems with DC components (i.e., valves, motors, solenoids, etc.)

COR0011302001030E Describe the interrelationships between Main Turbine Generator and Auxiliaries and the following: DC electrical distribution

Skills

245000.K1.09 Knowledge of the physical connections and/or cause-effect relationships between MAIN TURBINE GENERATOR AND AUXILIARY SYSTEMS and the following: (CFR: 41.2 to 41.9 / 45.7 to 45.8) D. C. electrical distribution (2.7/2.7)

Question 3 17847 (1 point(s))

Following a a reactor scram from 100% power the main turbine generator has automatically tripped.

Which one of the following groups of breakers will the generator trip automatically open?

The main generator output breakers...

- a. and the feeder breakers from the startup transformer **only**.
- b. and the feeder breakers from the normal transformer **only**.
- c. the feeder breakers from the startup transformer and the generator field breaker.
- d. the feeder breakers from the normal transformer and the generator field breaker.

Answer 3

d. the feeder breakers from the normal transformer and the generator field breaker.

Reference: COR001-13-01, Section III Instrumentation and Controls.

Foils:

- a. The generator field breaker is tripped and the startup breakers close vice open.
- b. The generator field breaker is tripped.
- c. The feeder breakers from the startup transformer will close vice open.

New Difficulty: 2 Cognitive level:1

Enabling Objectives

COR0010102001130A Predict the consequences of the following events on the AC Electrical Distribution System: Turbine/generator trip

Skills

295005.AA1.07 Ability to operate and/or monitor the following as they apply to MAIN TURBINE GENERATOR TRIP: (CFR: 41.7 / 45.6) A.C. electrical distribution (3.3/3.3)

Question 4 17889 (1 point(s))

Why is Recirculation pump speed limited following a reactor scram?

- a. To protect the Reactor Recirculation pump from damage due to lack of NPSH.
- b. To prevent damage to the Recirculation pump thrust bearing due to inadequate film layer.
- c. To protect the Reactor Recirculation pump motor from overload due to fluid density increase.
- d. To prevent damage to the Reactor Recirculation pump seals caused by excessive differential pressure.

Answer 4

a. To protect the Reactor Recirculation pump from damage due to lack of NPSH.

REFERENCE: COR0022202

Foils:

- b. Thrust bearing damage is not a reason for the #1 limiter.
- c. Motor overload is not a reason for the #1 limiter.
- d. Seal damage is a concern for the #1 limiter only if the Discharge valve is closed.

New Difficulty: 2 Cognitive level:1

Enabling Objectives

COR0022202001100A Describe the Reactor Recirculation system and/or Recirculation Flow Control system design features and/or interlocks that provide for the following: Adequate Recirculation Pump NPSH

Skills

295006.AK3.06 Knowledge of the reasons for the following responses as they apply to SCRAM: (CFR: 41.5 / 45.6) Recirculation pump speed reduction: Plant-Specific (3.2/3.3)

Question 5 17859 (1 point(s))

The plant is operating at 30% when the reactor operator is directed to raise power using Recirculation flow. As the controller output is raised, a momentary (1.5 seconds) loss of signal occurs from the "A" Recirculation Flow Controller. The operator continues to raise the controller output for several more seconds.

How will the "A" Recirculation MG Set be affected by this momentary loss and operator action?

- a. Automatically run back to ~ 22% speed
- b. A scoop tube lockup will prevent any further speed change.
- c. After a 1.5 second pause recirculation pump speed will rise as directed.
- d. Speed will initially rise, then lower rapidly for 1.5 seconds then rise again for several seconds.

Answer 5

b. A scoop tube lockup will prevent any further speed change.

Reference: 2.2.68, Attachment 1 Section 2.1.6

Foils:

- a. There is no runback.
- b. Scoop tube lockup prevents any speed changes.
- d. Scoop tube lockup prevents any speed changes.

New Difficulty 2 Cognitive Level 1

Enabling Objectives

COR0022202001130F Given plant conditions, determine if any of the following should occur: Recirculation MG set scoop tube lock.

COR0022201001060A Given plant and/or reactor recirculation system conditions, apply the design features and/or interlocks that provide for the following: MG Set Scoop Tube Lockout

SKL012422200A030I Given plant conditions, predict changes in the following Reactor Recirculation System components/parameters: RR pump speed

Skills

202002.K1.05 Knowledge of the physical connections and/or cause-effect relationships between RECIRCULATION FLOW CONTROL SYSTEM and the following: (CFR: 41.2 to 41.9 / 45.7 to 45.8) Recirculation MG set: Plant-Specific (3.5/3.5)

Question 6 16478 (1 point(s))

The plant is at 20% power when the following annunciator alarms:

- 9-4-3 / A-3, RECIRC PUMP A SEAL TROUBLE
- RONAN (1820): RECIRC PUMP A SEAL STAGING FLOW HIGH

The following indications are observed:

- Seal cavity #1 (inner) pressure 950 psig
- Seal cavity #2 (outer) pressure 950 psig

What is the state of the A Recirculation Pump seals?

- a. **Only** seal #1 is failed.
- b. **Only** seal #2 is failed.
- c. **Both** #1 and #2 seals are failed.
- d. The seal staging flow orifice is clogged.

Answer 6

a. Only seal #1 is failed.

Equal pressure between RR-PI-32A (RR-PI-32B)SEAL 2 BRG CAV and RR-PI-33A (RR-PI-33B) SEAL 1 BRG CAV indicates a #1 seal failure. Normally seal cavity 2 pressure should be about 1/2 of cavity 1 pressure.

REEFERENCE: 2.3_9.4.3 2.4RR; Attachment 3 - 1.3

Foils:

- b. Very low pressure in seal cavity #2, indicated on RR-PI-32A (RR-PI-32B) SEAL 2 BRG CAV, indicates #2 seal failure. Upper cavity pressure will approach lower cavity pressure.
- c. The pressure relationship between the seals would remain (1/2 for pressure). Would also receive (1819) Recirc Pump A Outer Seal Leakage Flow High Alarm.
- d. Will not receive seal staging flow high alarm for this condition.

Bank Difficulty 2 Cognitve Level 2

Enabling Objectives

COR0022202001140A Given plant conditions determine if the following has occurred: #1 seal failure only.

Skills

202001.A4.11 Ability to manually operate and/or monitor in the control room: (CFR: 41.7 / 45.5 to 45.8) Seal pressures: Plant-Specific (3.2/3.3)

Question 7 5497 (1 point(s))

Given the following conditions:

- The generator has been synchronized to the grid
- Bypass Valves are closed
- The load demand remains at 200
- Reactor power is raised using reactor recirculation flow

How will DEH respond to the power increase?

As reactor power is raised, turbine bypass valves...

- a. remain closed **and** DEH remains in MODE 3.
- b. remain closed **and** DEH remains in MODE 4.
- c. open when load exceeds 200 MW and DEH transfers to MODE 3.
- d. open when load exceeds 200 MW **but** DEH remains in MODE 4.

Answer 7

c. open when load exceeds 200 MW and DEH transfers to MODE 3.

EXPLANATION OF ANSWER: The load control signal enters a low value gate with pressure control signal. Whichever is lower will be passed through. Until megawatts exceeds 200 the load signal will be lower than the pressure control signal. At this point the opening of the control valves will be limited. This will cause the bypass valves to open. When the bypass valves open DEH will transfer to MODE 3.

REFERENCES: COR002-09-02, DEH. PR 2.2.77.1, DEH Control System

Foils:

- a. Bypass valves will open and DEH was in Mode 4.
- b. Bypass valves will open and DEH transfers to Mode 3.
- d. DEH will transfer to Mode 3.

Modified Difficulty: 2 Cognitive Level: 2

Enabling Objectives

COR0020902001040L Describe how the DEH control system operates to control the following: Bypass valve position

COR00209020011100 Define the four DEH Control system operating Modes used at CNS.

COR00209020011200 Given a specific DEH Control system operating Mode, identify the parameter controlled and components positioned for controlling it.

Skills

295007.AK2.01 Knowledge of the interrelations between HIGH REACTOR PRESSURE and the following: (CFR: 41.7 / 45.8) Reactor/turbine pressure regulating system (3.5/3.7)

Question 8 17890 (1 point(s))

During a plant transient, SRV "D" lifts in response to high pressure. When a tailpipe vacuum breaker operates to equalize pressure, it sticks in the **OPEN** position.

What are the possible consequences of this failure of the SRV tailpipe vacuum breaker?

If the SRV lifts again, ...

- a. the pressure trapped in the discharge pipe would raise the operating setpoint of the SRV, causing possible damage to the Reactor Vessel and piping.
- b. the water that was drawn up into the discharge pipe would cause a water hammer to occur, causing possible damage to the SRV, piping, and torus.
- c. the steam passing through the SRV will be released directly into the torus airspace, bypassing the pressure suppression function of the primary containment.
- d. the steam passing through the SRV will be released directly to the drywell atmosphere, producing primary containment conditions similar to a small break LOCA.

Answer 8

d. the steam passing through the SRV will be released directly to the drywell atmosphere, producing primary containment conditions similar to a small break LOCA.

REFERENCE: P&ID 2028

Foils:

- a. This will not occur if a vacuum breaker sticks open.
- b. This is the effect if the vacuum breakers stick closed.
- c. The SRV tailpipe vacuum breakers relieve to the drywell, not torus airspace.

New Difficulty 2 Cognitive Level 2 **Enabling Objectives**

COR0021602001080H Predict the consequences a malfunction of the following would have on the NPR system: Discharge line vacuum breaker

Skills

239002.A2.01 Ability to (a) predict the impacts of the following on the RELIEF/SAFETY VALVES; and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those...: (CFR: 41.5 / 45.6) Stuck open vacuum breakers (3.0/3.3)

Question 9 1499 (1 point(s))

An SRV is opened during normal power operations.

When read on MS-TR-166, SAFETY AND RELIEF VALVE LEAKAGE TEMPS, tail pipe temperature will indicate . . .

- a. between 250°F and 280°F.
- b. between 285°F and 325°F.
- c. between 385°F and 400°F.
- d. between 500°F and 550°F.

Answer 9

b. between 285°F and 325°F.

REFERENCE: COR002-16-02, page 23, section IV.E.2, rev. 09, Steam Tables

Foils:

- a. Saturation temp for 30 psia.
- c. Numbers to round out spacing of other numbers.
- d. Saturation temp of vessel.

Bank Difficulty 2 Cognitive Level 2

Provide to Candidate: Steam Tables

Enabling Objectives

SKL012421600A030F Given plant conditions, predict changes in the following NPR system components/parameters: SRV tailpipe temperatures

COR0021602001040A Given a Nuclear Pressure Relief system component manipulation, predict and explain the changes in the following parameters: Tail pipe temperatures

Skills

218000.A4.06 Ability to manually operate and/or monitor in the control room: (CFR: 41.7 / 45.5 to 45.8) ADS valve tail pipe temperature (3.5/3.6)

Question 10 16434 (1 point(s))

The plant is at 100% power when it becomes necessary to remove both RWCU Demineralizers from service. RWCU-MO-74, DEMIN SUCTION BV, is opened to prevent a low flow trip while the problems with the demineralizers is corrected.

What action is required?

- a. Lower reactor power.
- b. Do <u>not</u> allow RWCU blowdown flow to Radwaste.
- c. Do <u>not</u> change recirculation flow until RWCU-MO-74 is closed.
- d. Change the conductivity sample point to the Recirculation Loops.

Answer 10

a. Lower reactor power.

Core thermal power calculation looks at RWCU flow. With the bypass around the demins open there is no flow indication, but the cold water still exists and is missed causing the core thermal power calculation to be off by 4 MWt. Reactor power must be lowered to maintain <2377 Mwth.

Reference: 2.2.66, Section 2.16

Foils:

- b. Not a precaution.
- c. Flow can be changed.
- d. Not a precaution.

Bank Difficulty: 3 Cognitive level: 1

Enabling Objectives

COR0012002001100A Briefly describe the following concepts as they apply to RWCU: Demineralizer operation

COR0012002001130D Given a RWCU component manipulation, predict and explain the changes in the following parameters: Reactor water temperature

SKL012412000A0200 Explain the RWCU system limitations and precautions as stated in the SOP 2.2.66.

Skills

295014.AK2.06 Knowledge of the interrelations between INADVERTENT REACTIVITY ADDITION and the following: (CFR: 41.7 / 45.8) Moderator temperature. (3.4/3.5)

Question 11 17862 (1 point(s))

A station startup is in progress, reactor temperature is 178°F and rising at 80°F/hr. The Reactor Water Cleanup system (RWCU) is being used to control RPV water level when a high NRHX outlet temperature isolates RWCU.

How is RPV water level affected and what is the effect on the plant startup?

RPV water level . . .

- a. rises. The startup may continue.
- b. lowers. The startup may continue.
- c. rises. The startup must be stopped due to inability to control RPV water level.
- d. lowers. The startup must be stopped due to inability to control RPV water level.

Answer 11

c. rises. The startup must be stopped due to inability to control RPV water level.

Reference: 2.4RXLVL

Foils:

a.b.d. The loss of RWCU will prevent its use for RPV water level control (draining excess water via RWCU blowdown. Per 2.4RXLVL any power change must be stopped.

New Difficulty 2 Cognitive Level 2

Enabling Objectives

SKL012412000A030A Given plant conditions, predict changes in the following RWCU system components/parameters: Reactor vessel water level.

COR0012001001110D State how the following systems interrelate with the operation of the RWCU System: Main Condenser

Skills

204000.K3.02 Knowledge of the effect that a loss or malfunction of the REACTOR WATER CLEANUP SYSTEM will have on following: (CFR: 41.7 / 45.4) Reactor water level (3.1/3.1)

Question 12 17863 (1 point(s))

12 hours after shutdown, a loss of shutdown cooling has occurred. The crew has entered abnormal procedure 2.4SDC, "Shutdown Cooling Abnormal."

Which of the following systems can be used for alternate decay heat removal?

- a. Core Spray
- b. Fuel Pool Cooling
- c. Condensate Transfer
- d. Reactor Water Cleanup

Answer 12

RWCU can be lined up per 2.2.66 for alternate decay heat removal.

Reference: 2.4SDC

Foils:

- a. Core Spray is not an alternate decay heat removal system.
- b. Fuel pool cooling will not be available until the reactor head has been removed and the cavity flooded and the gates removed this will not occur within 12 hours of shutdown.
- c. Condensate Transfer is not an alternate decay heat removal system.

New Difficulty 2 Cognitive Level 1

Enabling Objectives

COR0012002001050C Briefly describe RWCU operation under the following conditions: Loss of Shutdown Cooling

d. Reactor Water Cleanup

Skills

205000.K5.03 Knowledge of the operational implications of the following concepts as they apply to SHUTDOWN COOLING SYSTEM (RHR SHUTDOWN COOLING MODE): (CFR: 41.5 / 45.3) Heat removal mechanisms (2.8/3.1)

Question 13 5030 (1 point(s))

Given the following conditions:

- The Reactor Core Isolation Cooling (RCIC) System is operating in the Test Mode.
- The RCIC flow controller is in BAL.
- The RCIC TURB TEST Switch is in TURB TEST.
- The RCIC TURB TEST POWER Switch is ON.
- RCIC flow is 300 gpm and turbine speed is 2500 rpm (indicated in the control room).

The operator then jogs M0-30, RCIC Test Bypass To ECST Valve, in the CLOSED direction. MO-30 is still partially open.

What is the expected *final* response of RCIC turbine speed and system flow if all equipment operates as designed?

- a. RCIC turbine speed rises. System flow rises.
- b. RCIC turbine speed lowers. System flow lowers.
- c. RCIC turbine speed is unchanged. System flow lowers.
- d. RCIC turbine speed is unchanged. System flow rises.

Answer 13

c. RCIC turbine speed is unchanged. System flow lowers.

EXPLANATION OF ANSWER: With the Test Controls ON and no initiation signal present, the Flow Controller is isolated from the turbine governor and turbine speed is controlled with the Test Pot. Positioning MO-30 and adjusting turbine speed regulates flow. As MO-30 is jogged in the closed direction, flow will lower and turbine speed will remain constant.

REFERENCE: STCOR0021802 Section III.C PR 2.2.67.1; Section 8.5 DWG 971E264 Sh. 5

Foils:

- a. Speed remains constant, flow lowers
- b. Speed remains constant.
- d. Flow lowers.

Bank Difficulty 3 Cognitive Level 3

Enabling Objectives

COR0021802001100H Predict the consequences of the following on the RCIC system: System Valve closures and openings

Skills

217000.A1.01 Ability to predict and/or monitor changes in parameters associated with operating the REACTOR CORE ISOLATION COOLING SYSTEM (RCIC) controls including: (CFR: 41.5 / 45.5) RCIC flow (3.7/3.7)

Question 14 17891 (1 point(s))

The plant was operating at full power with RCIC tagged out when it scrammed due to trip of both Feedwater pumps. HPCI injecting at full flow recovered RPV water level from -50" (WR) to +35" (WR). HPCI was tripped as RPV water level reached +35" (WR). Conditions are currently:

- Reactor pressure 700 psig (rising at 10 psig per minute)
- MSIVs Open
- Time after scram 5 minutes
- CRD pumps both tripped
- Drywell pressure 0.3 psig

If <u>no additional operator actions are taken</u>, what is the expected RPV water level response over the next 10 minutes and why?

RPV water level will ...

- a. lower below the low level alarm point due to shrink.
- b. lower below the low level alarm point due to steam loads reducing RPV water inventory.
- c. rise above the high RPV water level trip setpoint due to swell.
- d. rise above the high RPV water level trip setpoint due to Startup Valve leakage exceeding decay heat requirements.

Answer 14

c. rise above the high RPV water level trip setpoint due to swell.

The specific volume change from ECST water to saturated liquid at 700 psig results in ~ 40% increase in gallons/inches of RPV level. 85" of cold water added = ~ 119" (34" more or + 69")

REFERENCE: Plant events, Steam Tables

Foils:

a. RPV water level will rise. Level will not shrink.

- b. RPV water level will rise. BPVs will be closed at this pressure and remaining steam loads will not lower level under these conditions.
- d. Rx pressure is above Condensate Booster pump discharge pressure.

New Difficulty 3 Cognitive Level 2

Enabling Objectives

COR0021102001100F Predict the consequences of the following on the HPCI system: Low reactor water level

SKL012421100A030C Given plant conditions, predict changes in the following HPCI system components/parameters: Reactor water level

Skills

295008.AA2.05 Ability to determine and/or interpret the following as they apply to HIGH REACTOR WATER LEVEL: (CFR: 41.10 / 43.5 / 45.13) Swell. (2.9/3.1)

Question 15 12444 (1 point(s))

The plant was operating at power when a loss of off-site power occurred. The reactor scrammed and HPCI started on low reactor water level. Reactor water level quickly recovered and the HPCI turbine tripped on high RPV water level. The following plant conditions were present:

- Reactor water level 45" (NR) (lowering slowly)
- Reactor pressure 850 psig (rising slowly)
- Drywell pressure 2.2 psig (rising slowly)

What is/are the **MINIMUM** action(s) required to restart HPCI *at this time*? (NOTE: The choices are arranged in MIMIMUM to MAXIMUM order.)

- a. Momentarily depress the Reactor Hi Water Level Signal Reset pushbutton **ONLY**.
- b. Momentarily depress the Initiation Signal Reset pushbutton <u>AND</u> place the HPCI-MO-14 control switch to open.
- c. Momentarily depress the Reactor Hi Water Level Signal Reset pushbutton <u>AND</u> place the HPCI-MO-14 control switch to open.
- d. Momentarily depress the Reactor Hi Water Level Signal Reset pushbutton <u>AND</u> momentarily depress the Initiation Signal Reset pushbutton <u>AND</u> place the HPCI-MO-14 control switch to open.

Answer 15

a. Momentarily depress the Reactor Hi Water Level Signal Reset pushbutton **ONLY**.

During the transient drywell pressure has risen to greater than the initiation setpoint for HPCI. Since an automatic initiation signal is present, if the operator depresses the Reactor Hi Water Level Signal Reset pushbutton the system will reinitiate.

REFERENCE: 2.2.33

Foils: b, c, d - only the high level trip reset need be depressed. Bank Difficulty 3 Cognitive Level 2

Enabling Objectives

COR0021102001120A Given plant conditions, determine if the following HPCI actions should occur: System initiation

SKL012421100A030J Given plant conditions, predict changes in the following HPCI system components/parameters: Turbine speed

COR0021102001100V Predict the consequences of the following on the HPCI system: High reactor water level

Skills

206000.K4.07 Knowledge of HIGH PRESSURE COOLANT INJECTION SYSTEM design feature (s) and/or interlocks which provide for the following: (CFR: 41.7) Automatic system initiation: BWR-2,3,4 (4.3*/4.3)

Question 16 3790 (1 point(s))

Service Water is cross-connected to REC from the Control Room. SW is supplying cooling to the critical loops.

How are REC/Service Water systems affected (if at all) by a Group 6 isolation signal?

- a. Service Water will be isolated.
- b. Service Water **AND** REC will **NOT** be affected.
- c. REC will automatically realign to the critical loops.
- d. Some Service Water flow will bypass the critical loops.

Answer 16

d. Some Service Water flow will bypass the critical loops.

REFERENCES: SOP 2.2.65.1

Foils:

- a. Service Water will NOT isolate.
- b. Both Service Water and REC are affected.
- c. REC will not automatically realign.

Bank Difficulty 3 Cognitive Level 1

Enabling Objectives

SKL012421900A030L Given plant conditions, predict changes in the following Reactor Equipment Cooling System components/parameters: SW/REC Crosstie

COR0021902001040B Describe the REC design features and/or interlocks that provide for the following: Service Water Crosstie to REC

COR0021902001040D Describe the REC design features and/or interlocks that provide for the following: Isolation of Non-Critical Cooling loops

COR0021902001110A Given plant conditions, determine if any of the following should occur: Non-Critical loop isolation

Skills

295018.AA1.01 Ability to operate and/or monitor the following as they apply to PARTIAL OR COMPLETE LOSS OF COMPONENT COOLING WATER: (CFR: 41.7 / 45.6) Backup systems (3.3/3.4)

Question 17 16475 (1 point(s))

With the plant at 65% power, an attempt is made to single **<u>notch</u>** withdraw a control rod from notch 24 to notch 26. While the control rod is being withdrawn, a malfunction of the RMCS timer causes a constant withdrawal signal to be sent to the selected control rod.

Assume NO additional operator actions and that all control rods move at nominal control rod speed.

What is the FINAL POSITION of the control rod?

a. Notch 26

- b. Notch 28
- c. Notch 30
- d. Notch 48

Answer 17

b. Notch 28

Timer malfunction deselects the rod after 2 seconds (which is 1/2 second longer than the normal timer), causing the control rod to be de-selected

REFERENCE: IOP 4.3; Attachment 3, 1.3.2

Foils:

- a. From the given power level an Rx scram will not occur.
- c. An extra $\frac{1}{2}$ second will not result in a two (2) notch change.
- d. Rod will be de-selected after 2 seconds of motion.

Bank Difficulty 3 Cognitive Level 2

Enabling Objectives

COR0022002001040A Describe the RMCS design features and/or interlocks that provide for the following: Detection of sequence timer malfunction

COR0022002001060A Given a RMCS control manipulation, predict and explain the response of the following: Control rod position

COR0022002001080A Given a specific RMCS and/or RPIS malfunction, determine the effect on any of the following: Ability to move control rods

Skills

201002.A1.02 Ability to predict and/or monitor changes in parameters associated with operating the REACTOR MANUAL CONTROL SYSTEM controls including: (CFR: 41.5 / 45.5) Control rod position (3.4/3.3)
Question 18 5006 (1 point(s))

Given the following conditions:

- A plant startup is in progress with power at 8%
- Group 42 rods are being withdrawn
- ONLY one rod remains to be withdrawn in Group 42
- All other control rods are at their proper position
- The operator attempts to select AND withdraw a rod in Group 43 one notch

What is the response of the Group 43 control rod?

The Control rod will ...

- a. **NOT** withdraw and withdrawal blocks will be applied.
- b. **NOT** select and **NO** withdrawal blocks will be applied.
- c. withdraw one notch, then withdrawal blocks will be applied.
- d. withdraw one notch and **NO** withdrawal blocks will be applied.

Answer 18

d. withdraw one notch and **NO** withdrawal blocks will be applied.

EXPLANATION OF ANSWER: RWM will latch to group 43 when the first rod moves off of its insert limit. This will leave the group 42 rod as an insert error. No rod blocks will result from one insert error.

REFERENCE: PR 4.2 Rod Worth Minimizer

Foils:

- a. Rod will withdraw and no blocks are applied.
- b. Nothing prevents selecting the rod in this condition.
- c. no rod blocks will result.

Bank

Difficulty 4 Cognitive Level 2

Enabling Objectives

COR0022602001040C Describe the RWM design features and/or interlocks that provide for the following: Withdraw blocks and errors

COR0022602001050I Briefly describe the following concepts as they apply to the RWM: Withdraw block

COR0022602001050C Briefly describe the following concepts as they apply to the RWM: Latched groups

COR0022602001080B Predict the consequences of the following items on the RWM: Out of sequence rod movement

Skills

201006.K4.01 Knowledge of ROD WORTH MINIMIZER SYSTEM (RWM) (PLANT SPECIFIC) design feature (s) and/or interlocks which provide for the following: (CFR: 41.7) Insert blocks/errors: P-Spec (Not-BWR6) (3.4/3.5)

Question 19 17865 (1 point(s))

A LOCA is in progress with drywell spray in service on the "A" RHR loop. "B" RHR loop is in torus cooling with suppression pool temperature 78°F. Due to a logic failure, the RHR drywell spray valves will not automatically close.

What is the consequence if the Reactor Building to Torus Vacuum Breakers fail CLOSED under these conditions?

- a. Implosion of the primary containment.
- b. Over-pressurization of the primary containment.
- c. Excessive differential pressure from the Drywell to the Torus.
- d. Excessive differential pressure from the Torus to the Drywell.

Answer 19

a. Implosion of the primary containment.

The Reactor Building to Torus Vacuum Breakers open on a negative pressure in the torus to protect against external over-pressurization which is caused by RHR condensing the steam in the torus free air space.

Reference: Tech. Spec Bases section B.3.6.1.7

Foils:

- b. This failure would not result in containment overpresure.
- c. The downcomers prevent this pressure exceeding ~ 2 psid.
- d. Torus to drywell vacuum breakers would open on a high internal pressure.

New Difficulty 2 Cognitive Level 3

Enabling Objectives

COR0022302001080L Predict the consequences a malfunction of the following will have on the RHR system: Reactor building to Suppression chamber vacuum breakers

COR0020302001230D Predict the consequences of a malfunction of the following on the Primary containment: Drywell vacuum relief.

COR0022302001040H Describe the interrelationship between the RHR system and the following: Primary Containment

Skills

230000.K6.09 Knowledge of the effect that a loss or malfunction of the following will have on the RHR/LPCI: TORUS/SUPPRESSION POOL SPRAY MODE: (CFR: 41.7 / 45.7) Reactor building to suppression pool vacuum breakers (3.5/3.8)

Question 20 9228 (1 point(s))

The plant was at 100% power when a large break LOCA occurred. Reactor water level initially lowered to +5" (corrected Fuel Zone), then was restored using RHR pumps which automatically started. To control the level rise, the BOP stopped RHR pumps A and D by momentarily placing the control switches to STOP.

Before any additional actions were taken, a loss of off-site power (LOOP) occurred.

Which RHR pumps will be operating ten (10) seconds after the DGs energize the emergency buses, if any?

- a. All RHR pumps remain OFF.
- b. All RHR pumps are running.
- c. RHR pumps B and C are running. Other pumps remain OFF.
- d. RHR pumps A and D are running. Other pumps remain OFF.

Answer 20

c. RHR pumps B and C are running. Other pumps remain OFF.

A and D RHR pumps are OFF with a STOP signal sealed in. Even if power is lost and restored the STOP signal for A and D RHR pumps remains sealed in. B and C RHR pumps will start 5 seconds after power is restored to their respective bus.

REFERENCE: 2.2.69; Attachment 1 - 2.1.1.2.a, 2.1.1.2.b, 2.1.2.2

Foils:

- a. B and C pumps start after 5 seconds.
- b. A and D RHR pumps remain OFF.
- d. A and D pumps remain OFF. B and C RHR pumps will be running.

Bank Difficulty 3 Cognitive Level 3

Enabling Objectives

COR0022302001130D State the purpose of the following items related to the RHR system: Pumps

COR0022302001030F Describe RHR System design feature(s) and/or interlocks which provide for the following: Emergency Diesel Generator load sequencing

COR0022302001060I Given an RHR control manipulation, predict and explain changes in the following: Emergency Diesel Generator loading

COR0022302001150B Given plant conditions, determine if the following should occur: RHR pump start

Skills

203000.K2.01 Knowledge of electrical power supplies to the following: (CFR: 41.7) Pumps (3.5*/3.5*)

Question 21 1729 (1 point(s))

The RPV is at 30 psig operating in Shutdown Cooling using the "B" RHR pump.

The SDC Outboard Isolation Valve, MO-17, will...

- a. close if Reactor pressure is above 72 psig or a PCIS Group 2 isolation signal is received.
- b. remain "as is" under all conditions, because it is maintained de-energized once Shutdown Cooling is established.
- c. close if a PCIS Group 2 isolation signal is received, but will remain open if Reactor pressure rises above 72 psig.
- d. remain "as is" under all conditions, because the Shutdown Cooling Isolation logic is disabled below 72 psig Reactor pressure.

Answer 21

a. close if Reactor pressure is above 72 psig <u>OR</u> a PCIS Group 2 isolation signal is received.

REFERENCE: RHR Text, Procedure 2.2.69, Attach. 1, step 2.2.6.3

Foils:

- b. The valve is not allowed to be de-energized until Mode 4 is reached.
- c. High Rx pressure will close the SDC isolation valve.
- d. The isolation logic is never disabled, even in EOPs.

Modified Difficulty 3 Cognitive Level 1

Enabling Objectives

COR0022302001030B Describe RHR System design feature(s) and/or interlocks which provide for the following: Prevention of piping over-pressurization

COR0022302001030J Interpret RHR System design feature(s) and/or interlocks which provide for the following: High pressure isolation

COR0022302001040L Describe the interrelationship between the RHR system and the following: PCIS

Skills

223002.K1.08 Knowledge of the physical connections and/or cause- effect relationships between PRIMARY CONTAINMENT ISOLATION SYSTEM/NUCLEAR STEAM SUPPLY SHUT-OFF and the following: (CFR: 41.2 to 41.9 / 45.7 to 45.8) Shutdown cooling system/RHR (3/4/3.5)

Question 22 1744 (1 point(s))

Following a LOCA, the following conditions are present :

- Reactor pressure 700 psig
- RPV water level 100 in (wide range)
- Drywell pressure 11.0 psig
- Torus water temp 104 °F

What are the **MINIMUM** actions that are required in order to initiate Drywell Sprays with the "A" RHR loop? (NOTE: The choices are listed in MIMIMUM to MAXIMUM order.)

- a. Place Drywell Inbd (MO-31A) and Outbd (MO-26A) Spray Valve control switches in OPEN.
- b. Place Containment Cooling Valve Control Permissive switches in MANUAL, then place Drywell Inbd (MO-31A) and Outbd (MO-26A) Spray Valve control switches in OPEN.
- Place Containment Cooling 2/3 Core Valve Control Permissive switches in OVERRIDE, place the Containment Cooling Valve Control Permissive switches in MANUAL, then place Drywell Inbd (MO-31A) and Outbd (MO-26A) Spray Valve control switches in OPEN.
- d. Depress Containment Spray Initiation Signal Reset pushbuttons, place Containment Cooling 2/3 Core Valve Control Permissive switches in OVERRIDE, place the Containment Cooling Valve Control Permissive switches in MANUAL, then place Drywell Inbd (MO-31A) and Outbd (MO-26A) Spray Valve control switches in OPEN.

Answer 22

b. Place Containment Cooling Valve Control Permissive switches in MANUAL, then place Drywell Inbd (MO-31A) and Outbd (MO-26A) Spray Valve control switches in OPEN.

REFERENCE: RHR Text (COR0022302), Procedure 2.2.69, Attach. 1, Note page 43 & 2.2.10.2

Foils:

- a. Containment Cooling Valve Control Permissive switches must be placed in MANUAL
- c. There is no need to override 2/3 core height.
- d. There is no need to override 2/3 core height or reset the containment spray initiation.

Bank

Difficulty 2 cognitive Level 2

Enabling Objectives

COR0022302001030P Describe RHR System design feature(s) and/or interlocks which provide for the following: Spray flow cooling

COR0022302001170C Given plant conditions, determine actions necessary to place RHR in the following flowpaths: Drywell Spray

Skills

226001.A1.05 Ability to predict and/or monitor changes in parameters associated with operating the RHR/LPCI: CONTAINMENT SPRAY SYSTEM MODE controls including: (CFR: 41.5 / 45.5) System lineup (3.1/3.4)

Question 23 16499 (1 point(s))

During operation at full power annunciator 9-3-3/A-5, CORE SPRAY B BREAK DETECTION is received.

NO other annunciators alarm. A station operator sent to the d/p indicating switch reports that the d/p is +4.0 psid.

What is the significance of this alarm and d/p indication on core spray flow during a subsequent Core Spray initiation?

Core spray flow will flow ...

- a. into the Drywell through the broken pipe.
- b. inside the core shroud and out the broken pipe.
- c. into secondary containment through the broken pipe.
- d. into the downcomer region of the reactor through the broken pipe.

Answer 23

d. into the downcomer region of the reactor through the broken pipe.

REFERENCE: 2.3_9-3-3, ST COR002-06-02

Justification: The alarm and d/p reading indicate the break is outside the shroud but inside the reactor.

Foils:

- a. The indicated d/p would be pegged high (+1000 psig).
- b. The indicated d/p would be low -3.5 psig.
- c. The instrument measures d/p downstream of the check valve inside the primary containment.

Bank Difficulty 3 Cognitive Level 1 Enabling Objectives

COR0020602001090C Predict the consequences of the following items on the Core Spray System: Core Spray line break

Skills

209001.A4.11 Ability to manually operate and/or monitor in the control room: (CFR: 41.7 / 45.5 to 45.8) System flow (3.7/3.6)

Question 24 17871 (1 point(s))

The 12.5KV System has been removed from service. What Fire Protection System Fire Pumps (C, D, E) are available for use 15 minutes after the loss of 12.5KV?

a.	Only C
b.	Only D

- c. C and D
- d. D and E

Answer 24

c. C and D

C Fire Pump is powered from MCC-E and the Diesel pump ("D") will start from its batteries.

Reference: 2.2.90: 6.3, 6.26,6.27, and 6.28, COR0010501

Foils:

- a. D will start as well
- b. C will start as well
- d. E pump has lost power

New Difficulty 2 Cognitive level 1

Enabling Objectives

COR0010502001060A State the electrical power supply to the following: Diesel Fire Pump starting circuitry

COR0010502001060B State the electrical power supply to the following: Electric Fire Pumps "C" & "E"

Skills

286000.K2.02	Knowledge of electrical	power supplies to	the following:	(CFR: 41.7)	Pumps (2.9/3.1)
--------------	-------------------------	-------------------	----------------	-------------	-----------------

Question 25 16470 (1 point(s))

Given the following conditions:

- The piping just downstream of the 'A' SBLC squib valve (SLC-14A) is completely obstructed.
- The control switch for SLC PUMP A on Panel 9-5 is taken to the START position, then to the STOP position when the no-flow condition is recognized.
- The control switch for SLC PUMP B on Panel 9-5 is taken to the START position. The SLC Pump B trips. Then the control switch is taken to the STOP position.

Which one of the following describes the **MINIMUM** steps necessary to inject SLC under the current conditions? (Note: The choices are listed in MINIMUM to MAXIMUM order.)

- a. Return the control switch for SLC PUMP A on Panel 9-5 to the START position.
- b. Place the control switches for SLC PUMP A **AND** SLC PUMP B on Panel 9-5 to START.
- c. Start the B SLC Pump using the local test station keylock switch.
- d. Perform alternate boron injection with any available system per EOP-5.8.8.

Answer 25

- a. Return the control switch for SLC PUMP A on Panel 9-5 to the START position.
- Justification: Either pump can discharge through either squib valve once both switches are placed in START. the 'B' squib valve fires when SLC PUMP B is started, when A is re-started it will discharge through the B squib valve.

REFERENCE: 2.2.74; Attachment 1.2.2, 1.3.1, 1.3.2, 1.3.3, 1.3.4

foils:

- b. No need to place the SLC PUMP B control switch in start the squib valve has already been fired.
- c. The breaker has tripped this would not start the pump.
- d. No need to take the time for alternate injection. A SLC pump can inject.

Bank Difficulty 2 Cognitive Level 2

Enabling Objectives

COR0022902001060D Briefly describe the following concepts as they apply to SLC system: Squib valve operation

COR0022902001080D Given a SLC component manipulation, predict and explain the changes in the following: Flow indication

Skills

211000.K5.04 Knowledge of the operational implications of the following concepts as they apply to STANDBY LIQUID CONTROL SYSTEM: (CFR: 41.5 / 45.3) Explosive valve operation (3.1/3.2)

Question 26 16625 (1 point(s))

The plant is at 100% power with TIP traces in progress. Only "A" TIP machine is being used at this time. Currently, TIP "A" has reached the Core Bottom Limit and is moving at slow speed to the Core Top Limit. The IN-CORE light is ON.

A reactor scram due to low RPV water level occurs. One (1) minute later, an operator observes:

- TIP valve indication on Containment Isolation display (Panel 9-3) is RED
- IN-SHIELD light for TIP "A" is ON at Panel 9-13
- Drywell pressure is normal

What action is *required*?

- a. Fire TIP "A" shear valve.
- b. Close TIP "A" ball valve.
- c. Manually retract TIP "A" to fire the shear valve.
- d. Manually retract TIP "A" to close the ball valve.

Answer 26

b. Close TIP "A" ball valve.

The indications at Panel 9-3 indicate that a ball valve is open. If red light (Panel 9-3) stays on, at least one TIP ball valve has not closed. After automatic withdrawal of the TIP on the PCIS group 2 isolation signal, the ball valve failed to automatically close. This failed automatic action requires immediate operator action to manually perform the ball valve closure. The procedure directs the operator to attempt to manually retract TIP. Since the TIP is already retracted (IN-SHIELD light is on), this action is not necessary.

If ball valve cannot be closed and there are indications of a reactor coolant leak in drywell (as evidenced by the high drywell pressure) then fire appropriate shear valve by operating appropriate keylock switch.

Per 2.0.1.2, step 2.3 "Operators shall ensure automatic safety initiations and actuations. They shall ensure automatic actions take place in response to valid initiation signals per their safety function design.

Upon recognition of a failure of automatic safety feature, Operators shall manually perform those actions necessary to fulfill the safety function."

REFERENCE: 4.1.4; Section 6 and Attach. 1, step 2.1.6, 2.0.1.2 step 2.3

Foils:

- a. There is no indications of a LOCA and no attempt has yet been made to close the ball valve.
- c. The TIP has already retracted and retracting the TIP does not fire the shear valve.
- d. The TIP has already retracted.

Bank Difficulty 3 Cognitive Level 1

Enabling Objectives

COR0023102001110A Describe the TIP system design features and/or interlocks that provide for the following: Primary containment isolation

COR0023102001130C Given a TIP system control manipulation, predict and explain the changes in the following parameters: Valve status

COR0023102001140H Predict the consequences of the following on the TIP system: High primary containment pressure

COR0023102001160B Given plant conditions, determine if any of the following TIP actions should occur: Ball valve closure

Skills

215001.K6.04 Knowledge of the effect that a loss or malfunction of the following will have on the TRAVERSING IN-CORE PROBE: (CFR: 41.7 / 45.7) Primary containment isolation system: Mark-I&II (Not- BWR1) (3.1/3.4)

Question 271068(1 point(s))Given the following conditions:

- A Reactor Startup is in progress.
- Power is rising with a stable period.
- SRM detectors are withdrawn except for SRM "A" which fails to withdraw.
- The SRM UPSCALE OR INOPERATIVE alarm has been received.
- SRM "A" is **NOT** bypassed.

If power continues to rise, what is the FIRST point that control rods will be able to be withdrawn?

- a. ALL IRMs are on Range 2.
- b. ALL IRMs are on Range 3.
- c. ALL IRMs are on Range 8.
- d. The Mode switch is placed to RUN.

Answer 27

c. ALL IRMs are on Range 8.

IRMs on range 8 will bypass the SRM Rod Block.

Reference: COR0023002, 4.1.1

Foils:

- a.b. SRM Rod Block is not bypased
- d. Question asked for the FIRST point the control rods can be moved.

Bank Difficulty 2 Cognitive Level 2

Enabling Objectives

COR0023002001060F Describe the SRM system design features and/or interlocks that provide for the following: IRM/SRM interlock

Skills

215004.A3.04 Ability to monitor automatic operations of the SOURCE RANGE MONITOR (SRM) SYSTEM including: (CFR: 41.7 / 45.7) Control rod block status (3.6/3.6)

Question 28 1080 (1 point(s))

Given the following conditions:

- A plant startup is in progress.
- The Recirculation flow input signal to the Average Power Range Monitors (APRMs) is 50%.
- As Recirculation flow is raised, the output signal from the "B" Flow Unit remains at 50%.
- Actual Recirculation loop flows respond as expected.

As Recirculation flow continues to be raised, what will be the FIRST effect on plant operation from the APRMs/Flow Unit?

- a. A half scram will occur due to flow biased neutron flux high.
- b. A control rod block will occur due to a Flow Unit Comparator trip.
- c. A control rod block will occur due to flow biased neutron flux high.
- d. A half scram will occur due to a Flow Unit UPSCALE OR INOP trip.

Answer 28

b. A control rod block will occur due to a Flow Unit Comparator trip.

EXPLANATION OF ANSWER: A Flow Unit Comparator trip will occur when the A Flow Unit exceeds 60% (10% difference)

REFERENCES: STCOR002-01-02, page 16, section III.B, rev. 12. 2.3_9-5-1 9-5-1/A-4

Foils:

- a. The margin to the SCRAM is large such that the Comparator trip will occur first.
- c. The margin to the APRM rod block is large such that the Comparator trip will occur first.
- d. Flow units do not directly cause scram signals.

Bank

Difficulty 3 Cognitive Level 2

Enabling Objectives

COR0020102001050G Describe the interrelationships between the Average Power Range Monitor System and the following: Flow converter/comparator network

Skills

215005.K1.16 Knowledge of the physical connections and/or cause- effect relationships between AVERAGE POWER RANGE MONITOR/LOCAL POWER RANGE MONITOR SYSTEM and the following: (CFR: 41.2 to 41.9 / 45.7 to 45.8) Flow converter/comparator network: Plant-Specific (3.3/3.4

Question 29 1120 (1 point(s))

Given the following conditions:

- The plant is performing a startup following a refueling outage
- The Reactor Mode Switch is in START & HOT STBY
- The "A" Reactor Protection System (RPS) MG set is being returned to service following maintenance
- Power is on IRM Range 3.
- When the operator placed the RPS Bus "A" Power Supply Selector to "NORMAL," a full reactor scram resulted (all rods in)

What additional condition would have caused this full reactor scram?

- a. The Reactor Protection System shorting link switches are closed.
- b. IRM Channel "E" was upscale and **NOT** bypassed during the transfer.
- c. A Division 2 PCIS Group 1 half isolation was present during the transfer.
- d. APRM Channel "F" was upscale and **NOT** bypassed during the transfer.

Answer 29

d. APRM Channel "F" was upscale and **NOT** bypassed during the transfer.

REFERENCES: STCOR002-01-02 PR 4.1.3, page 2, section 2.2.3, rev. 18.

Foils:

- a. The shorting link switches are normally closed.
- b. Channel E is fed by 24 VDC "A".
- c. RMS in "Startup/Hot Standby" bypasses MSIV closure scram.

Bank Difficulty 2 Cognitive Level 2 Enabling Objectives

COR0020102001060A	State the electrical power supplies to the following:	LPRM channels
COR0020102001060B	State the electrical power supplies to the following:	APRM channels

Skills

215005.K2.02 Knowledge of electrical power supplies to the following: (CFR: 41.7) APRM channels (2.6/2.8)

Question 30 16433 (1 point(s))

A power ascension is in progress. Annunciator 9-5-1/D-4 RBM UPSCALE/INOP alarms. At Panel 9-14, using the Meter Function Switch on RBM "A", the following indications are observed:

- AVERAGE 89%
- APRM SIG 78%
- COUNT 2.0 v (25 % of assigned inputs)
- BLOCK 94%

What is the status of RBM "A"?

- a. RBM is inoperable from too few LPRM inputs.
- b. RBM is operable, but an edge rod has been selected.
- c. RBM is inoperable from a failure to null with the APRM.
- d. RBM is operable, but local power is above the APRM signal.

Answer 30

a. RBM is inoperable from too few LPRM inputs.

Too few LPRM inputs count circuit shows less than 50%

REFERENCE: 2.3_9-5-1, 4.1.5; 1.2.4.1

Foils:

- b. RBM is inoperable and edge rod would not cause the annunciator.
- c. A failure to null has not occurred, there are too few LPRM inputs.
- d. RBM is inoperable, local power is below APRM power but this is not the cause for a block, the RBM power is below the block setpoint.

Bank Difficulty 3 Cognitive Level 2

Enabling Objectives

COR0022402001130A Given plant conditions, determine if any of the following should occur: RBM control rod withdrawal block.

COR0022402001130C Given plant conditions, determine if any of the following should occur: RBM inop trip.

Skills

215002.A3.02 Ability to monitor automatic operations of the ROD BLOCK MONITOR SYSTEM including: (CFR: 41.7 / 45.7) Meters and recorders: BWR-3,4,5 (3.1/3.0)

Question 31 16511 (1 point(s))

While operating steady state at 100% power the following indications are observed:

- Reactor power lowers
- Narrow Range reactor water level rises
- Indicated core plate d/p lowers
- Indicated TOTAL core flow rises
- "A" and "B" recirculation loop flows rise by the same amount

Which one of the following failures caused the above conditions?

- a. A shroud support access hole cover has failed.
- b. One (1) of the Jet pumps has a blocked throat.
- c. One (1) recirculation pump's speed has raised to maximum.
- d. Flow through a control cell (four fuel bundles) has been blocked.

Answer 31

a. A shroud support access hole cover has failed.

A shroud support access hole cover is ~ 19 " in diameter. The effect to recirculation flow and core power by the separation of a cover could be significant. If a cover should separate, a flow path which bypasses the core is established which reduces the hydraulic resistance to flow through the core. This condition would indicate an increase in total core flow but actual flow through the core would drop and cause power to drop.

REFERENCES: 2.4RXPWR; 5.3, 6.2, 6.3

Foils:

- b. Loop flows will lower in one loop and reactor water level change would not be discernible.
- c. Would not provide these indications.
- d. This would lower core flow.

Bank Difficulty 3 Cognitive Level 1

Enabling Objectives

COR0011502001060C Given plant operating status, predict and explain the changes in the following parameters associated with the following: Reactor Power

COR0011502001060A Given a specific Nuclear Boiler system malfunction, determine the effect on any of the following: Reactor Water Level

COR0021502001020I Describe the interrelationships between NBI and the following: Reactor Vessel

Skills

290002.K3.07 Knowledge of the effect that a loss or malfunction of the REACTOR VESSEL INTERNALS will have on following: (CFR: 41.7 / 45.4) Nuclear boiler instrumentation (3.1/3.1)

Question 32 17860 (1 point(s))

The plant is operating at 50% power when a DEH malfunction causes the Main Turbine Bypass valves to rapidly open, causing the core void fraction to rapidly rise.

How is Wide Range RPV water level indication affected and why?

The ______ in flow resistance in the core region causes a/an ______ in the mass above the variable leg tap, causing a ______ in indicated RPV water level.

- a. increase, increase, rise
- b. increase, decrease, reduction
- c. decrease, increase, rise
- d. decrease, decrease, reduction

Answer 32

	•	•	•
a.	increase.	increase.	nse
	,		

Reference: COR002-15-02, 4.6.1, Attachment 2.

Foils:

- b. The mass above the variable leg increases and indicated level rises.
- c. The flow restriction rises.
- d. The flow restriction rises, the mass above the variable leg increases and indicated level rises.

New Difficulty 4 Cognitive Level 3

Enabling Objectives

COR0021502001040K Briefly describe the following concepts as they apply to NBI: Effects on level indication due to rapid changes in void fraction

Skills

216000.K5.12 Knowledge of the operational implications of the following concepts as they apply to NUCLEAR BOILER INSTRUMENTATION: (CFR: 41.5 / 45.3) Effects on level indication due to rapid changes in void fraction (3.2/3.3)

Question 33 16435 (1 point(s))

The plant is operating at power with the following reactor vessel level control alignment:

- RFC-LC-83, MASTER LEVEL CONTROLLER in balance
- RFC-MA-84A, FW CONTROLLER STATION A in balance
- RFC-MA-84B, FW CONTROLLER STATION B in balance
- Feedwater flow is approximately 9.6x10⁶ lbm/hr.
- Steam flow is approximately 9.6x10⁶ lbm/hr.
- RPV water level is +35 inches.
- ALL listed controllers have been nulled.

The Master Controller <u>OUTPUT</u> slowly fails downscale. The operator places the "A" and "B" RFP controller mode switches in MANUAL when RPV water level lowers to +27 inches.

Assuming NO additional action is taken by the operator, what is the response of Feedwater Flow and RPV water level?

Feedwater flow

a.	rises to 9.6x10 ⁶ lt	om/hr. Level rises	to +42 inches.
----	---------------------------------	--------------------	----------------

- b. rises to 9.6×10^6 lbm/hr. Level remains at +27 inches.
- c. rises above 9.6×10^6 lbm/hr. Level rises to +35 inches.
- d. remains below 9.6×10^6 lbm/hr. Level continues to lower.

Answer 33

b. rises to 9.6×10^6 lbm/hr. Level remains at +27 inches.

REFERENCE: 2.2.28; Attachment 1, Sections 1.2.5, 1.2.6 and 2.4RXLVL

Foils:

- a. Level will not rise.
- c. Feed flow will not rise above 9.6x10⁶ lbm/hr. Level will not rise. No recirc runback occurs.
- d. Feed flow rises to 9.6×10^6 lbm/hr. Level does not lower.

Bank Difficulty 3 Cognitive Level 3

Enabling Objectives

COR0023202001070A Given a RVLC system control manipulation, predict and explain the changes in the following parameters: RPV water level

COR0023202001070B Given a RVLC system control manipulation, predict and explain the changes in the following parameters: RFP Speed/Feed Flow

Skills

259002.A1.01 Ability to predict and/or monitor changes in parameters associated with operating the REACTOR WATER LEVEL CONTROL SYSTEM controls including: (CFR: 41.5 / 45.5) Reactor water level (3.8/3.8)

Question 34 1644 (1 point(s))

What effect (if any) will a high intake radiation have on the Main Control Room HVAC system?

- a. There is no automatic response to this signal.
- b. The system suction isolates and air is recirculated through the normal flowpath.
- c. The system lineup shifts to process all outside air through the emergency filter train.
- d. The system suction isolates and air is recirculated through the emergency filter train.

Answer 34

a. There is no automatic response to this signal.

(System mod removed intake monitor from initiation logic and replace it with Group 6 signal)

REFERENCES: COR0010802

Foils:

- b. The system does not respond to high intake radiation anymore.
- c. The system does not respond to high intake radiation anymore.
- d. The system does not respond to high intake radiation anymore.

Modified Difficulty 2 Cognitive Level 1

Enabling Objectives

COR0010802001120A Describe the control Room HVAC design features and interlocks that provide for the following: Control room HVAC reconfigurations

COR0010802001140A Briefly describe the following concepts as they apply to Control Room HVAC: Airborne contamination (e.g., radiological,toxic gas, smoke) control

COR0010802001200A Predict the consequences of the following items on the Control Room HVAC: Initiation/reconfiguration

Skills

295038.EA1.07 Ability to operate and/or monitor the following as they apply to HIGH OFF-SITE RELEASE RATE: (CFR: 41.7 / 45.6) Control room ventilation: Plant-Specific. (3.6/3.8)

Question 35 16512 (1 point(s))

The plant is at 100% power. Reactor Building Ventilation is operating as follows:

- EF-1-RB, Exhaust Fan, running
- SF-R-1A-B, Supply Fan, running
- BF-R-1B, Exhaust Booster Fan, running
- ALL other fans are selected to STBY
- HV-DPIC-835A is in AUTO with reactor building pressure is -0.30" wg

How will the Reactor Building Ventilation system respond if the reactor building pressure degrades to - 0.25" wg?

- a. Supply Fan SF-R-1A-A starts and the supply fan vortex dampers position to correct the reactor building pressure.
- b. Exhaust Fan EF-1-RA starts and the exhaust fan vortex dampers position to correct the reactor building pressure.
- c. Operating fan lineup does NOT change. Supply fan vortex dampers position to correct the reactor building pressure.
- d. Operating fan lineup does NOT change. Exhaust fan vortex dampers position to correct the reactor building pressure.

Answer 35

d. Operating fan lineup does NOT change. Exhaust fan vortex dampers position to correct the reactor building pressure.

Exhaust fan, exhaust booster fan, and supply fan will auto start when the control switch is in standby and Reactor Building pressure is below -0.15" wg and above -0.35" wg. This threshold has not been reached. The exhaust fan vortex dampers will position to improve the reactor building pressure.

REFERENCE: 2.2.47

Foils:

a. No fans auto start. Exhaust dampers reposition.

- b. No fans auto start.
- c. Exhaust dampers reposition.

New Difficulty 2 Cognitive Level 2

Enabling Objectives

COR0010802001110C Describe the HVAC design features and interlocks that provide for the following: Automatic starting and stopping of fans

COR0010802001130B Describe the control Room HVAC design features and interlocks that provide for the following: Differential pressure control

COR0010802001140B Briefly describe the following concepts as they apply to Control Room HVAC: Differential pressure control

Skills

295035.EA1.01 Ability to operate and/or monitor the following as they apply to SECONDARY CONTAINMENT HIGH DIFFERENTIAL PRESSURE: (CFR: 41.7 / 45.6) Secondary containment ventilation system (3.6/3.6)
Question 36 16496 (1 point(s))

The plant is at 100% power with the following conditions:

- Standby Gas Treatment (SGT) Exhaust Train A is being placed in service to support a surveillance test
- The control switch for SGT Fan 1F is in STBY
- The control switch for SGT Fan 1E is placed in RUN

If SGT-AO-251 (SGT Train A Outlet Valve) remains closed, how will SGT train B respond over the next one (1) minute?

"B" Standby Gas Treatment fan 1F...

- a. remains off. SGT-AO-252 (SGT Train B Outlet Valve) opens.
- b. starts on low flow. SGT-AO-252 (SGT Train B Outlet Valve) opens.
- c. remains off. SGT-AO-252 (SGT Train B Outlet Valve) remains closed.
- d. starts on low flow. SGT-AO-252 (SGT Train B Outlet Valve) remains closed.

Answer 36

c. remains off. SGT-AO-252 (SGT Train B Outlet Valve) remains closed.

Low flow in a train will cause the standby fan to start if it is in STBY, the operating train flow is <800 scfm, and a group 6 isolation signal is present or sealed in. There is no group 6 isolation signal for the conditions presented. No conditions will develop on the operating train to cause it to trip within 1 minute.

REFERENCE: 2.2.73

Foils:

- a. SGT-AO-252 (SGT Train B Outlet Valve) does not open.
- b. SGT B remains off.
- d. SGT B remains off.

Modified Difficulty 2 Coginitive Level 2

Enabling Objectives

COR0022802001080A Describe the Standby Gas Treatment design features and/or interlocks that provide for the following: Automatic system initiation

COR0022802001090B Briefly describe the following concepts as they apply to the Standby Gas Treatment system: Air operated valves operations

Skills

261000.K4.01 Knowledge of STANDBY GAS TREATMENT SYSTEM design feature (s) and/or interlocks which provide for the following: (CFR: 41.7) Automatic system initiation (3.7/3.8)

Question 37 1494 (1 point(s))

The turbine building HVAC was operating normally with all fan control switches in AUTO. A sudden atmospheric disturbance caused turbine building pressure to go 1" positive. The HVAC dP controller returned pressure to normal in 25 seconds.

What is the status of the turbine building supply and exhaust fans?

All supply fans . . .

- a. **AND** exhaust fans are tripped.
- b. **AND** exhaust fans remain running.
- c. are tripped, all exhaust fans remain running.
- d. remain running, all exhaust fans are tripped.

Answer 37

b. **AND** exhaust fans remain running.

REFERENCE: STCOR001-08-01, page 24, section II.F.3, Proc. 2.2.49, step 2.3 & 2.9

Foils:

- a. 45 second delay on trip for excessive dp
- c. 45 second delay on trip for excessive dp
- d. 45 second delay on trip for excessive dp

New Difficulty 2 Cognitive level: 1

Enabling Objectives

COR0010802001220F Given plant conditions, determine if the following should occur: Turbine Building Supply Fan trip

Skills

288000.A3.01 Ability to monitor automatic operations of the PLANT VENTILATION SYSTEMS including: (CFR: 41.7 / 45.7) Isolation/initiation signals (3.8/3.8)

Question 38 16489 (1 point(s))

With the plant at full power, the following Reactor Building vent exhaust plenum radiation monitor readings exist:

- RMP-RM-452A: 14 mrem/hr
- RMP-RM-452B: 12 mrem/hr
- RMP-RM-452C: 8 mrem/hr
- RMP-RM-452D: 7 mrem/hr

What is the effect on the Secondary Containment and why? (Note: Use *actual* setpoints in your evaluation.)

- a. NOT affected because only the *DIVISION I* logic has actuated.
- b. NOT affected because only the *DIVISION II* logic has actuated.
- c. Isolates but only "A" SGT initiates. There is NO start signal from one Division.
- d. Isolates and both SGT systems initiate. There is a start signal from both Divisions.

Answer 38

d. Isolates and both SGT systems initiate. There is a start signal from both Divisions.

Justification: If RMP-RM-452A or C <u>AND</u> RMP-RM-452B or D exceed 10 mrem/hr, Reactor Building isolates, and the SGT system starts.

REFERENCE: 2.2.73; 1.3.1.2 (logic), 2.3_9-4-1; Set Points

Foils:

- a: Both Divisions are actuated. The reactor building will isolate and SGT starts.
- b: Both Divisions are actuated. The reactor building will isolate and SGT starts.
- d: Both Divisions are actuated. The reactor building will isolate and both trains of SGT will start.

Bank Difficulty 2

Cognitive Level 2

Enabling Objectives

COR0022802001080A Describe the Standby Gas Treatment design features and/or interlocks that provide for the following: Automatic system initiation

COR0022802001130A Given plant conditions, determine if any of the following should occur: SGT automatic initiation

Skills

290001.A2.03 Ability to (a) predict the impacts of the following on the SECONDARY CONTAINMENT; and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal...: (CFR: 41.5 / 45.6) High area radiation (3.4/3.6

Question 39 1112 (1 point(s))

DG-1 is paralleled to 4160V Bus 1F for testing. The operator is in the process of adjusting load and voltage when the Governor Control switch sticks in the LOWER position.

If NO operator action is taken, what will be the Diesel Generator response to this condition?

DG output frequency will ...

- a. lower **AND** then the diesel will trip on overcurrent.
- b. lower **AND** then the diesel will trip on reverse power.
- c. remain constant **BUT** the diesel will trip on overcurrent.
- d. remain constant **BUT** the diesel will trip on reverse power.

Answer 39

d. remain constant **BUT** the diesel will trip on reverse power.

EXPLANATION OF ANSWER: Due to the diesel being paralleled the frequency will remain constant but load will be removed causing a reverse power trip which will trip the diesel generator lockout. a,b. Frequency will remain constant. c. Lowering on the governor control will remove load not increase load.

REFERENCES: STCOR002-08-02, page 34, section III.B.1, IV.4.C, rev. 10. PR 2.3.2.8, page 4, section C-1/A-4, rev. 20. PR 2.2.20, page 13, 8, section 4.4, 2.4.3.6, rev. 45.

Foils:

- a. frequency will not lower and diesel will not trip on overcurrent.
- b. frequency will not lower.
- c. diesel will not trip on overcurrent.

Bank Difficulty 2 Coginitive Level 3

Enabling Objectives

COR0020802001090A Describe the Diesel Generator design feature(s) and/or interlock(s) that provide for the following: Diesel Generator Trips (Normal)

COR0020802001090C Describe the Diesel Generator design feature(s) and/or interlock(s) that provide for the following: Speed Droop Control

COR0020802001130A Predict the consequences of the following items on the Diesel Generator: Parallel Operation of Diesel Generator

Skills

264000.K3.02 Knowledge of the effect that a loss or malfunction of the EMERGENCY GENERATORS (DIESEL/JET) will have on following: (CFR: 41.7 / 45.4) A.C. electrical distribution (3.9/4.0)

Question 40 16439 (1 point(s))

The plant is at 100% power near the end of cycle with all control rods fully withdrawn. When performing an APRM functional test (1/2 scram), the scram inlet valve (CRD-AOV-126) for control rod 30-31 opens.

What is the effect (if any) on reactor power and the Scram Discharge Volume (SDV) over the next five (5) minutes and why?

- a. The reactor will scram due to high Scram Discharge Volume level.
- b. Reactor power and SDV level are unaffected because **NO** control rod motion occurs.
- c. The control rod inserts causing reactor power to lower, but power operation continues as SDV level is unaffected.
- d. The control rod inserts causing reactor power to lower, but power operation continues and SDV level rises but remains below the scram setpoint.

Answer 40

c. The control rod inserts causing reactor power to lower, but power operation continues as SDV level is unaffected.

Control rod inserts. SDV level is unaffected because the over piston area volume is evacuated to the reactor vessel past the CRDM seals.

REFERENCE: 2.4CRD direct troubleshooting per 2.2.8. 2.2.8; section 25, Attachment 2 - 1.2.4.2

Foils:

- a. A reactor scram will not occur. The SDV level will not change.
- b. The control rod will insert into the core. A single control rod inserting will reduce reactor power.
- d. No leakage will occur into the SDV.

Bank Difficulty 3 Cognitive Level 2

Enabling Objectives

COR0020402001110H Predict the consequences a malfunction of the following would have on the CRDH systems: Leaking scram valves.

Skills

201003.A1.01 Ability to predict and/or monitor changes in parameters associated with operating the CONTROL ROD AND DRIVE MECHANISM controls including: (CFR: 41.5 / 45.5) Reactor power (3.7/3.8)

Question 41 16414 (1 point(s))

The plant is operating at 80% power. The CAM alarms in the Off-Gas Building and the following alarms are received:

- B-3/A-3, CONDENSER AIR REMOVAL ISOLATION
- B-3/B-3, CONDENSER AIR REMOVAL HIGH TEMP
- B-3/B-4, CONDENSER AIR REMOVAL HIGH PRESSURE
- K-1/A-4, OFFGAS FILTER HIGH D/P

What event has occurred?

- a. High Off-Gas activity.
- b. Fire in the Off-Gas Building.
- c. Explosion in the Off-Gas System.
- d. Trip of the Off-Gas Dilution Flow Fans.

Answer 41

- c. Explosion in the Off-Gas System.
- Justification: These alarms are consistent with an explosion in the off gas system and the CAM alarm for the hi radiation in the off gas building.
- REFERENCE: 2.40G 5.0; 2.3_B-3/A-3/B-3/B-4 section 3.2

Foils:

- a. This would cause the isolation but not the high temperature and pressure.
- b. This would not cause the isolation or the high pressure or the CAM alarm.
- d. This would not cause the isolation or high temperature or the CAM alarm.

Bank Difficulty 3 Cognitive Level 2

Enabling Objectives

COR0011602001100G Predict the consequences of the following items on the Off Gas system: Condenser Air Removal failure

SKL012411600A030D Given plant conditions, predict changes in the following Off-Gas system components/parameters: System flows.

SKL012411600A030E Given plant conditions, predict changes in the following Off-Gas system components/parameters: Process radiation monitoring indications.

Skills

271000.A3.05 Ability to monitor automatic operations of the OFFGAS SYSTEM including: (CFR: 41.7 / 45.7) System indicating lights and alarms (2.9/2.9)

Question 42 17884 (1 point(s))

The station was in a startup at 57% power when main condenser vacuum rapidly degraded. When vacuum degraded to 22.5" Hg, the CRS directed a manual reactor scram be inserted and then the main turbine be tripped.

Why was the reactor scrammed *before* the main turbine is tripped under these conditions?

To prevent ...

- a. forcing an automatic protective action.
- b. a rapid depressurization of a critical reactor due to bypass valves opening fully.
- c. the need to close the MSIVs which would add heat to the primary containment.
- d. reducing MCPR below the operating limit due to the reduction in feedwater heating.

Answer 42

a. forcing an automatic protective action.

Reference 2.4VAC, Operations strategy (2.0.3, 2.0.1.2)

Foils:

- b. this is not a basis for the scram.
- c. The MSIVs still may need to be closed.
- d. MCPR is not the basis for the scram.

NEW Difficulty 3 Cognitive Level 1

Enabling Objectives

INT0320132K0K0100 Given plant condition(s), determine from memory if a Main Turbine trip is required due to the event(s).

INT032010300C010G Discuss the following as described in conduct of Operations Procedure 2.0.3, Conduct of Operations: Operations Policy During Transient Operations

INT0320132J0J0100 Given plant condition(s), determine from memory if a manual reactor scram or an emergency shutdown from power is required due to the event(s).

Skills

295002.AK3.01 Knowledge of the reasons for the following responses as they apply to LOSS OF MAIN CONDENSER VACUUM: (CFR: 41.5 / 45.6) Reactor SCRAM: Plant-Specific (3.7/3.8)

Question 43 17888 (1 point(s))

The plant was operating at 100% power when 4KV bus 1F de-energized. The reactor is scrammed per the alarm card. After the immediate scram actions were complete, the Startup Transformer tripped. The following conditions exist:

- Groups 2, 3 and 6 isolations occurred
- HPCI and RCIC did not automatically start
- 87 control rods are between notch 12 and notch 36
- APRM downscales are in

What action(s) (if any) are required and why?

- a. Enter EOP 1A, "RPV Control". Do NOT enter 5.3EMPWR "Emergency Power" or 2.4CRD
 "CRD Trouble." Applicable Abnormal/Emergency procedures are NOT entered if EOP entry IS required.
- b. Enter 5.3EMPWR "Emergency Power", 2.4CRD "CRD Trouble" **AND** EOP 1A, "RPV Control." Do **NOT** execute any Abnormal procedure steps if they conflict with any steps in the EOPs.
- c. Enter 5.3EMPWR "Emergency Power" and 2.4CRD "CRD Trouble". Do **NOT** enter EOP 1A, "RPV Control" as EOP entry is **NOT** required if the specific condition is adequately addressed by the applicable Abnormal/Emergency procedure.
- d. Enter EOP 1A, "RPV Control", 5.3EMPWR "Emergency Power" and 2.4CRD "CRD Trouble". EOPs and applicable Abnormal/Emergency procedures must be entered and ALL Abnormal and EOP procedure steps must be completed.

Answer 43

b. Enter 5.3EMPWR "Emergency Power", 2.4CRD "CRD Trouble" **AND** EOP 1A, "RPV Control." Do **NOT** execute any Abnormal procedure steps if they conflict with any steps in the EOPs.

REFERENCE: 2.0.1.2 step 2.7. 0.1, 5.8 step 3.2.1, 3.2.6

Foils:

- a. Applicable Abnormal/Emergency procedures must be entered.
- c. Applicable EOPs must be entered
- d. ALL the AOP and EOP steps do NOT have to be performed if they are in conflict the EOPS take precedent.

K/A 295037 (SCRAM Condition Present and Reactor Power Above APRM Downscale or Unknown) 2.4.8

New

Cognitive Level: 2 Difficulty: 2

Enabling Objectives

INT032010100E0300 Describe the heirarchy between the Emergency Operating Procedures, Abnormal Procedures, and Emergency Procedures, including which guidance takes precedence.

Skills

2.4.8 Knowledge of how the event-based emergency/abnormal operating procedures are used in conjunction with the symptom-based EOPs. (CFR: 41.10 / 43.5 / 45.13)

Question 44 4243 (1 point(s))

A weekly surveillance test was completed at 1300 on Tuesday of last week.

In accordance with procedure 0.26 (Surveillance Program), what is the **LATEST** this test can be scheduled to be completed this week, without exceeding an LCO?

- a. 1300 on Wednesday
- b. 0100 on Thursday
- c. 0700 on Thursday
- d. 1300 on Thursday

Answer 44

c. 0700 on Thursday

A deviaiton of 25% of the weekly surveillance interval is allowed (42 hrs or 1.75 days)

Foils:

- a. 24 hrs
- b. 36 hrsd. 48 hrs
- REFERENCE: PR 0.26 Surveillanve Program Page 10 Section 8.1.5

Bank Difficulty 2 Cognitive Level: 1

Enabling Objectives

INT032010100G010J Discuss the following as described in Administrative Procedure 0.26, Surveillance Program: Surveillance test performance

INT032010100G010M Discuss the following as described in Administrative Procedure 0.26, Surveillance Program: Surveillance Test Frequency

INT032010100G010L Discuss the following as described in Administrative Procedure 0.26, Surveillance Program: Precautions and Limitations

Skills

2.2.12 Knowledge of surveillance procedures. (CFR: 41.10 / 45.13)

Question 45 5131 (1 point(s))

Which one of the following activities can have its concurrent/independent verification waived?

- a. A local control switch must be placed in Auto in a contaminated area as part of a tagout restoration.
- b. A 4160 VAC breaker already verified in test will have a test block and extention arm installed.
- c. A 480 VAC breaker for non-safety equipment will be racked out for a tagout requiring 25 mrem exposure to the performer.
- d. A valve must verified open, requiring 12 mrem exposure to the performer when performing a periodic system component checklist.

Answer 45

d. A valve must verified open, requiring 12 mrem exposure to the performer when performing a periodic system component checklist.

Component checklist item with a dose exposure in excess of 10 mrem.

Reference: 0.31

Foils:

- a. Required by procedure.
- b. Required by procedure.
- c. Not an exception.

Bank Difficulty 3 Cognitive Level 1

Enabling Objectives

SKL00803020010200 Describe the three forms of verification used to satisfy the requirements of the equipment status control program and when each form of verification is required or permissible.

INT032010100H010C Discuss the following as described in Administrative Procedure 0.31, Equipment Status Control: Independent/Concurrent verification

INT032010100H010L Discuss the following as described in Administrative Procedure 0.31, Equipment Status Control: Breaker position verification

Skills

2.1.29 Knowledge of how to conduct and verify valve lineups. (CFR: 41.10 / 45.1 / 45.12)

Question 46 16431 (1 point(s))

Following seven (7) days of vacation, an operator works twelve (12) hours on the first day back on shift and then works an additional four (4) hours of overtime.

Which one of the following describes the MAXIMUM number of hours this operator can work the next day WITHOUT exceeding the CNS working hour limitations?

- a. 4 hours.
- b. 8 hours.
- c. 12 hours.
- d. 16 hours.

Answer 46

b. 8 hours.

The restrictions are 16 hours in any 24-hour period and 24 hours in any 48-hour period. Since the operator worked 16 hours on the first day, then without any extension the operator is restricted to 8 hours on the second day of work.

REFERENCE: 0.12, 4.2.2

Foils:

- a. Can work 8 hours.
- c. Can only work 8 hours without an approved extension.
- d. Can only work 8 hours without an approved extension.

Bank Difficulty 2 Cognitive Level 2

Enabling Objectives

INT032010100F0100 State the working hours limitations and approval requirements associated with Administrative Procedure 0.12, Working Hours Limitations.

INT032010100F0200 Given the previous working hours/days history of an individual, determine if the individual is in compliance with the working hours limitations set forth in Administrative Procedure 0.12, Working Hours Limitations.

Skills

2.1.1 Knowledge of conduct of operations requirements. (CFR: 41.10 / 45.13)

Question 47 5654 (1 point(s))

A LOCA has occurred and the following conditions exist:

- RPV level is -120" and stable on the wide range instruments.
- Attempts at level restoration are in progress, but currently there are no means of injection available.
- Annunciator 9-3-1/A-1 ADS TIMERS ACTUATED is energized.
- RPV pressure is 490 psig and lowering.

What is the basis for inhibiting ADS at this time?

- a. To prevent large amounts of uncontrolled injection into the RPV.
- b. The ADS logic should not have actuated under current plant conditions.
- c. The operator has more information as to when the RPV should be depressurized.
- d. To allow the crew to rapidly depressurize the RPV to the main condenser and prevent adding significant heat to the suppression pool.

Answer 47

c. The operator has more information as to when the RPV should be depressurized.

REFERENCE: INT0080609 EOP basis, PR 2.3.2.22

Foils:

- a. This is a basis for terminating and preventing injection during an ATWS.
- b. These RPV pressure conditions would require ADS.
- d. The existance of adequate core cooling at the time of ADS initiation is not a basis for inhibiting ADS.

Modified Difficulty 3 Cognitive Level 1

Enabling Objectives

INT00806090011200 Given an EOP flowchart 1A, RPV CONTROL step, state the reason for the actions contained in the step.

Skills

2.4.18 Knowledge of the specific bases for EOPs. (CFR: 41.10 / 45.13)

Question 48 5349 (1 point(s))

A Loss of Coolant Accident has occurred with the following conditions:

-	Reactor pressure Indicated Wide Range Reactor water level	470 psig (lowering slowly) -120" (steady)
-	Drywell pressure	5.5 psig (rising slowly)
-	Drywell temperature	350° F (all points) (steady)

What is the status of Wide Range Reactor Level Instrumentation?

Wide Range Reactor Level Instrumentation is ...

- a. accurate **AND** can be used for trending. Actual Reactor level is -120".
- b. **NOT** accurate **BUT** can be used for trending. Actual Reactor level is <u>higher than</u> - 120".
- c. **NOT** accurate **BUT** can be used for trending. Actual Reactor level is <u>lower than</u> - 120".
- d. **NOT** accurate **AND CANNOT** be used for trending.

Answer 48

c. **NOT** accurate **BUT** can be used for trending. Actual Reactor level is <u>lower than</u> - 120".

EXPLANATION OF ANSWER: c. is correct. Indicated WR Level is above the minimum Indicated Level of EOP Graph 15 for 350° F so the instrument can be used for trending purposes. The elevated Drywell temperatures and increased density of RPV water combine to cause indicated level to be erroneously high and actual Reactor level will be lower than -120".

REFERENCES: EOP Graphs 1 & 15, CAUTION 1 INT0080618 INT0080605

Foils:

- a. Indicated level is erroneously high and actual Reactor level will be lower than 120".
- b. Actual Reactor level will be lower than -120".
- d. Indicated WR Level is above the minimum Indicated Level of EOP Graph 15 for 350° F so the instrument can be used for trending purposes.

Provide to Candidate: EOP Graphs 15A, B, C, D & E

Bank Difficulty 4 Cognitive Level 3

Enabling Objectives

INT00806050011000 Given plant conditions and EOP flowchart 1A, RPV CONTROL, determine required actions.

INT00806180010200 For each graph used in the flowcharts, identify the action(s) required if the parameters associated indicate operation in the restricted or prohibited area.

INT00806050011200 Given plant conditions, assess if RPV water level can be determined or not.

Skills

295028.EK1.01 Knowledge of the operational implications of the following concepts as they apply to HIGH DRYWELL TEMPERATURE: CFR: 41.8 to 41.10) Reactor water level measurement (3.5/3.7)

Question 49 5268 (1 point(s))

Given the following conditions:

- A small steam leak has occurred in the Drywell.
- Drywell temperature is 165° F and rising.
- Drywell pressure is 2.6 psig and rising.
- EOP-3A, Primary Containment Control has been entered.

What action is required to reduce Drywell temperature for these conditions?

- a. Vent the Drywell.
- b. Initiate Drywell sprays.
- c. Emergency Depressurize the RPV.
- d. Operate all available Drywell Cooling.

Answer 49

d. Operate all available Drywell Cooling.

EXPLANATION OF ANSWER: This is the first action specified by the Drywell Temperature leg of EOP-3A.

REFERENCE: EOP-3A

Foils:

- a. With a LOCA inside containment, venting the Drywell is not allowed.
- b. Drywell Sprays are not permitted by the Drywell Spray Initiation Limit Graph.
- c. Emergency Depressurization is not yet required.

Bank Difficulty 2 Cognitive Level 2

Provide to Candidate: EOP 3A with entry conditions and CAUTIONS Removed.

Enabling Objectives

INT00806130011100 Given plant conditions and EOP Flowchart 3A, PRIMARY CONTAINMENT CONTROL, determine required actions.

INT00806130101000 Identify any EOP support procedures referenced in Flowchart 3A and apply any associated special operating instructions or cautions.

Skills

295012.AK2.02 Knowledge of the interrelations between HIGH DRYWELL TEMPERATURE and the following: (CFR: 41.7 / 45.8) Drywell cooling. (3.6/3.7)

Question 50 17856 (1 point(s))

The plant is at 90% when a RCIC steam line break occurs. Initial event conditions were:

- RCIC cannot be isolated
- RCIC temperatures in the NE Quad are 214°F and rising
- RCIC Room radiation levels are 300 mr/hr and rising
- A reactor scram is inserted and all control rods fully insert

A high reactor building ventilation exhaust radiation level had isolated reactor building ventilation, but the condition has cleared and annunciator 9-4-1/E-4 RX BLDG VENT HI HI RAD reset.

What is the required EOP response to this annunciator clearing and the bases for the response?

- a. Restart Reactor Bldg. HVAC to ensure all radioactive discharges are elevated.
- b. Restart Reactor Bldg. HVAC to help return secondary containment parameters to normal.
- c. Ensure Reactor Bldg. HVAC remains isolated because EOP 1A requires a group 6 isolation.
- d. Ensure Reactor Bldg. HVAC remains isolated until RP ensures normal radiation levels to minimize the spread of contamination.

Answer 50

b. Restart Reactor Bldg. HVAC to help return secondary containment parameters to normal.

REFERENCE: EOP 5A, PSTG/SATG, 2.3_9-4-1

Foils:

- a. This is <u>not</u> a bases for restarting Reactor Bldg. HVAC and Rx Bldg ventilation releases are NOT considered elevated.
- c. The Isolation would only occur on low level (3) and if so, it should be bypassed.
- d. Per 2.1.22 if a Group 6 Isol had occurred, it should not be reset until Chem. and HP have ensured normal rad levels, but EOPs take precedence.

Bank Difficulty 3 Cognitive Level 2

Provide to Candidate: EOP 5A with entry conditions and Cautions removed.

Enabling Objectives

INT00806170010600 Given plant conditions and EOP flowchart 5A, SECONDARY CONTAINMENT CONTROL and RADIOACTIVITY RELEASE CONTROL, determine required actions.

INT00806170010700 Given plant conditions and EOP flowchart 5A, SECONDARY CONTAINMENT CONTROL and RADIOACTIVITY RELEASE CONTROL, state the reasons for the actions contained in the steps.

Skills

295034.EK2.04 Knowledge of the interrelations between SECONDARY CONTAINMENT VENTILATION HIGH RADIATION and the following: (CFR: 41.7 / 45.8) Secondary containment ventilation. (3.9/3.9)

Question 51 17157 (1 point(s))

The plant is operating at 100% power with "B" Narrow Range level indicator selected for level control. The following conditions occur:

- "A" and "C" Narrow range are 5" and lowering
- "B" Narrow range is 40" and rising
- Steam Nozzle is downscale

30 seconds later,

- "A" & "C" Narrow range are downscale
- "B" Narrow range is upscale
- "A" wide range is -10"
- "B" wide range is upscale
- ALL -42" and -113" alarms are clear
- Reactor Pressure 995 psi
- Drywell Temperature 125 °F

At the 30 second data time, can RPV water level be determined, and if so, what is actual RPV water level?

RPV water level ______ be determined. Actual RPV water level is ______.

- a. CANNOT, unknown
- b. CAN, above +60"
- c. CAN, -10"
- d. CAN, below -42" and above -113"

Answer 51

c. CAN, -10"

The conditions provided are indicative of a "B" side reference leg failure. There are multiple indications that RPV water level is above TAF.

REFERENCE: INT0080605, Attachment 2

Foils:

- a. RPV water level CAN be determined
- b. RPV water level is -10"
- d. RPV water level is -10"

Bank Difficulty 4 Cognitive Level 3

Enabling Objectives

or not.
(

INT00806050011200 Given plant conditions, assess if RPV water level can be determined or not.

Skills

295009.AA2.01 Ability to determine and/or interpret the following as they apply to LOW REACTOR WATER LEVEL: (CFR: 41.10 / 43.5 / 45.13) Reactor water level. (4.2/4.2)

Question 52 5920 (1 point(s))

Which of the following can be used to verify that the reactor will remain shut down under all conditions without boron *without* consulting the Reactor Engineer?

- a. All control rods are inserted to or beyond notch 04.
- b. One (1) control rod is at position 48, all other control rods are full in.
- c. Two (2) control rods are at position 12, all other control rods are full in.
- d. The withdrawn control rods are separated by at least two control rod cells in all directions.

Answer 52

b. One (1) control rod is at position 48, all other control rods are full in.

Reference: INT0080605

Foils:

- a. Must be inserted to or beyond notch 02.
- c. Shutdown margin may not be met. Not a condition specified to satisfy requirements.
- d. Shutdown margin may not be met. Not a condition specified to satisfy requirements.

Bank Difficulty: 2 Cognitive level: 1

Enabling Objectives

INT00806050010400 State the criteria used to determine that the reactor will remain shutdown under all conditions without boron injection.

Skills

295015.AK1.01 Knowledge of the operational implications of the following concepts as they apply to INCOMPLETE SCRAM: (CFR: 41.8 to 41.10) Shutdown margin. (3.6*/3.9*)

Question 53 16495 (1 point(s))

During a LOCA concurrent with a Loss of Offsite power, the following conditions exist:

- Drywell Pressure is 60 psig and slowly rising
- Torus Pressure is 58 psig and slowly rising
- PC water Level is 25 feet and stable

Which one of the following methods is required to *initially* vent the primary containment for these conditions?

- a. Vent the Torus using the hard pipe vent.
- b. Vent the Drywell using the 24" ductwork.
- c. Vent the Torus using the 1 and 2 inch bypass valves through SGT.
- d. Vent the Drywell using the 1 and 2 inch bypass valves through SGT.

Answer 53

- c. Vent the Torus using the 1 and 2 inch bypass valves through SGT.
- Justification: Per EOP-3A, Primary Containment Control, if Suppression Pool level is < 28.5', then vent the torus using the Torus Vent path and SGT.

Reference: EOP-3A, 5.8.18

Foils:

- a. Hard pipe venting is NOT required.
- b. The torus should be vented first, use of the 24" ductwork is NOT required.
- d. The torus should be vented first.

Bank Difficulty: 3 Cognitive level: 2

Enabling Objectives

INT00806130010500 Explain why the torus vent path is preferred over the drywell vent path.

INT00806130101000 Identify any EOP support procedures referenced in Flowchart 3A and apply any associated special operating instructions or cautions.

INT0080613001040A State the basis for primary containment control actions as they apply to the following: Specific setpoints

INT0080613001040B State the basis for primary containment control actions as they apply to the following: Primary Containment Control Systems

INT00806130011200 Given plant conditions and EOP flowchart 3A, PRIMARY CONTAINMENT CONTROL, state the reasons for the actions contained in the steps.

Skills

295010.AA1.05 Ability to operate and/or monitor the following as they apply to HIGH DRYWELL PRESSURE: (CFR: 41.7 / 45.6) Drywell/suppression vent and purge (3.1/3.4)
Question 54 16481 (1 point(s))

Given the following conditions:

- The plant has experienced a LOCA with a loss of ALL injection.
- All Control Rods have inserted.
- RPV pressure is being controlled with SRVs.
- RPV water level has lowered to -35 inches (Corrected Fuel Zone).

What is the status of core cooling?

Adequate core cooling exists . . .

- a. at this RPV water level.
- b. only when the SRVs are closed.
- c. only if RPV water level is raised 10 inches.
- d. only if injection is established at this water level.

Answer 54

a. at this RPV water level.

At levels above -40 inches with no injection there is sufficient steam flow to provide adequate core cooling.

REFERENCE: EPGS/SATGS, INT008-06-09

Foils:

- b. Just establishing injection will not assure adequate core cooling, level must also be restored to > -25".
- c. Adequate core cooling can be established by establishing injection and restoring level.
- d. RPV level does not have to be raised to -25".

KA 295031 Bank Cognitive Level: 3 Difficulty: 3

Provide to Candidate: EOP 1A with entry conditions and Cautions removed.

Enabling Objectives

INT00806070010800 Given plant conditions and EOP flowchart 2A, EMERGENCY RPV DEPRESSURIZATION/STEAM COOLING, state the reasons for the actions contained in the steps.

INT00806090010100 Describe the three mechanisms specified in the EOPs to assure adequate core cooling including the RPV water level band required and which is the preferred method.

Skills

295031.EA2.04 Ability to determine and/or interpret the following as they apply to REACTOR LOW WATER LEVEL: (CFR: 41.10 / 43.5 / 45.13) Adequate core cooling (4.6*/4.8*)

Question 55 17900 (1 point(s))

Why is entry into EOPs required if the Reactor Building dP cannot be maintained negative?

This reactor building (RB) dP is an indication that ...

- a. an uncontrolled, unmonitored release of radioactivity to the environment could exist.
- b. the continued operability of equipment needed to carry out EOP actions may be compromised.
- c. radioactivity is being released to the environment when the ventilation system should have automatically isolated.
- d. an indication that water from a primary system (or from a primary to secondary system leak) may be discharging into the secondary containment.

Answer 55

a. an uncontrolled, unmonitored release of radioactivity to the environment could exist.

REFERENCE: INT0080617

FOILS:

- b. This is the basis for the high temperature entry.
- c. This is the basis for the high Rx bldg exhaust radiation levle.
- d. This is the basis for the entry on Max Normal Water Level.

New Difficulty 3 Cognitive Level 1

Enabling Objectives

INT00806170010100 List the entry conditions to Flowchart 5A (including the radioactivity release path) and briefly explain each.

Skills

2.3.11 Ability to control radiation releases. (CFR: 45.9 / 45.10)

Question 56 4139 (1 point(s))

What is the basis for stopping and preventing HPCI when suppression pool level lowers to 11 feet, irrespective of adequate core cooling?

- a. Prevent HPCI pump damage from low NPSH.
- b. Prevent uncovering the downcomers in the torus.
- c. Prevent containment pressurization from HPCI exhaust.
- d. Prevent loss of the ultimate heat sink by removing too much water.

Answer 56

c. Prevent containment pressurization from HPCI exhaust.

REFERENCE: EOP-3A, INT0080613

Foils:

- a. HPCI protected for NPSH with low suction pressure trip.
- b. This is the HCLL curve flat area at 9.6'.
- d. Other level limits protect this 9.6' for downcomers, 6' for SRVs and HCTL and HCLL.

Bank Difficulty 2 Cognitive Level 1

Enabling Objectives

INT00806130010900 Explain why HPCI but not RCIC must be secured at a primary containment water level of 11 feet.

Skills

295030.EK3.02 Knowledge of the reasons for the following responses as they apply to LOW SUPPRESSION POOL WATER LEVEL: (CFR: 41.5 / 45.6) HPCI operation: Plant-Specific. (3.5/3.7)

Question 57 17896 (1 point(s))

Why is the RPV Emergency Depressurized if Pressure Suppression Pressure (Graph 10) is exceeded?

- a. Failure of primary containment may occur if a primary system rupture develops.
- b. Failure of primary containment may occur if drywell sprays are initiated.
- c. Failure of SRV Tailpipes may occur due to steam bypassing the suppression pool.
- d. Failure of SRV Tailpipes may occur due to inadequate differential pressure across the balancing disc.

Answer 57

a. Failure of primary containment may occur if a primary system rupture develops.

REFERENCE: INT0080618, PSTG

Foils:

- b. PSP is not based on drywell spray restricitons (DWSIL is).
- c. SRVTPLL is not based on steam bypassing the suppression pool.
- d. SRVTPLL is not based on dp on balancing disc (PCPL is).

Bank Difficulty: 3 Cognitive level: 1

Enabling Objectives

INT00806130011200 Given plant conditions and EOP flowchart 3A, PRIMARY CONTAINMENT CONTROL, state the reasons for the actions contained in the steps.

INT0080613001040C State the basis for primary containment control actions as they apply to the following: Graphs reference on Flowchart 3A

INT00806180010200 For each graph used in the flowcharts, identify the action(s) required if the parameters associated indicate operation in the restricted or prohibited area.

Skills

295024.EK3.04 Knowledge of the reasons for the following responses as they apply to HIGH DRYWELL PRESSURE: (CFR: 41.5 / 45.6) ?Emergency depressurization (3.7/4.1)

Question 58 16482 (1 point(s))

Following a control room evacuation due to toxic gas in the control room, operations personnel are at the stations required by the associated procedure.

Who verifies RPV level and RPV pressure?

- a. The Control Room Supervisor.
- b. The Reactor Building Station Operator.
- c. The Control Building/Critical Switchgear Operator.
- d. The Turbine Building Switchgear A and B Operators.

Answer 58

- a. The Control Room Supervisor.
- Justification: Verified at the ASD Panel, which is manned by the SS and CRS.

REFERENCE: 5.1ASD

Foils:

- b. Operates SW Valve
- c. Checks Critical Buses and isolates RCIC
- d. Determines status of Non-critical 4 KV Buses

Bank Difficulty 2 Cognitive Level 1

Enabling Objectives

OTH01592020010600 Given a standard set of references available in the Control Room, be able to perform the steps necessary to shutdown the reactor from outside the control room as the ASD room operator.

Skills

295016.AA1.06 Ability to operate and/or monitor the following as they apply to CONTROL ROOM ABANDONMENT: (CFR: 41.7 / 45.6) Reactor water level. (4.0/4.1)

Question 59 17858 (1 point(s))

The plant is at 60% power for a rod sequence change.

The RO has just withdrawn control rod 22-19 to notch 24. After the rod control movement switch is released and the SETTLE light turns off, the RO observes control rods 22-19 slowly moving inward. No other control rods are moving.

The following CRD parameters exist:

- CRD Drive Water D/P 350 psid (pegged high)
- CRD Cooling Water flow 60 gpm (pegged high)

What action is required?

- a. Scram the reactor.
- b. Using EMERGENCY IN, fully insert rod 22-19.
- c. Momentarily place the rod movement control switch to WITHDRAW.
- d. Using CRD-MO-20, DRIVE PRESSURE CONT VALVE, reduce drive water differential pressure.

Answer 59

b. Using EMERGENCY IN, fully insert rod 22-19.

REFERENCE: 2.4CRD

Foils:

- a. The reactor would be scramed if two or more rods were drifting in, not for a single rod.
- c. This may temporarily stop the rod movement, but the rod must be driven in.
- d. Drive water D/P is high but the action required is to insert the control rod, then diagnose the cause of the rod drift.

Modified Difficulty 3 Cognitive Level 2 **Enabling Objectives**

INT0320122I0I0100 Given plant condition(s), determine from memory if a manual reactor scram or an emergency shutdown from power is required due to the event(s).

INT0320122J0J0100 Given plant condition(s), and the applicable Abnormal/Emergency Procedure, determine the correct subsequent actions required to mitigate the event(s).

Skills

201001.A2.12 Ability to (a) predict the impacts of the following on the CONTROL ROD DRIVE HYDRAULIC SYSTEM; and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those ...: (CFR: 41.5/45.6) High cooling (2.8/2.9)

Question 60 16490 (1 point(s))

The reactor has been shutdown for 18 hours and is currently in Cold Shutdown (MODE 4). A cooldown is in progress with reactor coolant temperature at 162°F. RHR Loop "A" is in Shutdown Cooling with both reactor recirculation pumps tripped. Subsequently, a Group 2 isolation signal occurs and RHR CANNOT be restarted.

Where is RPV water level required to be maintained for the current conditions and why?

- a. Above +48 inches on the narrow range RPV level instruments to promote natural circulation.
- b. At 0.0 inches on the wide range RPV level instruments to support alternate heat removal using RWCU.
- c. Flooded (solid) on the shutdown range RPV level instruments to support alternate heat removal using the SRVs.
- d. Between +27.5 inches and +42.5 inches on the narrow range RPV level instruments to minimize thermal stratification in the reactor pressure vessel.

Answer 60

a. Above +48 inches on the narrow range RPV level instruments to promote natural circulation.

REFERENCE:

2.4SDC; 4.9, and attachment 2 (Step 4.4 to step 4.9 to Attachment 2) 2.1.4 precaution 2.9

Foils:

- b. Water level is not high enough to support this method of heat removal
- c. Not an approved method of heat removal under these conditions.
- d. Circulation is needed to minimize thermal stratification.

Bank Difficulty 2 Cognitive Level 2

Enabling Objectives

INT032010400B0400 Discuss cautions and notes associated with Procedure 2.1.4, Normal Shutdown.

INT0320126Q0Q0100 Given plant condition(s), and the applicable Abnormal/Emergency Procedure, determine the correct subsequent actions required to mitigate the event(s).

Skills

295021.AK3.05 Knowledge of the reasons for the following responses as they apply to LOSS OF SHUTDOWN COOLING: (CFR: 41.5 / 45.6) Establishing alternate heat removal flow paths (3.6/3.8)

Question 61 16468 (1 point(s))

The unit is operating at 100% power when the following alarms are energized:

- M-1/A-1, REC SYSTEM LOW PRESSURE
- M-1/A-3, REC SURGE TANK LOW LEVEL

Fifty (50) seconds after receipt of the alarms, the appropriate immediate operator actions have been completed. REC pressure is 56 psig and lowering.

What action(s) is/are now required?

a. Trip ALL Drywell FCUs.

- b. Isolate REC to the Augmented Radwaste System.
- c. Manually scram the reactor and shutdown ALL REC Pumps.
- d. Perform rapid power reduction per 2.1.10 to 35 Mlbm/hr core flow.

Answer 61

- c. Manually scram the reactor and shutdown ALL REC Pumps.
- Justification: These alarms indicate a break in the REC piping that will exceed makeup capacity and result in a loss of ability to cool the recirc pumps and reactor auxiliary equipment. The system must be shutdown, the reactor scrammed, and then limited cooling may be accomplished with one pump.

REFERENCE: 5.2REC 4.1, 4.7 Attachment 2, Step 1.1

Foils:

- a. There is no requirement to secure the FCUs.
- b. This valve automatically isolates when REC pressure falls to 60.5 psig for 40 seconds which was satisfied based on the alarm condition present for 50 seconds.
- d. This would be required by 2.4PC if not for the reactor scram that is required first.

K/A 400000 Component Cooling Water

Bank Difficulty 2 Cognitive Level 2

Enabling Objectives

INT0320126O0O0100 Given plant condition(s), determine from memory if a manual reactor scram or an emergency shutdown from power is required due to the event(s).

INT0320126Q0Q0100 Given plant condition(s), and the applicable Abnormal/Emergency Procedure, determine the correct subsequent actions required to mitigate the event(s).

Skills

2.4.31 Knowledge of annunciators alarms and indications / and use of the response instructions. (CFR: 41.10 / 45.3)

Question 62 13338 (1 point(s))

With the plant operating at 100% power, a loss of off site power occurs. Both diesel generators fail to start and CANNOT be started. HPCI and RCIC recover RPV water level to +35" (NR), when flow is stopped on both systems. RPV water level is lowering at an average of 1 inch per minute due to SRV operation.

What procedural restriction (if any) applies to the continued use of HPCI in response to this event until on-site or off-site electrical power can be restored?

- a. HPCI suction must be shifted to the suppression pool.
- b. HPCI must be placed in RPV Pressure Control Mode.
- c. HPCI can be operated until the division 2 battery is exhausted.
- d. HPCI must be secured after one cycle of operation and must remain off.

Answer 62

d. HPCI must be secured after one cycle of operation and must remain off.

This procedure assumes that RPV water level and pressure is initially controlled by HPCI, as directed by the EOPs. CNS has committed to secure HPCI after one cycle of operation, even if EOPs *allow* HPCI use, in order to extend station battery life during station blackout. HPCI would still be operated if *required* by EOPs, but the conditions provided are within RCIC capability.

REFERENCES:		5.3SBO; 1.4 and NOTE, and 5.3
Foils:	a. b. c.	There is no requirement to shift to the SP HPCI must be secured to save DC power. HPCI must be secured to save DC power.

Modified Difficulty 3 Cognitive Level 1

Enabling Objectives

INT0060119001150D Describe each of the following special events evaluated in the CNS USAR that could challenge the integrity of the radioactive material barriers: Station Blackout

INT0320131W0W0100 Given plant condition(s), and the applicable Abnormal/Emergency Procedure, determine the correct subsequent actions required to mitigate the event(s).

INT00601190012200 Given a specific USAR analyzed Special Event, describe the initial plant condition assumed in the analysis.

INT00601190012500 Given a specific analyzed Anticipated Operational Transient or Special Event, state the appropriate safety actions necessary to prevent exceeding their safety design bases.

Skills

295003.AK1.06 Knowledge of the operational implications of the following concepts as they apply to PARTIAL OR COMPLETE LOSS OF A.C. POWER: (CFR: 41.8 to 41.10) Station blackout: Plant-Specific. (3.8/4.0*)

Question 63 3175 (1 point(s))

Given the following conditions:

- The Plant is operating at 100% power.
- A fire in the Cable Spreading Room has been reported **AND** the Fire Brigade is on the scene.
- The actions of 5.4FIRE, "General Fire Procedure" **AND** 5.4POST-FIRE, "Post-Fire Operational Information" are being performed.
- The Control Room Supervisor enters 5.4FIRE-SD, "Fire Induced Shutdown From Outside Control Room" as directed by procedure.

Based on these conditions, which choice below describes a condition that will dictate a Turbine Trip be initiated per 5.4FIRE-SD, "Fire Induced Shutdown From Outside Control Room"?

A Turbine Trip should be performed ...

- a. prior to leaving the Control Room, **IF** possible.
- b. **ONLY** for a confirmed fire in the Control Room.
- c. **ONLY IF** the fire in the Cable Spreading Room is confirmed.
- d. **ONLY IF** unexpected DEH/Turbine related actuations occur.

Answer 63

a. prior to leaving the Control Room, **IF** possible.

REFERENCE: PR 5.4FIRE-SD, "Fire Induced Shutdown From Outside Control Room"

Foils:

- b. Required prior to leaving if possible, irrespective of fire location.
- c. Not a reason to trip the turbine.
- d. Not a reason to trip the turbine.

Bank

Difficulty 2 Cognitive Level 1

Enabling Objectives

INT0320134G0G0100 Given plant condition(s), determine from memory if a Main Turbine trip is required due to the event(s).

Skills

2.4.27 Knowledge of fire in the plant procedure. (CFR: 41.10 / 43.5 / 45.13)

Question 64 17850 (1 point(s))

A plant shutdown is in progress at 88% power when the following indications are received:

- Steam line flow on the "D" steam line indicates zero (0) flow.
- Annunciator 9-5-2/F-2, REACTOR HIGH PRESSURE alarms.
- Reactor pressure continues to rise.

What action is required?

- a. Lower the DEH pressure setpoint.
- b. Place Governor valves in MANUAL.
- c. Manually scram the reactor at 1030 psig.
- d. If only one (1) MSIV is closed, re-open the valve.

Answer 64

c. Manually scram the reactor at 1030 psig.

Manually scram the reactor at 1030 psig per 2.4DEH and 2.3_9-5-2.

Reference 2.4DEH and 2.3_9-5-2.

Foils:

- a. This would have no effect and is not in accordance with any procedure.
- b. This would not be appropriate and would not correct the problem.
- d. An MSIV should not be re-opened without engineering concurrence.

K/A 295025 (High Reactor Pressure), 2.4.11 (3.4)

Bank Difficulty: 4 Cognitive level: 3

Enabling Objectives

INT0320125L0L0100 Given plant condition(s), determine from memory if a manual reactor scram or an emergency shutdown from power is required due to the event(s).

Skills

2.4.11 Knowledge of abnormal condition procedures. (CFR: 41.10 / 43.5 / 45.13)

Question 65 10634 (1 point(s))

The plant was operating at 100% power when the following annunciators alarmed:

- A-4/B-5, SERVICE AIR LOW PRESSURE
- A-4/B-4 SERVICE AIR ISOLATION PCV-609
- A-4/A-4, AIR RECEIVER A OR B LOW PRESSURE alarmed

The crew noted INSTRUMENT AIR PRESSURE (IA-PI-606), indicated 75 psig and closed IA-MO-80, NON CRIT INSTRUMENT AIR ISOLATION. Immediately following the closure of IA-MO-80 control room indications are:

- SERVICE AIR PRESSURE (SA-PI-611), indicates 0 psig.
- INSTRUMENT AIR PRESSURE (IA-PI-606), indicates 90 psig and increasing.

Which operator actions(s) is/are required next?

- a. Re-open SA-PCV-609 to restore Service Air.
- b. Re-open IA-MO-80 to restore non-critical Instrument Air.
- c. Scram the reactor and transfer level control to HPCI/RCIC.
- d. Manually open "A" Air Compressor TEC Return Isolation, TEC-AOV-21AV.

Answer 65

c. Scram the reactor and transfer level control to HPCI/RCIC.

Even though the closure of IA-MO-80 restored the instrument air pressure the loss of noncritical instrument air supply causes unsafe operation due to the loss of feedwater heating. The reactor should be scrammed as a scram required setpoint has been exceeded, even though air pressure is now above that requiring a scram.

REFERENCE: 5.2AIR; 2.1.5, Attachment 2 2.0.1.2 Step 7.1.4 SER 4-00

Foils:

a. is incorrect. Even though this action could be performed to safely restore service air, a scram is required.

- b. is incorrect. Even though this action could be performed to safely restore instrument air, a scram is required.
- d. is incorrect. This is a valve that fails closed on a loss of air, but there is no guidance to manually open the valve.

K/A 295019 (Part. Or Comp. Loss of Inst. Air) 2.4.31 Bank Difficulty 3 Cognitive Level 2

Enabling Objectives

INT0320136N0N0100 Given plant condition(s), determine from memory if a manual reactor scram or an emergency shutdown from power is required due to the event(s).

Skills

2.4.31 Knowledge of annunciators alarms and indications / and use of the response instructions. (CFR: 41.10 / 45.3)

Question 66 7755 (1 point(s))

Which one of the following is the normal, 100% power, lineup of the Containment H_2 and O_2 Monitoring system per 2.2.60.1 and what indications are available?

- a. One Division in operation provides only O₂ measurement <u>*capability*</u> consisting of PMIS displays, O₂ recorders, an O₂ digital indicator.
- b. One Division in operation provides H₂ AND O₂ measurement <u>*capability*</u> consisting of PMIS displays, H₂ AND O₂ recorders, an O₂ digital indicator and H₂ annunciation.
- c. Two divisions in operation. Both provide H₂ **AND** O₂ monitoring consisting of H₂ **AND** O₂ recorders, a digital O₂ indicator and H₂ annunciation. **NO** input is provided to PMIS.
- d. Two divisions in operation. One division provides H₂ monitoring, the other provides O₂ monitoring. An O₂ recorder, digital O₂ indicator and H₂ annunciation are provided. Both divisions provide input into PMIS displays.

Answer 66

b. One Division in operation provides H₂ AND O₂ measurement <u>*capability*</u> consisting of PMIS displays, H₂ AND O₂ recorders, an O₂ digital indicator and H₂ annunciation.

Foils:

- a. H2 monitoring is available and annunciated.
- c. Only one division in service, PMIS input is provided.
- d. Only one division in service monitoring both parameters.

Reference: 2.2.60.1 Discussion Section.

New Difficulty 3 Cognitive Level 1

Enabling Objectives

COR0020302001140D Briefly describe the following concepts as they apply to the Primary containment: Hydrogen/oxygen concentration measurement

Skills

500000.EA1.02 Ability to operate and monitor the following as they apply to HIGH CONTAINMENT HYDROGEN CONTROL: (CFR: 41.7 / 45.6) Primary containment oxygen instrumentation (3.3/3.2)

Question 67 17854 (1 point(s))

The plant is operating at rated power when one (1) inboard MSIV fast closes. What is the expected plant response and why?

Reactor power and pressure will rise due to ...

- a. decreased control rod worths. The reactor will scram.
- b. feedback from the void coefficient of reactivity. The reactor will scram.
- c. decreased control rod worths. Reactor power will stabilize above 100%, but below the scram setpoint.
- d. feedback from the void coefficient of reactivity. Reactor power will stabilize above 100%, but below the scram setpoint.

Answer 67

b. feedback from the void coefficient of reactivity. The reactor will scram.

REFERENCE: Reactor theory, USAR IV-4.

Foils:

- a. Reactor pressure will rise because the steam lines have isolated.
- c. Reactor power will lower because a scram occurs on an MSIV isolation on low pressure in RUN (<835 psig).
- Reactor power will lower because a scram occurs on an MSIV isolation on low pressure in RUN (<835 psig)
 Reactor pressure will rise because the steam lines have isolated.

New Difficulty 2 Cognitive Level 2

Enabling Objectives

INT00601190010100 Given a set of initial operating conditions, select those conditions that would tend to make the consequences of an analyzed Anticipated Operational Transient more severe.

COR0021402001060B Given a specific Main Steam system malfunction, determine the effect on any of the following: Reactor pressure

INT0060119001050A For each of the following Anticipated Operational Transient categories listed, select an example of each transient, as stated in the CNS USAR: Nuclear system pressure increase

COR0021402001060D Given a specific Main Steam system malfunction, determine the effect on any of the following: Reactor power

Skills

295020.AK3.04 Knowledge of the reasons for the following responses as they apply to INADVERTENT CONTAINMENT ISOLATION: (CFR: 41.5 / 45.6) Reactor pressure response. (4.1/4.1)

Question 68 13752 (1 point(s))

During a LOCA, the CRS requests a round of primary containment parameters. The RO reports the following:

- DW pressure: 4.5 psig and rising
- DW temperature: 160°F and rising
- Torus water level: 0 inches
- Torus water temp: 85°F

Does the report made by the RO meet the requirement(s) for the requested information and why or why not?

- a. Meets. ONLY values are required.
- b. Meets. ONLY changing parameters require trends.
- c. **NOT** meet. Trends are required for ALL of the identified parameters in the initial report.
- d. **NOT** meet. Rate of trend is required for the identified parameters that are changing or out of specification in the initial report.

Answer 68

c. **NOT** meet. Trends are required for ALL of the identified parameters in the initial report.

During execution of EOPs, the CRS is expected to periodically direct one CRO to provide a round of primary containment parameters. Upon request, the parameter, trend, and rate of trend are to be included with no exceptions. Per 2.0.3, step 7.3.7, only the parameter and trend are normally required but since a "round of parameters" was requested, the rate of trend is also required.

REFERENCE: 2.0.3, step 7.3.7 and step 8.6

Foils:

- a. Does not meet standards. Trends are required in the initial report.
- b. Does not meet standards. Trends are required for parameters that are stable.
- d. Rate of trend is not required in the initial report.

Bank Difficulty 2 Cognitive Level 1

Enabling Objectives

INT032010300C010G Discuss the following as described in conduct of Operations Procedure 2.0.3, Conduct of Operations: Operations Policy During Transient Operations

OTH0151003001010D From memory define the following terms in accordance with in procedure 2.0.3, Conduct of Operations, and Operations Instruction #7: Briefs and updates

Skills

2.4.12 Knowledge of general operating crew responsibilities during emergency operations. (CFR: 41.10 / 45.12)

Question 69 17873 (1 point(s))

Which one of the following is the FEDERAL LIMIT for annual whole body dose to a control room operator in a calendar year?

- a. 1 rem/calendar year
- b. 5 rem/calendar year
- c. 15 rem/calendar year
- d. 50 rem/calendar year

Answer 69

b. 5 rem/calendar year

The federal limit is 5 rem/year.

Reference: 10CFR20

Foils:

- a. 1 Rem is a CNS administrative limit.
- c. 15 Rem is the federal limit for dose to the lens of the eye.
- d. 50 Rem is the federal limit for dose to the extremities.

New Difficulty 2 Cognitive level: 1

Enabling Objectives

INT03201160000100 State the CNS administrative and federal exposure limits

Skills

2.3.1 Knowledge of 10 CFR: 20 and related facility radiation control requirements. (CFR: 41.12 / 43.4. 45.9 / 45.10)

Question 70 6047 (1 point(s))

A Site Area Emergency has been declared at CNS. Which Emergency Response Facility provides the location for the overall response to an emergency, once all the Emergency Response Facilities are activated?

- a. Control Room
- b. Technical Support Center.
- c. Operations Support Center.
- d. Emergency Operations Facility.

Answer 70

d. Emergency Operations Facility

Reference: 5.7.9

Foils:

- a. The Control room manages the plant the EOF provides the overall response.
- b. The TSS provides technical support to the EOF
- c. The OSC provides support to the EOF.

Bank Difficulty 2 Cognitive Level 1

Enabling Objectives

GEN0030401B0B040B Emergency Response Facilities (ERFs): b) Describe the functions of each of the following ERFs: 1) Control Room (CR) 2) Technical Support Center (TSC) 3) Operation Support Center (OSC) 4) Emergency Operations Facility (EOF) 5) Joint Information Center (JIC)

Skills

2.4.29 Knowledge of the emergency plan. (CFR: 43.5 / 45.11)

Question 71 3144 (1 point(s))

Given the following conditions:

- The plant is operating at 100% power.
- High Pressure Coolant Injection (HPCI) is in service for the quarterly full-flow test.
- Initial Suppression Pool Temperature is 92°F.

As HPCI continues to operate, what Technical Specifications actions are required?

When Suppression Pool Temperature exceeds ...

- a. 100° F, reduce thermal power to $\leq 1\%$ Rated Thermal Power
- b. 100°F, verify Suppression Pool temperature is less than 120°F once every 30 minutes.
- c. 105° F, remove HPCI from service.
- d. 105°F, place the Reactor Mode Switch in SHUTDOWN.

Answer 71

c. 105° F, remove HPCI from service.

REFERENCE: T.S 3.6.2.1

Foils:

- a. Not required until completion times not satisfied.
- b. Not required until 110°F
- d. Not required until 110°F

Bank Difficulty 2 Cognitive Level 2

Provide to Candidate: T.S. 3.6.2.1 and bases.

Enabling Objectives

INT00705070010400 From memory, in MODES 1,2, and 3, state the actions required in less than one hour if suppression pool average temperature exceeds 105 degrees F and THERMAL POWER IS > 1% RAP and performing testing that adds heat to the suppression pool (LCO 3.6.2.1)

Skills

295013.AA2.01 Ability to determine and/or interpret the following as they apply to HIGH SUPPRESSION POOL TEMPERATURE: (CFR: 41.10 / 43.5 / 45.13) Suppression pool temperature (3.8/4.0)
Question 72 17855 (1 point(s))

With the plant operating at full power, what is the basis for the Technical Specification requirement to place the Reactor Mode Switch in SHUTDOWN on high suppression pool temperature?

- a. Ensure that low pressure ECCS pump NPSH requirements are met during a design bases LOCA.
- b. Ensure that low pressure ECCS pump Vortex limits re not exceeded during a design bases LOCA.
- c. Ensures that unstable condensation (chugging) does not occur in the suppression pool during a design bases LOCA.
- d. Ensures the reactor is shutdown to prevent the suppression pool from being heated beyond design limits by the steam generated during a design bases LOCA.

Answer 72

d. Ensures the reactor is shutdown to prevent the suppression pool from being heated beyond design limits by the steam generated during a design bases LOCA.

REFERENCE: T.S. 3.6.2.1 Bases

Foils:

- a. NPSH is an EOP related concept, not directly a Tech Spec limit bases.
- b. Vortex limits is an EOP related concept, not a Tech Spec limit bases.
- c. Chugging is an EOP related concept, not a Tech Spec limit bases.

New Difficulty 3 Cognitive Level 1

Enabling Objectives

INT00705070010500 From memory in MODES 1,2, and 3, state the actions required in less than one hour if suppression pool average temperature > 110 degrees F but is either less than or equal to 120 degrees F (LCO 3.6.2.1)

INT00705070010200 Discuss the applicable Safety Analysis in the Bases associated with each Chapter 3.6 specification.

Skills

295026.EK3.05 Knowledge of the reasons for the following responses as they apply to SUPPRESSION POOL HIGH WATER TEMPERATURE: (CFR: 41.5 / 45.6) Reactor SCRAM. (3.9/4.1)

Question 73 17892 (1 point(s))

The plant is at 69% power with MAIN STEAM ISOLATION VALVE OPERABILITY TEST (IST) in progress. Inboard MSIV 80A will be tested. The operator depresses MSIV 80A TEST button and HOLDS it in the depressed state.

What will be the *final* valve position and Reactor Pressure response for the action above?

The MSIV ...

- a. partially closes. Reactor pressure rises above the scram setpoint.
- b. partially closes. Reactor pressure rises and stabilizes below the scram setpoint.
- c. fully closes. Reactor pressure rises above the scram setpoint.
- d. fully closes. Reactor pressure rises slightly and stabilizes below the scram setpoint.

Answer 73

d. fully closes. Reactor pressure rises slightly and stabilizes below the scram setpoint.

REFERENCE: COR0021402, 6.MS.201

Foils:

- a. The MSIV goes fully closed, pressure will rise slightly, not above scram setpoint.
- b. The MSIV goes fully closed.
- c. Pressure will rise slightly, not above scram setpoint.

New Difficulty 2 Cognitive Level 2

Enabling Objectives

SKL012421400A030A Given plant conditions, predict changes in the following Main Steam system components/parameters: System pressure

SKL012421400A030F Given plant conditions, predict changes in the following Main Steam system components/parameters: MSIVs

SKL012421400A030D Given plant conditions, predict changes in the following Main Steam system components/parameters: Reactor pressure

Skills

239001.A4.04 Ability to manually operate and/or monitor in the control room: (CFR: 41.7 / 45.5 to 45.8) System pressure (3.8/3.7)

Question 74 3963 (1 point(s))

The plant is at 75% power when a LOSS of the Normal Station Transformer occurs.

- EXCEPT for Bus 1B, ALL 4160 VAC buses transferred to the Startup Transformer successfully
- Due to a relay failure, breaker 1BS does not close automatically until two (2) seconds after the loss of the Normal transformer.
- Bus 1B is currently energized via 1BS

What is the state (running or stopped) of the Condensate (COND) and Condensate Booster (CB) pumps *powered from Bus 1B* five (5) seconds after Bus 1B is energized?

	COND PUMPS	<u>CB PUMPS</u>
a.	RUNNING	RUNNING
b.	RUNNING	STOPPED
c.	STOPPED	RUNNING
d.	STOPPED	STOPPED

Answer 74

a. RUNNING RUNNING

CP and CBP breakers do not have UV protection and will remain closed upon loss of power.

REFERENCE: 2.4MC-CF 2-2; 2.3_C-3/A-7 2.1.3.3, 2.1.3.4; 2.2.6 2.3 STCOR0020202 Condensate and Feed Page 20 Section II.B Rev 11; PR

Foils:

b.c.d. Both CB and CBP breakers remain closed and the pumps will be running after the bus is reenergized. The 1 second is much shorter than the low suction pressure trip setpoint for the CBP.

Bank Difficulty 2 Cognitive Level 2

Enabling Objectives

COR0020202001080E Predict the consequences a malfunction of the following would have on the Condensate and Feedwater system: AC Power

Skills

259001.K6.03 Knowledge of the effect that a loss or malfunction of the following will have on the REACTOR FEEDWATER SYSTEM: (CFR: 41.7 / 45.7) A.C. electrical power (2.9/3.1)

Question 75 16412 (1 point(s))

The plant is at **75%** power. The Reactor Level Control system is maintaining RPV level at +35 inches (NR) in three (3) element control. The "C" main steam flow transmitter output goes to ZERO and remains at zero.

How will RPV water level change (lower or rise) and what will be the magnitude of the change?

RPV water level . . .

- a. LOWERS and the reactor scrams on low level.
- b. LOWERS and stabilizes at approximately +26 inches (NR).
- c. RISES and stabilizes at approximately +44 inches (NR).
- d. RISES and the reactor scrams when the main turbine trips.

Answer 75

b. LOWERS and stabilizes at approximately +26 inches (NR).

Level lowers until it stabilizes at 26 inches. A reactor scram will not occur. The magnitude of the level change is driven by the initial power level. 100% = 12" change, 75% = 9" change.

REFERENCE: 2.4RXLVL; 5.7

Foils:

- a. The reactor will not scram.
- c. Level lowers. It will rise if a feedwater transmitter failed low.
- d. Level lowers. It will rise if a feedwater transmitter failed low.

Bank Difficulty 2 Cognitive Level 2

Enabling Objectives

COR0023202001090D Given a specific RVLC system malfunction determine the effect on any of the following: RPV water level

COR0023202001060I Predict the consequences of the following on the RVLC system: Loss of one or more main steam flow inputs

Skills

259002.A3.03 Ability to monitor automatic operations of the REACTOR WATER LEVEL CONTROL SYSTEM including: (CFR: 41.7 / 45.7) Changes in main steam flow (3.2/3.2)

Question 76 5103 (1 point(s))

Given the following conditions:

- The reactor has been shut down for 12 days, with the reactor cavity flooded to 1001
- A complete loss of Reactor Equipment Cooling (REC) flow occurs
- It is unknown when REC System flow will be restored

Which method of cooling the Fuel Pool is available?

Fuel Pool cooling will be provided by ...

- a. the cross-tie with Circulating Water (CW) System.
- b. the cross-tie with Turbine Equipment Cooling (TEC) System.
- c. the cross-tie with the Residual Heat Removal (RHR) System.
- d. the Service Water Cross-tie to the Fuel Pool Cooling Heat Exchanger.

Answer 76

c. the cross-tie with the Residual Heat Removal (RHR) System.

RHR cross-tie is available in the Shutdown Cooling Mode.

REFERENCES: COR001-06-02, page 21-23, section IV, V PR 2.4.8.6, page 1, section 4, PR 2.2.69.2, page 33, section 14

Foils:

- a. Circ Water cross-ties with Service Water, but does not cross-tie with FPC.
- b. REC provides backup cooling for some REC loads but not for FPC.
- d. Service Water is used as an emergency makeup source but cannot be aligned to cool the FPC HX.

Bank	
Difficulty 2	
Cognitive Level	1

Enabling Objectives

COR0010602001050A Describe the interrelationship between the FPC system and the following: Reactor Equipment Cooling

COR0010602001050B Describe the interrelationship between the FPC system and the following: Residual Heat Removal

COR0010602001080E Predict the consequences a malfunction of the following would have on the FPC system: REC

Skills

233000.K1.02 Knowledge of the physical connections and/or cause- effect relationships between FUEL POOL COOLING AND CLEAN-UP and the following: (CFR: 41.2 to 41.9 / 45.7 to 45.8) Residual heat removal system: Plant-Specific (2.9/3.0)

Question 77 16409 (1 point(s))

NOTE: COR002-21-02, Figure 3 (RPS Trip System A) is provided for use with this question.

From rated conditions, a power excursion to 125% occurs. The following annunciators are received:

- 9-5-2/A-3, REACTOR SCRAM CHANNEL B
- 9-5-2/B-1, NEUTRON MONITORING TRIP

NO control rods moved. At the 9-5 vertical panel, you observe the following:

- White CRD Scram Solenoid Group lights for RPS Trip System "A" are ON
- White CRD Scram Solenoid Group lights for RPS Trip System "B" are OFF

NO operator actions have been taken in response to the conditions stated above. If the 5A-K15A and the 5A-K15C relays will NOT change state, which one of the following operator actions will cause <u>ALL</u> control rods to fully insert?

- a. Depressing the "A" manual scram pushbutton.
- b. Placing the Reactor Mode Switch to SHUTDOWN.
- c. Resetting RPS and then inserting a manual reactor scram.
- d. Placing "A" and "C" RPS trip channel test switches to TRIP.

Answer 77

d. Placing "A" and "C" RPS trip channel test switches to TRIP.

This will directly remove power from the K14 relays which will de-energize the 117/118 solenoids at the HCU and scram the rods.

REFERENCE: RPS prints

RPS Trip System A Figure (COR002-21-02, Figure 3)

Foils:

- a. K15A and K15C must both actuate to insert all control rods. This action will de-energize the K-15 relays which will not change state. If they don't drop out, the reactor will scram.
- b. K15A and xK15C must both actuate to insert all control rods. This action will de-energize the K-15 relays which will not change state. If they don't drop out, the reactor will scram.
- c. K15A and K15C must both actuate to insert all control rods. This action will de-energize the K-15 relays which will not change state. If they don't drop out, the reactor will scram.

Bank Difficulty 4 Cognitive Level 3

Provide to Candidate: RPS Trip System A Figure (COR002-21-02, Figure 3)

Enabling Objectives

COR0022102001050A Briefly describe the following concepts as they apply to RPS: Logic arrangements

COR0022102001080F Given a specific RPS malfunction, determine the effect on any of the following: RPS logic channels

Skills

212000.A2.21 Ability to (a) predict the impacts of the following on the REACTOR PROTECTION SYSTEM; and (b) based on those predictions, use procedures to correct, control...: (CFR: 41.5 / 45.6) ?Failure of individual relays to repositition: Plant-Specific (3.6/3.9)

Question 78 1071 (1 point(s))

Given the following:

- A Reactor startup in progress.
- All IRMs are on range 9 and reading approximately 10 on the lower (Red) scale.
- The Reactor Mode switch is in START & HOT STBY.
- IRM A fails downscale.

What is the Rod Block status for the present conditions **AND** if the Reactor Mode Switch is placed in RUN?

- a. NO Rod Block exists.Placing the Reactor Mode switch in RUN WILL result in a Rod Block.
- b. NO Rod Block Exists.Placing the Reactor Mode switch in RUN will NOT result in a Rod Block.
- c. A rod Block exists.The Rod Block WILL clear after placing the Reactor Mode switch in RUN.
- d. A Rod Block exists.The Rod Block will **NOT** clear after placing the Reactor Mode switch in RUN.

Answer 78

c. A rod Block exists.The Rod Block WILL clear after placing the Reactor Mode switch in RUN.

EXPLANATION OF ANSWER: An IRM downscale will generate a rod block. All IRM SCRAMs, Rod Blocks and Alarms are bypassed when the Mode Switch is in RUN, except Upscale or INOP with the companion APRM downscale.

Foils:

- a,b. An IRM downscale will generate a rod block with the Mode Switch not in RUN.
- d. All IRM SCRAMs, Rod Blocks and Alarms are bypassed when the mode switch is in RUN, except Upscale or IPOP with the companion APRM Downscale.

REFERENCES: STCOR002-12-02, 4.1.2

Bank

Difficulty 2 Cognitive Level 3

Enabling Objectives

COR0021202001060C Given a specific IRM malfunction, determine the effect on any of the following: Reactor manual control system

Skills

215003.K3.02 Knowledge of the effect that a loss or malfunction of the INTERMEDIATE RANGE MONITOR (IRM) SYSTEM will have on following: (CFR: 41.7 / 45.4) Reactor manual control (3.6/3.6)

Question 79 17852 (1 point(s))

The station is in Mode 2 withdrawing control rods in an approach to criticality during a startup. The following equipment simultaneously trips:

- IRM "A", "C", "E" and "G"
- SRM "A" and "C"
- Off-Gas Radiation monitor "A"
- Reactor Building Vent Radiation monitors "A" and "C"

Control rods remain at their pre-transient position and NO group isolations have occurred.

Which one of the following conditions exists and what action (if any) is required?

- a. A loss of RPSPP "A" has occurred. Manually initiate a Reactor scram and a Group 6 isolation.
- b. A loss of RPSPP "A" has occurred. **NO** operator actions are required to compensate for logic actuation failure.
- c. A loss of 24 VDC "A" has occurred. Manually initiate a Reactor scram and a Group 6 isolation.
- d. A loss of 24 VDC "A" has occurred. **NO** operator actions are required to compensate for logic actuation failure.

Answer 79

d. A loss of 24 VDC "A" has occurred. **NO** operator actions are required to compensate for logic actuation failure.

The loss of 24 vdc will cause all these instruments to become inoperative. No scram or group isolation will occur due to this single power loss.

REFERENCE: 2.2.26

Foils:

- a. RPS power loss would not cause the loss of IRMs/SRMs. No ATWS or group isolation failure has occurred.
- b. RPS power loss would not cause the loss of IRMs/SRMs.
- c. No ATWS or group isolation failure has occurred.

K/A 295004 (295004 Partial or Complete Loss of DC Power), 2.4.48 ((3.5)

New Difficulty 3 Cognitive Level 3

Enabling Objectives

COR0020702001080B Given a specific DC Electrical Distribution system malfunction, determine the effect on any of the following: Components using DC control power (i.e., breakers)

COR0020702001080J Given a specific DC Electrical Distribution system malfunction, determine the effect on any of the following: Reactor Protection system

COR0021202001070B Predict the consequences of a loss or malfunction of the following would have on the IRM system: 4/48 VDC

COR0020702001080K Given a specific DC Electrical Distribution system malfunction, determine the effect on any of the following: IRMs

COR0020702001080L Given a specific DC Electrical Distribution system malfunction, determine the effect on any of the following: SRMs

COR0020702001080R Given a specific DC Electrical Distribution system malfunction, determine the effect on any of the following: Radiation Monitoring systems

Skills

2.4.48 Ability to interpret control room indications to verify the status and operation of system / and understand how operator actions and directives affect plant and system conditions. (CFR: 43.5 / 45.12)

Question 80 715 (1 point(s))

The plant is at power during an ATWS. An SRV closes after automatically lifting on pressure setpoint.

What effect does the SRV closing have on reactor power and why?

Power will . . .

- a. rise due to reduction in core inlet subcooling.
- b. rise due to collapse of voids in the core region.
- c. lower due to reduction in core inlet subcooling.
- d. lower due to collapse of voids in the core region.

Answer 80

b. rise due to collapse of voids in the core region.

Reference 2.4SRV

Foils:

- a power rise is not due to inlet subcooling.
- c. power will rise and is not due to inlet subcooling
- d. power will rise

Modified Difficulty 2 Cognitive Level 1

Enabling Objectives

COR0021602001040F Given a Nuclear Pressure Relief system component manipulation, predict and explain the changes in the following parameters: Reactor power

Skills

295007.AK1.03 Knowledge of the operational implications of the following concepts as they apply to HIGH REACTOR PRESSURE: (CFR: 41.8 to 41.10) Pressure effects on reactor power (3.8/3.9)

Question 81 17899 (1 point(s))

Given the following conditions:

- Reactor is in Hot Shutdown
- DG 1 is paralleled to 1F for surveillance testing
- The diesel governor fails to maximum fuel rack position

Which breaker(s) will trip (if any) as a result (direct or indirect) of the high DG 1 current?

- a. **ONLY** 1AF
- b. **ONLY** 1FA
- c. **BOTH** 1AF and 1FA
- d. **NEITHER** 1AF or 1FA

Answer 81

b. **ONLY** 1FA

EXPLANATION OF ANSWER: 1FA is tripped by the over current condition. 1AF will not trip because 1AF is in NORMAL AFTER CLOSE and Bus 1A is energized.

REFERENCES: STCOR001-01-02 PR 2.2.18, page 13, 15, section 4.6.2, 4.9.2.4 PR 2.2.20, page 16, section 4.9

Foils:

a. **only** 1FA trips on overcurrent

c. **only** 1FA trips on overcurrent

d. **only** 1FA trips on overcurrent

Bank Difficulty 3 Cognitive Level 2

Enabling Objectives

COR0010102001090B Describe the AC Electrical Distribution System design feature(s) and/or interlock(s) that provide for the following: Circuit breaker automatic trips

COR0020802001080C Given a specific Diesel Generator malfunction, determine the effect on any of the following: AC Electrical Distribution

Skills

262001.A2.10 Ability to (a) predict the impacts of the following on the A.C. ELECTRICAL DISTRIBUTION; and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences...: (CFR: 41.5 / 45.6) Exceeding current limitations (2.9/3.4)

Question 82 5459 (1 point(s))

Given the following:

- Reactor power is 84%
- ARI & ATWS RPT LOGIC POWER FAILURE alarm has occurred
- It has been determined that 125 VDC panel BB3 has been lost

What Alternate Rod Insertion (ARI) SYSTEM FUNCTIONS is/are available (if any)?

- a. **NO** ARI functions are available.
- b. **ALL** ARI functions are available.
- c. **ONLY** control rod insertion via ARI manual initiation pushbuttons.
- d. **ONLY** automatic initiation of the recirculation pump field breaker trips.

Answer 82

b. **ALL** ARI functions are available.

Foils:

- a. All functions are available.
- c. Automatic control rod and RPT is available.
- d. Manual and automatic control rod insertion is available.

REFERENCES: COR0023302, page 18 and 21

New Difficulty 3 Cognitive level 1

Enabling Objectives

COR0023302001060A Predict the consequences a malfunction of the following would have on the ARI system: 125 VDC System

COR0023302001080A Briefly describe the interrelationship between ARI and the following: 125 VDC System

Skills

263000.K3.03 Knowledge of the effect that a loss or malfunction of the D.C. ELECTRICAL DISTRIBUTION will have on following: (CFR: 41.7 / 45.4) Systems with D.C. components (i.e. valves, motors, solenoids, etc.) (3.4/3.8)

Question 83 3287 (1 point(s))

The plant is operating at 75% power when the following indications are received:

- 9-4-1/C-5, OFFGAS HIGH RAD alarm
- 9-4-1/C-4, OFFGAS TIMER INITIATED alarm
- K-1/A-4, OFFGAS FILTER HIGH D/P alarm
- OFF-gas flow indicates 100 cfm on Recorder AR-FR-47, SJAE AIR FLOW

If the above conditions are sustained for 16 minutes, what automatic actions will occur?

- a. AOG-AO-901 "AOG Supply valve" closes.
- b. AOG-AO-902 "AOG Return valve" closes.
- c. OG-AO-254 "Offgas System Isolation valve" opens.
- d. AR-AO-12 "30 Minute Holdup Pipe Drain valve" opens.

Answer 83

b. AOG-AO-902 "AOG Return valve" closes.

REFERENCE: PR 2.3.2.24 9-4-1/C-4, PR 2.4OG

Foils:

- a. AOG-AO-901 remains open.
- c. OG-AO-254 closes
- d. AR-AO-12 closes

Bank Difficulty 3 Cognitive Level 1

Enabling Objectives

COR0011602001080G Describe the Off Gas system design feature(s) and/or interlock(s) that provide for the following: Automatic system isolation

COR0011602001100B Predict the consequences of the following items on the Off Gas system: Process Radiation Monitoring failure

Skills

272000.K4.02 Knowledge of RADIATION MONITORING System design feature (s) and/or interlocks which provide for the following: (CFR: 41.7) Automatic actions to contain the radioactive release in the event that the predetermined release rates are exceeded (3.7/4.1)

Question 84 3799 (1 point(s))

Given the following conditions:

- Pressure in the reactor building is 14.7 psia.
- Pressure in the torus is 14.1 psia.
- Pressure in the drywell is 13.5 psia.

What will be the status of the primary containment vacuum relief system for these conditions?

- a. **NO** vacuum breakers are open.
- b. **ALL** vacuum breakers are open.
- c. **ONLY** the torus to drywell vacuum breakers are open.
- d. **ONLY** the reactor building to torus vacuum breakers are open.

Answer 84

- b. **ALL** vacuum breakers are open.
- REFERENCES: STCOR002-03-02, page 17, section II.A.4, rev. 11.

Foils:

a, c, d All vacuum breakers would be open.

Bank Difficulty 2 Cognitive Level 2

Enabling Objectives

SKL012420300A030P Given plant conditions, predict changes in the following Containment system components/parameters: Vacuum breaker-Drywell to suppression chamber (Torus)

COR0020302001230D Predict the consequences of a malfunction of the following on the Primary containment: Drywell vacuum relief.

SKL012420300A0300 Given plant conditions, predict changes in the following Containment system components/parameters: Vacuum breaker-SRV operation

Skills

223001.K4.05 Knowledge of PRIMARY CONTAINMENT SYSTEM AND AUXILIARIES design feature (s) and/or interlocks which provide for the following: (CFR: 41.7) Maintains proper suppression pool to drywell differential pressure (2.9/3.1)

Question 85 5471 (1 point(s))

The following conditions exist:

- Reactor power is 67% and being raised
- Throttle pressure indicates 946 psig
- Load Limit set at 839
- Flow Limiter at 110%
- Both throttle pressure transducers have failed causing the Governor and bypass valves to transfer to Manual
- THROT PRESS MONITOR light has illuminated

If a turbine trip occurs, the turbine bypass valves will ...

- a. remain closed and **CANNOT** be manually opened.
- b. remain closed but can be manually opened by the operator.
- c. automatically full open and **CANNOT** be manually closed.
- d. automatically full open and must be manually closed.

Answer 85

d. automatically full open and must be manually closed.

At greater than 25% power with bypass valves in MANUAL, the bypass valves fail open and must be manually closed on a turbine trip.

REFERENCES: COR0020902 Student Text, 2.4DEH Attachment 4

Foils:

- a. The bypass valves fail open, not closed.
- b. The bypass valves fail open, not closed.
- c. The valves can be manually closed.

Bank Difficulty 2 Cognitive Level 1 **Enabling Objectives**

COR0020902001070E Given a specific DEH Control system malfunction, determine the effect on any of the following: Bypass valves

COR0020902001080M Predict the consequences a malfunction of the following would have on DEH Control system: Low turbine inlet pressure (loss of pressure signal)

Skills

241000.K3.25 Knowledge of the effect that a loss or malfunction of the REACTOR/TURBINE PRESSURE REGULATING SYSTEM will have on following: (CFR: 41.7 / 45.4) Reactor cooldown (3.3/3.3)

Question 86 2116 (1 point(s))

What indications are expected when performing a coupling check on an UNcoupled control rod?

Overtravel Annunciator		<u>4-Rod Display</u>		Rod Drift Red Light	Rod Drift Red Light	
a.	ON		48	ON		
b.	OFF		48	OFF		
с.	ON		blank	ON		
d.	OFF		blank	OFF		
Answer 80	6					

REFERENCE: Reactor Manual Control System Text, Proc. 4.3 Section 9 & 10

blank

ON

Foils:

c.

a. 48 would not be displayed.

ON

b. Would have overtravel annunciator, 48 would not be displayed and drift light would be on.

d. Would have overtravel annunciator and drift light would be on.

Bank Difficulty 2 Cognitve Level 1

Enabling Objectives

COR0022002001090F Describe the interrelationships between RMCS and/or RPIS, and the following: Full Core Display

Skills

214000.K1.05 Knowledge of the physical connections and/or cause- effect relationships between ROD POSITION INFORMATION SYSTEM and the following: (CFR: 41.2 to 41.9 / 45.7 to 45.8) Full core display: Plant-Specific (3.3/3.3)

Question 87 673 (1 point(s))

How does a loss of 125 VDC A & B affect RPS?

- a. RPS logic strings A1, A2, B1 and B2 de-energized due to the TSVs closing.
- b. The backup scram valves would not be available. Automatic scrams are still available.
- c. RPS logic strings A1, A2, B1 and B2 de-energized due to the SDIV level transmitters losing of power.
- d. The SDV drain valves close, isolating the scram discharge volume. Automatic scrams are still available.

Answer 87

b. The backup scram valves would not be available. Automatic scrams are still available.

Reference: 4.5, COR0022102

Foils:

- a. Logic strings are supplied by RPS 120 VAC, TSVs would not be affected directly by the loss of 125vdc.
- c. Logic strings are supplied by RPS 120 VAC, SDIV instruments would not be affected directly by the loss of 125vdc
- d. SDV level instruments are supplied by RPS and would not close.

Bank Difficulty 2 Cognitive Level 1

Enabling Objectives

COR0022102001090D Predict the consequences a malfunction of the following would have on the RPS system: D.C. electrical distribution

Skills

212000.K6.04 Knowledge of the effect that a loss or malfunction of the following will have on the REACTOR PROTECTION SYSTEM: (CFR: 41.7 / 45.7) D.C. electrical distribution (2.8/3.1)

Question 88 2288 (1 point(s))

Who's approval is required for an Emergency Plan Temporary Configuration Change in accordance with procedure 3.4 (Configuration Change Control)?

- b. Shift Supervisor
- c. OPS/EOP Advisor
- d. Engineering Team Leader

Answer 88

b. Shift Supervisor

REFERENCES: PR 3.4

Foils:

- a. Must be SS or Emergency Director.
- c. Must be SS or Emergency Director.
- d. Must be SS or Emergency Director.

Bank Difficulty 2 Cognitive Level 1

Enabling Objectives

INT0320109A0A010B Discuss the following as described in Engineering Procedure 3.4, Configuration Change Control: Emergency Plan TCCs

Skills

2.2.11 Knowledge of the process for controlling temporary changes. (CFR: 41.10 / 43.3 / 45.13)

Question 89 16474 (1 point(s))

With the plant at 100% power, HPCI indvertently initiates. What is the **MINIMUM** required of the BOP to confirm the condition, and once confirmed, is CRS concurrence required before stopping and preventing HPCI injection?

(NOTE: The choices are listed from MINIMUM to MAXIMUM order.)

After confirming that the initiation is inadvertent on at least ...

- b. one (1) indication, obtain CRS concurrence, then stop and prevent injection.
- b. one (1) indication, stop and prevent injection. CRS concurrence is **NOT** required.
- c. two (2) independent indications, obtain CRS concurrence, then stop and prevent injection.
- d. two (2) independent indications, stop and prevent injection. CRS concurrence is **NOT** required.

Answer 89

d. two (2) independent indications, stop and prevent injection. CRS concurrence is **NOT** required.

Two independent indications of a parameter are to be checked to validate an initiation signal. CRS permission must be obtained PRIOR to defeating an automatic initiation of an ECCS component UNLESS it is an immediate operator action.

REFERENCE: 2.0.3; 8.2.1.2, 8.2.3.1, 2.0.1.2; 7.7.1, 7.7.2, 2.4CSCS; 3.1

Foils:

- a. Two independent indications of a parameter are to be checked to invalidate an initiation signal. CRS permission is NOT required.
- b. Two independent indications of a parameter are to be checked to invalidate an initiation signal.
- c. CRS permission is NOT required.

Bank Difficulty 2 Cognitive Level 1

Enabling Objectives

OTH0151003001030C Given a video tape or during observation of crew performance determine deviation from correct behaviors, as addressed in procedure 2.0.3, Conduct of Operations, and Operations Instruction #7 for the following areas: Critical parameter control

INT032010300A010A Discuss the following as described in Conduct of Operations Procedure 2.0.1, Plant Operations Policy: Precautions and Limitations

INT032010300C010G Discuss the following as described in conduct of Operations Procedure 2.0.3, Conduct of Operations: Operations Policy During Transient Operations

Skills

2.1.7 Ability to evaluate plant performance and make operational judgments based on operating characteristics / reactor behavior / and instrument interpretation. (CFR: 43.5 / 45.12 / 45.13)

Question 90 16403 (1 point(s))

During an ATWS, the RO is directed to perform alternate control rod insertion. The RO will be performing the actions to insert control rods by resetting RPS and inserting a manual reactor scram. The CRS has mandated that all peer check requirements be complied with. Another licensed operator is available to assist as necessary.

What are the peer checking requirements to perform this task?

- a. All steps of the task require peer check.
- b. Peer checking is waived for Panel 9-5 actions but all other steps require peer check.
- c. Peer checking is waived for jumper installation but all other steps require peer check.
- d. All steps of the task are waived from the peer check.

Answer 90

c. Peer checking is waived for jumper installation but all other steps require peer check.

Peer check will be performed for front panel manipulations prior to manipulating controls. This verification will be performed during steady state manipulations and whenever possible during abnormal and transient conditions. Immediate operator actions shall not be delayed to wait for peer check. Peer check can be suspended for specific tasks during transients by the CRS.

REFERENCE: OI-7, 2.0.3

Foils:

- a. Back panel actions do not require peer check (jumpers).
- b. Panel 9-5 actions require peer check, back panel does not.
- d. Panel 9-5 actions require peer check.

Bank Difficulty 2 Cognitive Level 1

Enabling Objectives
INT032014000A010A Discuss the following concepts as they are described in Operations Instruction #7, "Operations Expectations:" Peer check

Skills

2.1.20 Ability to execute procedure steps. (CFR: 41.10 / 43.5 / 45.12)

Question 91 16633 (1 point(s))

The plant is shutdown for a refueling outage. How many ROs are required to be in the control room and what is their responsibility during the core off load?

(Assume the allowance for higher grade Licensed Operators to take the place of lower grade Licensed Operators will NOT be exercised).

- a. One. Must be at the controls and also monitoring fuel movements.
- b. Two. One at the controls and the other is monitoring fuel movements.
- c. Two. One at the controls is monitoring fuel movements and the other for security.
- d. Three. One at the controls, another is monitoring fuel movements, and a third for security.

Answer 91

b. Two. One at the controls and the other is monitoring fuel movements.

REFERENCE:

10.21; 9.2.2.4

Control Room activities affecting the transfer of fuel shall be monitored by a Licensed Operator with no other concurrent duties, who will act as the Control Room Monitor.

2.0.3; section 9, NOTE 2

Higher grade qualified Licensed Operators may take the place of lower grade Licensed or Non-licensed Operators.

2.0.3; 9.2.1

The minimum shift staffing requirements for MODE 4 or 5 shall include two active Licensed Operators (one of which must be an SRO).

2.0.3; 9.2.4.1

For this shift complement, an active Licensed SRO or RO shall be at the controls in the Control Room.

Foils:

- a. Must be two. One ATC and the other dedicated to fuel movement.
- c. Second RO is dedicated to fuel movements.
- d. Only two are required.

Bank Difficulty 3 Cognitive Level 1

Enabling Objectives

INT032010300C010H Discuss the following as described in conduct of Operations Procedure 2.0.3, Conduct of Operations: Control Room and Station Shift Staffing Requirements

Skills

2.2.30 Knowledge of RO duties in the control room during fuel handling such as alarms from fuel handling area / communication with fuel storage facility / systems operated from the control room in support of fueling operations / and supporting instrumentation. (CFR: 43.6)

Question 92 8875 (1 point(s))

Firefighting activities are in progress in the Reactor Building due to an <u>ACTIVE</u> fire. An automatic reactor scram has just occurred due to damage caused by the fire. High-high sump level conditions exist in Reactor Building Sumps B and D and the sump levels continue to rise.

What actions are required?

Start all available Reactor Building sump pumps and ...

- a. cooldown the reactor at < 100 °F/hour only.
- b. rapidly depressurize the RPV with the Main Turbine Bypass valves **only**.
- c. isolate Torus Area drains **AND** rapidly depressurize the RPV with the Main Turbine Bypass valves.
- d. isolate <u>ALL</u> systems that are discharging water into the affected areas AND cooldown the reactor at < 100 °F/hour.

Answer 92

a. cooldown the reactor at < 100 °F/hour only.

REFERENCE: EOP-5A.

K/A 295036 Secondary Containment Sump High Water Level

Foils:

- b. No ED condition is being approached.
- c. No requirement to isolate Torus area drains and NO ED condition is being approached.
- d. Fire water should NOT be isolated

Bank
Difficulty 4
Cognitive Level 3

Provide to Candidate: EOP 1A and 5A with entry conditions removed

Enabling Objectives

INT00806170010600 Given plant conditions and EOP flowchart 5A, SECONDARY CONTAINMENT CONTROL and RADIOACTIVITY RELEASE CONTROL, determine required actions.

Skills

2.4.11 Knowledge of abnormal condition procedures. (CFR: 41.10 / 43.5 / 45.13)

Question 93 17857 (1 point(s))

The plant is operating at 100% power when a steam line drain line breaks in the HPCI Room. This raises the temperatures in the area and a high temperature alarm is received for the SW Quad. HPCI then automatically isolates due to high temperature.

What actions are *required* regarding Reactor Building cooling?

- a. Start ALL Room FCUs. Operate them until EOP-5A has been exited.
- b. Start **only** the HPCI Room FCU. Operate it until EOP-5A has been exited.
- c. Start **ALL** Room FCUs. Operate them until all area temperatures are below Maximum Safe Operating Value.
- d. Start **only** the HPCI Room FCU. Operate it until the area temperatures is below Maximum Normal Operating Value.

Answer 93

a. Start ALL Room FCUs. Operate them until EOP-5A has been exited.

REFERENCE: EOP-5A

Foils:

- b. All FCUs should be run.
- c. The FCUs should be run until EOP-5A is exited.
- d. All FCUs should be run. The RB HVAC system should not be isolated.

New Difficulty 3 Cognitive Level 3

Provide to Candidate: EOP 5A with entry conditions removed

Enabling Objectives

INT00806170010600 Given plant conditions and EOP flowchart 5A, SECONDARY CONTAINMENT CONTROL and RADIOACTIVITY RELEASE CONTROL, determine required actions.

Skills

295032.EK2.02 Knowledge of the interrelations between HIGH SECONDARY CONTAINMENT AREA TEMPERATURE and the following: (CFR: 41.7 / 45.8) Secondary containment ventilation. (3.6/3.7)

Question 94 17897 (1 point(s))

For which of the conditions below would it be appropriate to "Anticipate Emergency Depressurization" per EOP-1A, RPV CONTROL?

- a. -130" (WR) and lowering RPV water level, **NO** injection available.
- b. RWCU room temperature 205 °F and rising, Reactor building "A" sump 6 feet and rising.
- c. 1000 psig and rising RPV pressure, 125 °F torus temperature and rising, no SRVs operable.
- d. Primary Containment water level 15.5 feet and rising, injection from sources external to the primary containment required for adequate core cooling.

Answer 94

d. Primary Containment water level 15.5 feet, injection from sources external to the primary containment required for adequate core cooling.

REFERENCE: INT0080605

FOILS:

- a. Step RC/L-7 does not immediately precede an ED step.
- b. does not immediately precede an ED step
- c. Step RC/P-5 or RC/P-6 will not require ED. Step SP/T-5, HCTL is OK.

K/A 295029 High Suppression Pool Water New Difficulty 2 Cognitive Level 2

Enabling Objectives

INT00806050010500 State the criteria used to determine that "Emergency Depressurization is Anticipated".

INT00806050011000 Given plant conditions and EOP flowchart 1A, RPV CONTROL, determine required actions.

Skills

2.4.6 Knowledge symptom based EOP mitigation strategies. (CFR: 41.10 / 43.5 / 45.13)

Question 95 10688 (1 point(s))

- The Emergency Director declared a Site Area Emergency five (5) minutes ago.
- The TSC is **NOT** operational.
- EOP actions outside the control room are necessary to perform manual draining of the SDV.
- ALL Area Radiation Monitors (ARMs) on the Reactor Building 903' elevation are alarming and indicate off-scale high.
- Drywell radiation monitor RMA-RM-40A and RMA-RM-40B indicate $2 \ge 10^3$ rem/hour.

In addition to a TLD and PD-1, "Digital Alarming Dosimeter," which one of the following describes the **MINIMUM** additional requirements (if any) necessary to perform the directed actions per 5.8.3, "Alternate Rod Insertion Methods?" (NOTE: The choices are listed in MINIMUM to MAXIMUM order.)

- a. The operator may perform the actions independently with **NO** additional radiological protection.
- b. The operator must be accompanied by a Radiological Protection Technician or Chemistry/Radiological Protection On-Site Availability Technician <u>OR</u> the operator shall carry a survey instrument capable of monitoring radiation dose rates.
- c. The operator must be accompanied by a Radiological Protection Technician or Chemistry/Radiological Protection On-Site Availability Technician. (An operator carrying a survey instrument capable of monitoring radiation dose rates does <u>NOT</u> satisfy the requirements.)
- d. The operator may **NOT** enter Secondary Containment until the TSC is operational.

Answer 95

 c. The operator must be accompanied by a Radiological Protection Technician or Chemistry/Radiological Protection On-Site Availability Technician. (An operator carrying a survey instrument capable of monitoring radiation dose rates does <u>NOT</u> satisfy the requirements.)

REFERENCE: ESP 5.8.3

Foils:

a. This is true if NO ARMs are in alarm.

- b. This is not an option when the ARM is off-scale high.
- d. This is true if the Drywell radiation monitor RMA-RM-40A or RMA-RM-40B indicate $>10^4$ rem/hour.

Bank Difficulty 3 Cognitive Level 1

Enabling Objectives

INT00806060010900 Identify any EOP support procedures addressed in Flowchart 6A and apply any associated special operating instructions or cautions.

Skills

295033.EK1.02 Knowledge of the operational implications of the following concepts as they apply to HIGH SECONDARY CONTAINMENT AREA RADIATION LEVELS: (CFR: 41.8 to 41.10) Personnel protection (3.9/4.2*)

Question 96 6062 (1 point(s))

Given the following conditions:

- The plant is at 100% power.
- A Reactor shutdown is commenced at 2200 on 1/2.
- The following is the projected power reduction schedule: 100% at 2200 on 1/2 (power reduction started) 75% at 0800 on 1/3 50% at 2000 on 1/3 25% at 2200 on 1/3 15% at 0200 on 1/4 5 % at 0300 on 1/4

Which choice below is the **EARLIEST** time where the Primary containment oxygen concentration can exceed 4%?

(Note: Choices are listed from EARLIEST to LATEST.)

- a. 2300 on 1/1/00
- b. 0300 on 1/2/00
- c. 2300 on 1/2/00
- d. 0300 on 1/3/00

Answer 96

d. 0300 on 1/3/00

REFERENCES: COR002-03-02, page 2, rev. 11. T.S. 3.6.3.1

Foils:

- a. This is the time shutdown is commenced and is > 24 hrs. prior to reducing power to < 15%.
- b. This is 47 hrs. prior to reducing power to < 15%.
- c. Time is 28 hrs. before and O2 must be < 4%.

K/A 223001 Primary CTMT and Auxiliaries

Bank

Difficulty 3 Cognitive Level 2

Provide to Candidate: T.S. 3.6.3.1 and bases

Enabling Objectives

INT00705070010300 Given a set of plant conditions that constitutes non-compliance with a Chapter 3.6 LCO, determine the ACTIONS that are required.

INT00705070010100 Given a set of plant conditions, recognize non-compliance with a Chapter 3.6 LCO.

Skills

2.1.12 Ability to apply technical specifications for a system. (CFR: 43.2 / 43.5 / 45.3)

Question 97 3339 (1 point(s))

Given the following plant conditions:

- "A" Recirc MG set speed is lowering
- Attempts to manually control the "A" Recirc MG set have been unsuccessful
- Core Flow is 37Mlbm/hr and slowly lowering
- Core thermal power is 70% and slowly lowering

What immediate operator action must be performed?

- a. Trip the "A" Recirculation pump.
- b. Press the "A" SCOOPTUBE LOCKOUT button.
- c. Scram and concurrently enter Procedure 2.1.5 "Reactor Scram."
- d. Reduce the speed of "B" Recirculation pump to match the "A" Recirculation pump.

Answer 97

b. Press the "A" SCOOPTUBE LOCKOUT button.

REFERENCES: PR 2.4RR

foils:

- a. Tripping "A" Recirc pump is not required under these conditions.
- c. A scram is not required under these conditions.
- d. Matching recirc speeds is not an immediate action and would place the plant in the instability region.

Modified Difficulty 2 Cognitive Level 2

Provide to Candidate: *Power to Flow Map* (2.1.10)

Enabling Objectives

INT032012400H0H00 Given plant condition(s), determine from memory if a manual reactor scram or an emergency shutdown from power is required due to the event(s).

INT032012400G0G00 Given plant condition(s), determine from memory all immediate operator actions required to mitigate the event(s).

Skills

295001.AA1.01 Ability to operate and/or monitor the following as they apply to PARTIAL OR COMPLETE LOSS OF FORCED CORE FLOW CIRCULATION: (CFR: 41.7 / 45.6) Recirculation system (3.5/3.6)

Question 98 5421 (1 point(s))

Given the following conditions:

- The plant is operating at 76% power
- The A Recirc Pump trips
- Power lowers to 50% **AND** Core flow lowers to 27 x 10^6 lbm/hr
- APRM indications are oscillating 12% peak-to-peak

What action is *required* and what is the reason for that action?

- a. Initiate actions to prevent Cold Water Stratification.
- b. Initiate a manual Scram to terminate power oscillations.
- c. Raise Recirc flow to exit the Stability Exclusion Region.
- d. Reduce B Recirc Pump speed to prevent Jet Pump Vibrations.

Answer 98

c. Raise Recirc flow to exit the Stability Exclusion Region.

REFERENCE: PR 2.4.RR; PR 2.1.10

Foils:

- a. Stratification is not a concern if Core flow >20%.
- b. Scram is not directed by procedure.
- d. Jet Pump vibrations are not a concern here. Lowering flow will aggravate Power to Flow situation.

K/A 202002 Recirculation Flow Control

Modified Difficulty 3 Cognitive Level 3

Provide to Candidate: Power to Flow Map (2.1.10)

Enabling Objectives

INT032012400G0G00 Given plant condition(s), determine from memory all immediate operator actions required to mitigate the event(s).

INT032012400I0I00 Given plant condition(s) and the applicable Abnormal/Emergency Procedure, determine the correct subsequent actions required to mitigate the event(s).

INT032012400H0H00 Given plant condition(s), determine from memory if a manual reactor scram or an emergency shutdown from power is required due to the event(s).

Skills

2.1.25 Ability to obtain and interpret station reference materials such as graphs / monographs / and tables which contain performance data. (CFR: 41.10 / 43.5 / 45.12)

Question 99 17864 (1 point(s))

While using the 'B" loop of RHR to cool the suppression pool, RHR-MO-66B, B HX BYPASS VLV must be fully CLOSED.

Which one of the following precautions apply and what is the bases for this precaution?

- a. Do **NOT** hold the control switch in close after the green indicating light turns on to prevent hammering the valve.
- b. Do **NOT** hold the control switch in close longer than 1 second after the green indicating light turns on to prevent tripping the valve breaker.
- c. Hold the control switch in close for 5 seconds after the red indicating light turns off to ensure the valve closure is terminated by torque switch.
- d. Hold the control switch in close for 3 seconds after the red indicating light turns off to ensure the valve closure is terminated by the closed limit switch.

Answer 99

c. Hold the control switch in close for 5 seconds after the green indicating light turns on to ensure the valve closure is terminated by torque switch.

RHR-MO-66B, B HX BYPASS VLV is a throttle valve and throttle valves are held in closed an additional 5 seconds to ensure they are closed by their torque switch.

Reference: 2.2.69.3, Section 2.6

Foils:

- a. This is based on the precaution from the procedure on seal-in limitorque operators.
- b. This is based on the precaution from the procedure on seal-in limitorque operators.
- d. The valve is held for 5 seconds (3 seconds is time delay for reversing directions) to prevent terminating the closure with the close limit switch.

K/A 219000 RHR/LPCI: Torus/Pool Cooling Mode

New Difficulty 2 Cognitive Level 1

Enabling Objectives

SKL012422300A0200 Explain the Residual Heat Removal system limitations and precautions as stated in the SOP 2.2.69, SOP 2.2.69.1, SOP 2.2.69.2 and SOP 2.2.69.3.

COR0022302001050B Briefly describe the following concepts as they apply to the RHR system: Valve operation

Skills

2.1.32 Ability to explain and apply system limits and precautions. (CFR: 41.10 / 43.2 / 45.12)

Question 100 5226 (1 point(s))

Given the following conditions:

- The plant is operating at 100% power with a Nitrogen Makeup to the Primary Containment in progress
- A loss of the "B" Reactor Protection System (RPS) Motor Generator Set occurs
- Torus N2 Supply Isolation Valve MO-1301 AND Drywell N2 Supply Isolation Valve MO-1312 closed
- RPS power has been restored

Which of the following actions are **<u>required</u>** to restore the Nitrogen makeup flowpath for these conditions?

MO-1301 AND MO-1312 switches ______ when the group isolation signal is reset.

After the isolation has been reset, MO-1301 **AND** MO-1312 switches must be positioned to ______ to re-open the valves.

- a. <u>must</u> be in OVRD OPEN
- b. <u>must</u> be in CLOSE OPEN
- c. <u>can</u> be in any position CLOSE AND THEN to OPEN
- d. <u>can</u> be in any position OVRD AND THEN to OPEN

Answer 100

c. <u>can</u> be in any position CLOSE AND THEN to OPEN

EXPLANATION OF ANSWER:

After the isolation is reset, the control switches are positioned to close to reset the valve circuit and then to open to reposition the valve.

REFERENCE: STCOR0020302 Containment Rev 11; PR 2.1.22 Recovering From a Group Isolation Page 14 Section 8

Foils:

a.	The isolation can be reset with the switches in any position. The switch must be left in
	OVRD to keep the valve open for this choice.
b.	The isolation can be reset with the switches in open.
d.	The valves will not open unless the switch is first positioned to close and then to open.

Bank Difficulty 3 Cognitive Level 2

Enabling Objectives

COR0020302001130E Describe the PCIS design features and/or interlocks that provide for the following: Operator action to defeat/reset isolations

Skills

223002.A4.03 Ability to manually operate and/or monitor in the control room: (CFR: 41.7 / 45.5 to 45.8) Reset system isolations (3.6/3.5)