

## ADMINISTRATIVE CONTROLS

---

### CORE OPERATING LIMITS REPORT (Continued)

9. CENPD-397-P-A, Revision 01, "Improved Flow Measurement Accuracy Using Crossflow Ultrasonic Flow Measurement Technology," May 2000.

(Methodology for operating at a RATED THERMAL POWER of 3,853 Mwt)

10. WCAP-13749-P-A, "Safety Evaluation Supporting the Conditional Exemption of the Most Negative EOL Moderator Temperature Coefficient Measurement," March 1997, (W Proprietary)

(Methodology for Specification 3.1.1.3 – Moderator Temperature Coefficient.)

- 6.9.1.6.c The core operating limits shall be determined so that all applicable limits (e.g., fuel thermal-mechanical limits, core thermal-hydraulic limits, ECCS limits, nuclear limits such as shutdown margin, and transient and accident analysis limits) of the safety analysis are met.