

5.0 Environmental Impacts of Postulated Accidents

Environmental issues associated with postulated accidents are discussed in the *Generic Environmental Impact Statement for License Renewal of Nuclear Plants (GEIS)*, NUREG-1437, Volumes 1 and 2 (NRC 1996b; 1999).^(a) The GEIS includes a determination of whether the analysis of the environmental issue could be applied to all plants and whether additional mitigation measures would be warranted. Issues are then assigned a Category 1 or a Category 2 designation. As set forth in the GEIS, Category 1 issues are those that meet all of the following criteria:

- (1) The environmental impacts associated with the issue have been determined to apply either to all plants or, for some issues, to plants having a specific type of cooling system or other specified plant or site characteristic.
- (2) A single significance level (i.e., SMALL, MODERATE, or LARGE) has been assigned to the impacts (except for collective off site radiological impacts from the fuel cycle and from high level waste and spent fuel disposal).
- (3) Mitigation of adverse impacts associated with the issue has been considered in the analysis, and it has been determined that additional plant-specific mitigation measures are likely not to be sufficiently beneficial to warrant implementation.

For issues that meet the three Category 1 criteria, no additional plant-specific analysis is required unless new and significant information is identified.

Category 2 issues are those that do not meet one or more of the criteria for Category 1, and therefore, additional plant-specific review of these issues is required.

This chapter describes the environmental impacts from postulated accidents that might occur during the license renewal term.

5.1 Postulated Plant Accidents

Two classes of accidents are evaluated in the GEIS. These are design-basis accidents (DBAs) and severe accidents, as discussed below.

(a) The GEIS was originally issued in 1996. Addendum 1 to the GEIS was issued in 1999. Hereafter, all references to the "GEIS" include the GEIS and Addendum 1.

Postulated Accidents

5.1.1 Design-Basis Accidents

In order to receive NRC approval to operate a nuclear power facility, an applicant must submit a safety analysis report (SAR) as part of its application. The SAR presents the design criteria and design information for the proposed reactor and comprehensive data on the proposed site. The SAR also discusses various hypothetical accident situations and the safety features that are provided to prevent and mitigate accidents. The NRC staff reviews the application to determine whether the plant design meets the Commission's regulations and requirements and includes, in part, the nuclear plant design and its anticipated response to an accident.

DBAs are those accidents that both the licensee and the NRC staff evaluate to ensure that the plant can withstand normal and abnormal transients, and a broad spectrum of postulated accidents without undue hazard to the health and safety of the public. A number of these postulated accidents are not expected to occur during the life of the plant, but are evaluated to establish the design basis for the preventive and mitigative safety systems of the facility. The acceptance criteria for DBAs are described in 10 CFR Part 50 and 10 CFR Part 100.

The environmental impacts of DBAs are evaluated during the initial licensing process, and the ability of the plant to withstand these accidents is demonstrated to be acceptable before issuance of the operating license (OL). The results of these evaluations are found in license documentation such as the staff's Safety Evaluation Report (SER), the Final Environmental Statement (FES), the licensee's Updated Final Safety Analysis Report (UFSAR), and Section 5.1 of this Supplemental Environmental Impact Statement (SEIS). The licensee is required to maintain the acceptable design and performance criteria throughout the life of the plant, including any extended-life operation. The consequences for these events are evaluated for the hypothetical maximally exposed individual; as such, changes in the plant environment will not affect these evaluations. Because of the requirement that aging management programs be in effect for license renewal, and the requirement that the consequences of any DBA remain below specified acceptable levels at all times during plant operation, the environmental impacts as calculated for DBAs should not differ significantly from initial licensing assessments over the life of the plant, including the license-renewal period. Accordingly, the design of the plant relative to DBAs during the period of extended operation is considered to remain acceptable and the environmental impacts of those accidents were not examined further in the GEIS.

The Commission has determined that the environmental impacts of DBAs are of SMALL significance for all plants because the plants were designed to successfully withstand these accidents. Therefore, for the purposes of license renewal, design-basis events are designated as a Category 1 issue in 10 CFR Part 51, Subpart A, Appendix B, Table B-1. The early resolution of the DBAs make them a part of the current licensing basis of the plant; the current licensing basis of the plant is to be maintained by the licensee under its current license and,

therefore, under the provisions of 10 CFR 54.30, is not subject to review under license renewal. This issue, applicable to North Anna Power Station, Units 1 and 2, is listed in Table 5-1.

Table 5-1. Category 1 Issue Applicable to Postulated Accidents During the Renewal Term

ISSUE—10 CFR Part 51, Subpart A, Appendix B, Table B-1	GEIS Section
POSTULATED ACCIDENTS	
Design-basis accidents (DBAs)	5.3.2; 5.5.1

Based on information in the GEIS, the Commission found that

The NRC staff has concluded that the environmental impacts of design-basis accidents are of small significance for all plants.

The Virginia Electric and Power Company (VEPCo) stated in its Environmental Report (ER; VEPCo 2001a) that it is not aware of any new and significant information associated with the renewal of the North Anna, Units 1 and 2 OLS. The staff has not identified any significant new information on this issue during its independent review of the VEPCo ER, the staff's site visit, the scoping process, or its evaluation of other available information. Therefore, the staff concludes that there are no impacts related to this issue beyond those discussed in the GEIS.

5.1.2 Severe Accidents

Severe nuclear accidents are those that are more severe than DBAs because they could result in substantial damage to the reactor core, whether or not there are serious offsite consequences. The GEIS assessed the impacts of severe accidents during the license-renewal period, using the results of existing analyses and site-specific information to conservatively predict the environmental impacts of severe accidents for each plant during the renewal period.

Based on information in the GEIS, the Commission found that

The probability weighted consequences of atmospheric releases, fallout onto open bodies of water, releases to ground water, and societal and economic impacts from severe accidents are small for all plants. However, alternatives to mitigate severe accidents must be considered for all plants that have not considered such alternatives.

Postulated Accidents

Therefore, the Commission has designated mitigation of severe accidents as a Category 2 issue in 10 CFR Part 51, Subpart A, Appendix B, Table B-1. This issue, applicable to North Anna Units 1 and 2, is listed in Table 5-2.

Table 5-2. Category 2 Issue Applicable to Postulated Accidents During the Renewal Term

ISSUE—10 CFR Part 51, Subpart A, Appendix B, Table B-1	GEIS Sections	10 CFR 51.53(c)(3)(ii) Subparagraph	SEIS Section
POSTULATED ACCIDENTS			
Severe Accidents	5.3.3; 5.3.3.2; 5.3.3.3; 5.3.3.4; 5.3.3.5; 5.4; 5.5.2	L	5.2

The staff has not identified any significant new information with regard to the consequences from severe accidents during its independent review of the VEPCo ER (VEPCo 2001a), the staff's site visit, the scoping process, or its evaluation of other available information. Therefore, the staff concludes that there are no impacts of severe accidents beyond those discussed in the GEIS. However, in accordance with 10 CFR 51.53(c)(3)(ii)(L), the staff has reviewed severe accident mitigation alternatives (SAMAs) for North Anna Units 1 and 2. The results of its review are discussed in Section 5.2.

5.2 Severe Accident Mitigation Alternatives (SAMAs)

10 CFR 51.53(c)(3)(ii)(L) requires that license renewal applicants consider alternatives to mitigate severe accidents if the staff has not previously evaluated SAMAs for the applicant's plant in an environmental impact statement (EIS) or related supplement or in an environmental assessment. The purpose of this consideration is to ensure that plant changes (i.e., hardware, procedures, and training) with the potential for improving severe accident safety performance are identified and evaluated. SAMAs have not been previously considered for North Anna Power Station, Units 1 and 2; therefore, the following addresses those alternatives.

5.2.1 Introduction

VEPCo submitted an assessment of SAMAs for North Anna Units 1 and 2 as part of the ER (VEPCo 2001a). The assessment was based on the North Anna Probabilistic Risk Assessment (PRA), which is an updated version of the North Anna Individual Plant Examination (IPE) for internal events (VEPCo 1992), the North Anna Individual Plant Examination for External Events (IPEEE) (VEPCo 1994), and supplemental analyses of offsite consequences and economic impacts performed specifically for the SAMA analysis. VEPCo generated a list of 158

candidate SAMAs based on a review of previous SAMA analyses in support of original plant licensing and license renewal, NRC and industry reports discussing potential plant improvements, dominant risk contributors in the plant-specific risk study, and insights provided by VEPCo's PRA staff. VEPCo assessed the costs and benefits associated with each of the potential SAMAs and concluded that none of the candidate SAMAs evaluated were cost-beneficial for North Anna Power Station.

Based on a review of the applicant's SAMA assessment, the NRC issued a request for additional information (RAI) to VEPCo by letter dated October 17, 2001 (NRC 2001). Key questions concerned the modifications to the North Anna PRA made subsequent to the IPE, treatment of external events in the SAMA analysis, the use of the plant-specific risk study in the SAMA identification process, and the evaluation of costs and benefits for certain SAMAs. VEPCo submitted additional information by letter dated December 10, 2001 (VEPCo 2001b) and by emails dated January 15 and 22, 2002 (NRC 2002a), and February 4 and 6, 2002 (NRC 2002b), in response to the staff's RAIs. As set forth below, these responses addressed the staff's concerns and reaffirmed the conclusion that none of the SAMAs would be cost-beneficial.

An assessment of SAMAs for North Anna Power Station follows.

5.2.2 Estimate of Risk for North Anna, Units 1 and 2

VEPCo's estimates of offsite risk at North Anna Power Station are summarized below. The summary is followed by an evaluation of VEPCo's risk estimates.

5.2.2.1 VEPCo's Risk Estimates

Two distinct analyses are combined to form the basis for the risk estimates used in the SAMA analysis: (1) the North Anna level 1 and 2 PRA model, which is an updated version of the IPE, and (2) a supplemental analysis of offsite consequences and economic impacts (essentially a level 3 PRA model) developed specifically for the SAMA analysis. The North Anna PRA level 1 and 2 models were originally developed in response to the request for an IPE contained in Generic Letter 88-20 (NRC 1988). The level 1 model was updated in 1994 before performing the IPEEE fire analysis, in 1996 to add the system model for the station blackout (SBO) diesel, and in the 1997-1998 time period to support implementation of the maintenance rule. The third update, referred to as the N7B model, is the most up-to-date model and was used for the SAMA analysis. The level 2 model was slightly updated for the SAMA analysis.

The baseline core damage frequency (CDF) for the purpose of SAMA evaluation is approximately 3.5×10^{-5} per reactor-year, based on the risk assessment for internally initiated events. |

Postulated Accidents

Although VEPCo did not include the contribution of risk from external events within the North Anna Power Station risk estimates, it did account for the potential risk reduction benefits associated with external events by doubling the estimated benefits for internal events. This is discussed further in Section 5.2.2.2. A breakdown of the CDF is provided in Table 5-3. As shown in this table, loss-of-coolant accidents (LOCAs) contribute about 47 percent, while SBO and loss of offsite power (SBO/LOOP) contribute about 24 percent of the total internal events CDF. Anticipated transients without scram (ATWS) are negligible contributors to CDF for North Anna Power Station. The frequency associated with the largest releases (i.e., interfacing system LOCA [ISLOCA] and steam generator tube rupture [SGTR]) for North Anna Power Station is estimated to be about 5.8×10^{-6} per reactor-year (i.e., about 17 percent of the internal events CDF). The CDFs that were used in the SAMA analysis and that are cited here are best-estimate values. The uncertainty analysis for the updated PRA indicates a 95 percent confidence level (upper) CDF value 1.84×10^{-4} per reactor-year, or about five times the best-estimate value. The impact of this uncertainty on the SAMA analysis is discussed in Section 5.2.6.2.

Table 5-3. North Anna Power Station Core Damage Frequency (CDF)

Initiating Event	Frequency (per reactor-year)
Loss-of-coolant accident (LOCA)	1.6×10^{-5}
Station blackout/loss of offsite power (SBO/LOOP)	8.5×10^{-6}
Other electrical transients	5.6×10^{-7}
Steam generator tube rupture (SGTR)	4.2×10^{-6}
General transients	3.2×10^{-6}
Interfacing system LOCA (ISLOCA)	1.6×10^{-6}
Anticipated transient without scram (ATWS)	4.4×10^{-7}
Total CDF from internal events	3.5×10^{-5}

The offsite consequences and economic impact analyses use the MELCOR Accident Consequence Code System 2 (MACCS2) code, Version 1.12, to determine the offsite risk impacts on the surrounding environment and public. Inputs for this analysis include plant/site-specific input values for core radionuclide inventory, source term and release fractions, meteorological data, projected population distribution, emergency response evacuation modeling, and economic data. The magnitude of the onsite impacts (in terms of clean-up and

decontamination costs and occupational dose) is based on information provided in NUREG/BR-0184 (NRC 1997b).

VEPCo estimates the dose to the population within 80 km (50 mi) of the North Anna Power Station from the risk of severe accidents caused by internal initiators to be about 0.25 person-Sv (25 person-rem) per year. Table 5-4 shows the contributions to population dose by containment release mode. SGTRs and ISLOCAs together account for practically all (99 percent) of the population dose, although they collectively comprise only about 17 percent of the total internal events CDF. This is due to the relatively high fission product releases in these sequences. Early and late containment failure contribute about 1 percent of the population dose. About 68 percent of the core melt accidents at North Anna Power Station do not result in containment failure and have only a minimal contribution to population dose.

Table 5-4. North Anna Power Station Risk Profile

Containment Release Mode	Contribution to Release Frequency ^(a) (percent)	Contribution to Population Dose ^(b) (percent)
Containment intact	68	<0.1
Early containment failure	<1	<1
Late containment failure	14	1
Containment bypass - SGTR	12	80
Containment bypass - ISLOCA	5	19
(a) Total release frequency for internal events = 3.5×10^{-5} per reactor-year.		
(b) Total population dose = 0.25 person-Sv (25 person-rem) per reactor-year.		

5.2.2.2 Review of VEPCo’s Risk Estimates

VEPCo’s determination of offsite risk at North Anna Power Station is based on the following three major elements of analysis:

- the level 1 and 2 risk models for North Anna Power Station that form the basis for the 1992 IPE submittal and the 1994 IPEEE submittal
- the modifications to the risk model subsequent to the IPE that distinguish the current PRA from the IPE
- the MACCS2 analyses performed to translate fission product release frequencies from the level 2 PRA model into offsite consequence measures.

Postulated Accidents

Each of these analyses was reviewed to determine the acceptability of VEPCo's risk estimates for the SAMA analysis, as summarized below.

The staff's review of the North Anna IPE is described in a staff report dated March 5, 1996 (NRC 1996a). In that review, the staff evaluated the methodology, models, data, and assumptions used to estimate the CDF and characterize containment performance and fission product releases. The staff concluded that VEPCo's analysis met the intent of Generic Letter 88-20 (NRC 1988); that is, the IPE was of adequate quality to be used to look for design or operational vulnerabilities. Although the staff reviewed certain aspects of the IPE in more detail than others, it primarily focused on the licensee's ability to examine North Anna Power Station for severe accident vulnerabilities and not specifically on the detailed findings or quantification estimates. Overall, the staff believed that the North Anna IPE was of adequate quality to be used as a tool in searching for areas with high potential for risk reduction and to assess such risk reductions, especially when the risk models are used in conjunction with insights, sensitivity, and uncertainty analyses. It is important to note that some changes have been made to the North Anna risk model since the original IPE was completed and reviewed by the NRC staff. These include both modifications to the models and changes due to plant modification, as discussed below.

A comparison of CDF profiles between the original IPE and the current PRA indicates that the estimate of the CDF for internal events has been reduced from 7.1×10^{-5} per reactor-year to about 3.5×10^{-5} per reactor-year. The lower values in the current PRA are attributed to plant and modeling improvements that have been implemented at North Anna Power Station since the IPE was submitted.

The original level 1 model, documented in the 1992 North Anna IPE submittal, had a CDF of 7.1×10^{-5} per reactor-year (from internal initiating events and internal flooding). A minor update to the level 1 model was performed before the licensee completed the IPEEE fire analysis in June 1994. A significant update to the level 1 model occurred in 1996 to add the system model for the SBO diesel generator as part of a risk-informed technical specification allowed outage time submittal. Another significant update occurred in the 1997-1998 time period to support implementation of the maintenance rule. These updates were performed to incorporate significant plant modifications, correct model errors, and enhance the model with state-of-the-art improvements. Among the individual fault tree models changed or added were those involving the emergency diesel generator, alternate alternating current (AAC) diesel, charging pumps (including Unit 1 and Unit 2 cross-tie), reactor coolant pumps, and service water (SW) system. The circulating water (CW) system fault tree was modified to include the dependency of the steam dumps on CW. The modified baseline CDF as of the most recent model changes is 3.5×10^{-5} per reactor-year.

The updated CDF value is lower than most of the original IPE values estimated for other pressurized water reactors (PWRs) with large dry containments. Figure 11.6 of NUREG-1560 (NRC 1997c) shows that the IPE-based total internal events CDF for Westinghouse 3-loop plants ranges from 6×10^{-5} to 4×10^{-4} per reactor-year. However, many of these CDF estimates have similarly been reduced due to modeling and hardware changes subsequent to the respective IPE submittals. Thus, a reduction in CDF from the IPE value is not unexpected.

As noted in Table 5-4, SGTR and ISLOCA contribute 12 percent and 5 percent, respectively, to the total release frequency for internal events. Because of the large fission product releases for bypass sequences relative to other release modes, these sequences dominate the North Anna Power Station risk profile. The conditional probability of early containment failure is 0.4 percent, and about 14 percent of core damage sequences are expected to lead to late containment failure. Due to the sub-atmospheric design of the containment, containment isolation failures are relatively insignificant (about 0.3 percent of CDF). With the exception of the somewhat high CDF associated with bypass of the containment, and the lack of credit in the PRA for scrubbing releases from SGTRs (both of which make the analysis conservative), the results of the updated North Anna PRA appear to be consistent with those of other IPEs for PWRs with large dry or sub-atmospheric containments insofar as the general CDF, the containment response, and release and risk profiles are concerned.

VEPCo submitted an IPEEE by letter dated June 28, 1994 (VEPCo 1994). VEPCo did not identify any fundamental weaknesses or vulnerabilities to severe accident risk in regard to the external events related to seismic, fire, high winds, floods, transportation and nearby facility accidents, and other external hazards. In the associated safety evaluation report (NRC 2000), the staff concluded that the IPEEE met the intent of Supplement 4 to Generic Letter 88-20 (NRC 1991).

Although VEPCo used probabilistic risk methods for the seismic and fire portions of the IPEEE, in their SAMA analysis they chose to capture the potential risk benefits associated with external events by doubling the calculated internal events benefits for each SAMA. In assessing the reasonableness of this assumption, the staff considered the relative contribution to the total risk from the various external events based on best available information. The North Anna Power Station high winds and external flooding analyses showed that the plant is adequately designed to protect against the effects of these natural events. Transportation and nearby facility accidents were not considered to be potential sources of damage at the plant because of the plant's rural locale. Other external events were evaluated and found to be insignificant contributors to CDF. Even though VEPCo's doubling of CDF to account for the benefits of a SAMA in external events provides a reasonable numerical estimate of the potential impact of external events, this approach may potentially fail to capture the benefits that could result from specific SAMAs that would be aimed at particular external events. In response to an RAI,

Postulated Accidents

VEPCo reasoned that since no external events vulnerabilities in terms of containment bypass or isolation failure were identified in the IPEEE, the offsite consequences can be bounded by the use of an internal events profile. In addition, the CDF from external events – approximately 3.9×10^{-6} per reactor-year – is considerably lower than the CDF for internal events (3.5×10^{-5} per reactor-year). Therefore, the approach used by VEPCo is considered to be acceptable.

The North Anna Power Station level 2 IPE submittal (VEPCo 1992) that was reviewed by NRC in 1996 (NRC 1996a) has been modified to make the North Anna and Surry models consistent. Both plants' models were converted to large early release frequency (LERF) models shortly after the IPE/IPEEE process was completed. The models remained so until the beginning of the SAMA analysis, at which time a unified source term category (STC) grouping was implemented. This was essentially the same approach used in the original North Anna IPE. The general containment event tree (CET) was also modified to reflect recent experimental results in severe accident analysis research (e.g., the resolution of the direct containment heating issue). The revision in the level 2 PRA model, as a result of the aforementioned changes, resulted in a reduction in the overall contribution to early containment failure. This has a relatively small impact on the overall risk of severe accidents at North Anna Power Station since the contribution to risk from early containment failure was already small. The staff concludes that the use of the North Anna Power Station level 2 model provides a sufficiently detailed characterization of containment response to support a license renewal SAMA analysis.

The staff reviewed the process used by VEPCo to extend the containment performance (level 2) portion of the PRA to an assessment of offsite consequences (essentially a level 3 PRA). This included consideration of the source terms used to characterize fission product releases for each of 24 STCs and consideration of the major inputs and assumptions used in the offsite consequence analyses. VEPCo used the severe accident source terms presented in the North Anna IPE as input to the NRC-developed MACCS2 code. For radionuclides not reported in the IPE, releases were set to zero. VEPCo's source terms were reviewed and found to be consistent with the source terms provided in other plants' submittals, and are considered reasonable.

The applicant used site-specific meteorological data processed from hourly measurements for one full year (1998) as input to the MACCS2 code. All data was collected at the North Anna Power Station meteorology tower. Hourly meteorological data for two additional years (1996 and 1997) were also used for sensitivity comparison. The use of data from either 1996 or 1997 results in only a few percent change in the total benefit of the candidate SAMAs. Year-to-year weather variations are not significant in the SAMA analysis because: (1) weather variations are diminished in the MACCS2 analyses due to its weather sampling scheme, and (2) the same meteorological assumptions are used in estimating both the base-case consequences and the SAMA-case consequences.

The population distribution the applicant used as input to the MACCS2 analysis was initially prepared using the computer program SECPOP90 (NRC 1997a). The output from SECPOP90 is a file based on a reference data base for the specified site. The SECPOP90-prepared population data was then modified and updated using the North Anna Power Station UFSAR, Section 2.1.3, 50-mile population distribution for the year 2030 in place of the SECPOP90 1990 Census data. The methods and assumptions for estimating population are considered reasonable and acceptable for purposes of the SAMA evaluation.

The applicant's emergency evacuation modeling was based on a single evacuation zone extending out 16 km (10 mi) from the plant. The applicant assumed that the people within the evacuation zone would move at an average evacuation speed of 1.8 m/s (4 mph) with a 5400-second delay between the alarm and start of evacuation. The applicant's base case analysis assumed 100 percent of the population within the emergency planning zone participate in the evacuation. In contrast, in NUREG-1150 (NRC 1990a) the staff assumed evacuation of 99.5 percent of the population. As part of the Surry SAMA analysis, VEPCo performed a sensitivity analysis in which only 95 percent of the population evacuates. The result was only about a 1 percent change in the total benefit of the candidate SAMAs. The staff concludes that the applicant's assumption regarding the percentage population participating in the evacuation at North Anna Power Station similarly would not substantially change the total benefit of the candidate SAMAs. VEPCo also performed sensitivity analyses in which MACCS2 parameters relating to the timing and energy of release were varied. The results of the analyses are reported in Table G.2-3 of the ER (VEPCo 2001a). The change in the total benefit of the candidate SAMAs was typically only about 10 percent, and in all cases was less than a factor of two. This change is small and would not alter the outcome of the SAMA analysis. Accordingly, the evacuation assumptions and analysis are deemed reasonable and acceptable for purposes of the SAMA evaluation.

Much of the site-specific economic data were provided by SECPOP90 (NRC 1997a) and used in the MACCS2 analyses. SECPOP90 contains a database extracted from U.S. Census Bureau CD-ROMs (1990 census data), the 1992 Census of Agriculture CD-ROM Series 1B, the 1994 U.S. Census County and City Data Book CD-ROM, the 1993 and 1994 Statistical Abstract of the United States, and other sources. These regional economic values were updated to 1999 using cost of living and other data from the Bureau of the Census and the Department of Agriculture. VEPCo performed a sensitivity analysis in which the farmland and non-farmland decontamination costs were increased by 25 percent. The result was about a 5 percent or less increase in the total benefit of the candidate SAMAs.

The staff concludes that the methodology used by VEPCo to estimate the CDF and offsite consequences for North Anna Power Station provides an acceptable basis from which to

Postulated Accidents

proceed with an assessment of the risk reduction potential for candidate SAMAs. Accordingly, the staff based its assessment of offsite risk on the CDF and offsite doses reported by VEPCo.

5.2.3 Potential Design Improvements

The process for identifying potential plant improvements, an evaluation of that process, and the improvements evaluated in detail by VEPCo are discussed in this section.

5.2.3.1 Process for Identifying Potential Design Improvements

VEPCo's process for identifying potential plant improvements consisted of the following elements:

- a review of SAMA analyses submitted in support of original licensing and license renewal activities for other operating nuclear power plants and advanced light water reactor plants,
- a review of other NRC and industry reports discussing potential plant improvements, e.g., NUREG-1560 (NRC 1997c), and NUREG/CR-5575 (NRC 1990b),
- a review of plant-specific improvements identified in the North Anna IPE and IPEEE,
- a review of the top 100 cutsets of the updated North Anna PRA, and survey of North Anna PRA staff for additional insights.

VEPCo's initial list of 158 candidate improvements was extracted from the process and is reported in Table G.2-1 in Appendix G of the ER (VEPCo 2001a).

VEPCo performed a qualitative screening on the initial list of 158 SAMAs using the following criteria:

- The SAMA is not applicable to North Anna Power Station either because (1) the enhancement is only for boiling water reactors, the Westinghouse AP600 design, or ice condenser containments, or (2) it is a plant-specific enhancement that does not apply at North Anna Power Station, or the SAMA has already been implemented at North Anna Power Station (or the North Anna Power Station design meets the intent of the SAMA), or
- The SAMA is related to a reactor coolant pump (RCP) seal vulnerability at many PWRs, stemming from charging pump dependency on component cooling water (CCW). The

North Anna plants do not have this vulnerability because the charging pumps do not rely on CCW. However, other RCP seal LOCA improvements are considered, such as installing improved RCP seals.

Based on the qualitative screening, 107 SAMAs were eliminated. Of these 107 SAMAs, 37 were eliminated because they had already been implemented at North Anna Power Station (or the design met the intent of the SAMA). The 51 remaining SAMAs are listed in Table G.2-2 of Appendix G of the ER (VEPCo 2001a), and were subjected to a final screening and evaluation process. The final screening process involved identifying and eliminating those SAMAs whose cost exceeded their benefit by at least a factor of two. All of the 51 remaining SAMAs were eliminated in this final screening.

5.2.3.2 Staff Evaluation

The preliminary review of VEPCo's SAMA identification process raised several questions regarding the set of SAMAs identified. The staff requested clarification regarding the portion of risk represented by the top 100 cutsets, and whether an importance analysis was used to confirm the adequacy of the SAMA identification process, since a review of the importance ranking of basic events in the PRA has the potential to identify SAMAs that may not be apparent from a review of the top cutsets.

VEPCo chose to review the top 100 cutsets for identification of potential SAMAs because they contain the dominant contributors to risk. The applicant stated that the top 100 cutsets examined account for the majority (about 70 percent) of the CDF for internal events, and contain all of the ISLOCA and much of the SGTR contribution to offsite consequences. The cutsets appearing below the 100th cutset have an individual frequency of 4.9×10^{-8} per reactor-year or less, and a collective frequency of approximately 1×10^{-5} per reactor-year. VEPCo also noted that since none of the SAMAs identified from the top 100 cutsets were found to be cost beneficial, it is not likely that SAMAs from the cutsets below the top 100 would be either.

VEPCo indicated that an importance analysis was not used in the initial SAMA identification process. However, an importance analysis was performed as part of the model update. The importance list contained 110 basic events with a risk reduction worth (RRW) above 1.005. VEPCo performed a limited review of the importance list and verified that the risk significant basic events were contained in the top 100 cutsets (NRC 2002b).

The staff notes that SAMAs with greatest risk reduction potential should be revealed through the cutset screening because the top cutsets include the majority of the CDF and the risk significant sequences, and all elements of their contribution are examined. Further, since the individual frequency of cutsets below the cutoff is 4.9×10^{-8} per reactor-year or less, and the

Postulated Accidents

collective frequency of cutsets below the cutoff is about 1×10^{-5} per reactor-year, it is unlikely that consideration of additional cutsets or further importance analyses would identify additional SAMAs that offer similar or greater risk reduction potential than those identified through cutset screening. The staff concludes that the process used to identify candidate SAMAs is sufficient to identify potential plant improvements that can significantly reduce risk.

VEPCo's efforts to identify potential SAMAs focused primarily on areas associated with internal initiating events. This is reasonable, since external events only contribute a small amount to the total CDF, and the containment response to external events was found to be similar to that from internal events in the IPE. The list of 51 SAMAs generally addressed the accident categories that are dominant CDF contributors or issues that tend to have a large impact on a number of accident sequences at North Anna Power Station. The potential SAMA candidates included a balance of both hardware, procedure, and training enhancements, e.g;

- for loss of offsite power sequences, SAMAs included providing a hardwired connection to an alternate offsite power (SAMA 77), and a lower cost alternative of developing procedures to repair or change out failed 4kV breakers (SAMA 69)
- for sequences with loss of heating ventilation and air conditioning (HVAC), SAMAs included providing a non-safety related, redundant train of switchgear ventilation (SAMA 25), and a lower cost alternative of developing procedures for opening doors and using fans to limit temperature increases (SAMA 26), the latter of which is already implemented at North Anna Power Station
- for sequences involving loss of support systems, the SAMAs included adding a third component cooling water pump (SAMA 15) and a lower cost alternative of enhancing training and procedures for loss of component cooling water or service water (SAMA 21).

The set of SAMAs submitted is not all inclusive because additional, possibly even less expensive, design alternatives can always be postulated. However, the staff concludes that the benefits of any additional modifications are unlikely to exceed the benefits of the modifications evaluated and that the alternative improvements would not likely cost less than the least expensive alternatives evaluated, when the subsidiary costs associated with maintenance, procedures, and training are considered.

The staff concludes that VEPCo used a systematic and comprehensive process for identifying potential plant improvements for North Anna Power Station. While explicit treatment of external events in the SAMA identification process was limited, VEPCo doubled the estimated benefit for

internal events to account for any unmodelled risk reduction that could be attributed to external events. Therefore, the staff concludes that this limited treatment of external events is acceptable.

5.2.4 Risk Reduction Potential of Design Improvements

VEPCo evaluated each of the 51 SAMAs remaining after the qualitative screening using a bounding technique. Twenty-seven bounding analysis cases were developed to accomplish this effort. Table 5-5 lists the remaining SAMAs, the bounding analyses performed to estimate the risk reduction for each SAMA, the estimated risk reduction in terms of percent reduction in CDF and person-sievert (person-rem) dose, and the estimated total benefit (present value) of the averted risk. As discussed previously, VEPCo doubled the estimated benefit for internal events to account for any unmodelled risk reduction that could also occur in external events. The total benefit values reported in Table 5-5 incorporate this doubling. The determination of the benefits for the various SAMAs is discussed in Section 5.2.6.

The staff has reviewed VEPCo's bases for calculating the risk reduction for the various plant improvements and concludes that the rationale and assumptions for estimating risk reduction are reasonable and generally conservative (i.e., the estimated risk reduction is higher than what would actually be realized). Accordingly, the staff based its estimates of averted risk for the various SAMAs on VEPCo's risk reduction estimates. The estimated risk reduction for several of the SAMAs was negligible or zero. In these instances, the SAMA either affects sequences or phenomena that do not contribute to risk at North Anna Power Station, or represents an ineffective plant improvement. As such, a minimal impact on risk is not unreasonable in those cases.

5.2.5 Cost Impacts of Candidate Design Improvements

VEPCo estimated the costs of implementing each SAMA through the application of engineering judgment, estimates from other applicants' submittals, and site-specific cost estimates. The SAMA cost analyses were prepared by VEPCo staff experienced in estimating the cost of performing work at a nuclear plant. Cost estimates were made as order of magnitude approximations. The depth of analysis performed varied depending on magnitude of the expected benefit. For most of the SAMAs considered, the cost estimates were sufficiently greater than the benefits calculated such that no detailed evaluation was required. In these cases, the applicant indicated that the implementation costs would exceed twice the benefit. Detailed cost estimating was only applied in those situations in which the benefit is significant and application of judgement would be questioned. Detailed cost estimates were developed for the nine SAMAs listed in Table 5-6.

Table 5-5. SAMA Cost/Benefit Screening Analysis

Analysis Case and Applicable SAMAs	Analysis Assumption	Percent Reduction		Total Benefit (\$)
		CDF	Dose	
Improvements Related to Ex-Vessel Accident Mitigation/Containment Phenomena				
Qualitative Assessment 39-create a giant concrete crucible with heat removal potential under the basemat to contain molten debris 40-create a water cooled rubble bed on the pedestal 47-create a core melt source reduction system 55-create another building, maintained at a vacuum to be connected to containment	Eliminate all offsite releases.	0.0	100	2.2M
SCB 42-enhance fire protection system and/or standby gas treatment system hardware and procedures 54-provide a reactor vessel exterior cooling system	Set the frequencies for STC frequencies 1 through 16, 19 and 20 to zero.	0.0	1.1	14K
HYD 37-install hydrogen igniters with independent power supply 38-create a passive hydrogen ignition system 48-provide containment inerting capability	Set the probability of late containment failure due to hydrogen burn to zero.	0.0	0.1	2K
DEB 43-create reactor cavity flooding system 44-create other options for reactor cavity flooding 152/153-create/enhance reactor coolant system depressurization ability	Modify the CET failure probabilities for debris cooling.	0.0	0.0	0
No analysis case 46-provide core debris control system	This failure mode was zero in the North Anna Level 2 analysis, so no further calculation was required.	0.0	0.0	0

Table 5-5. (contd)

Analysis Case and Applicable SAMAs	Analysis Assumption	Percent Reduction		Total Benefit (\$)
		CDF	Dose	
CSP 30-install containment spray throttle valves 32-develop an enhanced containment spray system 33-provide a dedicated existing containment spray system 49-use fire water spray pump for containment spray 50-install a passive containment spray system	Replace event tree functional equations related to containment and recirculation sprays with an event that has an unavailability of zero.	0.2	0.1	4K
Improvements Related to RCP Seal LOCAs				
SLO 10-create independent RCP seal injection system with dedicated diesel 11-create independent RCP seal injection system without dedicated diesel 14-install improved RCP seals	Change event tree functional equations to eliminate the RCP seal LOCA contribution.	9.6	0.3	140K
No analysis case 21-enhance training and procedures for loss of CCW or SW	Utilize results from Surry analysis that show negligible benefit for Surry and North Anna plant design.	0.0	0.0	0
Improvements Related to Secondary/Support Systems				
SWH 23-improve SW pump alignments when a header is out for maintenance	Set service water header test and maintenance basic events to zero.	0.2	0.02	3K
Improvements in Alternating Current (AC)/Direct Current (DC) Power Reliability and Availability				
BCH 61-use fuel cells instead of lead-acid batteries 64-alternate battery charging capability 113-provide portable generators to be hooked into the turbine-driven auxiliary feedwater (TDAFW) after battery depletion	Set battery failures in long-term SBO to zero.	2.0	0.1	29K

Table 5-5. (contd)

Analysis Case and Applicable SAMAs	Analysis Assumption	Percent Reduction		Total Benefit
		CDF	Dose	
OSP 73-install gas turbine generator 77-provide a connection to alternate offsite power source	Reduce loss of offsite power frequency by a factor of five.	19.6	1.8	318K
OPR 70-emphasize steps in recovery of offsite power after SBO	Reduce offsite power recovery basic events by 25 percent.	4.4	0.4	72K
4KV 69-develop procedures for repair or change-out of failed 4kV breakers	Reduce basic events for all 4 kV breaker failures by a factor of two.	0.7	3.6	88K
BAT 60-provide additional DC battery capability ⁽¹⁾	Set battery failures in long-term SBO to zero.	2.0	0.1	29K
Improvements Related to HVAC				
HVC 25-provide a non-safety related, redundant train of emergency switchgear room (ESGR) ventilation	Change the initiating events frequency of the loss of HVAC to zero, and eliminate conditional ESGR failure by setting unavailability to zero.	7.4	1.0	123K
HVA 27-add a switchgear room high temperature alarm	Reduce operator error for failure to recover HVAC by a factor of ten.	0.9	0.1	14K

(1) The total benefit reported in the ER for this SAMA is \$876K. However, in their December 10, 2001, response to RAIs, VEPCo indicated that a more detailed evaluation in which battery failures in long-term SBO events were set to zero indicates the total benefit to be \$29K.

Table 5-5. (contd)

Analysis Case and Applicable SAMAs	Analysis Assumption	Percent Reduction		Total Benefit
		CDF	Dose	
Improvements Related to Decay Heat Removal (DHR) Capability				
DHR	Replace event tree functional equations related to containment heat removal with an event that has an unavailability of zero.	0.7	0.04	11K
34-install a containment vent large enough to remove anticipated transient without scram (ATWS) decay heat		0.7	1.2	25K
35-install a filtered containment vent to remove decay heat		0.7	0.04	11K
36-install an unfiltered containment vent to remove decay heat				
DFW	Reduce transient and loss of main feedwater (MFW) initiating event frequencies by a factor of three.	4.5	0.6	76K
106-digital feedwater upgrade				
FDW	Modify event tree functional equations related to MFW or auxiliary feedwater to use a basic event whose unavailability is zero.	16.8	2.5	294K
120-create passive secondary side coolers				
SGP	Set basic event REC-INAIR-LOCAL to zero.	0.0	0.0	0
121-automate air bottle swap for steam generator power-operated relief valves (SG PORVs)				
CND	Remove house event XHOS-NO-CND-DUMP from five fault trees and gates.	0.3	0.0	5K
122-utilize bypass around the main steam trip valves to use condenser dump after safety injection				
No analysis case	Set the main steam line break (MSLB) initiating event frequencies to zero.	0.0	0.0	0
156-install secondary side guard pipes up to the main steam isolation valves (MSIVs)				

Table 5-5. (contd)

Analysis Case and Applicable SAMAs	Analysis Assumption	Percent Reduction		Total Benefit
		CDF	Dose	
Improvements Related to Emergency Core Cooling System				
ISS 99-add remotely-operated firewater line that could be used to scrub ISLOCA releases	Transfer the entire frequency of CET endstate 23 (unscrubbed ISLOCA) to CET endstate 22 (scrubbed LOCA).	0.0	3.5	38K
ISL 101-add a check valve downstream of the low head safety injection (LHSI) pumps on cold leg injection line to reduce ISLOCA frequency	Reduce ISLOCA frequency to zero.	4.6	18.7	220K
LHI 123-provide capability for diesel-driven, low pressure vessel makeup	Use unavailability of zero for all "late" low head safety injection and recirculation events in the event trees, and credit the fire protection connection to low head safety injection and recirculation in the fault trees.	5.6	0.0	82K
HPI 124/125-provide an additional high pressure injection pump with independent diesel	Add new pump logic to all charging and high head safety injection fault trees.	0.03	0.0	<1K
Improvements Related to Reducing Initiating Event Frequency				
ATW 143/144-install motor generator (MG) set trip breakers in control room	Set the frequency of the ATWS initiating events to zero.	1.3	0.1	20K
LLO 157-add digital large break LOCA protection	Reduce the large LOCA initiating event frequency by 25 percent.	2.9	0.01	22K
MGB 81-install fast acting MG breaker	Reduce the transient initiating event frequency by 25 percent.	1.7	0.2	29K

Table 5-6. North Anna Power Station SAMAs with Detailed Cost Estimates

SAMA No.	Description	Cost (\$)
60	Provide additional DC battery capability	2-5 M
64	Provide a portable, diesel-driven battery charger and associated disconnects	1.5-3 M
73	Install a combustion turbine generator	20-30 M
77	Provide a connection to alternate offsite power source (the nearby dam), and associated switchgear and disconnects	2-5 M
84	Provide improved instrumentation and control circuits to detect and respond to SGTR	1.5-3 M
99	Add remotely operated firewater line that could be used to scrub ISLOCA releases	125 K
101	Add check valve in each cold leg injection path to reduce ISLOCA frequency	750 K-1.25M
106	Upgrade feedwater instrumentation to digital	4-7 M
123	Add a line to permit low-pressure vessel makeup from firewater header	350-600 K

VEPCo assumed the minimum cost of generating a new procedure, including its implementation, to be \$30,000. If the SAMA involved a hardware modification, it was assumed that the cost would be at least \$100,000.

The staff requested additional justification for several of the detailed cost estimates provided by VEPCo, including SAMAs 64, 77, and 84. VEPCo provided this information by email dated January 22, 2002 (NRC 2002a). The staff reviewed the bases for the applicant's cost estimates. For certain improvements, the staff also compared the quantitative or qualitative cost estimates provided in Table 4-6 of the ER to estimates developed elsewhere for similar improvements, including estimates developed as part of other applicants' analyses of SAMAs for operating reactors and advanced light water reactors. Based on this audit, the detailed cost estimates were judged to reflect valid bases and assumptions with the exception of some labor estimates, which appear high. However, even if such estimates were lowered by an order of magnitude, the cost of the alternative would not be altered to the extent that it would become cost beneficial given the relatively small total benefits of the SAMAs. The qualitative cost

Postulated Accidents

estimates in Table 4-6 of the ER were found to be consistent with previous estimates and reasonable for the SAMAs under consideration. The staff concludes that the cost estimates are sufficient and appropriate for use in the SAMA evaluations.

5.2.6 Cost-Benefit Comparison

The cost-benefit comparison, as evaluated by VEPCo and the staff evaluation of the cost-benefit analysis, are described in the following sections.

5.2.6.1 VEPCo Evaluation

The methodology used by VEPCo was based primarily on NRC's guidance for performing cost-benefit analysis, i.e., NUREG/BR-0184, *Regulatory Analysis Technical Evaluation Handbook* (NRC 1997b). The guidance involves determining the net value for each SAMA according to the following formula:

$$\text{Net Value} = (\$APE + \$AOC + \$AOE + \$AOSC) - \text{COE}$$

where \$APE = present value of averted public exposure (\$)
\$AOC = present value of averted offsite property damage costs (\$)
\$AOE = present value of averted occupational exposure (\$)
\$AOSC = present value of averted onsite costs (\$)
COE = cost of enhancement (\$).

If the net value of a SAMA is negative, the cost of implementing the SAMA is larger than the benefit associated with the SAMA and it is not considered cost-beneficial. VEPCo's derivation of each of the associated costs is summarized below.

Averted Public Exposure (APE) Costs.

The APE costs were calculated using the following formula:

APE = Annual reduction in public exposure (Δ person-rem/reactor-year)
x monetary equivalent of unit dose (\$2000 per person-rem)
x present value conversion factor (10.76, based on a 20-year period with a 7-percent discount rate).

As stated in NUREG/BR-0184 (NRC 1997b), it is important to note that the monetary value of the public health risk after discounting does not represent the expected reduction in public health risk due to a single accident. Rather, it is the present value of a stream of potential

losses extending over the remaining lifetime (in this case, the renewal period) of the facility. Thus, it reflects the expected annual loss due to a single accident, the possibility that such an accident could occur at any time over the renewal period, and the effect of discounting these potential future losses to present value. For the purposes of determining the maximum attainable benefit, VEPCo calculated an APE of \$547,000.

Averted Offsite Property Damage Costs (AOC).

The AOCs were calculated using the following formula:

$$\begin{aligned} \text{AOC} = & \text{Annual CDF reduction} \\ & \times \text{offsite economic costs associated with a severe accident (on a per-event basis)} \\ & \times \text{present value conversion factor.} \end{aligned}$$

VEPCo cited an annual offsite economic risk of \$48,846 based on the Level 3 risk analysis. This value appears to be higher than values for other sites and those presented in NUREG/BR-0184 (NRC 1997b). This higher value is primarily due to the high contribution to CDF from SGTRs in the North Anna PRA (4.29×10^{-6} per reactor-year, including both SGTR initiators and induced ruptures), which contribute 84 percent of the total offsite economic risk. For the purposes of determining the maximum attainable benefit, VEPCo calculated an AOC of \$526,000.

Averted Occupational Exposure (AOE) Costs.

The AOE costs were calculated using the following formula:

$$\begin{aligned} \text{AOE} = & \text{Annual CDF reduction} \\ & \times \text{occupational exposure per core damage event} \\ & \times \text{monetary equivalent of unit dose} \\ & \times \text{present value conversion factor.} \end{aligned}$$

VEPCo derived the values for averted occupational exposure based on information provided in Section 5.7.3 of NUREG/BR-0184 (NRC 1997b). Best estimate values provided for immediate occupational dose (3300 person-rem) and long-term occupational dose (20,000 person-rem over a 10-year cleanup period) were used. The present value of these doses was calculated using the equations provided in NUREG/BR-0184 in conjunction with a monetary equivalent of unit dose of \$2000 per person-rem, a real discount rate of 7 percent, and a time period of 20 years to represent the license-renewal period. For the purposes of determining the maximum attainable benefit, VEPCo calculated an AOE of \$13,000.

Postulated Accidents

Averted Onsite Costs (AOSC).

The AOSCs include averted cleanup and decontamination costs, and averted power replacement costs. Repair and refurbishment costs are considered for recoverable accidents only and not for severe accidents. VEPCo derived the values for AOSC based on information provided in Section 5.7.6 of NUREG/BR-0184 (NRC 1997b).

Averted cleanup and decontamination costs (ACC) are calculated using the following formula:

$$\begin{aligned} \text{ACC} = & \text{Annual CDF reduction} \\ & \times \text{present value of cleanup costs per core damage event} \\ & \times \text{present value conversion factor.} \end{aligned}$$

The total cost of cleanup and decontamination subsequent to a severe accident is estimated in NUREG/BR-0184 (NRC 1997b) as $\$1.5 \times 10^9$ (undiscounted). This value was converted to present costs over a 10-year cleanup period and integrated over the term of the proposed license extension.

Averted power replacement costs RPC are calculated using the following formula:

$$\begin{aligned} \text{RPC} = & \text{Annual CDF reduction} \\ & \times \text{present value of replacement power for a single event} \\ & \times \text{factor to account for remaining service years for which replacement power is required} \\ & \times \text{reactor power scaling factor.} \end{aligned}$$

Each of the units at North Anna Power Station has a gross electrical rating of 982 MWe, which is higher than the reference rating in NUREG/BR-0184. Thus, a scaling factor (982/910) of 1.08 was applied to the corresponding formula. For the purposes of determining the maximum attainable benefit, VEPCo calculated an AOSC (combination of ACC and RPC) of \$683,000.

Using the above equations, VEPCo estimated the total present dollar value equivalent associated with completely eliminating internally initiated severe accidents at North Anna Power Station to be \$1,770,000 for each unit. This value was then doubled to account for additional risk reduction associated with also eliminating external events. This results in a maximum attainable benefit of \$3.5 million for eliminating all severe accident risk.

VEPCo Results.

The total benefit associated with each of the 51 SAMAs remaining after the initial screening is provided in column 5 of Table 5-5. These values were determined based on the above equations for the various averted costs together with the estimated annual reductions in CDF and person-rem dose (columns 3 and 4 of Table 5-5). The estimated benefits were then doubled to account for additional risk reduction in external events. The values for total benefit reported in Table 5-5 include this doubling.

In determining the net value of each SAMA, VEPCo applied an additional factor of two multiplier to account for uncertainties in the cost-benefit methodology. Specifically, for each SAMA, they compared the total benefit^(a) (which had been doubled to account for external events) to the estimated cost of the enhancement, and screened out the SAMA only if the cost of the enhancement was at least twice the benefit. All 51 SAMAs were eliminated because the estimated costs are expected to exceed the total benefit by at least a factor of two. The end result was that no SAMA candidates were found to be cost-beneficial.

VEPCo performed sensitivity analyses to evaluate the impact of parameter choices on the analysis results. The sensitivity analyses included the calculation of candidate SAMA benefits using a 3-percent discount rate as recommended in NUREG/BR-0184 (NRC 1997b). The sensitivity cases resulted in less than a factor of two increase in the benefit calculation, and therefore, all SAMAs were still screened out. Thus, the conclusion that none of the candidate SAMAs would be cost-beneficial remains unchanged.

5.2.6.2 Staff Evaluation

The cost-benefit analysis performed by VEPCo was based primarily on NUREG/BR-0184 (NRC 1997b) and was executed appropriately. The risk profile for North Anna Power Station is observed to be dominated by containment bypass events (primarily SGTRs). With the exception of seven costly modifications that are not properly applicable to an existing plant (e.g., redesign of the reactor cavity to accommodate a water-cooled rubble bed), the analysis found a maximum benefit of \$318K, with most changes resulting in a benefit of less than about \$100K.

The staff questioned the evaluation of several SAMAs that appeared to be cost-beneficial, in particular, SAMAs 69 and 70. SAMA 69 involves developing procedures to repair or change out failed 4kV breakers. This offers a recovery from SBO sequences involving a failure of the

(a) The benefit can be due to a reduction in CDF and/or a reduction in person-Sv (person-rem) dose resulting from the alternative being implemented.

Postulated Accidents

breakers that transfer the 4.16 kV non-emergency buses from unit station service transformers to system station service transformers. According to Table 4-6 of the ER (VEPCo 2001a), a benefit of \$88K was calculated. VEPCo estimated the minimum cost of a procedure change to be \$30K. Because this amount is less than the estimated benefit, the SAMA appears to be cost-beneficial. In their RAI response (NRC 2002a), VEPCo noted that this SAMA is applicable to seven non-safety 4 kV breakers associated with the alternate AAC diesel, and that the benefit of the SAMA was conservatively calculated by reducing the failure probability of all (21) 4 kV breakers, including the seven AAC breakers, by 50 percent. If the change in failure probability were applied only to the seven AAC breakers, the reduction in CDF would be at most 1/3 of the bounding benefit reported in Table 4-6 of the ER. Based on this assessment, VEPCo estimated the bounding benefit to more realistically be on the order of \$30K for North Anna Power Station. VEPCo further stated that the implementation of SAMA 69 would primarily involve the cost of purchasing, sheltering, and maintaining multiple, pre-staged 4 kV breakers, and that the material cost alone for two non-safety-related breakers would be \$60K. The associated procedures, maintenance, and sheltering would increase the implementation cost. Based on this rationale, the staff agrees that this SAMA is not cost-beneficial and does not appear to be warranted.

SAMA 70 involves a change to procedures for recovery of offsite power after a SBO. According to Table 4-6 of the ER (VEPCo 2001a), a benefit of \$72K was calculated. VEPCo estimated the minimum cost of a procedure change to be \$30K. Because this amount is less than the estimated benefit, the SAMA appears to be cost-beneficial. However, in their RAI response (NRC 2002a), VEPCo indicated that the benefit was calculated assuming a 25 percent reduction in the offsite power non-recovery terms, and that this is very optimistic because training for offsite power recovery is already given, and failure to recover offsite power is more likely attributed to actual failures of the grid and not personnel error. Operator training has no impact on these types of failure. VEPCo indicated that the benefit in this area is actually quite small and would realistically be 1 percent or 2 percent as opposed to the 25 percent presented in the SAMA analysis. Based on this assessment, the total benefit would be at least an order of magnitude less than that provided in Table 4-6 of the ER. VEPCo further stated that it would not be practical to eliminate or trade off any of the current training material given the heavily loaded training schedule. Based on this rationale, the staff agrees that this SAMA does not appear to be warranted.

The staff concludes that the costs of the 51 candidate SAMAs assessed would be considerably higher than the associated benefits. This conclusion is upheld despite a number of uncertainties and non-quantifiable factors in the calculations, noted as follows:

- External events were accounted for in the analysis by doubling the risk-benefits found considering internal events only. This was justified on the basis of the fact that the

externally initiated CDF at North Anna Power Station (3.9×10^{-6} per reactor-year for fires, and a seismic CDF that is also likely to be relatively small by analogy with Surry) is much less than the internally initiated CDF (3.5×10^{-5} per reactor-year), and the observation that there are no particular containment vulnerabilities in the external event risk profile.

- Uncertainty in the internal events CDF was not explicitly included in the calculations, which employed best-estimate values. The 95 percent confidence level for the internal events CDF is approximately five times the best estimate. The results of the SAMA analysis show that no SAMA is found to be cost-beneficial within a factor of three or four at the North Anna Power Station. This would suggest that, when considering the CDF at the 95 percent confidence level, some candidate SAMAs might be assessed as being cost-beneficial. However, the risk reduction and cost estimates used in the cost-benefit assessment were generally found to be conservative. Therefore, consideration of CDF uncertainty is not expected to alter the conclusions of the analysis.
- A number of sensitivity risk-benefit calculations were performed with respect to the discount rate (as low as 3 percent) and various MACCS2 parameters, including evacuation time and completeness, meteorological data, source term energy, and sheltering time. The results of these calculations showed that none of the risk benefits were increased by more than a factor of two. Because this is less than the margin between cost and benefit for the most mitigative SAMA considered, the staff concludes that uncertainties in these parameters would not alter the conclusions.

5.2.7 Conclusions

VEPCo compiled a list of 158 SAMA candidates using the SAMA analyses as submitted in support of licensing activities for other nuclear power plants, NRC and industry documents discussing potential plant improvements, and the plant-specific insights from the VEPCo IPE, IPEEE, and PRA model. Candidate SAMAs were identified by a thorough and systematic process that included examination of the North Anna IPE and IPEEE, the top cutsets from the updated North Anna PRA, and review of SAMA analyses for other operating nuclear power plants and other NRC and industry documentation. While few SAMAs were identified with a view towards external events, the IPEEE revealed no containment vulnerabilities particular to external events, and the staff judges that the process could be effectively carried out by considering primarily internal events. A qualitative screening removed SAMA candidates that did not apply to North Anna Power Station for various reasons. A total of 107 SAMA candidates were either eliminated or combined with other potential improvements during the initial screening process, leaving only 51 SAMA candidates subject to the final screening process.

Postulated Accidents

Using guidance in NUREG/BR-0184 (NRC 1997b), the updated North Anna PRA model, and a level 3 analysis developed specifically for SAMA evaluation, VEPCo estimated the total benefits for each of the 51 remaining SAMAs based on consideration of internal events, and doubled the benefits for each SAMA to account for additional risk reduction in external events. In determining the net value of each SAMA, VEPCo applied an additional factor of two multiplier to account for uncertainties in the cost-benefit methodology. Specifically, for each SAMA they compared the total benefit (which had been doubled to account for external events) to the estimated cost of the enhancement, and screened out the SAMA only if the cost of the enhancement was at least twice the benefit. All 51 SAMAs were eliminated because the estimated costs are expected to exceed the total benefit by at least a factor of two. The end result was that no SAMA candidates were found to be cost-beneficial.

The staff reviewed the VEPCo analysis and concluded that the methods used and the implementation of those methods were sound. Based on its review, the staff concludes that none of the candidate SAMAs are cost-beneficial. This conclusion is consistent with the low residual level of risk indicated in the North Anna PRA and the fact that VEPCo has already implemented many plant improvements identified from the IPE and IPEEE process at the North Anna Power Station.

5.3 References

10 CFR Part 50. Code of Federal Regulations, Title 10, *Energy*, Part 50, "Domestic Licensing of Production and Utilization Facilities."

10 CFR Part 51, Subpart A, Appendix B, Table B-1, "Summary of Findings on NEPA Issues for License Renewal of Nuclear Power Plants."

10 CFR 51.53(c), "Operating license renewal stage."

10 CFR Part 54. Code of Federal Regulations, Title 10, *Energy*, Part 54, "Requirements for renewal of operating licenses for nuclear power plants."

10 CFR Part 100. Code of Federal Regulations, Title 10, *Energy*, Part 100, "Reactor Site Criteria."

U.S. Nuclear Regulatory Commission (NRC). 1988. Generic Letter 88-20, "Individual Plant Examination for Severe Accident Vulnerabilities," November 23, 1988.

U.S. Nuclear Regulatory Commission (NRC). 1990a. *Severe Accident Risks - An Assessment for Five U.S. Nuclear Power Plants*. NUREG-1150, Washington, D.C.

U.S. Nuclear Regulatory Commission (NRC). 1990b. *Quantitative Analysis of Potential Performance Improvements for the Dry PWR Containment*. NUREG/CR-5575, Washington, D.C.

U.S. Nuclear Regulatory Commission (NRC). 1991. *Individual Plant Examination of External Events (IPEEE) for Severe Accident Vulnerabilities*, Supplement 4 to Generic Letter 88-20, June 28, 1991.

U.S. Nuclear Regulatory Commission (NRC). 1996a. Letter from L. Engle, Nuclear Regulatory Commission to J. P. O'Hanlon, Virginia Electric and Power Company. Subject: NRC Staff's Evaluation of the North Anna Power Station, Units 1 and 2, Individual Plant Examination (IPE) Submittal, March 5, 1996.

U.S. Nuclear Regulatory Commission (NRC). 1996b. *Generic Environmental Impact Statement for License Renewal of Nuclear Plants*. NUREG-1437, Washington, D.C.

U.S. Nuclear Regulatory Commission (NRC). 1997a. *SECPOP90: Sector Population, Land Fraction, and Economic Estimation Program*. NUREG/CR-6525, Washington, D.C.

U.S. Nuclear Regulatory Commission (NRC). 1997b. *Regulatory Analysis Technical Evaluation Handbook*. NUREG/BR-0184, Washington, D.C.

U.S. Nuclear Regulatory Commission (NRC). 1997c. *Individual Plant Examination Program: Perspectives on Reactor Safety and Plant Performance*. NUREG-1560, Washington, D.C.

U.S. Nuclear Regulatory Commission (NRC). 1999. *Generic Environmental Impact Statement for License Renewal of Nuclear Plants Main Report*, "Section 6.3 – Transportation, Table 9.1, Summary of findings on NEPA issues for license renewal of nuclear power plants, Final Report." NUREG-1437, Volume 1, Addendum 1, Washington, D.C.

U.S. Nuclear Regulatory Commission (NRC). 2000. Letter from S. Monarque, Nuclear Regulatory Commission, to D. A. Christian, Virginia Electric and Power Company. Subject: North Anna Power Station, Units 1 and 2—Review of Individual Plant Examination of External Events (IPEEE) (TAC Nos. M83647 and M83648), June 5, 2000.

U.S. Nuclear Regulatory Commission (NRC). 2001. Letter from Andrew Kugler, Nuclear Regulatory Commission to David Christian, VEPCo. Subject: Request for Additional Information Related to the Staff's Review of Severe Accident Mitigation Alternatives for the Surry and North Anna Power Stations, Units 1 and 2 (TAC Nos. MB1992, MB1993, MB1994, and MB1995), October 17, 2001.

Postulated Accidents

U.S. Nuclear Regulatory Commission (NRC). 2002a. Note to file from Andrew Kugler, Nuclear Regulatory Commission. Subject: Requests for Additional Information Regarding SAMA Analysis for Surry and North Anna Power Stations, Units 1 and 2. January 23, 2002.

U.S. Nuclear Regulatory Commission (NRC). 2002b. Note to file from Andrew Kugler, Nuclear Regulatory Commission. Subject: Requests for Additional Information Regarding SAMA Analysis for North Anna Power Stations, Units 1 and 2. February 11, 2002.

Virginia Electric and Power Company (VEPCo). 1992. Letter from W. L. Stewart, Virginia Electric and Power Company, to U.S. Nuclear Regulatory Commission. Subject: PRA North Anna Power Station Units 1 and 2 Individual Plant Examination in Response to Generic Letter 88-20 Supplement, December 14, 1992.

Virginia Electric and Power Company (VEPCo). 1994. Letter from J.P. O'Hanlon, Virginia Electric and Power Company, to U.S. Nuclear Regulatory Commission. Subject: Individual Plant Examination of Non-Seismic External Events and Fires, June 28, 1994.

Virginia Electric and Power Company (VEPCo). 2001a. *Applicant's Environmental Report—Operating License Renewal Stage, North Anna Power Station Units 1 and 2*. Glen Allen, Virginia, May 2001.

Virginia Electric and Power Company (VEPCo). 2001b. Letter from David A. Christian, VEPCo, to U.S. Nuclear Regulatory Commission. Subject: Request for Additional Information, License Renewal Applications, December 10, 2001.